

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Apr/2017 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	161.904	3990.751	1) Gujrat	1.889	15.502
2) Hydro	21.808	441.582	2) Madhya Pradesh	16.330	309.560
3) Gas	10.613	258.801	3) Chattisgarh	6.880	147.040
Total MSPGCL	194.325	4691.134	4) Maharashtra Net	131.623	3458.935
B) 1) APML	43.267	1242.473	5) Goa (Amona)	-0.638	-16.740
2) JSWEL	21.195	558.742	Total	156.084	3914.297
3) VIPL	7.164	252.961	a) Mumbai Schedule	25.187	653.529
4) RPL(AMT)	11.344	503.000	b) Mumbai Drawl	26.377	720.640
5) WPCL	1.888	90.573	c) MSEDCL Bilateral *	38.446	939.436
6) PGPL	0.000	0.000	Include PX	16.923	174.935
7) Other IPP	3.373	95.828	d) Mumbai Bilateral *	25.187	653.189
C) 1) TPCL Thermal	17.482	416.035	Include PX	8.961	167.913
2) TPCL Hydro	4.463	100.481	Include Standby	0.000	0.340
3) TPCL Gas	4.504	116.994	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	12.006	299.702	1) MSEDCL	423.804	11064.395
D) STATE			2) Mumbai Discoms	64.832	1653.850
1) Thermal	279.623	7450.065	TOTAL STATE	488.636	12718.245
(A1+C1+C4+(B1-B6))					
2) Hydro	26.271	542.063			
(A2+C2)					
3) Gas	15.117	375.795			
(A3+B6+C3)					
4) Wind	9.904	394.663			
6) SOLAR	1.637	41.364			
TOTAL STATE	332.552	8803.950			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6694	6769	6785	6782
MSPGCL Hydro	819	1407	1517	277
MSPGCL Gas	428	435	445	451
MSPGCL Total Generation	7941	8611	8747	7510
Central Sector Receipt	7803	7595	5748	5567
WIND	161	445	285	697
CPP / IPP Thermal	3605	3646	3784	3668
CPP / IPP Gas	0	0	0	0
SOLAR	238	83	0	0
Exchange with Mumbai	-1415	-1381	-1174	-615
MSEDCL DEMAND MET	18333	18999	17390	16827
Load Shedding	0	0	0	0
MSEDCL DEMAND	18333	18999	17390	16827
TPCL GENERATION	1290	1327	1192	922
R-INFRA GENERATION	488	497	505	506
MUMBAI DEMAND	3193	3205	2871	2043
STATE DEMAND MET	21526	22204	20261	18870
STATE DEMAND	21526	22204	20261	18870
Frequency (Hz)	49.92	49.91	49.92	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 10.01 Hrs	49.73 Hz at 19.38 Hrs	49.93	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 26/Apr/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.69	88.96	165	140
Unit 8	13.32	269.55	610	400
Unit 9	12.06	312.08	590	402
Unit 10	0.00	124.42	0	0
Total	29.06	795.01		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	4.10	105.54	175	165
Unit 4	9.30	252.84	505	350
Unit 5	8.95	252.36	445	350
Total	22.35	610.75		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.94	151.69	250	235
Unit 7	5.62	125.72	254	184
Unit 8	0.00	35.14	0	0
Total	11.56	312.55		
Chandrapur				
Unit 3	4.07	113.33	180	160
Unit 4	4.63	121.42	197	183
Unit 5	10.43	232.80	445	415
Unit 6	9.90	258.05	425	388
Unit 7	0.00	0.00	0	0
Unit 8	9.60	232.80	460	331
Unit 9	11.01	169.29	500	371
Total	49.65	1127.70		
Paras				
Unit 3	6.02	109.17	256	242
Unit 4	5.87	137.88	250	237
Total	11.90	247.05		
Khaparkheda				
Unit 1	4.45	106.82	190	170
Unit 2	4.08	106.84	180	150
Unit 3	4.68	112.73	200	170
Unit 4	4.49	100.11	190	177
Unit 5	11.46	244.88	500	460
Total	29.18	671.38		
Nasik				
Unit 3	0.00	36.00	0	0
Unit 4	3.71	76.44	204	0
Unit 5	4.50	113.87	200	160
Total	8.21	226.31		
Uran				
All Units	10.61	258.80	463	420
Total	10.61	258.80		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.21	2.40	39	0
Total	0.21	2.40		
Koyna				
Stage 1-2	6.51	131.20	470	40
Stage 4	9.11	165.31	863	0
Stage 3	3.23	66.01	240	0
Total	18.85	362.52		
Hydro				
KDPH	0.65	15.29	27	27
VTRNA	0.64	14.29	61	0
TILLARI	0.20	2.78	60	0
BHTGR/VEER	0.00	0.06	0	0
BHIRA T.R.	0.20	5.30	56	0
RNGR+BHTSA	0.30	7.32	13	12
BHANDARDRA	0.47	12.95	20	19
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.50	12.30	29	18
GHATGHAR	0.00	8.78	0	0
Total	2.96	79.06		
Wind				
Total	9.90	394.66	0	0
Total	9.90	394.66		
CPP				
APML(Mus)	43.27	1242.47	0	0
JSWEL(Mus)	21.20	558.74	0	0
VIPL(Mus)	7.16	252.96	0	0
RPLAMT(Mus)	11.34	503.00	0	0
WPCL(Mus)	1.89	90.57	0	0
Other(Mus)	3.37	95.83	0	0
Total	88.23	2743.58		
SOLAR				
Total	1.64	41.36	0	0
Total	1.64	41.36		
Tata				
Trombay 5	11.62	273.18	493	441
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.91	75.30	123	112
Trombay 7B	1.60	41.69	68	65
Trombay 8	5.86	142.86	249	215
TATA Hydro	4.46	100.48	418	0
Total	26.45	633.51		
R-INFRA				
DTPS U-1&2	12.01	299.70	508	450
Total	12.01	299.70		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	161.90	3990.75	MSPGCL Total	194.32	4691.13
			MSPGCL Thml+Gas	172.52	4249.55	Koyna 1,2 & 4 Total	15.62	296.51
			MSPGCL Hydro	21.81	441.58	State Total	332.55	8803.95

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/Apr/2017

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	6831	1145	451	8427	546	3669	0	0	6099	6064	-1043	17663	0	17663	2546	20209	49.92
2	6813	957	451	8221	571	3643	0	0	5943	5801	-845	17391	0	17391	2284	19675	49.92
3	6833	571	451	7855	678	3649	0	0	5849	5872	-716	17338	0	17338	2145	19483	49.95
4	6782	277	451	7510	697	3668	0	0	5637	5567	-615	16827	0	16827	2043	18870	49.94
5	6621	442	451	7514	654	3675	0	0	5596	6036	-568	17311	0	17311	1998	19309	49.92
6	6642	804	463	7909	614	3673	0	0	5824	6008	-603	17601	0	17601	2031	19632	49.93
7	6657	897	454	8008	573	3656	0	4	6608	6524	-626	18139	0	18139	2054	20193	49.96
8	6797	684	453	7934	514	3666	0	48	6449	6431	-791	17802	0	17802	2220	20022	49.98
9	6950	609	456	8015	421	3660	0	110	6662	6620	-975	17851	0	17851	2424	20275	49.99
10	6828	873	432	8133	224	3681	0	179	6809	6527	-1226	17518	0	17518	2861	20379	49.95
11	6801	717	440	7958	179	3609	0	187	7247	5897	-1413	16417	0	16417	3125	19542	49.99
12	6694	819	428	7941	161	3605	0	238	7823	7803	-1415	18333	0	18333	3193	21526	49.92
13	6743	885	420	8048	199	3640	0	228	7909	8150	-1402	18863	0	18863	3205	22068	49.97
14	6767	888	424	8079	227	3676	0	203	7602	7701	-1381	18505	0	18505	3111	21616	49.91
15	6717	1295	422	8434	310	3669	0	189	7563	7408	-1431	18579	0	18579	3191	21770	49.89
16	6735	1048	436	8219	408	3649	0	134	7756	7880	-1435	18855	0	18855	3231	22086	49.90
17	6769	1407	435	8611	445	3646	0	83	6898	7595	-1381	18999	0	18999	3205	22204	49.91
18	6703	886	429	8018	481	3673	0	32	6653	7204	-1352	18056	0	18056	3064	21120	49.94
19	6633	174	442	7249	418	3613	0	2	6487	6515	-1351	16446	0	16446	2936	19382	49.99
20	6742	1198	444	8384	325	3784	0	0	5904	6006	-1201	17298	0	17298	2934	20232	49.90
21	6785	1517	445	8747	285	3784	0	0	5654	5748	-1174	17390	0	17390	2871	20261	49.92
22	6805	1463	446	8714	311	3811	0	0	5582	5472	-1145	17163	0	17163	2744	19907	49.87
23	6658	1448	445	8551	340	3723	0	0	5545	5467	-1177	16904	0	16904	2724	19628	49.89
24	6598	804	444	7846	323	3711	0	0	5981	5788	-1111	16557	0	16557	2692	19249	49.89
MUs	161.90	21.81	10.61	194.33	9.90	88.23	0.00	1.64	156.08	156.08	-26.38	423.81	0.00	423.81	64.83	488.64	49.93

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Apr/2017

Position as on 6.30 Hrs of 27/Apr/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown,(AOH for 06.03.2016 To 04.04.2016) Unit Test synch.07.04.2016 (12.03 To 12.30hrs)After overhaul	
MSPGCL	Chandrapur Unit 7	500	25/01/2017	19.32		Continued.	Turbine Problem, continued under COH	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No PPA.	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Nasik Unit 3	210	09/04/2017	15.50		Continued.	tripped on boiler feed pump problem and continued under zero schedule by MSEDCL	
IPP	VIPL U-1	300	13/04/2017	03.34		Continued.	Boiler Tube Leakage	
IPP	RPL(AMT) U-5	270	15/04/2017	08.59		Continued.	Coal Shortage	
IPP	RPL(AMT) U-4	270	15/04/2017	12.08		Continued.	Coal Shortage	
IPP	Adani U-1	660	18/04/2017	13.12		Continued.	Due to coal shortage.	
IPP	RPL(AMT) U-3	270	19/04/2017	19.30		Continued.	Coal Shortage	
CPP	SWPGL U-3	135	25/04/2017	00.01		Continued.	ESP.	
MSPGCL	Parli Unit 8	250	25/04/2017	07.52		Continued.	Turbine bearing Vabration high	
MSPGCL	Koradi Unit 10	660	25/04/2017	13.17		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 4	210	26/04/2017	03.50	26/04/2017	07.48	Furnace draft high protection.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Apr/2017

Position as on 6.30 Hrs of 27/Apr/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Koyana Unit 10	80	26/04/2017	06.50	26/04/2017	15.00	PT REPALCEMENT.	
MSPGCL	Koyana Unit 8	80	26/04/2017	21.10	26/04/2017	23.40	OIL LEVEL LOW.	
IPP	JSW (J) U2	300	27/04/2017	00.29		Continued.	ZERO SCHEDULE.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2017

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi III - Akola II- ckt-II	IntraState	26/04/2017	15.52	26/04/2017	16.39	PO	Attending Hot Spot
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar I	InterState	25/04/2017	20.05		Continued.	HT	Over Voltage
Ektuni-Bableswhar ckt I	IntraState	25/04/2017	09.56		Continued.	HT	Controlling 400kv padgha bableswhar line loading.
Nagothane - Dabhol-II	IntraState	26/04/2017	07.37	26/04/2017	20.19	PO	ISULATOR COLD LINE WASHING.
Babhaleswhar - Padghe-I	IntraState	27/04/2017	01.31	27/04/2017	06.06	EO	Attending Hot Spot
Babhaleswhar - Padghe-II	IntraState	27/04/2017	02.22	27/04/2017	02.39	T	Distance Protection
Babhaleswhar - Padghe-II	IntraState	27/04/2017	04.04		Continued.	T	Distance Protection
Kharghar-Talegaon(PG)	IntraState	27/04/2017	05.55		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT- II @Warora	IntraState	27/03/2017	12.58		Continued.	PO	Dismantling Work And Will Be Transport At Padgha.
400/220kv 315 MVA ICT- III@Padgha	IntraState	25/04/2017	21.30	26/04/2017	01.57	T	Over load
400/220kv 315 MVA ICT I @ Kolhapur	IntraState	26/04/2017	10.00	26/04/2017	10.56	T	OVERCURENT BACK FAULT, E/FPROTECTION OPERATED.AC SUPPLY FAIL.
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	26/04/2017	10.00	26/04/2017	10.15	T	OVERCURENT BACK FAULT, E/FPROTECTION OPERATED.AC SUPPLY FAIL.
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	26/04/2017	10.00		Continued.	T	Differential protection
400/220kv 315 Mva ICT I @Karad	IntraState	26/04/2017	10.01	26/04/2017	10.32	T	BACK UP O/C TRIP,LTS STAGE-1 AND STAGE-2 OPERATED,T/F OVERLOAD ALARM
400/220kv 315 Mva ICT III @Karad	IntraState	26/04/2017	10.01	26/04/2017	10.15	T	BACK UP O/C TRIP,LTS STAGE-1 AND STAGE-2 OPERATED,T/F OVERLOAD ALARM.
400/220kv 315 Mva ICT II @Karad	IntraState	26/04/2017	10.01	26/04/2017	10.26	T	BACK UP O/C TRIP,LTS STAGE-1 AND STAGE-2 OPERATED,T/F OVERLOAD ALARM.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	26/04/2017	10.00		Continued.	HT	HANDTRIPPED.
Mudshingi - Chikodi	InterState	26/04/2017	10.01	26/04/2017	13.32	HT	HANDTRIPPED.
Nasik Navsari II	InterState	27/04/2017	03.13	27/04/2017	03.36	T	TRIPPED AT NAVSARI END.
Nasik Navsari I	InterState	27/04/2017	03.55		Continued.	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Harangul-Parly	IntraState	24/04/2017	18.00		Continued.	PO	Distance Relay replacement Work.
Padgha - Temghar I	IntraState	25/04/2017	21.58	26/04/2017	04.37	HT	To control ICT loading
Padgha-Temghar-II	IntraState	25/04/2017	21.58	26/04/2017	04.37	HT	To control ICT loading
Warora - Wardha	IntraState	26/04/2017	06.45	26/04/2017	15.54	PO	REPLACEMENT OF FAULTY DISC INSULATOR CLEARANCE.
Osmanabad - Barshi	IntraState	26/04/2017	08.20	26/04/2017	11.40	PO	WORK AT BARSHI END.
Pedambe-Nerle	IntraState	26/04/2017	08.20	26/04/2017	11.00	PO	FOR PT REMOVING.
Butibori - Khaperkheda	IntraState	26/04/2017	08.38	26/04/2017	15.23	PO	Attending Hot Spot
Karad-Nerle	IntraState	26/04/2017	10.01	26/04/2017	10.38	T	TRIPPED AT NERALE END ONLY.
Talandge(400kv)- Ichalkaranji 1	IntraState	26/04/2017	10.02	26/04/2017	10.27	HT	HANDTRIPPED.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2017

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Talandge(400kv)- Ichalkaranji 2	IntraState	26/04/2017	10.02	26/04/2017	10.23	HT	HANDTRIPPED.
Talandge-Mudshingi Ckt-I	IntraState	26/04/2017	10.02	26/04/2017	10.18	HT	HANDTRIPPED.
Talandge(400 Kv)- Mumewadi 2 Line	IntraState	26/04/2017	10.02	26/04/2017	10.19	HT	HANDTRIPPED.
Talandage - Sawantwadi I	IntraState	26/04/2017	10.02	26/04/2017	10.43	HT	HANDTRIPPED.
Kolhapur - 5 Star Ckt I	IntraState	26/04/2017	10.02	26/04/2017	10.17	HT	HANDTRIPPED.
Talandge-Hamidwada	IntraState	26/04/2017	10.02	26/04/2017	11.03	HT	HANDTRIPPED.
220kv Halkarni- Tillary	IntraState	26/04/2017	10.03	26/04/2017	18.30	T	Distance Protection
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	26/04/2017	10.13	26/04/2017	10.45	HT	HANDTRIPPED.
Karad(400kv) -Nigade	IntraState	26/04/2017	10.13	26/04/2017	10.43	HT	HANDTRIPPED.
Karad(400kv) - Ogalewadi Ckt 2	IntraState	26/04/2017	10.13	26/04/2017	10.44	HT	HANDTRIPPED.
Karad - Kadegaon	IntraState	26/04/2017	10.13	26/04/2017	10.36	HT	HANDTRIPPED.
Karad - Vita Ckt- II	IntraState	26/04/2017	10.13	26/04/2017	10.33	HT	HANDTRIPPED.
Karad - Vita Ckt- I	IntraState	26/04/2017	10.13	26/04/2017	10.33	HT	HANDTRIPPED.
Karad(400kv) - Wathar	IntraState	26/04/2017	10.13	26/04/2017	10.41	HT	HANDTRIPPED.
Karad -Mudshingi Ckt- IV	IntraState	26/04/2017	10.13	26/04/2017	10.40	HT	HANDTRIPPED.
Malharpeth - Karad(400kv)	IntraState	26/04/2017	10.13	26/04/2017	10.39	HT	HANDTRIPPED.
Warora - Hinganghat	IntraState	26/04/2017	16.25	26/04/2017	19.18	PO	REPLACEMENT OF CROSS ARM RAFTER MEMBER AT LOC 338 R PHASE.
Walchandnagar-Bhigwan	IntraState	26/04/2017	16.50	26/04/2017	18.45	HT	LONI DEVKARA SUB STATION TAP CANNECTION WORK.
Padgha - Temghar I	IntraState	26/04/2017	22.48		Continued.	HT	CONTROL LOAD ON ICT AT PADGHA.
Padgha-Temghar-II	IntraState	26/04/2017	22.48		Continued.	HT	CONTROL LOAD ON ICT AT PADGHA.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132KV 100MVA ICT-II@Shivajinagar	IntraState	26/04/2017	17.06	26/04/2017	19.19	PO	Quarterly Maintainance Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage