

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Apr/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	169.529	4301.744	1) Gujrat	-2.818	-104.292
2) Hydro	19.451	759.675	2) Madhya Pradesh	7.463	238.143
3) Gas	6.122	170.811	3) Chattisgarh	4.230	120.370
Total MSPGCL	195.102	5232.230	4) Maharashtra	189.539	4595.875
B) 1) APLM	73.901	1782.238	5) Goa (Amona)	-1.356	-40.503
2) JSWEL	22.295	521.925	Total	197.058	4809.593
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.032	775.802
4) RPL(AMT)	31.657	808.173	b) Mumbai Drawl	37.616	863.966
5) SWPGPL	9.004	216.148	c) MSEDCL Bilateral *	55.762	1879.777
6) Other IPP	28.735	851.707	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.032	774.857
C) 1) TPCL Thermal	16.297	412.469	Include PX	0.000	0.858
2) TPCL Hydro	3.898	104.276	Standby	0.000	0.946
3) TPCL Gas	4.066	82.067	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.643	301.404	1) MSEDCL	532.432	13703.933
D) STATE			2) Mumbai Discoms	73.520	1764.189
1) Thermal	363.061	9195.808	3) Other Discoms	9.262	235.170
(A1+C1+C4+(B1-B6))			TOTAL STATE	615.214	15703.292
2) Hydro (A2+C2)	23.349	863.951			
3) Gas (A3+B7+C3)	10.188	252.878			
4) Wind	12.517	356.731			
6) SOLAR	9.041	224.324			
TOTAL STATE	418.156	10893.692			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6916	7212	7153	6940
MSPGCL Hydro	450	1100	1076	408
MSPGCL Gas	256	267	257	256
MSPGCL Total Generation	7622	8578	8486	7604
Central Sector Receipt	8833	9661	7682	7684
WIND	246	316	377	568
CPP / IPP Thermal	6774	7008	7015	7013
CPP / IPP Gas	0	0	0	0
SOLAR	1217	785	0	272
Exchange with Mumbai	-1858	-2131	-1549	-1266
MSEDCL DEMAND MET	22402	23794	21571	21463
Load Shedding	0	0	0	0
MSEDCL DEMAND	22402	23794	21571	21463
TPCL GENERATION	1172	1024	1123	877
AEML GENERATION	485	461	499	416
MUMBAI DEMAND	3515	3616	3171	2559
OTHER DISCOM DEMAND	433	424	439	413
STATE DEMAND MET	26350	27834	25182	24434
STATE DEMAND	26350	27834	25182	24434
Frequency (Hz)	49.87	49.81	49.71	50.04

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 18:01 Hrs	49.49 Hz at 22:14 Hrs	49.87	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/Apr/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.76	106.30	210	175
Unit 7	0.00	0.00	0	0
Unit 8	12.23	348.92	568	401
Unit 9	13.05	355.12	582	502
Unit 10	12.62	135.48	585	431
Total	42.65	945.82		
Bhusawal				
Unit 3	3.02	65.86	135	110
Unit 4	7.40	237.97	355	280
Unit 5	7.20	240.81	350	280
Total	17.62	544.64		
Parli				
Unit 6	4.05	115.24	195	0
Unit 7	5.20	115.83	230	173
Unit 8	3.25	86.92	148	130
Total	12.49	318.00		
Chandrapur				
Unit 3	4.08	108.88	174	140
Unit 4	3.62	98.35	160	133
Unit 5	8.92	213.46	380	365
Unit 6	9.06	198.39	390	345
Unit 7	8.89	232.90	427	298
Unit 8	9.94	272.24	455	377
Unit 9	10.30	264.09	443	384
Total	54.82	1388.32		
Paras				
Unit 3	4.52	138.00	225	150
Unit 4	4.35	130.40	213	152
Total	8.87	268.40		
Khaparkheda				
Unit 1	2.86	80.80	130	90
Unit 2	3.62	84.76	160	135
Unit 3	4.28	99.12	186	168
Unit 4	3.37	87.62	154	123
Unit 5	10.73	282.30	475	410
Total	24.85	634.62		
Nasik				
Unit 3	4.25	100.62	190	129
Unit 4	0.00	63.85	0	0
Unit 5	3.97	37.48	193	129
Total	8.23	201.95		
Uran				
All Units	6.12	170.81	276	236
Total	6.12	170.81		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	3.20	41	0
Total	0.19	3.20		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	6.04	163.83	495	40
Stage 4	3.08	287.84	678	0
Stage 3	2.28	97.91	202	0
Total	11.40	549.58		
Hydro				
KDPH	0.37	20.74	16	16
VTRNA	0.84	20.48	59	0
TILLARI	0.52	12.53	58	0
BHIRA T.R.	0.16	4.84	77	0
SMLHY_PTN	5.35	142.26	248	191
GHATGHAR	0.62	6.04	125	0
Total	7.87	206.89		
Wind				
Total	12.52	356.73	0	0
Total	12.52	356.73		
CPP				
APML(Mus)	73.90	1782.24	0	0
JSWEL(Mus)	22.30	521.92	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.66	808.17	0	0
SWPGPL-Mus	9.00	216.15	0	0
Other(Mus)	28.74	851.71	0	0
Total	165.59	4180.19		
SOLAR				
Total	9.04	224.32	0	0
Total	9.04	224.32		
Tata				
Trombay 5	10.58	274.48	456	415
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.65	49.27	114	108
Trombay 7B	1.42	32.79	67	0
TATA Hydro	3.90	104.28	336	16
Trombay 8	5.72	137.99	242	231
Total	24.26	598.81		
AEML				
DTPS U-1&2	11.64	301.40	500	416
Total	11.64	301.40		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	169.53	4301.74	MSPGCL Total	195.10	5232.23
			MSPGCL Thml+Gas	175.65	4472.56	Koyna 1,2 & 4 Total	9.12	451.67
			MSPGCL Hydro	19.45	759.68	State Total	418.16	10893.69

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 26/Apr/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7055	652	256	7964	1254	7050	0	0	7811	7748	-1565	22126	0	22126	3019	324	25470	49.87
2	7006	748	267	8020	998	7072	0	0	7787	7665	-1427	22021	0	22021	2806	308	25134	49.85
3	6986	800	257	8042	835	7050	0	0	7617	7861	-1244	22258	0	22258	2615	286	25160	49.86
4	6997	804	257	8058	763	7052	0	0	7494	7850	-1118	22308	0	22308	2488	298	25094	49.91
5	6996	728	246	7970	642	7080	0	0	7557	7540	-1057	21876	0	21876	2416	299	24592	49.92
6	7072	1036	267	8376	550	7091	0	0	7660	7801	-1096	22392	0	22392	2468	329	25190	49.96
7	7031	1030	247	8308	595	7060	0	59	7548	7699	-1101	22243	0	22243	2471	376	25090	50.00
8	6940	408	256	7604	568	7013	0	272	7579	7684	-1266	21463	0	21463	2559	413	24434	50.04
9	6952	304	247	7504	305	6497	0	607	8022	8243	-1451	21289	0	21289	2825	416	24530	49.99
10	7202	458	257	7918	204	6491	0	884	8604	8854	-1732	22189	0	22189	3166	430	25784	49.98
11	7218	600	257	8076	148	6760	0	1074	9619	6973	-1658	20959	0	20959	3305	414	24678	50.06
12	6916	450	256	7622	246	6774	0	1217	10033	8833	-1858	22402	0	22402	3515	433	26350	49.87
13	7016	374	247	7636	334	6747	0	1222	10078	9570	-1923	23174	0	23174	3508	413	27094	49.93
14	7125	378	257	7760	296	6425	0	1188	10054	10088	-1925	23442	0	23442	3423	391	27256	49.92
15	7199	596	247	8042	285	6747	0	1023	9985	9909	-2034	23562	0	23562	3525	410	27498	49.68
16	7212	1100	267	8578	316	7008	0	785	9740	9661	-2131	23794	0	23794	3616	424	27834	49.81
17	7151	1220	236	8608	378	7006	0	497	9124	8995	-1992	23085	0	23085	3537	406	27028	49.79
18	7061	898	257	8216	400	7014	0	196	8404	8411	-1817	21978	0	21978	3415	442	25834	49.92
19	7083	548	257	7888	422	6986	0	17	7599	7790	-1608	21062	0	21062	3209	433	24704	49.82
20	7153	1076	257	8486	377	7015	0	0	7645	7682	-1549	21571	0	21571	3171	439	25182	49.71
21	7208	930	247	8384	494	6991	0	0	7534	7560	-1535	21457	0	21457	3120	438	25014	49.66
22	6997	1118	276	8392	749	6918	0	0	7392	7166	-1514	21319	0	21319	3066	391	24776	49.66
23	6949	1422	257	8628	710	6871	0	0	7743	7794	-1480	22133	0	22133	3112	390	25636	49.83
24	7004	1770	247	9020	648	6874	0	0	7846	7681	-1535	22329	0	22329	3165	360	25854	49.76
MUs	169.53	19.45	6.12	195.10	12.52	165.59	0.00	9.04	200.47	197.06	-37.62	532.43	0.00	532.43	73.52	9.26	615.21	49.87

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Apr/2022

Position as on 6.30 Hrs of 27/Apr/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	03/05/2022
MSPGCL	Nasik Unit 4	210	16/04/2022	20:58		Continued.	Condenser Tube Leakage (Unit 4 was not available due to Critical coal stock since from Unit 5 synchronization 04:53 hrs. of 17.04.2022)	24/04/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 5	108	20/04/2022	16::27		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	25/04/2022	22:28	26/04/2022	02:07	Condenser Extractor Pump Alarm	
IPP	SWPGPL U-2	135	26/04/2022	21:24		Continued.	ID Fan Vibration High	
MSPGCL	Parli Unit 6	250	26/04/2022	21:30	27/04/2022	07:12	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LR Outages/Trippings							
Pole-2 Non base AC filter Z4 (80 MVAR) @ Chandrapur HVDC	IntraState	25/04/2022	09:29	26/04/2022	19:25	PO	For Refurbishment & RTV Coating of AC Filter Air Core reactor through Expert Agency as per OEM M/s Trench Austria guidelines hence this work to be carried out on top priority to avoid Failure of Air Core Reactor
400 KV LINE Outages/Trippings							
PADGHE - BOISAR (PG)	InterState	26/04/2022	10:09	26/04/2022	10:52	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - TARAPUR CKT - 1	InterState	26/04/2022	10:09	26/04/2022	10:44	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - TARAPUR CKT - 2	InterState	26/04/2022	10:09	26/04/2022	10:44	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
DHULE - SSNNL CKT - 2	InterState	26/04/2022	13:08	26/04/2022	19:46	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work. 400kV SSNNL Ckt-1 A/R switch will be kept on non auto mode.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/04/2022	11:23			HT	HT for Load Management
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	26/04/2022	06:34	26/04/2022	09:45	T	Distance Protection
BABHALESHWAR - PADGHE CKT- 1	IntraState	26/04/2022	10:09	26/04/2022	10:30	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
BABHALESHWAR - PADGHE CKT - 2	IntraState	26/04/2022	10:09	26/04/2022	10:31	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - PADGHE HVDC CKT- 1	IntraState	26/04/2022	10:09	26/04/2022	10:57	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - NAGOTHANE CKT - 2	IntraState	26/04/2022	10:09	26/04/2022	11:22	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - NAGOTHANE CKT - 1	IntraState	26/04/2022	10:09	26/04/2022	10:53	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - PADGHE HVDC CKT- 2	IntraState	26/04/2022	10:09	26/04/2022	18:16	T	Bus Fault on 400KV Padghe- HVDC-2 Bay R-ph C-Bus Isolator's Post Insulator Flashover
PADGHE - KALWA CKT - 1	IntraState	26/04/2022	10:09	26/04/2022	10:32	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - KALWA CKT - 2	IntraState	26/04/2022	10:09	26/04/2022	10:36	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
BABHALESHWAR - PADGHE CKT- 1	IntraState	26/04/2022	14:25	26/04/2022	14:45	T	DP due to fire farm waste
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	27/04/2022	06:22			PO	For replacement of Faulty Dead end & Mid span joint & Faulty insulator strings by Long Rod porcelain detected in PID at various LOCs
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:57	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:34	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:47	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:46	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	11:00	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
400 KV BR Outages/Trippings							
80 MVar Bus reactor @ Talandge	IntraState	24/04/2022	18:45			T	Differential Trip
220 KV MAINBAY Outages/Trippings							
METERING BAY (CONSUMER) - 2 @ SERUM	IntraState	26/04/2022	16:15			PO	Replacement of 06 Nos. Of 75/5 A CT by New 100/5A CT.(Main and check) for metering bay-02.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
ADLABS - PEDAMBE	IntraState	25/04/2022	16:33	26/04/2022	01:35	T	Distance Protection
KHARGHAR - SONKHAR	IntraState	25/04/2022	19:17	26/04/2022	00:03	EO	1)B-phase LA replacement work & High LCM values Ir leakage - 654 microamp. Ir corrected - 613 microamp. I total < 1560 microamp. 2) Diagnostic testing. 3) Line Isolator Jaw & blade replacement work & Alignment work.
PADGHE - WADA	IntraState	26/04/2022	01:54	26/04/2022	06:40	EO	1) Attending hot spot at loc. No Dp 1 (Temp.108 B-PhPadgha side), Dp2(Temp.112 B-Ph Wada side & 110 B-PhPadgha side),81(Temp. 100 B-PhPadgha side),80A(Temp.112 R-Ph Wada side),80D (Temp.91 R-PhPadgha side) by Line Maintenance S/Dn, Boisar 2) To rectify problem in trip ckt supn relay (Y phase) of 220kV Wada Padgha line at 220KV Wada S/stn
MIRAJ - ICHALKARANJI	IntraState	26/04/2022	09:55	26/04/2022	19:41	PO	For replacement of B Ph CT having higher tan delta value
EKLAHARE (OCR) - PADGHE	IntraState	26/04/2022	10:09	26/04/2022	11:08	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - WADA	IntraState	26/04/2022	10:09	26/04/2022	11:06	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - NALASOPARA	IntraState	26/04/2022	10:09	26/04/2022	11:03	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - KAMBA 1	IntraState	26/04/2022	10:09	26/04/2022	11:03	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - TEMGHAR - 2	IntraState	26/04/2022	10:09	26/04/2022	11:06	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - TEMGHAR - 1	IntraState	26/04/2022	10:09	26/04/2022	10:47	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - JINDAL	IntraState	26/04/2022	10:09	26/04/2022	11:02	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - JAMBHUL 2	IntraState	26/04/2022	10:09	26/04/2022	11:01	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - JAMBHUL 1	IntraState	26/04/2022	10:09	26/04/2022	10:47	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
PADGHE - KAMBA 2	IntraState	26/04/2022	10:09	26/04/2022	11:03	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
BORIVALI - BOISAR (PG)	IntraState	26/04/2022	10:10	26/04/2022	10:48	T	over load.
GHODBUNDER - MSETCL BORIVALI	IntraState	26/04/2022	10:10	26/04/2022	10:52	T	LTS Operated.
MALHARPETH SATARA MIDC	IntraState	26/04/2022	10:13	26/04/2022	18:41	PO	Replacement of single/double suspension hardware at various towers & providing and fixing of doublr jumpering at CP location
PANDHARPUR - MALINAGAR	IntraState	26/04/2022	19:40	26/04/2022	21:40	EO	Attending hot spot of R and B phase Wave trap to line Isolator jump by replacing the existing jump by new one.
KALWA - MULUND 2	IntraState	27/04/2022	00:18	27/04/2022	03:36	PO	Removal Y Phase 2000A wave trap and installation of 1250A wave trap on Y Phase.
KHARGHAR - TOPWORTH	IntraState	27/04/2022	08:08			PO	For charging of 220kV Cable (KK line) for soak test from proposed Khandeshwar GIS to proposed Panvel Timber market93km)
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132 KV 200 MVA ICT 3 @ BABHLESHWAR	IntraState	20/12/2021	22:45			T	Tripped on Diferrential protection and Declare faulty
220/132 KV 100 MVA ICT 1 @ LONIKAND 2	IntraState	01/03/2022	18:17			T	Differential Protection
220/33 KV 50 MVA PTR 1	IntraState	20/04/2022	09:41			PO	50MVA BBL TF-1 Top plate gasket replacement work including radiators gasket and all allied works.
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	26/04/2022	09:11	26/04/2022	17:18	PO	Half yearly maintainance work,Diagnostic testing work, Annual testing, & Conservator aircell checking & re
220/100 KV 200 MVA ICT 3 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:55	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:58	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
220/100 KV 200 MVA ICT 1 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	10:48	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	26/04/2022	10:09	26/04/2022	11:08	T	Bus fault on 400 kV Padge- HVDC -2 Bay R-Ph C- Bus Isolator's Post insulator flashover.
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	26/04/2022	14:23	26/04/2022	16:04	EO	For attending 'TCIV Closed' indication which is observed frequently on CTR panel & to rectify the same by M/s CTR representative.
220/33kV 50MVA TF-1 @ KOPARGAON	IntraState	26/04/2022	16:05	26/04/2022	19:05	EO	For attending Hot spot & Pre-Monsoon maintenance activity works
110 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2022

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage