

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Apr/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	160.425	4282.706	1) Gujrat	-2.509	-87.138
2) Hydro	13.867	508.841	2) Madhya Pradesh	8.929	236.320
3) Gas	3.994	75.473	3) Chattisgarh	5.550	121.910
Total MSPGCL	178.286	4867.020	4) Maharashtra	205.092	4776.248
B) 1) APML	65.929	1851.499	5) Goa (Amona)	-1.359	-38.575
2) JSWEL	26.034	658.657	Total	215.703	5008.765
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.454	911.599
4) RPL(AMT)	30.670	778.439	b) Mumbai Drawl	44.091	1006.255
5) SWPGPL	12.275	303.108	c) MSEDCL Bilateral *	107.555	2586.010
6) Other IPP	17.763	533.741	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.454	911.599
C) 1) TPCL Thermal	10.486	307.831	Include PX	0.000	0.000
2) TPCL Hydro	2.767	134.690	Standby	0.000	0.000
3) TPCL Gas	4.085	85.485	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.933	244.433	1) MSEDCL	519.885	13451.767
D) STATE			2) Mumbai Discoms	71.362	1778.692
1) Thermal	333.515	8960.414	3) Other Discoms	10.485	266.422
(A1+C1+C4+(B1-B6))			TOTAL STATE	601.732	15496.881
2) Hydro	16.634	643.531			
3) Gas	8.079	160.958			
4) Wind	12.592	326.932			
6) SOLAR	15.209	396.283			
TOTAL STATE	386.029	10488.118			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6236	6654	6745	6730
MSPGCL Hydro	707	1057	923	297
MSPGCL Gas	223	158	150	276
MSPGCL Total Generation	7166	7869	7818	7303
Central Sector Receipt	10517	10287	8147	7554
WIND	131	298	973	843
CPP / IPP Thermal	5213	5892	6793	6889
CPP / IPP Gas	0	0	0	0
SOLAR	2128	1551	0	0
Exchange with Mumbai	-2252	-2156	-1829	-1779
MSEDCL DEMAND MET	22422	23269	21436	20401
Load Shedding	0	0	0	0
MSEDCL DEMAND	22422	23269	21436	20401
TPCL GENERATION	746	756	898	769
AEML GENERATION	475	497	404	386
MUMBAI DEMAND	3473	3409	3131	2934
OTHER DISCOM DEMAND	481	472	466	409
STATE DEMAND MET	26376	27150	25033	23744
STATE DEMAND	26376	27150	25033	23744
Frequency (Hz)	49.94	49.79	49.92	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.31 Hz at 16.05 Hrs	49.65 Hz at 14.12 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.40	99.38	205	135
Unit 8	13.94	316.83	601	530
Unit 9	0.00	154.40	0	0
Unit 10	11.53	338.96	490	468
Total	29.88	909.56		
Bhusawal				
Unit 3	3.66	87.82	165	125
Unit 4	10.08	242.32	480	355
Unit 5	11.18	277.53	490	425
Total	24.94	607.66		
Parli				
Unit 6	5.28	135.45	250	147
Unit 7	4.33	125.62	245	112
Unit 8	5.19	98.92	240	145
Total	14.80	359.99		
Chandrapur				
Unit 3	3.94	99.65	168	135
Unit 4	3.89	75.80	164	161
Unit 5	9.67	241.08	415	360
Unit 6	9.14	208.50	410	330
Unit 7	10.04	218.72	443	355
Unit 8	11.53	292.17	496	463
Unit 9	0.00	211.09	0	0
Total	48.21	1347.01		
Paras				
Unit 3	4.76	121.66	217	175
Unit 4	5.43	124.16	240	178
Total	10.20	245.82		
Khaparkheda				
Unit 1	3.01	71.54	135	110
Unit 2	3.08	66.18	142	116
Unit 3	3.24	103.08	188	0
Unit 4	4.34	110.74	191	134
Unit 5	10.56	257.33	460	392
Total	24.22	608.87		
Nasik				
Unit 3	0.00	67.03	0	0
Unit 4	4.20	73.99	182	164
Unit 5	3.99	62.77	171	160
Total	8.19	203.80		
Uran				
All Units	3.99	75.47	283	100
Total	3.99	75.47		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.77	0	0
Total	0.00	1.77		
Koyna				
Stage 1-2	2.24	121.32	390	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.41	203.06	523	0
Stage 3	1.53	69.86	186	0
Total	9.18	394.24		
Hydro				
KDPH	0.77	21.26	32	32
VTRNA	1.18	30.78	61	0
TILLARI	0.46	3.89	58	0
BHIRA T.R.	0.16	7.84	40	0
SMLHY_PTN	2.11	49.06	107	75
GHATGHAR	0.00	0.00	0	0
Total	4.68	112.83		
Wind				
Total	12.59	326.93	0	0
Total	12.59	326.93		
CPP				
APML(Mus)	65.93	1851.50	0	0
JSWEL(Mus)	26.03	658.66	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.67	778.44	0	0
SWPGPL-Mus	12.28	303.11	0	0
Dhariwal	5.74	157.09	271	147
IEPL	5.26	137.92	269	196
Other(Mus)	6.77	238.74	0	0
Total	152.67	4125.44		
SOLAR				
Total	15.21	396.28	0	0
Total	15.21	396.28		
Tata				
Trombay 5	6.93	200.28	340	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.55	51.46	107	106
Trombay 7B	1.54	34.03	64	63
TATA Hydro	2.77	134.69	277	24
Trombay 8	3.56	107.55	186	132
Total	17.34	528.01		
AEML				
DTPS U-1&2	9.93	244.43	500	329
Total	9.93	244.43		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	160.42	4282.71	MSPGCL Total	178.29	4867.02
			MSPGCL Thml+Gas	164.42	4358.18	Koyna 1,2 & 4 Total	7.66	324.38
			MSPGCL Hydro	13.87	508.84	State Total	386.03	10488.12

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planne d	Trans missio n Constr aint					
1	6804	421	140	7365	777	6883	0	0	8933	8548	-1764	21427	0	0	21427	2868	383	24677	50.00
2	6700	210	140	7050	655	6874	0	0	8692	9076	-1592	21709	0	0	21709	2663	354	24726	49.93
3	6650	318	142	7110	487	6856	0	0	8539	8853	-1459	21508	0	0	21508	2499	339	24346	50.00
4	6619	271	142	7032	452	6848	0	0	8516	8580	-1350	21225	0	0	21225	2377	337	23939	50.01
5	6655	252	142	7049	444	6833	0	0	8941	8612	-1335	21251	0	0	21251	2323	352	23926	50.00
6	6678	299	143	7120	376	6842	0	0	9256	9285	-1337	21901	0	0	21901	2353	385	24639	49.89
7	6836	517	142	7495	260	6698	0	121	9343	9152	-1401	21914	0	3	21914	2397	411	24722	50.00
8	6943	715	144	7802	221	6347	0	571	8424	8802	-1540	21757	0	13	21757	2536	446	24739	50.00
9	6841	577	161	7579	183	6114	0	1156	8949	8758	-1843	21485	0	33	21485	2853	462	24800	49.99
10	6737	578	180	7495	217	5601	0	1651	9553	9525	-1962	22050	0	36	22050	3185	477	25712	50.03
11	6616	757	163	7536	171	5348	0	2037	10432	9864	-2170	22313	0	171	22313	3399	473	26185	50.03
12	6236	707	223	7166	131	5213	0	2128	10511	10517	-2252	22422	0	152	22422	3473	481	26376	49.94
13	6415	1024	196	7635	101	5386	0	2074	9988	10129	-2181	22694	0	44	22694	3436	450	26580	49.93
14	6649	876	189	7714	167	5665	0	1880	10001	9915	-2069	22806	0	60	22806	3338	466	26610	49.94
15	6654	1057	158	7869	298	5892	0	1551	10395	10287	-2156	23269	0	0	23269	3409	472	27150	49.79
16	6636	820	100	7556	330	6383	0	1083	10432	10242	-2152	22954	0	0	22954	3456	488	26898	49.98
17	6661	842	113	7616	569	6461	0	655	10294	9565	-2258	22117	0	0	22117	3411	491	26019	50.05
18	6646	766	138	7550	794	6265	0	281	9250	8962	-2184	21164	0	0	21164	3310	504	24978	50.02
19	6689	666	155	7510	1006	6279	0	21	8332	8450	-2046	20746	0	0	20746	3145	474	24365	50.01
20	6745	923	150	7818	973	6793	0	0	8006	8147	-1829	21436	0	0	21436	3131	466	25033	49.92
21	6787	375	175	7337	1100	6835	0	0	8158	7615	-1843	20568	0	0	20568	3015	476	24059	49.95
22	6756	298	199	7253	1041	6485	0	0	7725	7808	-1784	20347	0	0	20347	2933	456	23736	49.93
23	6742	301	283	7326	996	6881	0	0	7864	7457	-1805	20422	0	0	20422	2918	433	23773	49.98
24	6730	297	276	7303	843	6889	0	0	7782	7554	-1779	20401	0	0	20401	2934	409	23744	49.96
MUs	160.43	13.87	3.99	178.29	12.59	152.67	0.00	15.21	218.32	215.70	-44.09	519.89	0.00	0.51	519.89	71.36	10.48	601.73	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1) 132kv BBLR Sangamner line overload.2)400kv bus voltage reduced to 372kv DLS implement to avoid LTS operation. 3)DLS done due to overloading of 220kv jejuri lonand line. 4) DLS done AG feeders at 220kv Ranjangaon ss due to low voltage at 400kv lonikand.5) FLS given to manage Kolhapur ICT loading.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Apr/2023

Position as on 6.30 Hrs of 27/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51	26/04/2023	08:44	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 6	108	20/04/2023	19:15		Continued.	No Schedule.	
MSPGCL	Koradi Unit 9	660	22/04/2023	20:27		Continued.	Boiler Tube Leakage	28/04/2023
MSPGCL	Chandrapur Unit 9	500	24/04/2023	10:09		Continued.	Boiler Tube Leakage	28/04/2023
MSPGCL	Khaparkheda Unit 3	210	26/04/2023	11:39	26/04/2023	16:29	Flame Failure	
MSPGCL	Uran Unit B0	120	26/04/2023	13:42	26/04/2023	19:00	For Synchronization in Combine Cycle.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ KORADI 3	IntraState	27/04/2023	09:22			PO	Annual Maintenance of Bus Equipments
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	25/04/2023	22:57	26/04/2023	02:02	EO	Emergency Shutdown of HVDC Pole-1 Non BASE FILTER Z11-Z3/Z4 for attending Hotspots at various locations in Z11-Z3/Z4 R-Phase, Respective images are also attached.
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	26/04/2023	02:28	26/04/2023	04:22	EO	Emergency Shutdown of HVDC Pole-1 Base filter Z11-Z1/Z2 for attending Hotspots at various locations in all the three phase,respective images are also attached
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF KARAD LINE AND 400/220KV 315MVA ICT - 1 @ SOLAPUR (PG)	InterState	15/04/2023	09:39			PO	411-Bay Y.Ph CT Replacement due to oil seepage from porcelain and cementing joint
TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	IntraState	26/04/2023	08:28			PO	For balance testing work and charging of 125 MVAR bus shunt reactor.
400 KV MAINBAY Outages/Trippings							
MAIN BAY 416 OF 400KV 125MVAR BUS REACTOR	InterState	26/04/2023	08:28			PO	For balance testing work and charging of 125 MVAR bus shunt reactor.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
LONIKAND - JEJURI CKT - 1	IntraState	26/04/2023	09:13	26/04/2023	12:03	EO	For shifting 400 kV Lonikand 2 Jejuri ckt 1 Line on 400kV TBC due to 29 B Isolator B Phase Hotspot attending work at BPI clamp(160degree)
GTR - 9 @ CHANDRAPUR SWITCHING SS	IntraState	26/04/2023	10:05				for Diagnostic testing & allied bay maintenance work
KORADI - KHADKA	IntraState	26/04/2023	15:47	26/04/2023	19:26	T	Tripped on Distance protection.
RPL(AMT) NANDGAON PETH - AKOLA 2 CKT - 2	IntraState	26/04/2023	18:28	26/04/2023	21:21	T	Tripped on Distance protection.
PADGHE - KALWA CKT - 1	IntraState	27/04/2023	00:32	27/04/2023	05:59	HT	Emergency outage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 1 @ WALUJ	IntraState	24/04/2023	10:24	26/04/2023	19:55	PO	1. ICT-I IV Bay Circuit Breaker pole overhauling work. 2. ICT-I IV will be charged through TBC Bay.
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	25/04/2023	10:41			PO	For termination of power cable
STATION TRANSFORMER - 2 @ NANDGAON PETH	IntraState	25/04/2023	13:16			PO	ST-2 TRANSFORMER OIL LEAKAGE ARRESTING , MAINTENANCE AND DIAGNOSTIC TESTING WORK.
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	26/04/2023	15:57	26/04/2023	16:47	T	Tripped On NDR
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
NEW KOYNA - PEDAMBE	IntraState	25/04/2023	10:57	26/04/2023	18:40	PO	TBC Shifting of Bay for detecting & attending SF-6 gas leakage from Pole.
COLOURCHEM - TEMGHAR	IntraState	26/04/2023	07:22	26/04/2023	10:20	EO	For attending 220KV Temghar line CB hot spot on Y-ph top palm Nut-bolt after shifting the line on TBC.
BUS @ BARSHI	IntraState	26/04/2023	09:15	26/04/2023	14:11	PO	Outage is required for Quarterly Maintenance
PEDHAMBE ONI LINE	IntraState	26/04/2023	09:25	26/04/2023	19:25	PO	For Cold washing of insulator string
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	26/04/2023	09:28	26/04/2023	10:59	HT	H/T TO CONTROL BBLR LINE LOADING
LAMBOTI - PANDHARPUR	IntraState	26/04/2023	10:58	26/04/2023	15:00	PO	Outage is required for To attend developing hot spot at Loc no. 531A, 521, 498 (Temp ranges from 52 to 63.9 degree celcius
ABHIJEET-WARDHA-1	IntraState	26/04/2023	12:16	26/04/2023	16:41	PO	TESTING OF DISTANCE PROTECTION RELAY BY TESTING UNIT MANKAPUR & MEASUREMENT OF BREAKER TIMING,CRM & IR VALUES OF CB AT 220KV ABHIJEET SUBSTATION
TALOJA - PANCHANAND	IntraState	26/04/2023	12:19	26/04/2023	18:11	EO	To attend hot spot at various Location i.e Loc no. 652B, 647B, 641B, 1B, 4B.
LAMBOTI - KARKAMB	IntraState	26/04/2023	15:13	26/04/2023	18:39	PO	Outage is required for To attend developing hot spot at Loc no.459 B ph (Lamboti & Karkambh side) Temp is 60.1/58.5 degree celcius
LAMBOTI - KARKAMB	IntraState	26/04/2023	15:13	26/04/2023	18:39	PO	Outage is required for Quarterly Maintenance
MIRAJ - ICHALKARANJI	IntraState	26/04/2023	18:00	26/04/2023	19:28	EO	For attending hotspot at T.L No-5, Y phase- 98.6C
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	26/04/2023	19:01	26/04/2023	23:27	T	Distance Protection.
KARAD -NIGADE	IntraState	27/04/2023	09:32			T	TRIPPED ON DISTANCE PROTECTION
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 25 MVA PTR 1 @ NAGOTHANE	IntraState	25/04/2023	09:10	26/04/2023	08:28	PO	22 KV BUS JUMPER TIGHTNING AND PRE MANSOON MAINTENANCE AND OTHER WORK.
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	IntraState	26/04/2023	10:10	26/04/2023	12:26	PO	CB Diagnostic & RM Work.
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	26/04/2023	10:22	26/04/2023	13:05	PO	Outage is required for Quarterly Maintenance
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	26/04/2023	10:55	26/04/2023	19:10	PO	For replacement of air cell and general maintenance work
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	27/04/2023	08:31			PO	Half yearly maintenance & Dignostic testing work.
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	27/04/2023	09:32			PO	To attend Red Hot at HV Side R-Ph Isolator ICT side Jaw and Blade.
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	27/04/2023	09:56			PO	CB Diagnostic & RM Work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 27/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - BHIVPURI CKT - 2	IntraState	26/04/2023	05:50	26/04/2023	10:32	PO	For Attending to transfer bus side GOD closing problem and Routine maintenance of line GOD

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage