

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/May/2018 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.712	3771.231	1) Gujrat	-2.044	-76.437
2) Hydro	18.719	655.349	2) Madhya Pradesh	13.864	404.160
3) Gas	6.998	191.288	3) Chattisgarh	5.870	180.540
Total MSPGCL	169.429	4617.868	4) Maharashtra Net	128.319	3398.838
B) 1) APML	58.898	1218.392	5) Goa (Amona)	-0.066	-8.382
2) JSWEL	27.841	719.995	Total	145.943	3898.719
3) VIPL	7.481	148.096	a) Mumbai Schedule	29.182	759.263
4) RPL(AMT)	19.922	417.903	b) Mumbai Drawl	32.687	820.005
5) WPCL	4.754	109.917	c) MSEDCL Bilateral *	46.698	1204.221
6) PGPL	0.000	0.000	Include PX	7.992	289.531
7) Other IPP	15.322	288.018	d) Mumbai Bilateral *	28.882	758.698
C) 1) TPCL Thermal	16.785	433.723	Include PX	10.906	306.156
2) TPCL Hydro	4.709	136.269	Include Standby	0.300	0.565
3) TPCL Gas	2.585	67.089	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	11.926	305.379	1) MSEDCL	443.399	11295.115
D) STATE			2) Mumbai Discoms	68.693	1762.452
1) Thermal	306.641	7412.654	TOTAL STATE	512.092	13057.567
(A1+C1+C4+(B1-B6))					
2) Hydro	23.428	791.618			
(A2+C2)					
3) Gas	9.583	258.377			
(A3+B6+C3)					
4) Wind	20.388	540.913			
6) SOLAR	6.108	155.299			
TOTAL STATE	366.148	9158.861			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6198	6238	6106	5614
MSPGCL Hydro	769	1612	1398	353
MSPGCL Gas	282	290	295	286
MSPGCL Total Generation	7249	8140	7799	6253
Central Sector Receipt	6505	7219	5657	5670
WIND	909	395	401	1038
CPP / IPP Thermal	5574	5581	5495	5647
CPP / IPP Gas	0	0	0	0
SOLAR	821	505	19	0
Exchange with Mumbai	-1617	-1543	-1366	-1456
MSEDCL DEMAND MET	19441	20297	18005	17152
Load Shedding	0	0	0	0
MSEDCL DEMAND	19441	20297	18005	17152
TPCL GENERATION	1052	1252	1063	1027
R-INFRA GENERATION	497	495	496	500
MUMBAI DEMAND	3166	3290	2925	2983
STATE DEMAND MET	22607	23587	20930	20135
STATE DEMAND	22607	23587	20930	20135
Frequency (Hz)	49.91	49.79	49.93	49.81

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.13 Hz at 13.03 Hrs	49.57 Hz at 19.49 Hrs	49.91	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 26/May/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.61	212.61	331	299
Unit 9	7.70	226.93	346	300
Unit 10	7.62	213.74	331	300
Total	22.92	653.28		
Bhusawal				
Unit 3	0.00	79.04	0	0
Unit 4	10.76	235.43	485	420
Unit 5	10.54	264.32	470	420
Total	21.30	578.80		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.14	127.09	179	166
Unit 7	4.10	126.57	191	162
Unit 8	3.33	120.39	170	0
Total	11.56	374.05		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	11.06	266.42	465	455
Unit 6	0.00	0.00	0	0
Unit 7	10.52	215.90	453	362
Unit 8	10.52	253.72	485	410
Unit 9	10.80	254.94	474	423
Total	42.90	990.98		
Paras				
Unit 3	5.85	148.84	250	225
Unit 4	5.87	136.12	250	230
Total	11.72	284.97		
Khaparkheda				
Unit 1	3.72	94.10	165	140
Unit 2	3.77	101.68	160	155
Unit 3	3.78	101.77	167	150
Unit 4	3.36	100.31	165	0
Unit 5	9.52	267.85	505	0
Total	24.14	665.70		
Nasik				
Unit 3	4.53	5.83	196	171
Unit 4	4.64	113.34	199	188
Unit 5	0.00	104.27	0	0
Total	9.17	223.44		
Uran				
All Units	7.00	191.29	300	278
Total	7.00	191.29		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	2.52	23	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.13	2.52		
Koyna				
Stage 1-2	6.36	169.52	485	40
Stage 4	7.31	316.62	750	0
Stage 3	3.11	106.67	320	0
Total	16.78	592.81		
Hydro				
KDPH	0.42	16.47	28	14
VTRNA	0.00	0.00	0	0
TILLARI	0.12	3.29	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.36	7.76	80	0
RNGR+BHTSA	0.26	7.03	11	10
BHANDARDRA	0.00	11.62	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.35	9.31	22	12
GHATGHAR	0.43	7.05	125	0
Total	1.94	62.54		
Wind				
Total	20.39	540.91	0	0
Total	20.39	540.91		
CPP				
APML(Mus)	58.90	1218.39	0	0
JSWEL(Mus)	27.84	720.00	0	0
VIPL(Mus)	7.48	148.10	0	0
RPLAMT(Mus)	19.92	417.90	0	0
WPCL(Mus)	4.75	109.92	0	0
Other(Mus)	15.32	288.02	0	0
Total	134.22	2902.32		
SOLAR				
Total	6.11	155.30	0	0
Total	6.11	155.30		
Tata				
Trombay 5	11.14	287.20	480	418
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.50	38.24	96	45
Trombay 7B	1.09	28.85	59	37
Trombay 8	5.64	146.52	243	229
TATA Hydro	4.71	136.27	389	0
Total	24.08	637.08		
R-INFRA				
DTPS U-1&2	11.93	305.38	500	492
Total	11.93	305.38		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.71	3771.23	MSPGCL Total	169.43	4617.87
			MSPGCL Thml+Gas	150.71	3962.52	Koyna 1,2 & 4 Total	13.67	486.14
			MSPGCL Hydro	18.72	655.35	State Total	366.15	9158.86

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/May/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5814	388	290	6492	1544	5721	0	0	5414	5862	-1405	18214	0	18214	2945	21159	49.94
2	5806	715	299	6820	1373	5719	0	0	5372	5670	-1269	18313	0	18313	2748	21061	49.95
3	5943	369	299	6611	1250	5637	0	0	5559	5784	-1168	18114	0	18114	2573	20687	49.94
4	6071	108	300	6479	1156	5631	0	0	5515	5736	-1102	17900	0	17900	2450	20350	49.99
5	6064	78	300	6442	1109	5653	0	0	5578	5981	-1106	18079	0	18079	2415	20494	50.01
6	6096	273	290	6659	1102	5656	0	0	6077	6018	-1121	18314	0	18314	2421	20735	49.96
7	6056	543	300	6899	912	5620	0	51	6421	6491	-1082	18891	0	18891	2342	21233	49.98
8	6085	575	300	6960	886	5596	0	221	6020	6089	-1125	18627	0	18627	2374	21001	50.03
9	6084	525	299	6908	991	5552	0	419	5810	5963	-1281	18552	0	18552	2519	21071	49.99
10	6063	276	287	6626	898	5570	0	615	5826	5649	-1388	17970	0	17970	2778	20748	49.99
11	6119	354	293	6766	867	5540	0	761	5833	5936	-1569	18301	0	18301	3034	21335	49.93
12	6198	769	282	7249	909	5574	0	821	6339	6505	-1617	19441	0	19441	3166	22607	49.91
13	6194	502	290	6986	800	5565	0	813	6988	6817	-1623	19358	0	19358	3194	22552	49.89
14	6222	442	281	6945	660	5537	0	775	6859	7048	-1586	19379	0	19379	3158	22537	49.93
15	6239	1241	278	7758	473	5530	0	665	6826	6832	-1616	19642	0	19642	3253	22895	49.85
16	6238	1612	290	8140	395	5581	0	505	6670	7219	-1543	20297	0	20297	3290	23587	49.79
17	6268	1682	281	8231	423	5568	0	314	6665	7138	-1467	20207	0	20207	3219	23426	49.81
18	6193	1726	283	8202	444	5535	0	129	6431	6470	-1381	19399	0	19399	3068	22467	49.88
19	6106	1398	295	7799	401	5495	0	19	5701	5657	-1366	18005	0	18005	2925	20930	49.93
20	5746	1207	294	7247	353	5464	0	0	5465	5395	-1262	17197	0	17197	2955	20152	49.77
21	5491	1592	287	7370	382	5623	0	0	5382	5330	-1341	17364	0	17364	2978	20342	49.90
22	5452	1316	297	7065	868	5641	0	0	5391	5308	-1400	17482	0	17482	2922	20404	49.83
23	5550	675	297	6522	1154	5561	0	0	5420	5375	-1413	17199	0	17199	2982	20181	49.82
24	5614	353	286	6253	1038	5647	0	0	5523	5670	-1456	17152	0	17152	2983	20135	49.81
MUs	143.71	18.72	7.00	169.43	20.39	134.22	0.00	6.11	143.08	145.94	-32.69	443.40	0.00	443.40	68.69	512.09	49.91

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/May/2018

Position as on 6.30 Hrs of 27/May/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
MSPGCL	Chandrapur Unit 6	500	04/01/2018	13.30		Continued.	Water Shortage, converted to AOH w.e.f 01.02.2018, 00:00Hrs	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown. (NO PPA FROM 01.04.2018)	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 3	210	03/12/2017	01.35		Continued.	Water Shortage	
MSPGCL	Chandrapur Unit 4	210	03/12/2017	14.17		Continued.	Water Shortage	
MSPGCL	Koradi Unit 7	210	07/01/2018	17.00		Continued.	Poor Coal Receipt.	
MSPGCL	Uran Unit 8	108	25/03/2018	06.25		Continued.	Tripped on Thrust Bearing	
IPP	VIPL U-1	300	01/04/2018	00.26		Continued.	Coal Shortage	
MSPGCL	Ghatghar Unit-1	125	14/04/2018	23.45		Continued.	Stator Earth Fault	
IPP	Adani U-5	660	24/04/2018	08.53		Continued.	Bottom Ash problem	
IPP	RPL(AMT) U-1	270	01/05/2018	00.00		Continued.	Coal Shortage	
CENT.SECTOR	TARAPUR-3	540	02/05/2018	20.01	27/05/2018	03.31	Problem In Reactor	
IPP	RPL(AMT) U-2	270	06/05/2018	18.00		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	12/05/2018	19.16		Continued.	Due To Unit 7 Outage.	
MSPGCL	Uran Unit 7	108	12/05/2018	19.30		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	IEPL INTER CHANGE.	
MSPGCL	Nasik Unit 5	210	25/05/2018	16.00		Continued.	Boiler Inspection work	
MSPGCL	Khaparkheda Unit 4	210	25/05/2018	22.04	26/05/2018	02.03	Furnace Pressure High	
MSPGCL	Parli Unit 8	250	26/05/2018	18.56	26/05/2018	22.15	Drum level low	
MSPGCL	Khaparkheda Unit 5	500	26/05/2018	19.42		Continued.	Boiler Tube Leakage	
MSPGCL	Paras Unit 3	250	27/05/2018	09.38	27/05/2018	12.52	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2018

Statement-VII

Position as on 6.30 Hrs of 27/May/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	25/05/2018	18.03	26/05/2018	10.22	T	DT send from Dhule end
Dhule Sar'Sarovar II	InterState	26/05/2018	18.29		Continued.	HT	Over Voltage
Koradi Bhilai	InterState	26/05/2018	21.33	26/05/2018	22.17	T	Distance Protection
Chandrapur Bhadravati III	InterState	26/05/2018	22.02	27/05/2018	00.04	T	Distance Protection
Kharghar-Talegaon(PG)	IntraState	26/05/2018	01.10	26/05/2018	01.41	T	Distance Protection
Kalwa - Talegaon(PG)	IntraState	26/05/2018	05.21	26/05/2018	11.32	EO	Insulator String Replacement Work.
Chandrapur-Parali III	IntraState	26/05/2018	08.44	26/05/2018	18.05	PO	Line Maintenance work
New Koyna - Dabhol - li	IntraState	26/05/2018	08.47	26/05/2018	19.22	PO	Routine Maintenance Work
Koradi-Bhusawal	IntraState	26/05/2018	17.12	26/05/2018	18.18	T	Distance Protection
Parly(MS)- Nanded ckt I	IntraState	26/05/2018	22.37	26/05/2018	23.43	T	Distance Protection
Karad-Jaigad - I	IntraState	27/05/2018	18:15		Continued.	T	Distance Protection. RFC 19:43 DT:27/05/2018
Lonikand I - Koyna stage-IV	IntraState	27/05/2018	22.15	27/05/2018	22.39	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220/33 Kv 500 Mva Ict 1 @Chandrapur 2	IntraState	31/03/2018	21.21		Continued.	HT	hand tripped after charge.
400/220kv, 500 MVA ICT-II @Deepnagar	IntraState	26/05/2018	06.38	26/05/2018	16.48	PO	Routine Maintenance Work
400/220/33 Kv 315 Mva Ict 1 @Dhule	IntraState	26/05/2018	11.10		Continued.	PO	Replacement Of Y PH Unit.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	26/05/2018	11.50	26/05/2018	20.43	PO	Routine Maintenance Work
400/220KV 500MVA ICT1@koradi 2	IntraState	26/05/2018	19.10	26/05/2018	20.54	T	NDR Protection.
400/220KV 500MVA ICT 2@koradi 2	IntraState	26/05/2018	19.10	26/05/2018	21.14	T	NDR Protection.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	27/05/2018	05.25	27/05/2018	11.09	PO	Testing Work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Wardha Deoli (Pg)	InterState	26/05/2018	15.30	26/05/2018	18.50	HT	HT for O/D.
Badnera - Deoli (PG)	InterState	26/05/2018	15.40	26/05/2018	18.51	HT	HT for O/D
Borivali - Tarapur	InterState	27/05/2018	06.41	27/05/2018	09.02	PO	SHIFTING OF PHWR CALANDRIA TUBE SHEET ON TRAILER.
Boisar Tarapur	InterState	27/05/2018	07.32	27/05/2018	08.32	PO	SHIFTING OF PHWR CALANDRIA TUBE SHEET ON TRAILER.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Sonkhar - Trombay	IntraState	15/05/2018	23.50		Continued.	PO	REPLACEMENT OF HTLS CONDUCTOR.
Bableshwar -Bhenda	IntraState	26/05/2018	07.30	26/05/2018	13.32	PO	Routine Maintenance Work
Dahanu Ghodbunder Line 1	IntraState	26/05/2018	07.42	26/05/2018	12.07	EO	Attending Hot Spot
Pirangut - Hinjawadi 2	IntraState	26/05/2018	09.05	26/05/2018	12.26	PO	Half yearly maintenance work
Kalwa - Siemens	IntraState	26/05/2018	09.07	26/05/2018	14.15	PO	Line Maintenance work
Chalisgaon-Sayne	IntraState	26/05/2018	09.19	26/05/2018	13.11	PO	Checking Of L A s

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2018

Statement-VII

Position as on 6.30 Hrs of 27/May/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Mahad - Pedambe	IntraState	26/05/2018	10.05	26/05/2018	10.28	T	LBB OPTD Due To Unit 10 BR Stuck Up While Withdrawing Unit.
New Koyna - Pedambe	IntraState	26/05/2018	10.05	26/05/2018	14.45	T	LBB OPTD Due To Unit 10 BR Stuck Up While Withdrawing Unit.
Pedambe-Pophali	IntraState	26/05/2018	10.05	26/05/2018	10.30	T	LBB OPTD Due To Unit 10 BR Stuck Up While Withdrawing Unit.
Main Bus Section-I@ Pedambe	IntraState	26/05/2018	10.05	26/05/2018	10.25	T	LBB OPTD Due To Unit 10 BR Stuck Up While Withdrawing Unit.
Nagothane - Posco	IntraState	26/05/2018	10.44	26/05/2018	17.55	PO	Insulator String Replacement.
Dahanu-Viraj	IntraState	26/05/2018	12.40	26/05/2018	14.17	EO	Attending Hot Spot
Ranjangaon-Lonikand	IntraState	26/05/2018	14.15	26/05/2018	16.20	T	Distance Protection
Warora - Wardha	IntraState	26/05/2018	19.59	27/05/2018	22.25	T	Distance Protection
Wani-Warora	IntraState	26/05/2018	21.23	26/05/2018	22.20	T	Distance Protection
Nanded - Parli Ext. Ckt I	IntraState	26/05/2018	22.37	26/05/2018	23.44	T	Distance Protection
Warora - Hinganghat	IntraState	26/05/2018	23.10	27/05/2018	01.23	PO	B phase jumper open.
Pedambe-Nerle	IntraState	27/05/2018	08.15	27/05/2018	17.32	PO	REPLACEMENT OF FAULTY INSULATOR STRING.
Ghodbunder - Gorai	IntraState	27/05/2018	09.03	27/05/2018	09.55	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
Gorai MSETCL Borivali Line-2	IntraState	27/05/2018	09.03	27/05/2018	10.50	PO	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
Gorai MSETCL Borivali Line-1	IntraState	27/05/2018	09.03	27/05/2018	10.49	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
Versova Gorai Line	IntraState	27/05/2018	09.03	27/05/2018	09.57	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
Nerul-Trombay	IntraState	27/05/2018	11.49	27/05/2018	15.13	T	Distance Protection
Akola-Paras Ckt No-Ii	IntraState	27/05/2018	11.54	27/05/2018	12.13	T	Distance Protection
Karad(400kv) - Ogalewadi Ckt 1	IntraState	27/05/2018	12.03	27/05/2018	12.23	T	Distance Protection
Shivajinagar-Gangapur	IntraState	27/05/2018	15.26	27/05/2018	19.18	PO	Line Maintenance work
Paranda Tap Osmanabad - Barshi	IntraState	27/05/2018	18.52	27/05/2018	19.30	T	Distance Protection
Paranda-Barshi	IntraState	27/05/2018	19.10	27/05/2018	19.48	T	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(repaired and ready for commissioning)
220/100 Kv 200 MVA ICT-IV@Kalwa	IntraState	24/11/2017	01.58		Continued.	T	Buchholz PRV Operated(Failed on Internal Fault)
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	25/05/2018	08.11	26/05/2018	00.03	PO	P T Replacement.
220/132 Kv 200 MVA ICT II @Babhleshwar	IntraState	26/05/2018	09.45	26/05/2018	15.15	PO	Pre-monsoon Maintenance Work.
220/33kv 125 Mva Transformer 2 @Gorai R/S	IntraState	27/05/2018	09.03		Continued.	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2018

Statement-VII

Position as on 6.30 Hrs of 27/May/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33kv 125 Mva Transformer 1 @Gorai R/S	IntraState	27/05/2018	09.03	27/05/2018	10.03	T	WHILE CHANGEOVER 125 MVA TF 2 FROM M B 2 TO M B 1, BUS FAULT OF BUS 1 & 2 OCCURRED. LOAD AFFECTED 46 MW. ALL LOAD SHIFTED ON BUS 2.
132 KV LINE Outages/Trippings							
Mansar PENCH	InterState	26/05/2018	16.21		Continued.	HT	HT for O/D.
Paranda - Bhoom	IntraState	27/05/2018	18.52	27/05/2018	19.30	PO	I/C SUPPLY FAIL.
Paranda-Kharda	IntraState	27/05/2018	18.52	27/05/2018	19.30	PO	I/C SUPPLY FAIL.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage