

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/May/2022 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	164.927	4328.163	1) Gujrat	-6.988	-150.739
2) Hydro	25.309	575.795	2) Madhya Pradesh	4.492	135.896
3) Gas	4.916	146.314	3) Chattisgarh	3.070	90.490
Total MSPGCL	195.152	5050.272	4) Maharashtra	175.731	4775.850
B) 1) APML	75.895	1679.450	5) Goa (Amona)	-1.379	-34.902
2) JSWEL	16.457	470.493	Total	174.926	4816.595
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.698	924.577
4) RPL(AMT)	19.230	631.171	b) Mumbai Drawl	40.332	993.149
5) SWPGPL	9.486	219.280	c) MSEDCL Bilateral *	80.504	1977.115
6) Other IPP	15.492	514.580	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.698	924.421
C) 1) TPCL Thermal	14.639	375.480	Include PX	0.000	0.000
2) TPCL Hydro	4.309	107.647	Standby	0.000	0.156
3) TPCL Gas	2.497	58.529	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.538	290.690	1) MSEDCL	498.855	13202.707
D) STATE			2) Mumbai Discoms	73.315	1825.479
1) Thermal	327.664	8509.307	3) Other Discoms	9.529	242.845
(A1+C1+C4+(B1-B6))			TOTAL STATE	581.699	15271.031
2) Hydro (A2+C2)	29.618	683.442			
3) Gas (A3+B7+C3)	7.413	204.843			
4) Wind	31.731	819.247			
6) SOLAR	10.347	237.613			
TOTAL STATE	406.773	10454.452			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6739	6869	7265	6596
MSPGCL Hydro	904	1092	810	998
MSPGCL Gas	195	264	265	150
MSPGCL Total Generation	7838	8224	8340	7744
Central Sector Receipt	8991	8650	6025	6546
WIND	527	905	2044	1704
CPP / IPP Thermal	5595	5604	5921	5713
CPP / IPP Gas	0	0	0	0
SOLAR	1306	910	1	0
Exchange with Mumbai	-2175	-2122	-1434	-1246
MSEDCL DEMAND MET	21651	21748	20461	20163
Load Shedding	0	0	0	0
MSEDCL DEMAND	21651	21748	20461	20163
TPCL GENERATION	851	924	1190	844
AEML GENERATION	474	487	457	467
MUMBAI DEMAND	3500	3533	3081	2557
OTHER DISCOM DEMAND	432	424	436	298
STATE DEMAND MET	25582	25704	23978	23018
STATE DEMAND	25582	25704	23978	23018
Frequency (Hz)	50.00	50.03	49.96	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 08:02 Hrs	49.74 Hz at 22:20 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.62	100.96	160	135
Unit 7	0.00	0.00	0	0
Unit 8	14.31	348.03	608	576
Unit 9	12.20	321.08	577	455
Unit 10	13.23	332.02	593	535
Total	43.36	1102.09		
Bhusawal				
Unit 3	0.00	74.35	0	0
Unit 4	8.51	206.95	430	280
Unit 5	8.25	230.14	430	280
Total	16.76	511.44		
Parli				
Unit 6	5.50	75.20	243	165
Unit 7	5.24	107.13	245	169
Unit 8	3.10	70.33	134	127
Total	13.84	252.66		
Chandrapur				
Unit 3	3.16	97.00	160	126
Unit 4	3.12	89.87	144	120
Unit 5	1.65	190.74	341	0
Unit 6	9.17	211.55	390	360
Unit 7	9.78	233.72	422	383
Unit 8	10.81	260.57	458	441
Unit 9	10.38	261.83	441	423
Total	48.07	1345.27		
Paras				
Unit 3	4.62	109.97	225	138
Unit 4	3.97	113.64	188	140
Total	8.59	223.61		
Khaparkheda				
Unit 1	3.12	76.98	140	100
Unit 2	3.39	91.22	155	120
Unit 3	4.17	93.50	180	151
Unit 4	3.19	82.58	145	123
Unit 5	11.07	286.09	475	450
Total	24.95	630.38		
Nasik				
Unit 3	2.22	81.68	188	0
Unit 4	3.66	89.78	170	139
Unit 5	3.49	91.26	166	117
Total	9.36	262.71		
Uran				
All Units	4.92	146.31	277	130
Total	4.92	146.31		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.13	2.98	25	0
Total	0.13	2.98		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.79	120.00	485	40
Stage 4	12.00	194.08	1008	210
Stage 3	3.44	69.78	320	80
Total	19.23	383.86		
Hydro				
KDPH	0.59	13.94	25	25
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.16	4.92	77	0
SMLHY_PTN	5.20	135.25	225	207
GHATGHAR	0.00	9.26	0	0
Total	5.94	188.96		
Wind				
Total	31.73	819.25	0	0
Total	31.73	819.25		
CPP				
APML(Mus)	75.90	1679.45	0	0
JSWEL(Mus)	16.46	470.49	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.23	631.17	0	0
SWPGPL-Mus	9.49	219.28	0	0
Other(Mus)	15.49	514.58	0	0
Total	136.56	3514.97		
SOLAR				
Total	10.35	237.61	0	0
Total	10.35	237.61		
Tata				
Trombay 5	9.38	244.60	456	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.51	36.47	114	46
Trombay 7B	0.99	22.06	65	0
TATA Hydro	4.31	107.65	434	62
Trombay 8	5.26	130.88	231	145
Total	21.44	541.66		
AEMIL				
DTPS U-1&2	11.54	290.69	500	427
Total	11.54	290.69		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	164.93	4328.16	MSPGCL Total	195.15	5050.27
			MSPGCL Thml+Gas	169.84	4474.48	Koyna 1,2 & 4 Total	15.79	314.09
			MSPGCL Hydro	25.31	575.80	State Total	406.77	10454.45

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 26/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6686	1954	140	8780	1749	5942	0	0	6620	6529	-1572	21084	0	21084	3084	344	24512	49.97
2	6700	1596	130	8426	1708	5937	0	0	6630	6533	-1444	20847	0	20847	2890	312	24050	50.00
3	6609	1510	140	8260	1788	5934	0	0	6343	6354	-1334	20694	0	20694	2696	308	23698	50.00
4	6596	998	150	7744	1704	5713	0	0	6692	6546	-1246	20163	0	20163	2557	298	23018	50.01
5	6593	1008	130	7730	1654	5644	0	0	6845	6803	-1227	20291	0	20291	2490	313	23094	49.97
6	6589	1538	140	8268	1379	5671	0	0	6901	6966	-1202	20745	0	20745	2483	337	23564	49.95
7	6681	1660	130	8472	980	5600	0	83	7206	7084	-1329	20507	0	20507	2446	383	23336	49.97
8	6648	1078	150	7876	853	5563	0	359	7493	8098	-1536	20803	0	20803	2567	409	23780	50.08
9	6586	850	130	7566	858	5541	0	721	7957	7807	-1807	20240	0	20240	2846	446	23532	50.07
10	6690	872	147	7708	779	5558	0	1049	8025	7915	-1901	20668	0	20668	3180	441	24288	50.02
11	6673	802	168	7642	632	5613	0	1242	8492	8414	-2068	21039	0	21039	3417	437	24892	50.01
12	6739	904	195	7838	527	5595	0	1306	8826	8991	-2175	21651	0	21651	3500	432	25582	50.00
13	6889	876	253	8018	441	5609	0	1316	8878	8663	-2207	21428	0	21428	3507	413	25348	50.00
14	6878	790	254	7922	460	5430	0	1319	9020	8754	-2144	21345	0	21345	3435	396	25176	49.98
15	6882	758	263	7902	639	5597	0	1170	9036	9058	-2251	21706	0	21706	3521	410	25636	50.05
16	6869	1092	264	8224	905	5604	0	910	8612	8650	-2122	21748	0	21748	3533	424	25704	50.03
17	6979	906	264	8150	1222	5601	0	555	8196	8096	-2078	21106	0	21106	3473	440	25018	50.04
18	6994	634	254	7882	1441	5598	0	263	7576	7671	-1908	20484	0	20484	3337	464	24284	50.09
19	7149	582	274	8004	1741	5708	0	53	6651	6556	-1609	20003	0	20003	3143	450	23596	50.00
20	7265	810	265	8340	2044	5921	0	1	6205	6025	-1434	20461	0	20461	3081	436	23978	49.96
21	7267	950	265	8482	2117	5782	0	0	6128	5905	-1480	20382	0	20382	3054	424	23860	50.00
22	7211	896	265	8372	1976	5639	0	0	5954	5899	-1399	20064	0	20064	2989	423	23476	49.95
23	7336	1080	277	8694	2045	5831	0	0	5968	5772	-1440	20491	0	20491	3013	411	23914	49.94
24	7418	1164	268	8850	2089	5929	0	0	5730	5837	-1419	20905	0	20905	3073	381	24358	49.99
MUs	164.93	25.31	4.92	195.15	31.73	136.56	0.00	10.35	175.98	174.93	-40.33	498.85	0.00	498.85	73.32	9.53	581.70	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/May/2022

Position as on 6.30 Hrs of 27/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 5	108	16/05/2022	12:59	26/05/2022	09:42	Gas shortage	
TPC-G	Trombay 7B	60	16/05/2022	23:59	26/05/2022	01:25	Non availability of APM gas.	
MSPGCL	Nasik Unit 3	210	21/05/2022	17:14	26/05/2022	09:40	Boiler Tube Leakage	26/05/2022
MSPGCL	Chandrapur Unit 5	500	23/05/2022	07:45	26/05/2022	18:00	Boiler Tube Leakage	26/05/2022
IPP	RPL(AMT) U-3	270	24/05/2022	02:23		Continued.	Flame Failure	28/05/2022
MSPGCL	Bhusawal Unit 3	210	24/05/2022	17:31		Continued.	CVSM Control Valve Problem	30/05/2022
MSPGCL	Koradi Unit 6	210	27/05/2022	06:05		Continued.	Boiler Tube Leakage	29/05/2022

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 26/May/2022

Statement-VII

Position as on 6.30 Hrs of 27/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Tripping							
TBC @ PADGHE	IntraState	26/05/2022	10:12	26/05/2022	17:15	PO	1) Bay Maint work 2) MTAMC work
400 KV LR Outages/Tripping							
400 KV KARAD - SOLAPUR (PG) LR	IntraState	26/05/2022	08:37	26/05/2022	19:11	PO	For attending oil leakages through PRV by replacing new PRV and replacement of RTD sensor with CCU of WTI & OTI and attending problem of motorised 400 kV Reactor isolator problem
400 KV LINE Outages/Tripping							
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	26/05/2022	06:06	26/05/2022	16:47	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/05/2022	11:07			HT	H/T FOR LOAD MANAGEMENT
PADGHE - NAGOTHANE CKT - 2	IntraState	26/05/2022	12:25	26/05/2022	13:33	PO	For jumper tightning work and emergency tree cutting work
KARAD - LONIKAND I	IntraState	26/05/2022	23:42	27/05/2022	2:058	HT	load management
KARAD - LONIKAND I	IntraState	26/05/2022	23:42	27/05/2022	2:058	HT	load management
400 KV ICT Outages/Tripping							
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	26/05/2022	08:54	26/05/2022	18:12	PO	(1) SFRA measurement ICT Units. (2) Bay maintenance work.
400/220/33KV 500 MVA ICT - 1 @ KUDUS	IntraState	26/05/2022	11:50	26/05/2022	17:57	HT	E/O AVAILED BY PG
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	26/05/2022	12:07	26/05/2022	19:58	PO	Routine Maintenance & testing work
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	26/05/2022	22:05	27/05/2022	05:58	PO	For pre-monsoon maintenance,CTR work & testing
220 KV TBC Outages/Tripping							
TBC @ AAREY	IntraState	26/05/2022	09:00	26/05/2022	17:50	PO	For Safety Purpose
TBC @ GHODBUNDER	IntraState	26/05/2022	09:22	26/05/2022	11:28	PO	For Safety purpose
220 KV LINE Outages/Tripping							
NALASOPARA - BOISAR PG	InterState	27/05/2022	02:29			PO	1) Destrining of existing 0.4ACSR Zebra conductor at loc. No. 03-04 (Western Railway Crossing) & 004 & #65533; 005. 2) Restrining of 0.4ACSR Zebra conductor at loc. No. 003 & #65533; New MD+18 & MD+18 & #65533; 005 of 220kv of 220KV PGCIL & #65533; NALASOPARA LINE
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
BORIVALI - TARAPUR	IntraState	18/05/2022	14:36	26/05/2022	22:12	PO	Replacement of existing 0.5 ACSR MOOSE Conductor at loc. No. 11- 28, replacement of heavily Rusted Hardware , heavily rusted earth wire and all insulator strings of the line.
PADGHE - TEMGHAR - 2	IntraState	20/05/2022	00:02	26/05/2022	07:20	PO	Bunching at Loc.no.82 and jumper opening at Loc.no. 80.
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23	26/05/2022	07:21	PO	220KV Temghar -Padghe 1 & 220KV Temghar-Colourchem line will be in service. Load of T/F no.4 will be shifted to T/F no. 2. Load of T/F no.5 will be shifted to T/F no. 1 & 3.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2022

Statement-VII

Position as on 6.30 Hrs of 27/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS SECTION-4 @ TEMGHAR	IntraState	20/05/2022	07:23			EO	For closing 220kv Bus section 3 isolator
JEJURI - KONDHWA	IntraState	24/05/2022	10:41	26/05/2022	11:18	PO	220 kV Jejuri-Kondhwa bay CB mechanism overhauling work and attend of SF6 gas leakage of Y phase pole of CB.
VSNL - STT GIS CKT - 2	IntraState	24/05/2022	10:43			PO	Addition of New 02 Nos of GIS T/F Bay to existing 220kv Bus 2 at 220 KV STT GIS Substation end.
PADGHE - TEMGHAR - 1	IntraState	26/05/2022	00:07	26/05/2022	03:27	PO	For removing of bunching arrangement between 220KV Padgha-Temghar 1 & 2 line at Loc no.82 and re-fixing of jumper at Loc. no. 80.
CHAKAN-BHOSARI 1	IntraState	26/05/2022	11:36	26/05/2022	18:56	PO	Double Jumpering Work
PANDHARPUR - MALINAGAR	IntraState	26/05/2022	16:30	26/05/2022	18:56	PO	Outage is required For changing / replacement of faulty string at loc no. Main line - 1CP4, CP 11, CP, 19, 47 LILO Portion - 25, 39, 41.
BOISAR II - BOISAR (PG) CKT - 1	IntraState	27/05/2022	02:25			PO	1) Destrining of existing 0.4ACSR Zebra conductor at loc. No. 03-04 (Western Railway Crossing) & 004 & 005. 2) Restrining of new ACCC HTLS Drake conductor at loc. No. 003 & New MD+18 & MD+18 & 005 of 220kv BOISAR-PGCIL Line no. 01.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/33kv 100 MVA TF 3 @ AAREY	IntraState	26/05/2022	08:59	26/05/2022	17:50	PO	Annual and Premonsoon maintenance of Transformer, NGT and Bay Equipments
220/33KV 50MVA PTR 1 @ KURKUMBH	IntraState	26/05/2022	09:20	26/05/2022	13:01	PO	PREMONSOON MAINTENANCE WORK
220/33kv 100 MVA TF 1 @ GHODBUNDER	IntraState	26/05/2022	09:22	26/05/2022	11:28	PO	Premonsoon Maintenance
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	26/05/2022	09:36	26/05/2022	18:41	PO	Outage is required for Oil leakage attending work to be carried out by agency.
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	26/05/2022	10:02	26/05/2022	13:44	PO	Premonsoon RM work Earth pit resistance measurement
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	26/05/2022	10:05	26/05/2022	11:50	PO	Testing of relays & misc. maintenance work.
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	26/05/2022	10:10	26/05/2022	11:38	PO	Premansoon & Bay maintenance work
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	26/05/2022	10:17	26/05/2022	13:33	PO	Pre monsoon maintenance work .
220/33-33 KV 100 MVA PTR 2 @ BOISAR-II	IntraState	26/05/2022	10:21	26/05/2022	15:26	PO	Pre monsoon maintenance work & diagnostic testing works
220/132KV 100MVA ICT 2 @ KATHAPUR	IntraState	26/05/2022	11:10	26/05/2022	17:40	PO	Pre monsoon Maintenance Work
220/22KV 50MVA PTR 2 @ RANJANGAON	IntraState	26/05/2022	11:16	26/05/2022	17:13	PO	For Pre monsoon work
220/33kv 125 MVA TF 4 @ GHODBUNDER	IntraState	26/05/2022	11:59	26/05/2022	13:44	PO	Premonsoon Maintenance
220/132 KV 100MVA ICT - 2 @ MANMAD	IntraState	26/05/2022	12:26	26/05/2022	13:41	PO	Testing of relays & misc. maintenance work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2022

Statement-VII

Position as on 6.30 Hrs of 27/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	26/05/2022	13:07	26/05/2022	17:03	PO	PRE MONSOON MAINTENANCE WORK
220/33KV 50MVA PTR -2 @ KURKUMBH	IntraState	26/05/2022	13:15	26/05/2022	17:20	PO	PRE MONSOON MAINTENANCE WORK.
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	26/05/2022	21:10	26/05/2022	22:50	PO	For Pre-monsoon maintenance work.
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	26/05/2022	22:57	27/05/2022	01:24	PO	For Pre-monsoon maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage