

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/May/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	158.279	4270.186	1) Gujrat	-1.083	-81.046
2) Hydro	34.210	561.640	2) Madhya Pradesh	8.037	182.477
3) Gas	5.225	136.568	3) Chattisgarh	4.220	133.440
Total MSPGCL	197.714	4968.394	4) Maharashtra	189.689	5274.704
B) 1) APML	64.367	1494.998	5) Goa (Amona)	-1.651	-35.185
2) JSWEL	22.766	554.052	Total	199.212	5474.390
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.080	1025.019
4) RPL(AMT)	25.116	631.884	b) Mumbai Drawl	47.193	1124.298
5) SWPGPL	10.631	261.084	c) MSEDCL Bilateral *	131.290	2555.739
6) Other IPP	2.780	251.020	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.080	1024.930
C) 1) TPCL Thermal	10.697	300.948	Include PX	0.000	0.000
2) TPCL Hydro	5.849	124.623	Standby	0.000	0.089
3) TPCL Gas	2.155	58.075	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.379	261.320	1) MSEDCL	522.314	13162.388
D) STATE			2) Mumbai Discoms	75.273	1869.264
1) Thermal	304.015	8025.492	3) Other Discoms	10.730	268.219
(A1+C1+C4+(B1-B6))			TOTAL STATE	608.317	15299.871
2) Hydro (A2+C2)	40.059	686.263			
3) Gas (A3+B7+C3)	7.380	194.643			
4) Wind	40.144	505.424			
6) SOLAR	17.507	413.659			
TOTAL STATE	409.105	9825.481			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 7 Hrs
MSPGCL Thermal	5794	6736	6753	6875
MSPGCL Hydro	1343	1395	1714	1527
MSPGCL Gas	204	202	224	227
MSPGCL Total Generation	7341	8333	8691	8629
Central Sector Receipt	9877	9346	7622	7279
WIND	1277	1674	1604	1460
CPP / IPP Thermal	4046	4474	5956	5798
CPP / IPP Gas	0	0	0	0
SOLAR	2261	1466	0	169
Exchange with Mumbai	-2389	-2393	-1871	-1575
MSEDCL DEMAND MET	21919	22413	21525	21321
Load Shedding	0	0	0	0
MSEDCL DEMAND	21919	22413	21525	21321
TPCL GENERATION	766	824	905	601
AEML GENERATION	452	453	436	330
MUMBAI DEMAND	3607	3670	3212	2506
OTHER DISCOM DEMAND	494	487	477	439
STATE DEMAND MET	26020	26570	25214	24266
STATE DEMAND	26020	26570	25214	24266
Frequency (Hz)	49.93	49.92	49.96	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.29 Hz at 08.00 Hrs	49.69 Hz at 12.51 Hrs	49.93	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/May/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.78	110.42	180	120
Unit 8	13.27	297.89	598	505
Unit 9	13.34	328.19	595	518
Unit 10	13.03	249.44	585	508
Total	43.43	985.95		
Bhusawal				
Unit 3	3.43	88.41	155	130
Unit 4	11.12	217.06	500	305
Unit 5	0.00	244.74	0	0
Total	14.55	550.21		
Parli				
Unit 6	3.95	94.04	229	124
Unit 7	4.68	101.86	241	148
Unit 8	3.84	118.20	192	140
Total	12.47	314.10		
Chandrapur				
Unit 3	3.54	93.63	166	125
Unit 4	3.56	84.07	162	120
Unit 5	0.00	170.06	0	0
Unit 6	8.74	239.18	400	295
Unit 7	8.60	242.37	415	296
Unit 8	10.70	252.90	493	301
Unit 9	10.43	284.46	475	309
Total	45.57	1366.68		
Paras				
Unit 3	5.00	124.08	223	155
Unit 4	5.31	130.08	232	160
Total	10.30	254.15		
Khaparkheda				
Unit 1	3.02	78.66	135	110
Unit 2	2.32	75.62	140	74
Unit 3	4.16	104.64	184	133
Unit 4	3.77	103.69	190	0
Unit 5	11.03	234.52	465	450
Total	24.30	597.14		
Nasik				
Unit 3	0.00	25.27	0	0
Unit 4	3.91	104.85	182	126
Unit 5	3.75	71.84	181	118
Total	7.66	201.96		
Uran				
All Units	5.22	136.57	232	200
Total	5.22	136.57		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.05	0.81	28	0
Total	0.05	0.81		
Koyna				
Stage 1-2	8.66	118.92	535	115

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	16.03	253.49	1005	200
Stage 3	5.39	82.43	320	80
Total	30.08	454.84		
Hydro				
KDPH	0.56	17.18	24	23
VTRNA	1.09	27.01	60	0
TILLARI	0.12	2.25	58	0
BHIRA T.R.	0.28	7.27	77	0
SMLHY_PTN	2.01	52.24	86	82
GHATGHAR	0.03	0.03	34	0
Total	4.09	105.99		
Wind				
Total	40.14	505.42	0	0
Total	40.14	505.42		
CPP				
APML(Mus)	64.37	1495.00	0	0
JSWEL(Mus)	22.77	554.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.12	631.88	0	0
SWPGPL-Mus	10.63	261.08	0	0
Dhariwal	0.00	16.14	0	0
IEPL	0.00	116.69	0	0
Other(Mus)	2.78	118.19	0	0
Total	125.66	3193.04		
SOLAR				
Total	17.51	413.66	0	0
Total	17.51	413.66		
Tata				
Trombay 5	7.13	196.44	352	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.19	33.86	101	38
Trombay 7B	0.97	24.22	63	35
TATA Hydro	5.85	124.62	427	110
Trombay 8	3.57	104.50	176	130
Total	18.70	483.65		
AEML				
DTPS U-1&2	9.38	261.32	491	302
Total	9.38	261.32		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	158.28	4270.19	MSPGCL Total	197.71	4968.39
			MSPGCL Thml+Gas	163.50	4406.75	Koyna 1,2 & 4 Total	24.69	372.41
			MSPGCL Hydro	34.21	561.64	State Total	409.10	9825.48

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/May/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6898	1275	225	8398	2340	5990	0	0	8355	8210	-1965	22580	0	0	22580	3147	393	26120	49.98
2	6887	1593	229	8709	2443	5986	0	0	7745	7602	-1850	22519	0	0	22519	2941	371	25831	50.02
3	6837	1412	227	8476	2466	5984	0	0	7361	7404	-1723	22253	0	0	22253	2749	354	25356	49.99
4	6833	1420	232	8485	2234	5975	0	0	7109	7310	-1700	21956	0	0	21956	2615	348	24919	50.01
5	6848	1713	227	8788	2012	5944	0	0	7046	7249	-1619	22016	0	0	22016	2538	358	24912	50.04
6	6854	1866	227	8947	1783	5920	0	1	7413	7569	-1613	22225	0	0	22225	2529	382	25136	49.98
7	6875	1527	227	8629	1460	5798	0	169	7433	7279	-1575	21321	0	0	21321	2506	439	24266	49.96
8	6757	1033	228	8018	1323	5292	0	642	7939	8095	-1665	21249	0	0	21249	2639	456	24344	50.05
9	6472	891	220	7583	1262	4425	0	1308	8439	8747	-1891	20972	0	0	20972	2942	462	24376	50.06
10	6068	1390	213	7671	1316	4103	0	1792	8846	8939	-2104	21226	0	0	21226	3294	491	25011	49.96
11	5620	1607	207	7434	1362	4056	0	2116	9419	9655	-2341	21785	0	0	21785	3527	497	25809	49.99
12	5794	1343	204	7341	1277	4046	0	2261	9536	9877	-2389	21919	0	2	21919	3607	494	26020	49.93
13	6163	1298	206	7667	1300	4028	0	2268	9443	9360	-2382	21779	0	0	21779	3592	462	25833	49.00
14	6198	1100	200	7498	1473	4009	0	2143	9389	9445	-2247	21852	0	0	21852	3476	469	25797	49.95
15	6528	1059	202	7789	1445	4023	0	1936	9677	9948	-2395	22273	0	0	22273	3578	473	26324	49.92
16	6736	1395	202	8333	1674	4474	0	1466	9410	9346	-2393	22413	0	0	22413	3670	487	26570	49.92
17	6721	1124	205	8050	1750	5016	0	933	8860	8548	-2335	21469	0	0	21469	3609	493	25571	49.94
18	6724	1407	208	8339	1848	5093	0	407	8507	8542	-2383	21341	0	0	21341	3456	505	25302	49.97
19	6677	1146	219	8042	1745	5458	0	65	8202	7750	-2102	20452	0	0	20452	3256	506	24214	49.98
20	6753	1714	224	8691	1604	5956	0	0	7810	7622	-1871	21525	0	0	21525	3212	477	25214	49.96
21	6796	1660	225	8681	1539	6008	0	0	7498	7293	-1721	21328	0	0	21328	3148	472	24948	49.90
22	6763	1517	222	8502	1507	5981	0	0	7690	7347	-1656	21218	0	0	21218	3069	463	24750	49.89
23	6767	1761	224	8752	1476	6057	0	0	7701	8045	-1654	22230	0	0	22230	3055	446	25731	49.94
24	6710	1959	222	8891	1505	6038	0	0	7930	8030	-1619	22412	0	0	22412	3118	433	25963	49.95
MUs	158.28	34.21	5.23	197.71	40.14	125.66	0.00	17.51	198.76	199.21	-47.19	522.31	0.00	0.00	522.31	75.27	10.73	608.32	49.93

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) Conductor size of 110KV Tembhu line is 0.1 & Overload setting of said line at 220kv Ogalewadi S/S is 300Amps. To avoid overload tripping, DLS is carried out.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/May/2023

Position as on 6.30 Hrs of 27/May/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02	26/05/2023	22:25	Stator Earth Fault	01/06/2023
MSPGCL	Uran Unit 6	108	10/05/2023	02:00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-2	270	16/05/2023	23:00		Continued.	Ash Evacuation Problem has been resolved on dated 21.05.2023 18:00 hrs.Unit technically available, but the unit cannot be put on bar due to coal shortage.	
MSPGCL	Nasik Unit 3	210	20/05/2023	08:45		Continued.	Boiler Tube Leakage(under tolling from 22.25Hrs DT. 20-5-2023)	
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	30/05/2023
MSPGCL	Bhusawal Unit 5	500	24/05/2023	21:15		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	26/05/2023	22:55		Continued.	Air heater problem	
MSPGCL	Koradi Unit 6	210	27/05/2023	08:57		Continued.	Flame Failure	30/05/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2023

Statement-VII

Position as on 6.30 Hrs of 27/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/05/2023	19:08	27/05/2023	21:36	EO	Thyristor replacement at padghe HVDC
400 KV TIEBAY Outages/Trippings							
TIE BAY (409) OF BABHALESHWAR CKT - 2 @ EKTUNI	IntraState	26/05/2023	10:46	26/05/2023	13:34	PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV TBC Outages/Trippings							
TBC @ LONIKAND	IntraState	27/05/2023	10:15	27/05/2023	19:42	PO	29A, 29B Isolator O/H, gear mechanism Box replacement work.
400 KV MAINBAY Outages/Trippings							
MAIN BAY (402) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	25/05/2023	10:02	27/05/2023	21:17	PO	For servicing & overhauling of 400kv AREVA make KDK CKT-2 Main C.B. Mechanism
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV RPL-AKOLA 2 CKT 2	InterState	26/05/2023	06:35	26/05/2023	18:34	PO	Outage required for routine maintenance and per-monsoon activity of 400kv RPL to Akola II Line II.
LAMBOTI - SOLAPUR (PG)	InterState	27/05/2023	09:21	27/05/2023	15:42	EO	For Investigation of higher voltage on B Ph. Line CVT
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26			PO	Dismantling of exisging tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	23/05/2023	09:46			HT	For load management
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing & overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.
220 KV KORADI - II (400 KV) - KAULEWADA CKT - I	IntraState	26/05/2023	16:53	26/05/2023	18:20	PO	Attending Hot Spot.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	26/05/2023	10:34	26/05/2023	17:38	PO	Premonsoon maintenance & testing work.
400/220 KV 3X105 MVA ICT - 1 @ PADGHE	IntraState	27/05/2023	08:42	27/05/2023	08:42	EO	Changing LV Bus from B to A for balancing the Bus coupler load.
400 KV BUSBAR Outages/Trippings							
A-BUS @ KHARGHAR	IntraState	27/05/2023	02:09	27/05/2023	07:57	PO	1)Bus Extension Connection work along with charging of 2 nos of new 400KV Vikhroli Line Bay's at Kharghar(First time Charging). 2) For work of Damaged Quadraple conductor span replacement and Bus maintenance work.
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2023

Statement-VII

Position as on 6.30 Hrs of 27/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INTERCONNECTOR @ KALWA	IntraState	26/05/2023	00:27	26/05/2023	03:53	EO	Hot spot attending work at various place in interconnector bay 1) 52C CT Y ph -84 temp 2) 52 C R ph CB top pad -142 temp 3) 52 C B ph CB bottom pad -110 temp 4) 29 J Y ph ISO & 150 temp
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
ANANDNAGAR - PALAVA	IntraState	26/05/2023	07:18	26/05/2023	16:47	PO	R,Y & B Ph CT Replacement work. All three old CT's are aged and rusted .
MAIN BUS SECTION - 1 @ PANDHARPUR	IntraState	26/05/2023	08:13	26/05/2023	09:00	EO	Outage is required for Tightening of Jumper & fixing of missing Nut Bolt to Jumper at various Tension location.
WADA - BHAVEGHAR	IntraState	26/05/2023	10:16	26/05/2023	18:40	PO	"1) HV Breaker Overhauling, Dignostic Testing & Maintenance Work. 2) Hot Spot attending Work."
KORADI-KHAPERKHEDA	IntraState	26/05/2023	10:37	26/05/2023	16:18	PO	Rep Of F/O Disc Insulator String Loc No.22,23.
KHAPARKHEDA- BUTIBORI	IntraState	26/05/2023	10:38	26/05/2023	16:38	PO	Rep Of F/O Disc Insulator String Loc No.22,23.
DASTURI-KANDALGAON LINE	IntraState	26/05/2023	11:16	26/05/2023	20:35	PO	OPGW Installation work and removal of rusted earth wire.
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	26/05/2023	11:36	26/05/2023	16:34	PO	Signature Analysis Test.
KALWA - SIEMENS	IntraState	26/05/2023	11:55	26/05/2023	13:13	PO	Replacement of CT connection work by MSEDCL for Main Summation KVAH Energy Meter
ONGC URAN - JNPT	IntraState	26/05/2023	12:30	26/05/2023	17:28	PO	For Distance Relay replacement work at ONGC End
WADA - BHAVEGHAR	IntraState	26/05/2023	14:36	26/05/2023	16:12	EO	1) Outage is required on 220KV Bus section-2 (Bus section element not available in OMS). 2) Sparking observe on TF no.3 bus isolator & same needs to be attended on priority.
SIEMENS - RELIANCE GIS	IntraState	26/05/2023	14:38	26/05/2023	15:18	PO	Replacement of CT connection work by MSEDCL for Main Summation KVAH Energy Meter
MHAISAL - ALKUD	IntraState	26/05/2023	16:18	26/05/2023	19:10	PO	Pilot string fixing work at Loc No.01 B Ph (Alkud LILO) pilot string detached from bottom
APTA - KALWA	IntraState	26/05/2023	16:39	26/05/2023	21:16	T	Distance protection
UMRED-KANHAN 2	IntraState	26/05/2023	16:58	26/05/2023	17:27	T	Distance Protection.
HAMIDWADA - MUMEWADI	IntraState	26/05/2023	19:39	26/05/2023	22:40	EO	Attending Hot Spot
220 KV CHALISGAON - KHADKA CKT -1	IntraState	27/05/2023	06:32	27/05/2023	09:48	PO	Attend hot spot
POPHALI - KDPH	IntraState	27/05/2023	08:30	27/05/2023	17:45	PO	For replacement of badly damaged conductor at loc no & 12 middle ph KDPH side and loc no & 13 top ph Popphali side and bottom ph KDPH side and for replacement of deteriorated polymer insulator strings.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2023

Statement-VII

Position as on 6.30 Hrs of 27/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV HINGOLI -KURUNDA CKT	IntraState	27/05/2023	09:35	27/05/2023	12:50	EO	Hot spot observed at LOC no 39 Bph
KAMBA - KHARBAO TSS	IntraState	27/05/2023	09:40	27/05/2023	16:05	PO	Breaker Overhauling work , Diagnostics Testing , Pre Monsoon Work
BOISAR II - TARAPUR	IntraState	27/05/2023	10:06	27/05/2023	16:24	PO	1) Installation of Saver Assembly. 2) Replacement of rusted hardware and insulator. 3) Control & Relay Panel 220V DC Supply shifting from old charger to new DCDB.
KANDALGAON - SONA ALLOYS	IntraState	27/05/2023	13:05	27/05/2023	20:44	PO	Damaged conductor to be atteded by applying midspan joint at Loc.No.43,71 and other line maintenance work.
UMRED-KANHAN 2	IntraState	27/05/2023	15:38	27/05/2023	18:53	EO	Attending bend wave trap of R & Y phase by agency
VITA - MIRAJ	IntraState	27/05/2023	16:37	27/05/2023	20:12	PO	Fixing of DSN string at Loc no.127 Y Ph & broken disc replacement work at Loc No.107 B Ph
KANHAN-UMRED 1	IntraState	27/05/2023	19:01	27/05/2023	20:54	EO	R phase LA Supporting foundation base stud has broken & LA hanging on conductor
BORIVALI - TARAPUR	IntraState	27/05/2023	19:14		Continued.	T	Distance Protection
BORIVALI - BOISAR (PG)	IntraState	27/05/2023	19:14		Continued.	T	Distance Protection
TALANDGE - MUDSHINGI CKT - 2	IntraState	27/05/2023	21:43	27/05/2023	22:11	EO	For 220kV Bus seperation work at mudshingi substation
UMRED-KANHAN 2	IntraState	27/05/2023	22:07	27/05/2023	23:36	EO	For attending bend WT of R, B phase by agency
BHUGAON - WARDHA (PG)	IntraState	27/05/2023	23:30		Continued.	HT	To control OD on low frequency
WARDHA - WARDHA (PG)	IntraState	27/05/2023	23:32		Continued.	HT	To control OD on low frequency
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 100 MVA ICT 1 @ SAWANGI	IntraState	26/05/2023	09:40	26/05/2023	21:35	PO	Pre Monsoon Maintenance Work.
220/132KV 200MVA PTR 2 @ LONAND	IntraState	26/05/2023	10:08	26/05/2023	17:46	PO	1.CB Overhauling Work 2.Premonsoon Maintenance Work
220/132 KV 100 MVA ICT 2 @ GHATODI	IntraState	27/05/2023	06:40	27/05/2023	12:53	EO	For Attending oil leakage
220 / 110 / 33kV 250MVA AT 1 @ BACKBAY	IntraState	27/05/2023	08:05		Continued.	PO	Project Work-220kV CRP Replacement.
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	27/05/2023	08:45	27/05/2023	14:30	PO	1. Premonsoon and Bay maintenance work 2. Replacement of 1 No 132KV High tan delta CTs
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	27/05/2023	09:00	27/05/2023	12:20	PO	Pre-monsoon maintenance work
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	27/05/2023	17:01	27/05/2023	19:44	PO	For Pre Monsoon Maintenance work and Testing works
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 2	IntraState	26/05/2023	18:23	26/05/2023	21:40	PO	Normalization of 110kV Kalyan Kalwa Salsette line 2

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2023

Statement-VII

Position as on 6.30 Hrs of 27/May/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA KALYAN	IntraState	27/05/2023	00:27	27/05/2023	07:12	PO	Normalization of 110 kV Kalwa Kalyan line CAPACITY
KARANJADE - BHOKARPADA	IntraState	27/05/2023	08:38	27/05/2023	12:08	PO	TREE TRIMMING AND BIRD NEST REMOVAL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage