

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/May/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	155.407	4429.213	1) Gujrat	-3.740	2.461
2) Hydro	16.683	508.071	2) Madhya Pradesh	-2.489	133.671
3) Gas	6.806	182.563	3) Chattisgarh	1.430	99.990
Total MSPGCL	178.896	5119.847	4) Maharashtra	180.460	4840.870
B) 1) APML	55.222	1666.989	5) Goa (Amona)	-1.977	-52.232
2) JSWEL	25.808	702.154	Total	173.684	5024.760
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.938	1134.843
4) RPL(AMT)	25.086	762.990	b) Mumbai Drawl	44.004	1173.268
5) SWPGPL	11.842	318.193	c) MSEDCL Bilateral *	72.610	2094.799
6) Other IPP	15.767	434.838	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.938	1134.843
C) 1) TPCL Thermal	13.183	330.765	Include PX	0.000	0.000
2) TPCL Hydro	1.606	124.414	Standby	0.000	0.000
3) TPCL Gas	3.875	100.338	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.205	261.088	1) MSEDCL	496.356	13433.188
D) STATE			2) Mumbai Discoms	72.873	1989.867
1) Thermal	312.520	8906.230	3) Other Discoms	11.742	301.480
(A1+C1+C4+(B1-B6))			TOTAL STATE	580.971	15724.535
2) Hydro	18.289	632.485			
(A2+C2)					
3) Gas	10.681	282.901			
(A3+B7+C3)					
4) Wind	49.297	444.746			
6) SOLAR	16.500	433.419			
TOTAL STATE	407.287	10699.781			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5617	7078	6798	6268
MSPGCL Hydro	234	131	1055	691
MSPGCL Gas	281	278	282	284
MSPGCL Total Generation	6132	7487	8135	7243
Central Sector Receipt	8256	7697	6848	6701
WIND	1749	2235	1476	2251
CPP / IPP Thermal	4945	5510	6252	4998
CPP / IPP Gas	0	0	0	0
SOLAR	2207	1286	0	596
Exchange with Mumbai	-2067	-2143	-1974	-1309
MSEDCL DEMAND MET	20731	21540	20220	19981
Load Shedding	0	0	0	0
MSEDCL DEMAND	20731	21540	20220	19981
TPCL GENERATION	640	675	793	844
AEML GENERATION	318	449	380	503
MUMBAI DEMAND	3025	3267	3147	2656
OTHER DISCOM DEMAND	491	532	517	499
STATE DEMAND MET	24247	25339	23884	23136
STATE DEMAND	24247	25339	23884	23136
Frequency (Hz)	49.99	50.04	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 08.59 Hrs	49.8 Hz at 13.37 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.07	95.14	186	127
Unit 8	12.28	229.94	574	383
Unit 9	11.73	347.51	541	382
Unit 10	12.13	353.61	530	440
Total	40.20	1026.19		
Bhusawal				
Unit 3	0.00	76.13	0	0
Unit 4	9.63	236.58	475	290
Unit 5	7.82	245.92	490	0
Total	17.45	558.64		
Parli				
Unit 6	3.89	116.57	236	140
Unit 7	3.98	111.60	230	144
Unit 8	3.96	109.65	229	142
Total	11.82	337.82		
Chandrapur				
Unit 3	3.41	92.51	160	120
Unit 4	3.45	95.48	162	124
Unit 5	8.48	228.85	425	270
Unit 6	8.37	177.00	420	265
Unit 7	8.45	207.68	401	289
Unit 8	9.14	267.83	455	290
Unit 9	0.00	253.20	0	0
Total	41.30	1322.54		
Paras				
Unit 3	4.20	121.09	233	136
Unit 4	4.53	141.59	252	149
Total	8.74	262.68		
Khaparkheda				
Unit 1	3.56	91.12	165	115
Unit 2	3.88	110.92	195	116
Unit 3	3.75	102.43	171	129
Unit 4	4.02	101.92	186	134
Unit 5	11.20	261.75	500	300
Total	26.41	668.14		
Nasik				
Unit 3	3.24	80.14	165	122
Unit 4	3.14	91.34	141	125
Unit 5	3.09	81.71	151	117
Total	9.47	253.20		
Uran				
All Units	6.81	182.56	289	276
Total	6.81	182.56		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	2.68	119.69	365	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	8.52	219.46	998	0
Stage 3	2.47	75.62	240	0
Total	13.67	414.78		
Hydro				
KDPH	0.53	16.24	22	22
VTRNA	0.87	21.62	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.62	49.21	77	60
GHATGHAR	0.00	6.23	0	0
Total	3.01	93.29		
Wind				
Total	49.30	444.75	0	0
Total	49.30	444.75		
CPP				
APML(Mus)	55.22	1666.99	0	0
JSWEL(Mus)	25.81	702.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.09	762.99	0	0
SWPGPL-Mus	11.84	318.19	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.23	138.22	268	150
Other(Mus)	6.38	175.61	0	0
JPL	4.16	121.01	272	133
Total	133.72	3885.16		
SOLAR				
Total	16.50	433.42	0	0
Total	16.50	433.42		
Tata				
Trombay 5	8.75	225.36	445	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.41	62.11	109	83
Trombay 7B	1.47	38.23	64	55
TATA Hydro	1.61	124.41	211	24
Trombay 8	4.44	105.41	228	129
Total	18.66	555.52		
AEML				
DTPS U-1&2	10.20	261.09	504	287
Total	10.20	261.09		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	155.41	4429.21	MSPGCL Total	178.90	5119.85
			MSPGCL Thml+Gas	162.21	4611.78	Koyna 1,2 & 4 Total	11.20	339.15
			MSPGCL Hydro	16.68	508.07	State Total	407.29	10699.78

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7274	1477	286	9037	2570	6794	0	0	6381	6063	-1910	22082	0	0	22082	3366	472	25920	50.02
2	7286	1043	286	8615	2498	6679	0	0	7102	6282	-1883	21752	0	0	21752	3184	439	25375	50.02
3	6943	962	286	8191	2449	5975	0	0	7572	7121	-1646	21681	0	0	21681	3029	409	25119	50.00
4	7043	913	288	8244	2302	6031	0	0	7320	6807	-1508	21461	0	0	21461	2910	415	24786	50.01
5	7039	872	289	8200	2424	5694	0	0	7295	6872	-1459	21299	0	0	21299	2824	432	24555	49.96
6	7003	884	288	8175	2174	5592	0	0	7577	7175	-1466	21191	0	0	21191	2803	459	24453	49.93
7	6976	876	285	8137	2340	5371	0	121	7710	7066	-1343	21213	0	7	21213	2703	479	24395	50.00
8	6268	691	284	7243	2251	4998	0	596	7495	6701	-1309	19981	0	10	19981	2656	499	23136	50.00
9	5337	687	284	6308	2169	4483	0	1118	8024	7074	-1379	19262	0	1	19262	2702	511	22475	50.03
10	5288	414	284	5986	2046	4692	0	1724	8082	7705	-1665	19977	0	0	19977	2842	511	23330	50.08
11	5356	191	281	5828	1881	4816	0	2054	8305	8275	-1991	20346	0	0	20346	2935	517	23798	50.04
12	5617	234	281	6132	1749	4945	0	2207	8290	8256	-2067	20731	0	1	20731	3025	491	24247	49.99
13	5852	125	280	6257	1753	4987	0	2323	8382	8084	-2126	20788	0	7	20788	3076	490	24354	49.96
14	5877	175	279	6331	1779	4984	0	2138	8406	8203	-2184	20761	0	6	20761	3122	490	24373	49.94
15	6740	296	276	7312	1880	5121	0	1738	8416	8270	-2273	21572	0	1	21572	3215	476	25263	49.98
16	7078	131	278	7487	2235	5510	0	1286	8680	7697	-2143	21540	0	1	21540	3267	532	25339	50.04
17	6484	172	280	6936	2779	5100	0	800	8385	7480	-2077	20501	0	8	20501	3146	517	24164	50.03
18	5747	212	281	6240	2616	4902	0	351	8048	8053	-2107	19508	0	42	19508	2996	547	23051	50.01
19	5936	523	285	6744	2193	5044	0	44	7201	7271	-1955	18802	0	5	18802	2932	539	22273	50.01
20	6580	792	281	7653	1824	5492	0	0	7017	6944	-1911	19469	0	0	19469	3065	533	23067	49.97
21	6798	1055	282	8135	1476	6252	0	0	6884	6848	-1974	20220	0	0	20220	3147	517	23884	49.98
22	6853	1091	285	8229	1083	6751	0	0	6745	6538	-1922	20174	0	0	20174	3203	505	23882	50.04
23	7003	1476	288	8767	1154	6757	0	0	6732	6509	-1779	20915	0	0	20915	3296	493	24704	50.01
24	7029	1391	289	8709	1672	6755	0	0	7073	6390	-1927	21130	0	0	21130	3429	469	25028	50.02
MUs	155.41	16.68	6.81	178.90	49.30	133.72	0.00	16.50	183.12	173.68	-44.00	496.36	0.00	0.09	496.36	72.87	11.74	580.97	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132kV BBLR to Rahuri line Overload, 2)LTS due to tripping of 220kV Lamboti to Karkamb & 220kV Lamboti - Pandharpur line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/May/2024

Position as on 6.30 Hrs of 27/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 9	500	24/05/2024	01:59		Continued.	Boiler Tube Leakage	27/05/2024
MSPGCL	Bhusawal Unit 3	210	24/05/2024	15:37		Continued.	Boiler Tube Leakage	28/05/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	
MSPGCL	Bhusawal Unit 5	500	26/05/2024	19:16	26/05/2024	22:08	Electrical fault	
Total Capacity MSPGCL		1455						
IPP								
IPP	RPL(AMT) U-2	270	25/05/2024	13:52		Continued.	ID Fan Tripped at high Vibration.	27/05/2024
Total Capacity IPP		270						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2045						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	24/05/2024	02:00		Continued.	Due to Zero schedule by MSEDCL.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2024

Statement-VII

Position as on 6.30 Hrs of 27/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
PUNE(GIS) - TALEGAON(PG) CKT - 2	InterState	26/05/2024	01:51	26/05/2024	09:18	HT	HTdue to hotspot on 409 Rph Twin bus dropper to 409 bus isolator.
400KV-PARLI NEW-PARLI-M-1	InterState	26/05/2024	15:45	26/05/2024	17:56	T	Distance protection.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
BUS-1 @ TALEGAON (PG	IntraState	25/05/2024	23:24	26/05/2024	09:00	PO	For AMP works
JEJURI - KARAD	IntraState	26/05/2024	10:01	26/05/2024	18:54	PO	PID Faulty disc Insulator replacement work at Different Locations
CHANDRAPUR-PARLI CKT-3	IntraState	26/05/2024	15:50	26/05/2024	22:06	HT	Y-Ph CVT jumper broken.
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	26/05/2024	15:53	26/05/2024	22:51	HT	B-Ph CVT jumper broken.
AKOLA - KHADKA (BHUSAWAL)	IntraState	26/05/2024	17:36	26/05/2024	18:28	T	Distance protection.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	26/05/2024	23:21	26/05/2024	02:24	PO	Y-ph CVT jumper connection work.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	27/05/2024	23:21	27/05/2024	02:24	PO	Y-ph CVT jumper connection work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	26/05/2024	11:58	26/05/2024	14:26	PO	Auxiliary isolator found broken and hanging.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/05/2024	15:30	26/05/2024	17:02	T	Distance protection.
220 KV HARANGUL - PARLY (PG) CKT	InterState	26/05/2024	15:37	26/05/2024	17:30	T	Distance protection.
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/05/2024	15:40	26/05/2024	17:56	T	Distance protection.
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
COLOURCHEM - TEMGHAR	IntraState	25/05/2024	04:46	26/05/2024	12:23	PO	For erection of new tower structure, de-stringing of old conductor & stringing of new conductor at new loc no.06.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	25/05/2024	13:25			HT	For load management

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2024

Statement-VII

Position as on 6.30 Hrs of 27/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/05/2024	01:27			PO	B) As on dt: 25.05.2024 at 21:00Hrs to 27.05.2024 at 06:00Hrs. outage on 220kV Padghe- Nalasopara for the work of erection of in-line Monopole , cut point formation and conductor de-stringing & stringing work. 1) Jumper at loc.52 of 220kV Padghe-Nalasopara line will be opened to avoid the backfeeding from 220kV Vasai-Nalasopara link line. 2) After opening the jumper at loc.no. 52, 220kV Nalasopara-Vasai link line will be charged at 23:00Hrs. on dt:-25.05.2024 for 02 days. 3) In-line monopole erection work will be carry out at loc.no.48,49 & 49A. 4) Cut point formation over newly erected Monopole work will be carrying out at loc.no. 48,49,&49A of 220kV Padghe-Nalasopara line and also related tower's conductor de-stringing and stringing work will be carry out of above said ckt. 5) After erection of Monopole tower, cut point formation and conductor stringing work, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on dt: 27.05.2024.
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	IntraState	26/05/2024	08:45	26/05/2024	16:43	PO	MANDALE PROJECT WORK IN VICINITY
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	26/05/2024	09:43	26/05/2024	18:20	PO	Routine maintenance work, replacement of insulator, cold line cleaning work.
TROMBAY - VIKHROLI (GIS) CKT - 3	IntraState	26/05/2024	10:56	26/05/2024	12:42	PO	ATTENDING HOT SPOT
ICL - OLD GCR PARLI	IntraState	26/05/2024	15:19	26/05/2024	18:30	T	Distance protection.
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:30	26/05/2024	22:23	T	Distance protection.
220 PARLI U-8 - NEW GCR PARLI CKT I	IntraState	26/05/2024	15:38	26/05/2024	16:32	T	Tripped from Parli U8 end only.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 3	IntraState	26/05/2024	15:40	27/05/2024	02:55	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 4	IntraState	26/05/2024	15:40	27/05/2024	03:05	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
220 KV GHATODI - HINGOLI	IntraState	26/05/2024	16:07	26/05/2024	16:32	T	Distance protection.
220KV PANDHARKAWDA - WANI CKT II	IntraState	26/05/2024	16:39	26/05/2024	18:28	T	Distance protection.
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	Tripped on distance protection
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	Tripped of distance protection
KHARGHAR - BORIVALI CKT - 2	IntraState	26/05/2024	22:03	27/05/2024	02:34	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 66 sets are to be installed)
MULUND - GIS BHANDUP	IntraState	26/05/2024	22:05	27/05/2024	02:08	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 6 sets are to be installed)
KHAREPATAN -PAWAS LINE	IntraState	27/05/2024	08:39			PO	For Premonsoon activity.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/May/2024

Statement-VII

Position as on 6.30 Hrs of 27/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
THEUR-PHURSUNGI CKT I	IntraState	27/05/2024	09:12			PO	Dist. relay retrofitting, commissioning and testing work by agency GE
OSMANABAD - BARSHI	IntraState	27/05/2024	09:21			PO	Replacement of LA's under LE scheme along with quarterly bay maintenance work.
220 KV ICT Outages/Trippings							
220/100 KV 200 MVA ICT 2 @ TROMBAY	IntraState	26/05/2024	07:20	26/05/2024	21:19	PO	For safety purpose For tower painting work in 100KV Switchyard, Diagnostic testing & RM work
220 / 110 / 22kv 250MVA ICT 1 @ SAKI	IntraState	26/05/2024	09:45	26/05/2024	20:58	PO	RM, ICT testing and protection testing
220/110/33KV 250 MVA ICT-5 @ MAHALAXMI GIS (T)	IntraState	26/05/2024	09:51	26/05/2024	19:53	PO	RM & testing
220 / 110 / 33kv 250MVA AT 1 @ BACKBAY	IntraState	26/05/2024	10:08	26/05/2024	15:57	PO	R/M Testing & Protection testing &
220/33KV 50MVA PTR 2 @ KATHAPUR	IntraState	26/05/2024	11:24	26/05/2024	15:58	PO	Pre monsoon activities and general maintenance
220/132 KV 100 MVA PTR	IntraState	26/05/2024	15:21	26/05/2024	17:16	T	O/C E/F LV tripped.
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	26/05/2024	23:40	27/05/2024	06:35	PO	REPLACEMENT OF OIL COOLER
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	27/05/2024	08:35			PO	Diagnostic testing work. Quarterly maintenance work.
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	27/05/2024	09:09			PO	Quarterly Maintenance works.
220/33 kv 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	27/05/2024	09:16			PO	"Transformer painting work."
110 KV BUSBAR Outages/Trippings							
ZONE 2 (BUS SECTION 3+4+5+6) @ BHIVPURI	IntraState	26/05/2024	08:45	26/05/2024	17:54	PO	Main Bus GOD R/M , LA & PT Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage