

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Jun/2024 WEDNESDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 160.617        | 3950.870        | 1) Gujrat                      | -6.359         | -19.279          |
| 2) Hydro            | 6.577          | 220.758         | 2) Madhya Pradesh              | -2.212         | 7.650            |
| 3) Gas              | 7.484          | 177.876         | 3) Chattisgarh                 | 0.900          | 47.750           |
| <b>Total MSPGCL</b> | <b>174.678</b> | <b>4349.504</b> | 4) Maharashtra                 | 166.684        | 4765.318         |
| B) 1) APLM          | 61.209         | 1482.498        | 5) Goa (Amona)                 | -2.903         | -52.329          |
| 2) JSWEL            | 22.410         | 587.554         | <b>Total</b>                   | <b>156.110</b> | <b>4749.110</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 40.981         | 1096.311         |
| 4) RPL(AMT)         | 31.495         | 781.898         | b) Mumbai Drawl                | 42.152         | 1160.708         |
| 5) SWPGPL           | 12.270         | 315.070         | c) MSEDCL Bilateral *          | 89.008         | 2146.303         |
| 6) Other IPP        | 13.091         | 363.957         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 40.981         | 1096.259         |
| C) 1) TPCL Thermal  | 13.377         | 330.383         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 5.374          | 138.531         | Standby                        | 0.000          | 0.053            |
| 3) TPCL Gas         | 4.128          | 106.264         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 11.053         | 229.309         | 1) MSEDCL                      | 472.333        | 12207.176        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 76.084         | 1965.194         |
| 1) Thermal          | 325.522        | 8041.539        | 3) Other Discoms               | 11.393         | 300.271          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>559.810</b> | <b>14472.641</b> |
| 2) Hydro            | 11.951         | 359.289         |                                |                |                  |
| 3) Gas              | 11.612         | 284.140         |                                |                |                  |
| 4) Wind             | 37.997         | 636.155         |                                |                |                  |
| 6) SOLAR            | 16.618         | 402.409         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>403.700</b> | <b>9723.532</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 6543                      | 5532                  | 7378                      | 6799                      |
| MSPGCL Hydro               | 171                       | 141                   | 983                       | 187                       |
| MSPGCL Gas                 | 282                       | 274                   | 378                       | 284                       |
| MSPGCL Total Generation    | 6996                      | 5947                  | 8739                      | 7270                      |
| Central Sector Receipt     | 7330                      | 7444                  | 6170                      | 5760                      |
| WIND                       | 1872                      | 1986                  | 1757                      | 1187                      |
| CPP / IPP Thermal          | 4948                      | 4894                  | 6731                      | 6058                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 1952                      | 1965                  | 0                         | 0                         |
| Exchange with Mumbai       | -2226                     | -2243                 | -1723                     | -1420                     |
| <b>MSEDCL DEMAND MET</b>   | <b>20373</b>              | <b>19491</b>          | <b>21165</b>              | <b>18475</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 20373                     | 19491                 | 21165                     | 18475                     |
| TPCL GENERATION            | 904                       | 987                   | 1150                      | 723                       |
| AEML GENERATION            | 480                       | 502                   | 465                       | 480                       |
| <b>MUMBAI DEMAND</b>       | <b>3610</b>               | <b>3732</b>           | <b>3338</b>               | <b>2623</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>499</b>                | <b>502</b>            | <b>509</b>                | <b>381</b>                |
| STATE DEMAND MET           | 24482                     | 23725                 | 25012                     | 21478                     |
| <b>STATE DEMAND</b>        | <b>24482</b>              | <b>23725</b>          | <b>25012</b>              | <b>21478</b>              |
| Frequency (Hz)             | 50.02                     | 50.01                 | 50.00                     | 49.94                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.16 Hz at 13.02 Hrs | 49.86 Hz at 02.16 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 26/Jun/2024

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 4.21         | 108.60         | 186      | 155      |
| Unit 8             | 13.24        | 353.27         | 610      | 390      |
| Unit 9             | 12.50        | 316.38         | 583      | 390      |
| Unit 10            | 10.90        | 327.82         | 525      | 395      |
| <b>Total</b>       | <b>40.84</b> | <b>1106.07</b> |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 3.43         | 50.61          | 165      | 120      |
| Unit 4             | 0.00         | 151.03         | 0        | 0        |
| Unit 5             | 10.30        | 254.02         | 490      | 310      |
| <b>Total</b>       | <b>13.72</b> | <b>455.67</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 4.05         | 45.38          | 224      | 138      |
| Unit 7             | 4.14         | 60.64          | 223      | 144      |
| Unit 8             | 4.13         | 51.57          | 224      | 142      |
| <b>Total</b>       | <b>12.32</b> | <b>157.59</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.51         | 82.70          | 165      | 122      |
| Unit 4             | 3.53         | 91.83          | 161      | 130      |
| Unit 5             | 8.44         | 192.50         | 430      | 255      |
| Unit 6             | 7.78         | 161.88         | 390      | 270      |
| Unit 7             | 8.22         | 233.25         | 419      | 279      |
| Unit 8             | 9.04         | 213.10         | 410      | 272      |
| Unit 9             | 10.26        | 239.58         | 495      | 285      |
| <b>Total</b>       | <b>50.78</b> | <b>1214.84</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 4.24         | 119.65         | 232      | 106      |
| Unit 4             | 5.32         | 34.99          | 250      | 149      |
| <b>Total</b>       | <b>9.56</b>  | <b>154.64</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.38         | 88.40          | 155      | 120      |
| Unit 2             | 4.23         | 103.18         | 195      | 124      |
| Unit 3             | 3.91         | 86.68          | 174      | 133      |
| Unit 4             | 3.64         | 104.61         | 194      | 0        |
| Unit 5             | 10.62        | 280.67         | 475      | 350      |
| <b>Total</b>       | <b>25.78</b> | <b>663.54</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 64.85          | 0        | 0        |
| Unit 4             | 4.03         | 45.87          | 184      | 130      |
| Unit 5             | 3.58         | 87.81          | 170      | 126      |
| <b>Total</b>       | <b>7.60</b>  | <b>198.52</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 7.48         | 177.88         | 380      | 274      |
| <b>Total</b>       | <b>7.48</b>  | <b>177.88</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.05         | 1.47           | 33       | 0        |
| <b>Total</b>       | <b>0.05</b>  | <b>1.47</b>    |          |          |
| <b>Koyna</b>       |              |                |          |          |
| Stage 1-2          | 1.82         | 68.12          | 255      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.64          | 45.27          | 311      | 0        |
| Stage 3         | 0.85          | 29.53          | 160      | 0        |
| <b>Total</b>    | <b>3.32</b>   | <b>142.93</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 2.96           | 0        | 0        |
| VTRNA           | 0.77          | 18.81          | 60       | 0        |
| TILLARI         | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.40          | 4.05           | 40       | 0        |
| SMLHY_PTN       | 1.82          | 45.79          | 83       | 58       |
| GHATGHAR        | 0.26          | 6.22           | 125      | 0        |
| <b>Total</b>    | <b>3.26</b>   | <b>77.83</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 38.00         | 636.16         | 0        | 0        |
| <b>Total</b>    | <b>38.00</b>  | <b>636.16</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 61.21         | 1482.50        | 0        | 0        |
| JSWEL(Mus)      | 22.41         | 587.55         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 31.50         | 781.90         | 0        | 0        |
| SWPGPL-Mus      | 12.27         | 315.07         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.85          | 145.18         | 267      | 194      |
| Other(Mus)      | 1.68          | 79.46          | 0        | 0        |
| JPL             | 5.56          | 139.31         | 265      | 136      |
| <b>Total</b>    | <b>140.48</b> | <b>3530.98</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 16.62         | 402.41         | 0        | 0        |
| <b>Total</b>    | <b>16.62</b>  | <b>402.41</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.63          | 218.41         | 442      | 264      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.59          | 66.60          | 108      | 108      |
| Trombay 7B      | 1.54          | 39.66          | 64       | 64       |
| TATA Hydro      | 5.37          | 138.53         | 405      | 71       |
| Trombay 8       | 4.75          | 111.98         | 231      | 131      |
| <b>Total</b>    | <b>22.88</b>  | <b>575.18</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 11.05         | 229.31         | 503      | 384      |
| <b>Total</b>    | <b>11.05</b>  | <b>229.31</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 160.62      | 3950.87       | MSPGCL Total        | 174.68      | 4349.50       |
|                |             |         | MSPGCL Thml+Gas | 168.10      | 4128.75       | Koyna 1,2 & 4 Total | 2.47        | 113.40        |
|                |             |         | MSPGCL Hydro    | 6.58        | 220.76        | State Total         | 403.70      | 9723.53       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 26/Jun/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                             | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAND | OTHER<br>DISCOM<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|------------------------|------------------|-----------------------------|-------------------------------|------------------|---------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                        | Planned          | *Transmission<br>Constraint |                               |                  |                           |                 |               |
| 1                  | 7224        | 296  | 284  | 7804   | 1319  | 6767      | 0    | 0     | 5991        | 5475        | -1457                | 19464                  | 0                | 0                           | 19464                         | 3084             | 444                       | 22992           | 50.03         |
| 2                  | 7007        | 177  | 284  | 7468   | 1376  | 6585      | 0    | 0     | 5980        | 5317        | -1391                | 18939                  | 0                | 0                           | 18939                         | 2832             | 416                       | 22187           | 50.01         |
| 3                  | 6799        | 187  | 284  | 7270   | 1187  | 6058      | 0    | 0     | 6046        | 5760        | -1420                | 18475                  | 0                | 0                           | 18475                         | 2623             | 381                       | 21478           | 49.94         |
| 4                  | 6950        | 186  | 284  | 7420   | 1286  | 5966      | 0    | 0     | 5985        | 5882        | -1362                | 18807                  | 0                | 0                           | 18807                         | 2480             | 385                       | 21672           | 49.98         |
| 5                  | 7022        | 182  | 285  | 7489   | 1050  | 6211      | 0    | 0     | 6048        | 5818        | -1310                | 18858                  | 0                | 0                           | 18858                         | 2414             | 400                       | 21672           | 49.99         |
| 6                  | 7157        | 240  | 287  | 7684   | 1073  | 6424      | 0    | 0     | 6486        | 6288        | -1390                | 19656                  | 0                | 0                           | 19656                         | 2446             | 422                       | 22525           | 49.99         |
| 7                  | 7214        | 428  | 290  | 7932   | 1160  | 6490      | 0    | 150   | 6411        | 6463        | -1338                | 20410                  | 0                | 0                           | 20410                         | 2543             | 447                       | 23400           | 50.04         |
| 8                  | 7046        | 117  | 288  | 7451   | 1072  | 6222      | 0    | 682   | 6635        | 6077        | -1530                | 19490                  | 0                | 0                           | 19490                         | 2715             | 483                       | 22689           | 49.98         |
| 9                  | 6651        | 123  | 283  | 7057   | 1181  | 5421      | 0    | 1296  | 6935        | 7215        | -1953                | 19708                  | 0                | 0                           | 19708                         | 3054             | 509                       | 23271           | 49.99         |
| 10                 | 6598        | 161  | 284  | 7043   | 1549  | 5115      | 0    | 1709  | 7265        | 7034        | -2104                | 19836                  | 0                | 0                           | 19836                         | 3340             | 510                       | 23686           | 50.06         |
| 11                 | 6543        | 171  | 282  | 6996   | 1872  | 4948      | 0    | 1952  | 7357        | 7330        | -2226                | 20373                  | 0                | 0                           | 20373                         | 3610             | 499                       | 24482           | 50.02         |
| 12                 | 5914        | 157  | 276  | 6347   | 1899  | 4908      | 0    | 1996  | 7739        | 7517        | -2278                | 19891                  | 0                | 0                           | 19891                         | 3752             | 498                       | 24141           | 49.94         |
| 13                 | 5532        | 141  | 274  | 5947   | 1986  | 4894      | 0    | 1965  | 7823        | 7444        | -2243                | 19491                  | 0                | 0                           | 19491                         | 3732             | 502                       | 23725           | 50.01         |
| 14                 | 5234        | 112  | 277  | 5623   | 2122  | 4873      | 0    | 2023  | 7769        | 7250        | -2157                | 19252                  | 0                | 0                           | 19252                         | 3650             | 482                       | 23384           | 50.05         |
| 15                 | 5534        | 103  | 282  | 5919   | 2136  | 4882      | 0    | 1876  | 7770        | 7420        | -2237                | 19483                  | 0                | 0                           | 19483                         | 3717             | 513                       | 23713           | 50.06         |
| 16                 | 5491        | 101  | 368  | 5960   | 2247  | 4942      | 0    | 1463  | 7868        | 7556        | -2188                | 19490                  | 0                | 0                           | 19490                         | 3702             | 490                       | 23682           | 50.01         |
| 17                 | 6353        | 138  | 371  | 6862   | 2120  | 5021      | 0    | 957   | 7333        | 7015        | -1977                | 19483                  | 0                | 0                           | 19483                         | 3578             | 515                       | 23576           | 49.98         |
| 18                 | 6753        | 262  | 374  | 7389   | 1970  | 5138      | 0    | 463   | 7228        | 6763        | -1819                | 19376                  | 0                | 0                           | 19376                         | 3478             | 528                       | 23382           | 49.98         |
| 19                 | 7157        | 308  | 373  | 7838   | 1865  | 6072      | 0    | 86    | 6899        | 6371        | -1931                | 19776                  | 0                | 0                           | 19776                         | 3356             | 526                       | 23657           | 49.97         |
| 20                 | 7378        | 983  | 378  | 8739   | 1757  | 6731      | 0    | 0     | 6404        | 6170        | -1723                | 21165                  | 0                | 0                           | 21165                         | 3338             | 509                       | 25012           | 50.00         |
| 21                 | 7317        | 625  | 380  | 8322   | 1634  | 6681      | 0    | 0     | 6274        | 6135        | -1582                | 20682                  | 0                | 0                           | 20682                         | 3258             | 508                       | 24448           | 50.02         |
| 22                 | 7244        | 402  | 379  | 8025   | 1434  | 6669      | 0    | 0     | 6172        | 6034        | -1582                | 20094                  | 0                | 0                           | 20094                         | 3158             | 486                       | 23738           | 50.00         |
| 23                 | 7237        | 539  | 326  | 8102   | 1375  | 6678      | 0    | 0     | 5947        | 5970        | -1464                | 20178                  | 0                | 0                           | 20178                         | 3127             | 483                       | 23788           | 49.97         |
| 24                 | 7262        | 438  | 291  | 7991   | 1327  | 6780      | 0    | 0     | 5959        | 5806        | -1490                | 19955                  | 0                | 0                           | 19955                         | 3097             | 459                       | 23511           | 49.99         |
| MUs                | 160.62      | 6.58 | 7.48 | 174.68 | 38.00 | 140.47    | 0.00 | 16.62 | 162.32      | 156.11      | -42.15               | 472.33                 | 0.00             | 0.00                        | 472.33                        | 76.08            | 11.39                     | 559.81          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Jun/2024**

Position as on 6.30 Hrs of 27/Jun/2024

| Generating Company             | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|--------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Koyna Unit 2            | 70       | 15/06/2024   | 07:10        |            | Continued. | Govrner renovation                                                                                                                                      | 10/07/2024    |
| MSPGCL                         | Bhusawal Unit 4         | 500      | 16/06/2024   | 00:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 06/07/2024    |
| MSPGCL                         | Koyna Unit 10           | 80       | 20/06/2024   | 18:00        |            | Continued. | For laying of Optical fiber cable from powerhouse to switchyard on overhead 220 KV EHV line                                                             | 26/06/2024    |
| MSPGCL                         | Koyna Unit 9            | 80       | 20/06/2024   | 18:00        |            | Continued. | For laying of Optical fiber cable from powerhouse to switchyard on overhead 220 KV EHV line                                                             | 26/06/2024    |
| Total Capacity MSPGCL          |                         | 730      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE  |                         | 730      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                  |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/08/2024    |
| MSPGCL                         | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/07/2024    |
| MSPGCL                         | Khaparkheda Unit 4      | 210      | 26/06/2024   | 11:09        | 26/06/2024 | 14:10      | Due to Transmission Side NIT switch problem on Dt. 26/06/2024 During Transmission Back start activity,while shifting Unit 4 from Bus 1 to Bus 2.        |               |
| Total Capacity MSPGCL          |                         | 455      |              |              |            |            |                                                                                                                                                         |               |
| IPP                            |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                            | JPL Unit 1              | 150      | 26/06/2024   | 20:16        | 26/06/2024 | 22:38      | Electrical fault                                                                                                                                        |               |
| Total Capacity IPP             |                         | 150      |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                    | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                    | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |
| Total Capacity CENT.SECTOR     |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE   |                         | 925      |              |              |            |            |                                                                                                                                                         |               |
| UNIT UNDER ZERO SCHEDULE / RSD |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                         | Uran Unit 5             | 108      | 17/06/2024   | 21:44        |            | Continued. | Zero Schedule given by MSEDCL                                                                                                                           |               |
| MSPGCL                         | Uran Unit 6             | 108      | 25/06/2024   | 17:00        | 26/06/2024 | 14:54      | Zero Schedule given by MSEDCL                                                                                                                           |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Jun/2024**

Position as on 6.30 Hrs of 27/Jun/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                        | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-----------------------------------------|---------------|
| MSPGCL                                        | Uran Unit 6             | 108      | 26/06/2024   | 22:30        |           | Continued. | No Schedule from MSEDCL.                |               |
| Total Capacity MSPGCL                         |                         | 324      |              |              |           |            |                                         |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 324      |              |              |           |            |                                         |               |
| UNIT OUT ON TOLLING *                         |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                         |               |
| MSPGCL                                        | Nasik Unit 3            | 210      | 19/06/2024   | 17:30        |           | Continued. | Case IV Tolling                         |               |
| Total Capacity MSPGCL                         |                         | 210      |              |              |           |            |                                         |               |
| Total Capacity UNIT OUT ON TOLLING *          |                         | 210      |              |              |           |            |                                         |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                         |               |
| IPP                                           |                         |          |              |              |           |            |                                         |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                    |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                    |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019) |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)  |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                         |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                         |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Jun/2024

| Name of Line                                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                           |
|--------------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|--------------------------------------------------------------------------------------------------------------------------------------------|
| <b>500 KV TBC Outages/Trippings</b>                    |                           |              |              |            |            |             |                                                                                                                                            |
| POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC | IntraState                | 26/06/2024   | 02:21        | 26/06/2024 | 04:22      | EO          | To attend the Hotspot & to attend oil leakage from 245 KV CT.                                                                              |
| <b>400 KV LINE Outages/Trippings</b>                   |                           |              |              |            |            |             |                                                                                                                                            |
| CHAKAN - TALEGAON(PG)                                  | InterState                | 25/06/2024   | 20:25        | 26/06/2024 | 01:39      | HT          | For attending HOTSPOT at Talegaon PG end.                                                                                                  |
| SOLAPUR PG - ALKUD                                     | InterState                | 26/06/2024   | 17:02        | 27/06/2024 | 03:01      | PO          | Diagnostic testing & Maintenance work                                                                                                      |
| BUS REACTOR (50MVAR) @ PARLI                           | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                        |
| CHANDRAPUR 2 - WARORA CKT-1                            | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                            |
| CHANDRAPUR 2 - WARORA CKT-2                            | IntraState                | 22/04/2024   | 17:27        |            |            | T           | Tripped on distance protection.                                                                                                            |
| AURANGABAD(MS) - PUNE (GIS) CKT - 2                    | IntraState                | 23/06/2024   | 19:11        |            |            | HT          | H/T For load Management.                                                                                                                   |
| MAIN BUS - 2 @ TALANDGE                                | IntraState                | 24/06/2024   | 14:00        |            |            | PO          | Insulator cleaning work. 400kV PG Isolator alignment and maintenance work.                                                                 |
| PARLI - KARJAT CKT - 1                                 | IntraState                | 26/06/2024   | 13:09        | 26/06/2024 | 15:04      | T           | Line tripped on disatance protection.                                                                                                      |
| LONIKAND I - CHAKAN                                    | IntraState                | 27/06/2024   | 06:16        |            |            | PO          | DT Work & Bay Maintenance                                                                                                                  |
| <b>400 KV ICT Outages/Trippings</b>                    |                           |              |              |            |            |             |                                                                                                                                            |
| STATION TF No 3 @ CHANDRAPUR GCR                       | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                             |
| 400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS               | IntraState                | 10/02/2024   | 17:40        |            |            | HT          | H/T For LV only.                                                                                                                           |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA                    | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                    |
| 400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA             | IntraState                | 26/06/2024   | 06:44        | 26/06/2024 | 10:58      | PO          | for shifting of LV side (220kV) from bus 1 to bus 2 in view of black start mock drill                                                      |
| 400/220/20 KV 300 MVA ICT - 1 @ KORADI                 | IntraState                | 26/06/2024   | 06:54        | 26/06/2024 | 10:45      | PO          | for shifting of LV side (220kV) from bus 1 to bus 2 in view of black start mock drill                                                      |
| 400/11kV STN-4A @ DEEPNAGAR                            | IntraState                | 26/06/2024   | 11:13        |            |            | PO          | For E/M for checking, cleaning and oil filtration work at MSPGCL End.                                                                      |
| 400/220 KV 105 MVA SPARE ICT                           | IntraState                | 26/06/2024   | 11:43        | 26/06/2024 | 17:33      | PO          | i) 400/220 kV 105 MVA Spare ICT Back up & Trip relay retrofitting work.<br>ii) On ICT own relay panel cutting drilling work will required. |
| 500 MVA 400/220 KV ICT - 2 @ CHANDRAPUR 2              | IntraState                | 26/06/2024   | 11:48        | 26/06/2024 | 15:02      | PO          | Premonsoon maintenance work                                                                                                                |
| 400/220 KV 167MVA SPARE ICT @ LONIKAND 2               | IntraState                | 27/06/2024   | 07:10        |            |            | PO          | For RRS Trial work.                                                                                                                        |
| 400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2              | IntraState                | 27/06/2024   | 08:43        |            |            | PO          | For RRS Trial work.                                                                                                                        |
| 500 MVA 400/220 KV ICT - 1 @ CHANDRAPUR 2              | IntraState                | 27/06/2024   | 09:50        |            |            | PO          | Premonsoon maintenance work                                                                                                                |
| <b>220 KV MAINBAY Outages/Trippings</b>                |                           |              |              |            |            |             |                                                                                                                                            |
| 220KV YAWATMAL- WARDHA(DEOLI) PG CKT 2                 | InterState                | 26/06/2024   | 11:24        | 26/06/2024 | 15:18      | PO          | Maintenance work                                                                                                                           |
| 220KV BUS SECTION BAY @ PEDAMBE                        | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                               |
| BUS COUPLER @ SOUTH SOLAPUR                            | IntraState                | 26/06/2024   | 11:27        | 26/06/2024 | 12:04      | PO          | Outage is required for Quarterly Maintenance                                                                                               |
| <b>220 KV LINE Outages/Trippings</b>                   |                           |              |              |            |            |             |                                                                                                                                            |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Jun/2024

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                 |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| BALE - SOLAPUR (PG)                           | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |
| MAIN BUS - 1 @ GORAI                          | IntraState                | 28/05/2024   | 17:59        |            |            | T           | Bus Fault                                                                                                                                                                                                                                                                        |
| NTT - KALWA                                   | IntraState                | 05/06/2024   | 00:20        |            |            | PO          | For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tm M/s NTT Global DC NAV2 Pvt Ltd.                                                           |
| TOPWORTH - KHANDESHWAR                        | IntraState                | 15/06/2024   | 14:24        |            |            | PO          | Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel                                                                                                                                     |
| PANVEL TSS - KHANDESHWAR                      | IntraState                | 15/06/2024   | 14:30        |            |            | PO          | Making LILO of 220kV Khandeshwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel                                                                                                                                     |
| OSMANABAD - SOLAPUR (BALE)                    | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)    |
| KARAD - OGALEWADI CKT 2                       | IntraState                | 24/06/2024   | 08:24        |            |            | PO          | For Distance Relay Retrofitting and Relay Panel rewiring work.                                                                                                                                                                                                                   |
| KANDALGAON - BHIRA                            | IntraState                | 25/06/2024   | 11:56        | 26/06/2024 | 01:51      | T           | Tripped on Backup Protection.                                                                                                                                                                                                                                                    |
| KARAD - VITA CKT- 2                           | IntraState                | 26/06/2024   | 09:05        | 26/06/2024 | 17:45      | PO          | Insulator string replacement at various locations under scheme                                                                                                                                                                                                                   |
| ADLABS - PEDAMBE                              | IntraState                | 26/06/2024   | 10:20        | 26/06/2024 | 16:20      | HT          | Emergency outage at Pedambe end                                                                                                                                                                                                                                                  |
| 220KV BADNERA -220KV AVAADA(DHAMANGAON) SOLAR | IntraState                | 26/06/2024   | 12:17        | 26/06/2024 | 15:29      | EO          | FOR ATTENDING HOT SPOT WORK                                                                                                                                                                                                                                                      |
| PARANDA - OSMANABAD                           | IntraState                | 26/06/2024   | 12:42        | 26/06/2024 | 16:43      | PO          | CB OVERHAULING                                                                                                                                                                                                                                                                   |
| 220kV Koradi-2 - Uppalwadi ckt 1              | IntraState                | 26/06/2024   | 13:49        | 26/06/2024 | 15:13      | T           | D/P OPTED                                                                                                                                                                                                                                                                        |
| 220kV Koradi-2 - Uppalwadi ckt 2              | IntraState                | 26/06/2024   | 13:49        | 26/06/2024 | 18:35      | T           | D/P OPTED                                                                                                                                                                                                                                                                        |
| PUSAD - HINGOLI                               | IntraState                | 26/06/2024   | 15:20        | 26/06/2024 | 18:17      | PO          | RELAY TESTING WORK BY TESTING UNIT.                                                                                                                                                                                                                                              |
| BUTIBORI 3-PURTI                              | IntraState                | 26/06/2024   | 16:00        | 26/06/2024 | 18:21      | EO          | STRING FLASH OVER                                                                                                                                                                                                                                                                |
| PHALTAN MIDC - T.S.WIND CKT                   | IntraState                | 26/06/2024   | 16:23        | 26/06/2024 | 22:50      | PO          | For installation of insulation sleeve on 220kV IPS tube                                                                                                                                                                                                                          |
| MIDC CHANDRAPUR-GADCHANDUR                    | IntraState                | 26/06/2024   | 20:00        |            |            | T           | B PH WT JUMPER OPENED                                                                                                                                                                                                                                                            |
| GCR CHANDRAPUR - GRACE LTD                    | IntraState                | 26/06/2024   | 20:07        | 26/06/2024 | 21:05      | HT          | HEAVY SPARKING ON 29D ISOLATOR                                                                                                                                                                                                                                                   |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Jun/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Jun/2024

| Name of Line                                 | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                      |
|----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-----------------------------------------------------------------------------------------------------------------------|
| TROMBAY - DHARAVI 9                          | IntraState                | 26/06/2024   | 23:09        | 27/06/2024 | 04:00      | PO          | 220KV TD-9 relay testing (Protection trial, LBBU testing at Trombay generating station.                               |
| KARAD - VITA CKT- 2                          | IntraState                | 27/06/2024   | 09:18        |            |            | PO          | Insulator string replacement at various locations under scheme                                                        |
| VITA - KHANAPUR LINE                         | IntraState                | 27/06/2024   | 09:18        |            |            | PO          | Insulator string replacement at various locations under scheme                                                        |
| <b>220 KV ICT Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                       |
| 220/33KV 125 MVA TF 2 @ GORAI                | IntraState                | 28/05/2024   | 17:59        |            |            | T           | Bus Fault                                                                                                             |
| 220/132KV 100MVA ICT-2 @ WALCHANDNAGAR       | IntraState                | 21/06/2024   | 12:50        |            |            | PO          | Augmentation of 100 MVA ICT-02 with 200 MVA ICT                                                                       |
| 220/100 KV 100 MVA ICT 1 @ TALOJA            | IntraState                | 25/06/2024   | 20:25        | 26/06/2024 | 00:22      | T           | Tripped due to CB problem                                                                                             |
| 40 MVA STN TF - II                           | IntraState                | 26/06/2024   | 05:56        | 26/06/2024 | 12:51      | HT          | IN VIEW OF BLACK START ACTIVITY                                                                                       |
| 220/6.6 KV STN TF- IV @ KHAPARKHEDA - 220 KV | IntraState                | 26/06/2024   | 06:04        | 26/06/2024 | 12:36      | HT          | IN VIEW OF BLACK START ACTIVITY                                                                                       |
| 220/132KV 200MVA ICT 3 @ PANDHARPUR          | IntraState                | 26/06/2024   | 09:18        | 26/06/2024 | 19:17      | PO          | Outage is required for CTR RELATED WORK, TCIV REPLACEMENT WORK BY AGENCY                                              |
| 220/100 KV 200 MVA ICT 3 @ KALWA             | IntraState                | 26/06/2024   | 09:30        | 26/06/2024 | 14:43      | PO          | CTR MAKE FIRE FIGHTING SYSTEM SERVICEING AND MAINTANCE.                                                               |
| 220/132KV 200MVA ICT 1 @ JEUR                | IntraState                | 26/06/2024   | 10:07        | 26/06/2024 | 15:05      | PO          | Outage is required for Replacement of LA under LE scheme                                                              |
| 220/132KV 100MVA ICT 2                       | IntraState                | 26/06/2024   | 11:25        | 26/06/2024 | 14:07      | EO          | TO ATTEND THE FIRE DETECTOR TRIP INDICATION ON THE EXPLOSION PREVENTION FIRE & EXTINGUISHING SYSTEM.                  |
| 220/33 KV 50 MVA PTR 2 @ BABHLESHWAR         | IntraState                | 26/06/2024   | 15:05        | 26/06/2024 | 19:43      | PO          | Attending red hot on HV & LV CB, TF LV busing.                                                                        |
| 220/132 KV 200 MVA ICT 1                     | IntraState                | 26/06/2024   | 15:05        | 26/06/2024 | 19:13      | PO          | FOR R & Y PH HV SIDE LA REPLACEMENT WORK & PREMANSOON MAINTENANCE WORK.                                               |
| 220/100 KV 200 MVA ICT 1 @ PAL- DOMBIVALI    | IntraState                | 26/06/2024   | 17:00        | 26/06/2024 | 18:28      | HT          | Unhealthy relay status on differential relay observed.                                                                |
| 220/33 KV 50 MVA PTR NO 3 @ ALEPHATA         | IntraState                | 27/06/2024   | 09:43        |            |            | PO          | For Diagnostic Testing work , HV CT tan delta by testing team , Relay testing work , CB CRM & general bay maintenance |
| <b>220 KV BUSBAR Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                       |
| BUS COUPLER@PHALTAN MIDC- 220 KV             | IntraState                | 26/06/2024   | 09:42        | 26/06/2024 | 11:45      | PO          | 1.Hot Spot attending work on Y ph CT of Bus Coupler bay<br>2.Quarterly Maintenance Work                               |
| MAIN BUS @ BALE (SOLAPUR 2)                  | IntraState                | 26/06/2024   | 12:29        | 26/06/2024 | 16:01      | PO          | Outage is required for Quarterly Maintenance                                                                          |
| <b>132 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                       |
| KANHAN-PENCH                                 | IntraState                | 26/06/2024   | 08:48        | 26/06/2024 | 10:28      | PO          | 132kv Kanhan- Pench ckt ON and OFF operation required for black start activity                                        |
| <b>110 KV LINE Outages/Trippings</b>         |                           |              |              |            |            |             |                                                                                                                       |
| KALWA KALYAN                                 | IntraState                | 26/06/2024   | 17:43        | 26/06/2024 | 20:04      | HT          | Attending damaged B Phase conductor, span 180-181 .                                                                   |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage