

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Aug/2015 WEDNESDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	98.244	2411.502	1) Gujrat	11.646	244.106
2) Hydro	6.839	189.348	2) Madhya Pradesh	11.155	314.913
3) Gas	6.240	164.015	3) Chattisgarh	5.450	123.560
<b>Total MSPGCL</b>	<b>111.323</b>	<b>2764.865</b>	4) Maharashtra Net	99.901	2224.372
B) 1) APLM	54.700	1254.089	5) Goa	-6.785	-160.000
2) JSWEL	28.009	685.649	6) TAPS 1&2 Injection	2.508	67.839
3) VIPL	11.946	216.136	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	18.470	434.085	8) Pench (MS)	0.311	11.534
5) WPCL	3.615	90.598	9) Pench (Excess)	-0.311	-10.488
6) Other IPP	1.993	55.754	<b>Total</b>	<b>123.564</b>	<b>2804.302</b>
C) 1) TPCL Thermal	16.574	420.335	a) Mumbai Schedule	26.474	608.123
2) TPCL Hydro	3.082	84.127	b) Mumbai Drawl	27.765	670.391
3) TPCL Gas	2.017	47.059	c) MSEDCL Bilateral *	36.121	793.252
4) R-INFRA Thermal	11.955	294.773	Include PX	3.569	80.855
D) STATE			d) Mumbai Bilateral *	26.474	608.123
1) Thermal	245.506	5862.921	Include PX	2.782	111.823
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	9.921	273.475	<b>H) ENERGY CATERED (MUs)</b>		
3) Gas	8.257	211.074	1) MSEDCL	348.921	8301.865
4) Wind	22.040	641.238	2) Mumbai Discoms	61.392	1516.672
6) SOLAR	1.026	25.540	<b>TOTAL STATE</b>	<b>410.313</b>	<b>9818.537</b>
<b>TOTAL STATE</b>	<b>286.750</b>	<b>7014.248</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4199	4219	3972	4053
MSPGCL Hydro	780	401	613	121
MSPGCL Gas	256	254	262	266
MSPGCL Total Generation	5235	4874	4847	4440
Central Sector Receipt	6483	5908	4755	4009
WIND	469	868	1441	898
CPP / IPP	5006	5015	4969	4817
SOLAR	118	114	0	0
Exchange with Mumbai	-1496	-1438	-1280	-798
<b>MSEDCL DEMAND MET</b>	<b>15815</b>	<b>15341</b>	<b>14732</b>	<b>13366</b>
Load Shedding	31	25	28	26
MSEDCL DEMAND	15846	15366	14760	13392
TPCL GENERATION	1128	1079	1049	585
R-INFRA GENERATION	512	515	519	399
<b>MUMBAI DEMAND</b>	<b>3136</b>	<b>3032</b>	<b>2848</b>	<b>1782</b>
STATE DEMAND MET	18951	18373	17580	15148
<b>STATE DEMAND</b>	<b>18982</b>	<b>18398</b>	<b>17608</b>	<b>15174</b>
Frequency (Hz)	49.86	49.93	49.89	49.93

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.18 Hz at 18.02 Hrs	49.64 Hz at 00.17 Hrs	49.9	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 26/Aug/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 5	2.59	57.28	150	0
Unit 6	0.00	0.00	0	0
Unit 7	3.91	96.84	171	145
<b>Total</b>	<b>6.50</b>	<b>154.11</b>		
<b>Bhusawal</b>				
Unit 2	0.00	0.00	0	0
Unit 3	1.68	98.28	175	0
Unit 4	10.96	225.32	485	375
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>12.63</b>	<b>323.59</b>		
<b>Parli</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>Chandrapur</b>				
Unit 1	0.00	0.00	0	0
Unit 2	3.36	82.86	147	133
Unit 3	4.22	88.84	187	162
Unit 4	4.06	96.92	185	158
Unit 5	8.60	216.45	400	285
Unit 6	9.16	201.92	425	340
Unit 7	7.90	199.72	350	300
<b>Total</b>	<b>37.29</b>	<b>886.71</b>		
<b>Paras</b>				
Unit 3	4.89	119.88	228	188
Unit 4	5.12	123.60	230	200
<b>Total</b>	<b>10.01</b>	<b>243.49</b>		
<b>Khaparkheda</b>				
Unit 1	3.22	79.55	145	120
Unit 2	3.26	85.88	170	110
Unit 3	3.54	87.08	160	133
Unit 4	3.59	63.65	171	126
Unit 5	4.97	157.37	335	0
<b>Total</b>	<b>18.57</b>	<b>473.53</b>		
<b>Nasik</b>				
Unit 3	4.39	115.00	200	160
Unit 4	4.37	116.30	194	171
Unit 5	4.47	98.77	195	179
<b>Total</b>	<b>13.24</b>	<b>330.07</b>		
<b>Uran</b>				
All Units	6.24	164.02	266	252
<b>Total</b>	<b>6.24</b>	<b>164.02</b>		
<b>PENCH (MS)</b>				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.31	11.53	47	0
<b>Total</b>	<b>0.31</b>	<b>11.53</b>		
<b>Koyna</b>				
Stage 1-2	2.86	73.16	420	40
Stage 4	0.38	31.98	171	0
Stage 3	0.71	31.89	160	0
<b>Total</b>	<b>3.94</b>	<b>137.04</b>		
<b>Hydro</b>				
KDPH	0.60	4.29	38	19
VTRNA	0.31	0.75	61	0
TILLARI	0.00	2.12	0	0
BHTGR/VEER	0.00	1.26	0	0
BHIRA T.R.	0.24	8.06	80	0
RNGR+BHTSA	0.07	0.46	3	2
BHANDARDRA	0.54	8.69	37	13
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.45	4.05	19	18
GHATGHAR	0.69	22.63	136	0
<b>Total</b>	<b>2.90</b>	<b>52.31</b>		
<b>Wind</b>				
Total	22.04	641.24	0	0
<b>Total</b>	<b>22.04</b>	<b>641.24</b>		
<b>CPP</b>				
APML(Mus)	54.70	1254.09	0	0
JSWEL(Mus)	28.01	685.65	0	0
VIPL(Mus)	11.95	216.14	0	0
RPLAMT(Mus)	18.47	434.08	0	0
WPCL(Mus)	3.62	90.60	0	0
Other(Mus)	1.99	55.75	0	0
<b>Total</b>	<b>118.73</b>	<b>2736.31</b>		
<b>SOLAR</b>				
Total	1.03	25.54	0	0
<b>Total</b>	<b>1.03</b>	<b>25.54</b>		
<b>Tata</b>				
Trombay 5	10.82	271.40	491	318
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.02	47.06	115	60
Trombay 7B	0.00	0.00	0	0
Trombay 8	5.76	148.94	250	201
TATA Hydro	3.08	84.13	275	0
<b>Total</b>	<b>21.67</b>	<b>551.52</b>		
<b>R-INFRA</b>				
1-2	11.96	294.77	519	398
<b>Total</b>	<b>11.96</b>	<b>294.77</b>		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	98.24	2411.50
MSPGCL Thml+Gas	104.48	2575.52

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	6.84	189.35
MSPGCL Total	111.32	2764.86

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	3.23	105.14
State Total	286.75	7014.25

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 26/Aug/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	3902	338	265	4505	1156	4517	0	4087	4433	-803	13808	38	13846	2081	15927	49.83
2	3984	129	266	4379	1090	4839	0	4048	4193	-872	13629	26	13655	1930	15585	49.87
3	3988	116	265	4369	1022	4878	0	3747	4136	-857	13548	26	13574	1840	15414	49.89
4	4053	121	266	4440	898	4817	0	3711	4009	-798	13366	26	13392	1782	15174	49.93
5	4071	121	263	4455	857	4911	0	4046	4028	-786	13465	26	13491	1770	15261	49.87
6	4109	273	265	4647	755	4896	0	4501	4535	-715	14118	31	14149	1886	16035	49.95
7	4187	168	264	4619	743	5033	0	5184	5390	-734	15051	31	15082	2035	17117	49.89
8	4251	154	264	4669	627	5064	21	5436	5784	-871	15294	31	15325	2180	17505	49.98
9	4306	177	262	4745	631	5052	54	5892	6474	-1211	15745	31	15776	2545	18321	49.97
10	4265	220	256	4741	618	5061	109	6168	6617	-1426	15720	31	15751	2877	18628	49.89
11	4140	428	255	4823	504	4971	99	5972	6869	-1500	15766	31	15797	3118	18915	49.88
12	4199	780	256	5235	469	5006	118	6114	6483	-1496	15815	31	15846	3136	18982	49.86
13	4213	469	256	4938	446	5063	141	6034	6137	-1509	15216	31	15247	3120	18367	49.90
14	4214	385	256	4855	508	5079	142	5662	6176	-1395	15365	30	15395	2989	18384	49.92
15	4212	409	254	4875	806	5026	120	5494	5612	-1429	15010	25	15035	3025	18060	49.88
16	4219	401	254	4874	868	5015	114	5468	5908	-1438	15341	25	15366	3032	18398	49.93
17	4082	266	252	4600	1154	4992	74	5222	5588	-1437	14971	25	14996	3021	18017	49.87
18	3926	475	253	4654	1321	4978	34	4328	4104	-1379	13712	25	13737	2950	16687	49.93
19	3923	215	258	4396	1375	4985	0	4134	3872	-1237	13391	25	13416	2821	16237	49.92
20	3972	613	262	4847	1441	4969	0	4776	4755	-1280	14732	28	14760	2848	17608	49.89
21	3967	248	262	4477	1331	4913	0	5026	4855	-1303	14273	28	14301	2842	17143	49.90
22	4014	123	261	4398	1149	4859	0	4899	4505	-1165	13746	28	13774	2633	16407	49.88
23	3999	115	263	4377	1132	4890	0	4633	4766	-1109	14056	28	14084	2512	16596	49.87
24	4048	95	262	4405	1139	4919	0	4208	4336	-1015	13784	28	13812	2420	16232	49.90
<b>MUs</b>	<b>98.24</b>	<b>6.84</b>	<b>6.24</b>	<b>111.32</b>	<b>22.04</b>	<b>118.73</b>	<b>1.03</b>	<b>118.79</b>	<b>123.56</b>	<b>-27.77</b>	<b>348.92</b>	<b>0.69</b>	<b>349.61</b>	<b>61.39</b>	<b>411.00</b>	<b>49.90</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Aug/2015**

Position as on 6.30 Hrs of 27/Aug/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>PLANNED OUTAGE</b>								
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refueling work	
TPC-G	Trombay 7B	60	17/07/2015	20.00		Continued.	Gas Path Inspection	
MSPGCL	Bhusawal Unit 5	500	29/07/2015	06.29		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-2	250	20/08/2015	09.00		Continued.	Realigning of T-G Rotor & Adjusting the Bearing Clearances.(40 Days)	
<b>FORCED OUTAGE</b>								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Uran Unit 6	108	01/04/2015	16.35		Continued.	Gas shortage	
IPP	RPL(AMT) U-5	270	03/04/2015	14.22		Continued.	turbine Shaft Vibration high.	
MSPGCL	Uran Unit 7	108	17/04/2015	00.07		Continued.	Gas turbine problem	
TPC-G	Bhira PSU	150	09/06/2015	10.53		Continued.	Stator Earth Fault	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage	
IPP	WPCL U-2	135	16/06/2015	00.00		Continued.	No Schdule	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown	
IPP	Adani U-2	660	04/08/2015	00.03		Continued.	ID Fan Problem	
MSPGCL	Koradi Unit-8	660	20/08/2015	09.50		Continued.	EPS problem	
MSPGCL	Khaparkheda Unit 5	500	23/08/2015	07.51	26/08/2015	04.27	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit-8	500	23/08/2015	21.35		Continued.	cooling water pump tripped	
CPP	WPCL U-1	135	25/08/2015	19.18		Continued.	Maintenance work	

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Aug/2015**

**Position as on 6.30 Hrs of 27/Aug/2015**

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 3	210	26/08/2015	09.51		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 5	200	26/08/2015	16.50	26/08/2015	22.10	Flame Failure	

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Aug/2015**

**Statement-VII**

Position as on 6.30 Hrs of 27/Aug/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>400 KV LINE Outages/Trippings</b>							
Kolhapur Mapusa I	InterState	24/08/2015	17.16	26/08/2015	06.58	HT	Over Voltage
Kolhapur Mapusa II	InterState	25/08/2015	16.12	26/08/2015	06.47	HT	Over Voltage
Lamboti - Solapur (PG)	InterState	26/08/2015	21.30	26/08/2015	21.51	T	Distance Protection
Akola II - Taptitanda ckt-II	IntraState	20/07/2015	17.29		Continued.	HT	Over Voltage
karad -kolhapur-I	IntraState	25/08/2015	17.05	26/08/2015	06.50	HT	Over Voltage
Karad - Jaigad - II	IntraState	25/08/2015	17.58	26/08/2015	06.35	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	25/08/2015	21.38	26/08/2015	09.00	HT	Over Voltage
karad -kolhapur-I	IntraState	26/08/2015	06.52	27/08/2015	07.08	T	Distance Protection (RFC at 17:00 Hrs)
Nagothane - Dabhol-II	IntraState	26/08/2015	10.23		Continued.	EO	To attend Hot Spot
Karad-Jaigad - I	IntraState	26/08/2015	10.29		Continued.	PO	R.M.Work & Testing Work (RFC at 19:30 Hrs)
Babhaleshwar-Taptitanda ckt-II	IntraState	26/08/2015	11.36		Continued.	PO	Opportunity Outage for Rectification Work of Line .(RFC at 21:48 Hrs)
Solapur - Parli(PG) I	IntraState	26/08/2015	12.18	26/08/2015	19.46	PO	Crossing of 765kv D/C Solapur-Aurangabad Line.
Main Bus-I @ Koradi-II	IntraState	26/08/2015	15.02	26/08/2015	21.05	PO	Dropper Connection 400kv DIA 7 with Main Bus-1.
Padghe - Nagothane - I	IntraState	26/08/2015	17.03	26/08/2015	20.57	PO	Insulator String Replacement.
Babhaleshwar-Taptitanda ckt-I	IntraState	26/08/2015	17.08	27/08/2015	01.31	HT	To Control Over loading of 400kv padghe -BBLSR CKT-2.
Babhaleshwar - Padghe-I	IntraState	26/08/2015	17.43	27/08/2015	01.03	EO	Attending Hot Spot
Khadka-Aurangabad (Waluj)	IntraState	26/08/2015	18.08		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	26/08/2015	19.30		Continued.	HT	Over Voltage
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi - Chikodi	InterState	26/08/2015	07.20	26/08/2015	14.16	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and deenergising the line bet.86 to 107.
REL Borivali TPC Borivali line	IntraState	10/07/2015	16.22		Continued.	T	Distance Protection
Padghe - Vasai	IntraState	15/08/2015	08:35		Continued.	PO	Removal of jumper & bunching work at Loc No. 51/1 & 35 ( charged up to Loc No. 51/1 from Padghe end only )
Kalwa - Borivali	IntraState	16/08/2015	08.00		Continued.	PO	Erection of Loc.No.12 and shifting of conductor on NER M/C Tower
Kalwa - Mulund 1	IntraState	22/08/2015	07.35		Continued.	PO	Mumbai Strengthening work
Talandge-Mudshingi Ckt-I	IntraState	26/08/2015	07.28	26/08/2015	08.28	T	Distance Protection
Khaparkheda-Kaulewada-I	IntraState	26/08/2015	10.23	26/08/2015	13.35	PO	Line Singnature Work.
Butibori - Purti	IntraState	26/08/2015	10.39	26/08/2015	19.04	PO	Replacement of Auxillary Drum of Circuit Breaker.
Mahad - Posco	IntraState	26/08/2015	10.50	26/08/2015	14.04	T	Distance Protection
Karkamb - Jeur	IntraState	26/08/2015	10.54	26/08/2015	16.52	PO	Replacement of Coupling Capacitor.
Beed-Patoda Ckt 2	IntraState	26/08/2015	13.05	26/08/2015	16.23	PO	Quarterly Maintainance Work
Khaparkheda-Kaulewada-II	IntraState	26/08/2015	14.19	26/08/2015	15.52	PO	Line Singnature Work.
Chalisingaon -Babhaleshwar	IntraState	26/08/2015	15.26	26/08/2015	19.25	PO	Testing Work
New Koyna - Niwali	IntraState	26/08/2015	17.08	26/08/2015	19.06	EO	Attending Hot Spot
Padegaon-Sawangi	IntraState	26/08/2015	21.28	26/08/2015	21.47	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Aug/2015**

**Statement-VII**

Position as on 6.30 Hrs of 27/Aug/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Sonkhar - Trombay	IntraState	27/08/2015	00.15	27/08/2015	01.32	EO	Attending Hot Spot
<b>220 KV ICT Outages/Trippings</b>							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Internal Fault
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	26/08/2015	18.33	26/08/2015	20.20	PO	Routine Maintenance Work
220/132 Kv 100 Mva Cgl Ict 1 @Dondaicha	IntraState	26/08/2015	20.13	26/08/2015	20.43	T	Back up Protection Optd.
<b>132 KV LINE Outages/Trippings</b>							
Mankapur-Uppalwadi	IntraState	26/08/2015	06.32	26/08/2015	18.33	PO	Outage on 132kv Ambazari-Hingna CKT-1.
Ambazari-Hingna 1	IntraState	26/08/2015	06.34	26/08/2015	18.31	PO	Replacement of ACSR Conductor with high Ampacity conductor.
Amravati-Chandur-Bazar	IntraState	26/08/2015	09.36	26/08/2015	19.07	PO	Stringing work of Lilo of 220kv Amaravati-Badnera line for 220kv Nandgaonpeth.
Amravati-Achalpur	IntraState	26/08/2015	09.37	26/08/2015	19.05	PO	Stringing work of Lilo of 220kv Amaravati-Badnera line for 220kv Nandgaonpeth.
Deepnagar- Nimbhora	IntraState	26/08/2015	09.51	26/08/2015	10.25	T	Load Trimming optd.
Deepnagar- Yawal	IntraState	26/08/2015	09.51	26/08/2015	10.19	T	Load Trimming optd.
Telgaon - Majalgaon	IntraState	26/08/2015	10.15	26/08/2015	15.45	PO	Quarterly Maintainance Work
Georai - Mahakala	IntraState	26/08/2015	10.15	26/08/2015	13.55	PO	Quarterly Maintainance Work
Deepnagar (Gcr) - Pachora	IntraState	26/08/2015	16.14	26/08/2015	17.04	PO	Relay Testing Work
Dondaicha(220kv) - Dondaicha (132k	IntraState	26/08/2015	20.13	26/08/2015	22.30	T	Back up Protection optd.
Dondaicha- Shahada	IntraState	26/08/2015	20.38	26/08/2015	22.35	HT	To control on Shahada Ckt loading.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage