

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Aug/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.036	2676.389	1) Gujrat	10.877	238.373
2) Hydro	27.258	375.919	2) Madhya Pradesh	10.391	154.606
3) Gas	5.594	133.152	3) Chattisgarh	4.650	79.060
Total MSPGCL	145.888	3185.460	4) Maharashtra	170.397	3743.876
B) 1) APLM	62.453	1364.825	5) Goa (Amona)	-1.507	-42.783
2) JSWEL	15.331	366.539	Total	194.808	4173.132
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.937	785.321
4) RPL(AMT)	18.708	515.506	b) Mumbai Drawl	29.102	855.784
5) SWPGPL	5.555	157.723	c) MSEDCL Bilateral *	84.106	1973.456
6) Other IPP	4.922	148.537	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.921	785.037
C) 1) TPCL Thermal	12.877	269.796	Include PX	0.000	0.000
2) TPCL Hydro	8.479	162.043	Standby	0.016	0.284
3) TPCL Gas	2.234	49.992	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.815	225.952	1) MSEDCL	434.511	10066.355
D) STATE			2) Mumbai Discoms	63.509	1563.570
1) Thermal	243.697	5725.267	3) Other Discoms	8.951	226.542
(A1+C1+C4+(B1-B6))			TOTAL STATE	506.971	11856.467
2) Hydro	35.737	537.962			
(A2+C2)					
3) Gas	7.828	183.144			
(A3+B7+C3)					
4) Wind	14.328	1025.927			
6) SOLAR	10.571	211.032			
TOTAL STATE	312.161	7683.332			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4660	4726	4717	4546
MSPGCL Hydro	1251	1111	2095	494
MSPGCL Gas	237	225	227	234
MSPGCL Total Generation	6148	6062	7039	5274
Central Sector Receipt	10289	9947	7557	6809
WIND	275	235	745	854
CPP / IPP Thermal	4426	4409	4488	4434
CPP / IPP Gas	0	0	0	0
SOLAR	1227	1273	0	0
Exchange with Mumbai	-2053	-2052	-1204	-420
MSEDCL DEMAND MET	19897	19480	18209	16666
Load Shedding	0	0	0	0
MSEDCL DEMAND	19897	19480	18209	16666
TPCL GENERATION	825	786	1201	990
AEML GENERATION	378	368	492	492
MUMBAI DEMAND	3256	3206	2897	1902
OTHER DISCOM DEMAND	415	394	416	285
STATE DEMAND MET	23568	23080	21522	18853
STATE DEMAND	23568	23080	21522	18853
Frequency (Hz)	49.94	49.96	49.79	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.1 Hz at 17.02 Hrs	49.5 Hz at 19.14 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.04	67.25	180	60
Unit 7	0.00	0.00	0	0
Unit 8	0.45	103.07	226	0
Unit 9	0.00	46.51	0	0
Unit 10	10.05	268.29	440	330
Total	13.55	485.12		
Bhusawal				
Unit 3	0.00	7.23	0	0
Unit 4	9.56	212.50	445	350
Unit 5	0.00	55.81	0	0
Total	9.56	275.54		
Parli				
Unit 6	3.50	106.69	201	0
Unit 7	4.07	96.83	209	97
Unit 8	3.87	92.47	170	154
Total	11.44	296.00		
Chandrapur				
Unit 3	0.24	32.65	77	0
Unit 4	2.23	14.66	133	0
Unit 5	7.33	134.57	320	275
Unit 6	7.30	138.06	350	260
Unit 7	6.14	55.48	330	225
Unit 8	10.62	232.38	469	398
Unit 9	10.31	241.92	454	395
Total	44.16	849.71		
Paras				
Unit 3	4.52	93.92	210	163
Unit 4	4.48	98.19	203	170
Total	9.00	192.11		
Khaparkheda				
Unit 1	2.92	40.76	135	100
Unit 2	0.00	44.16	0	0
Unit 3	3.55	87.96	161	134
Unit 4	3.86	64.01	180	128
Unit 5	8.94	191.02	390	330
Total	19.26	427.92		
Nasik				
Unit 3	3.09	75.63	147	119
Unit 4	0.00	0.00	0	0
Unit 5	2.97	74.36	135	115
Total	6.06	149.99		
Uran				
All Units	5.59	133.15	245	224
Total	5.59	133.15		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	15.50	25	25
Total	0.60	15.50		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	4.81	66.95	430	20
Stage 4	9.48	64.27	1001	0
Stage 3	4.12	40.92	240	0
Total	18.42	172.14		
Hydro				
KDPH	0.00	11.91	0	0
VTRNA	0.64	15.90	61	0
TILLARI	0.58	13.87	58	0
BHIRA T.R.	0.48	12.21	80	0
SMLHY_PTN	6.42	129.44	281	249
GHATGHAR	0.13	4.96	64	0
Total	8.25	188.27		
Wind				
Total	14.33	1025.93	0	0
Total	14.33	1025.93		
CPP				
APML(Mus)	62.45	1364.82	0	0
JSWEL(Mus)	15.33	366.54	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.71	515.51	0	0
SWPGPL-Mus	5.56	157.72	0	0
Other(Mus)	4.92	148.54	0	0
Total	106.97	2553.13		
SOLAR				
Total	10.57	211.03	0	0
Total	10.57	211.03		
Tata				
Trombay 5	8.56	179.87	443	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.26	28.68	112	39
Trombay 7B	0.97	21.31	68	34
TATA Hydro	8.48	162.04	425	269
Trombay 8	4.31	89.92	223	129
Total	23.59	481.83		
AEML				
DTPS U-1&2	10.82	225.95	497	353
Total	10.82	225.95		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	113.04	2676.39	MSPGCL Total	145.89	3185.46
			MSPGCL Thml+Gas	118.63	2809.54	Koyna 1,2 & 4 Total	14.29	131.22
			MSPGCL Hydro	27.26	375.92	State Total	312.16	7683.33

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 26/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4584	1081	243	5908	1007	4473	0	0	6234	6332	-694	16690	0	16690	2251	336	19277	49.98
2	4549	968	234	5751	1036	4427	0	0	6334	6383	-547	16732	0	16732	2096	318	19146	50.02
3	4464	438	243	5145	973	4430	0	0	6690	6818	-468	16608	0	16608	1970	290	18868	50.04
4	4546	494	234	5274	854	4434	0	0	6794	6809	-420	16666	0	16666	1902	285	18853	50.02
5	4575	619	243	5437	818	4435	0	0	7004	6770	-399	16755	0	16755	1885	306	18946	49.87
6	4573	1422	235	6230	655	4452	0	0	6952	7452	-474	17992	0	17992	2010	323	20325	49.84
7	4618	1759	245	6622	461	4452	0	55	7756	8311	-640	18892	0	18892	2186	369	21447	49.86
8	4636	1734	243	6613	301	4451	0	304	8604	8870	-955	19191	0	19191	2384	393	21968	49.96
9	4700	774	231	5705	272	4444	0	702	9802	9882	-1528	19079	0	19079	2721	399	22198	49.99
10	4735	1036	241	6012	253	4414	0	1004	9460	9613	-1819	19074	0	19074	3022	403	22499	50.02
11	4671	1103	227	6001	220	4435	0	1275	9811	9972	-2026	19452	0	19452	3217	425	23094	50.01
12	4660	1251	237	6148	275	4426	0	1227	10100	10289	-2053	19897	0	19897	3256	415	23568	49.94
13	4726	1111	225	6062	235	4409	0	1273	10207	9947	-2052	19480	0	19480	3206	394	23080	49.96
14	4733	790	224	5747	234	4404	0	1341	9988	9915	-1956	19307	0	19307	3061	378	22746	50.01
15	4718	590	235	5543	364	4404	0	1368	9789	9940	-1894	19344	0	19344	3094	381	22819	49.90
16	4767	983	226	5976	465	4413	0	1012	9040	9077	-1783	18771	0	18771	3087	389	22247	49.97
17	4799	1353	225	6377	655	4411	0	689	8313	8320	-1697	18336	0	18336	3040	419	21795	50.01
18	4719	1257	225	6201	713	4465	0	286	8383	8066	-1605	17719	0	17719	2973	407	21099	50.01
19	4746	1497	234	6477	639	4459	0	33	7846	7638	-1347	17492	0	17492	2887	407	20786	49.82
20	4717	2095	227	7039	745	4488	0	0	7678	7557	-1204	18209	0	18209	2897	416	21522	49.79
21	4790	1407	236	6433	934	4498	0	0	7327	7510	-1045	17935	0	17935	2776	395	21106	49.97
22	4957	1047	226	6230	840	4556	0	0	6865	6849	-926	17172	0	17172	2632	377	20181	49.98
23	5112	1144	228	6484	727	4596	0	0	6419	6297	-829	16899	0	16899	2518	376	19793	49.98
24	4941	1309	227	6477	652	4593	0	0	6086	6187	-741	16819	0	16819	2436	349	19604	49.97
MUs	113.04	27.26	5.59	145.89	14.33	106.97	0.00	10.57	193.48	194.81	-29.10	434.51	0.00	434.51	63.51	8.95	506.97	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 26/Aug/2022

Position as on 6.30 Hrs of 27/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-3	250	27/08/2022	12:00		Continued.	Governing System Upgradation	05/09/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16	26/08/2022	20:34	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	31/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 4	210	09/08/2022	20:25	26/08/2022	01:05	FURNACE DRAFT VERY HIGH/ poor coal receipt & wet coal.	
MSPGCL	Chandrapur Unit 3	210	15/08/2022	12:50	26/08/2022	18:27	Poor Coal Receipt	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44	27/08/2022	02:44	Wet coal problem.	
MSPGCL	Khaparkheda Unit 2	210	19/08/2022	02:18		Continued.	Furnace Pressure High/poor coal receipt & wet coal.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Aug/2022

Position as on 6.30 Hrs of 27/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	RPL(AMT) U-5	270	19/08/2022	11:00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 8	660	21/08/2022	14:10	26/08/2022	20:18	SUSPECTED BOILER TUBE LEAKAGE	27/08/2022
MSPGCL	Uran Unit 5	108	24/08/2022	02:29		Continued.	Gas shortage	
IPP	Adani U-5	660	26/08/2022	00:06		Continued.	HOT PA-5A bellow leakage	30/08/2022
TPC-G	Trombay 7B	60	26/08/2022	00:53		Continued.	Due to Less availability of APM Gas.	
MSPGCL	Koyana STG-IV Unit-2	250	26/08/2022	05:18	26/08/2022	15:18	SPERICAL VALVE OIL SYSTEM PROBLEM	
MSPGCL	Parli Unit 6	250	26/08/2022	16:56	26/08/2022	21:29	Turbine Protection.	
MSPGCL	Koradi Unit 8	660	26/08/2022	22:51	27/08/2022	03:03	Water separator drum level high.	
IPP	JSW (J) U1	300	26/08/2022	23:55	27/08/2022	03:18	EH oil leakage.	
TPC-G	Trombay 7A	120	27/08/2022	01:13	27/08/2022	17:31	Due to Less availability of APM Gas.	
MSPGCL	Koradi Unit 8	660	27/08/2022	04:57	27/08/2022	16:32	Control and Instrument supply failure.	
MSPGCL	Chandrapur Unit 3	210	27/08/2022	14:52	27/08/2022	17:53	HP HEATER HIGH LEVEL	
MSPGCL	Uran Unit 8	108	27/08/2022	15:26		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
MSPGCL	Koyana STG-IV Unit-4	250	27/08/2022	18:40	27/08/2022	18:40	D.C.supply fail	
MSPGCL	Koyana STG-IV Unit-4	250	27/08/2022	18:41		Continued.	DC SUPPLY FAILED	
MSPGCL	Bhusawal Unit 3	210	27/08/2022	18:48	27/08/2022	20:59	Low Vaccum	
TPC-G	Trombay 7A	120	27/08/2022	23:14		Continued.	Due to Less availability of APM Gas.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 27/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (703) BUS REACTOR @ AKOLA 2	IntraState	26/08/2022	10:07	26/08/2022	13:42	PO	Circuit Breaker SF6 gas analysis & CB Preventive maintenance activities
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	27/08/2022	12:30	27/08/2022	15:27	EO	For attending 02 nos of hotspots having temprature 246 & 140 deg cel. Fumes are visible at 246 & C location with naked eye due to which jumper may break any time causing tripping of Pole II Base Filter
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11	27/08/2022	19:36	HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/08/2022	22:07	27/08/2022	02:54	EO	For removing grass & herbs in base filter area
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	27/08/2022	01:57	27/08/2022	04:40	T	TRIPPED UNDER REDUCED VOLTAGE
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KALWA - TALEGAON (PG)	InterState	25/08/2022	23:32	26/08/2022	07:00	HT	EMERGENCY OUTAGE AVAILED FOR CVT REPLACEMENT AT TALEGAON PG END
CHANDRAPUR - BHADRAVATI CKT - 1	InterState	26/08/2022	11:09	26/08/2022	18:32	HT	Outage by PG
PADGHE - BOISAR (PG)	InterState	26/08/2022	15:45	26/08/2022	17:58	T	Winding temperature high alarm and trip
KHADKA-AURANGABAD (WALUJ)	IntraState	25/08/2022	22:30	26/08/2022	06:32	HT	H/T DUE TO O/V
NEW KOYNA - DABHOL CKT - 1	IntraState	26/08/2022	02:48	26/08/2022	18:20	T	TRIPPED DUE TO OVER VOLTAGE
NEW KOYNA - DABHOL CKT - 1	IntraState	26/08/2022	09:24	26/08/2022	18:20	PO	Diagnostic testing & Relay testing work
KORADI II - KORADI III CKT - 2	IntraState	26/08/2022	11:00	26/08/2022	16:29	PO	Tan delta measurement of Line CT
NAGOTHANE - DABHOL CKT - 2	IntraState	27/08/2022	11:55	27/08/2022	16:22	T	Distance Protection
400 KV ICT Outages/Trippings							
95 MVA STN TF - II @KORADI 2	IntraState	23/08/2022	12:26			PO	1)Transformer testing and oil filtration 2)Transformer bus duct inspection 3) Station switch gear checking , breaker and relay testing
500 MVA 400/220 KV ICT - I @ CHANDRAPUR 2	IntraState	24/08/2022	16:01	26/08/2022	19:08	T	Y-Ph Buchholz trip.
220 KV MAINBAY Outages/Trippings							
PT BAY @ COLOURCHEM	IntraState	26/08/2022	14:15	26/08/2022	22:03	EO	To replace B phase PT with New PT, Due to Oil leakage. (220KV Kalwa-Colourchem Line is under outage by Project Circle, Kalwa)
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	26/08/2022	05:56	26/08/2022	12:59	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 27/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	19/08/2022	06:26	26/08/2022	13:02	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
WARDHA - WARDHA (PG)	IntraState	26/08/2022	06:44	26/08/2022	13:07	HT	H/T DUE TO HIGH O/D AT LOW FREQUENCY
KALWA - COLOURCHEM	IntraState	26/08/2022	09:33	26/08/2022	22:03	PO	Charging of 2000 Sq.mm Power cable Radially by making Tap on 220 Kalwa-Colourchem Line
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	26/08/2022	09:35	26/08/2022	15:27	PO	Bay Maintenance
POPHLI PEDHMBE LINE- 1	IntraState	26/08/2022	11:22	26/08/2022	19:05	HT	Emergency outage to replace conductor
KANDALGAON - KOYNA (POPHALI)	IntraState	26/08/2022	11:27	26/08/2022	18:42	HT	Emergency outage to replace conductor
KALWA - AIROLI KNOWLEDGE PARK	IntraState	26/08/2022	11:30	26/08/2022	15:35	EO	Outage required for Safety purpose for Damaged conductor replacement of 220KV Kalwa-Colourchem line at Loc. No. 407C & 407D which will be out for Project Dn, Kalwa. Both lines cross each other at above location.
POPHALI - KDPH	IntraState	26/08/2022	11:40	26/08/2022	18:40	HT	Emergency outage to replace conductor
MAIN BUS SECTION - 1 @ POPHALI	IntraState	26/08/2022	11:50	26/08/2022	18:40	EO	1. 220KV PPI- KDPH line MB side Y ph isolator conductor strands are damaged, need to attend. 2. 220KV PPL-KDPH line Y & B Ph transfer bus side step bus gantry to gantry, conductor strands are damaged, need to attend. 3. 220KV Bus Coupler I Y & B ph transfer bus side step bus gantry to gantry, conductor strands are damaged, need to attend.
TROMBAY - SALSETTE CKT - 1	IntraState	27/08/2022	08:22	27/08/2022	11:52	PO	Protection Testing at Trombay Generating Station
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	27/08/2022	09:51	27/08/2022	12:52	PO	1) Attending the damaged conductor in between Loc.No.97 and Loc.No.97A.
URAN - APTA CKT - 1	IntraState	27/08/2022	09:51	27/08/2022	14:52	PO	For string insulator replacement work & hot spot attending work
MHAISHAL- JATH	IntraState	27/08/2022	10:41	27/08/2022	13:52	PO	Damaged conductor replacement work at Loc No.216
MAHAD-KALAMBANI(TSS)	IntraState	27/08/2022	11:56	27/08/2022	21:40	PO	Control panel and relay panel height rising work.
ADLABS - PEDAMBE	IntraState	27/08/2022	20:28	27/08/2022	21:25	T	DP
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	25/08/2022	09:26	27/08/2022	17:18	PO	Commissioning of new HV & LV Relay & Control panel.
220/100 KV 200 MVA ICT 2 @ PAL-DOMBIVALI	IntraState	26/08/2022	10:18	26/08/2022	20:34	PO	Carrying out IR test of CFT point, Relay testing & Bay RM work.
220/33kv 125 MVA TF 2 @ GORAI	IntraState	27/08/2022	10:58	27/08/2022	15:18	PO	Attending oil leakage from HV neutral bushing CT terminal enclosure
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	IntraState	27/08/2022	11:28	27/08/2022	17:42	PO	HV & LV LA Insulation resistance measurement work & Bay RM work.
220/33KV 50MVA PTR 1 @ JEJURI	IntraState	27/08/2022	15:45		Continued.	PO	REPLACEMENT OF HV SIDE BUS ISOLATOR
220 KV BUSBAR Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 27/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 2 @ URAN	IntraState	26/08/2022	10:20	26/08/2022	19:11	PO	1) For MAIN BUS insulator and stub Bus insulator string replacement work & GT6 bay decapped hanging Tension string replacement work
MAIN BUS - 2 @ URAN	IntraState	27/08/2022	09:54	27/08/2022	18:29	PO	1) For MAIN BUS-2 insulator and stub Bus insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage