

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Sep/2018 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	115.282	2809.562	1) Gujrat	4.617	24.971
2) Hydro	22.479	380.056	2) Madhya Pradesh	24.065	422.490
3) Gas	7.143	124.754	3) Chattisgarh	6.320	135.320
Total MSPGCL	144.904	3314.372	4) Maharashtra Net	148.039	3256.709
B) 1) APML	54.012	1429.151	5) Goa (Amona)	-0.308	-7.722
2) JSWEL	28.143	572.002	Total	182.733	3831.768
3) VIPL	10.090	370.688	a) Mumbai Schedule	22.575	579.560
4) RPL(AMT)	6.474	647.168	b) Mumbai Drawl	26.891	607.669
5) WPCL	5.619	107.024	c) MSEDCL Bilateral *	93.809	1406.967
6) PGPL	0.000	0.000	Include PX	56.684	698.260
7) Other IPP	8.025	184.086	d) Mumbai Bilateral *	22.575	579.560
C) 1) TPCL Thermal	16.868	408.735	Include PX	6.443	45.833
2) TPCL Hydro	4.807	111.168	Include Standby	0.000	0.000
3) TPCL Gas	4.301	112.926	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	11.995	291.255	1) MSEDCL	424.757	10481.897
D) STATE			2) Mumbai Discoms	64.862	1531.751
1) Thermal	256.508	6819.671	TOTAL STATE	489.619	12013.648
(A1+C1+C4+(B1-B6))					
2) Hydro	27.286	491.224			
(A2+C2)					
3) Gas	11.444	237.680			
(A3+B6+C3)					
4) Wind	5.833	503.357			
6) SOLAR	5.815	129.950			
TOTAL STATE	306.886	8181.882			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4921	5027	4738	4789
MSPGCL Hydro	838	573	1673	173
MSPGCL Gas	286	294	289	308
MSPGCL Total Generation	6045	5894	6700	5270
Central Sector Receipt	8862	8767	7046	6909
WIND	202	163	349	193
CPP / IPP Thermal	4710	4683	4671	4707
CPP / IPP Gas	0	0	0	0
SOLAR	812	808	0	0
Exchange with Mumbai	-1465	-1421	-1259	-527
MSEDCL DEMAND MET	19166	18894	17507	16552
Load Shedding	34	0	0	0
MSEDCL DEMAND	19200	18894	17507	16552
TPCL GENERATION	1293	1275	1303	876
R-INFRA GENERATION	500	502	499	501
MUMBAI DEMAND	3258	3198	3061	1904
STATE DEMAND MET	22424	22092	20568	18456
STATE DEMAND	22458	22092	20568	18456
Frequency (Hz)	50.00	49.99	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.09 Hz at 16.07 Hrs	49.85 Hz at 17.39 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 26/Sep/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.15	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.48	183.74	422	240
Unit 9	0.00	38.80	0	0
Unit 10	7.64	153.52	502	199
Total	15.12	376.21		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.76	98.27	405	300
Unit 5	7.80	241.80	390	300
Total	15.56	340.06		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	14.31	0	0
Unit 7	4.67	136.08	209	144
Unit 8	3.18	124.14	189	86
Total	7.84	274.52		
Chandrapur				
Unit 3	3.81	97.68	173	130
Unit 4	4.09	101.91	178	147
Unit 5	9.99	174.13	450	370
Unit 6	0.00	114.65	0	0
Unit 7	10.14	152.18	432	406
Unit 8	9.19	188.19	470	275
Unit 9	9.54	227.23	424	368
Total	46.76	1055.98		
Paras				
Unit 3	0.00	59.46	0	0
Unit 4	5.18	123.58	237	190
Total	5.18	183.04		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	27.37	0	0
Unit 3	3.63	95.00	171	135
Unit 4	3.80	59.93	175	147
Unit 5	10.02	229.21	460	370
Total	17.46	411.51		
Nasik				
Unit 3	3.62	104.75	159	133
Unit 4	3.74	57.35	166	142
Unit 5	0.00	6.13	0	0
Total	7.36	168.23		
Uran				
All Units	7.14	124.75	309	283
Total	7.14	124.75		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.30	3.03	42	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.30	3.03		
Koyna				
Stage 1-2	5.94	101.80	535	40
Stage 4	11.17	162.39	1000	0
Stage 3	3.79	59.23	320	0
Total	20.90	323.42		
Hydro				
KDPH	0.44	15.38	19	18
VTRNA	0.00	5.30	0	0
TILLARI	0.00	5.98	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.33	8.10	80	0
RNGR+BHTSA	0.35	6.88	15	14
BHANDARDRA	0.00	2.87	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.22	8.52	9	9
GHATGHAR	0.24	3.60	125	0
Total	1.58	56.64		
Wind				
Total	5.83	503.36	0	0
Total	5.83	503.36		
CPP				
APML(Mus)	54.01	1429.15	0	0
JSWEL(Mus)	28.14	572.00	0	0
VIPL(Mus)	10.09	370.69	0	0
RPLAMT(Mus)	6.47	647.17	0	0
WPCL(Mus)	5.62	107.02	0	0
Other(Mus)	8.02	184.09	0	0
Total	112.36	3310.12		
SOLAR				
Total	5.82	129.95	0	0
Total	5.82	129.95		
Tata				
Trombay 5	11.34	270.32	482	449
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.71	71.31	115	110
Trombay 7B	1.59	41.62	67	65
Trombay 8	5.52	138.41	237	216
TATA Hydro	4.81	111.17	438	0
Total	25.98	632.83		
R-INFRA				
DTPS U-1&2	12.00	291.26	502	498
Total	12.00	291.26		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	115.28	2809.56	MSPGCL Total	144.90	3314.37
			MSPGCL Thml+Gas	122.42	2934.32	Koyna 1,2 & 4 Total	17.11	264.19
			MSPGCL Hydro	22.48	380.06	State Total	306.89	8181.88

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 26/Sep/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4746	579	296	5621	156	4807	0	0	6863	7003	-915	16672	0	16672	2300	18972	49.89
2	4732	393	306	5431	228	4683	0	0	6907	7049	-749	16642	0	16642	2107	18749	49.98
3	4775	242	307	5324	176	4698	0	0	6829	7068	-613	16653	0	16653	1978	18631	50.01
4	4789	173	308	5270	193	4707	0	0	6792	6909	-527	16552	0	16552	1904	18456	50.00
5	4820	400	297	5517	195	4682	0	0	6801	6696	-513	16577	0	16577	1887	18464	50.01
6	4821	658	308	5787	205	4695	0	0	7700	7578	-615	17650	0	17650	1998	19648	49.99
7	4756	1272	309	6337	258	4685	0	26	7976	8165	-734	18737	0	18737	2128	20865	50.02
8	4720	1519	308	6547	234	4692	0	190	8059	8092	-900	18855	0	18855	2289	21144	50.06
9	4881	929	304	6114	270	4716	0	415	8271	8432	-1210	18737	0	18737	2608	21345	50.03
10	4939	513	292	5744	253	4671	0	646	8499	8535	-1425	18424	34	18458	2939	21397	50.01
11	4974	277	300	5551	200	4685	0	728	8738	8848	-1426	18586	34	18620	3161	21781	50.03
12	4921	838	286	6045	202	4710	0	812	8818	8862	-1465	19166	34	19200	3258	22458	50.00
13	5027	573	294	5894	163	4683	0	808	8801	8767	-1421	18894	0	18894	3198	22092	49.99
14	5088	412	283	5783	172	4657	0	718	8692	8654	-1344	18640	0	18640	3108	21748	50.00
15	5028	649	293	5970	155	4695	0	626	8572	8387	-1372	18461	20	18481	3168	21649	49.96
16	4835	1176	284	6295	178	4652	0	479	8507	8604	-1366	18842	20	18862	3193	22055	49.95
17	4777	1496	297	6570	177	4556	0	289	8320	8148	-1379	18361	20	18381	3173	21554	50.00
18	4637	1620	286	6543	247	4585	0	76	7637	7420	-1354	17517	0	17517	3125	20642	49.95
19	4640	1838	299	6777	265	4697	0	2	6747	6750	-1310	17181	0	17181	3081	20262	49.90
20	4738	1673	289	6700	349	4671	0	0	6761	7046	-1259	17507	0	17507	3061	20568	49.98
21	4743	1257	301	6301	339	4695	0	0	6315	6443	-1201	16577	0	16577	2931	19508	49.96
22	4628	1361	291	6280	557	4702	0	0	6148	6235	-1256	16518	0	16518	2849	19367	49.98
23	4634	1331	302	6267	370	4653	0	0	6183	6625	-1260	16655	0	16655	2747	19402	49.96
24	4633	1300	303	6236	291	4686	0	0	6408	6417	-1277	16353	0	16353	2671	19024	49.98
MUs	115.28	22.48	7.14	144.90	5.83	112.36	0.00	5.81	181.34	182.73	-26.89	424.76	0.16	424.92	64.86	489.78	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Sep/2018

Position as on 6.30 Hrs of 27/Sep/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-3	660	03/09/2018	05.02		Continued.	Capital overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	Coal Swapping IEPL	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01:12		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
MSPGCL	Koradi Unit 7	210	03/08/2018	15.54		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 1	210	11/08/2018	23.57		Continued.	Poor coal Receipt	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Koradi Unit 9	660	04/09/2018	12.48		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Koradi Unit 6	210	09/09/2018	05.52		Continued.	Inspection of Boiler Tubes by R & M Team.	
MSPGCL	Khaparkheda Unit 2	210	10/09/2018	02.35		Continued.	Poor Coal Receipt.	
MSPGCL	Nasik Unit 5	210	11/09/2018	18.45		Continued.	Coal Swapping with DIL	
MSPGCL	Parli Unit 6	250	12/09/2018	06.57		Continued.	Poor Coal receipt	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit 6	500	20/09/2018	16:00	27/09/2018	01.00	Poor Coal Receipt	
IPP	RPL(AMT) U-5	270	21/09/2018	00.05		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-1	270	22/09/2018	00.00		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-3	270	25/09/2018	0.00		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit-8	500	27/09/2018	00.58		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U2	300	27/09/2018	05.05		Continued.	C.W.Duct Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe HvdC Pole 1	IntraState	27/09/2018	08.20	27/09/2018	14.17	PO	Testing Work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	25/09/2018	18.28	26/09/2018	06.43	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	26/09/2018	18.16	27/09/2018	07.15	HT	Over Voltage
Padgha Tarapur II	InterState	27/09/2018	10.18		Continued.	PO	Annual Maintenance Work
Dabhol Nagothane I	InterState	27/09/2018	15.21	27/09/2018	17.23	T	Distance Protection
Dhule Sar'Sarovar I	InterState	27/09/2018	20.11		Continued.	HT	Over Voltage
Dhule- Bableshtar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule - Bableshtar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Bhusawal-Aurangabad	IntraState	25/09/2018	17.52	26/09/2018	06.29	HT	Over Voltage
Jejuri- Koynastage-IV	IntraState	26/09/2018	04.24	27/09/2018	18.55	T	Distance protection Zone 1 R Phase E/F, Conductor Decapping at Loc.No. 135.(Afterwards Isolator Problem Y and B phase at Koyna Stage-IV detected)
Deepnagar Taptitanda	IntraState	26/09/2018	06.59	26/09/2018	16.59	PO	Replacement of dead end & conductor wherever necessary.
Kala Kudus Ckt-II	IntraState	26/09/2018	08.37	26/09/2018	20.42	PO	Replacement of string insulator by polymer string.
Chandrapur-II - Nanded ckt I	IntraState	26/09/2018	11.12	26/09/2018	16.18	T	Distance Protection
Warora-Adani(Tiroda)1	IntraState	26/09/2018	15.38	26/09/2018	15.50	EO	Outage on line SF6 gas refilling.
karad -kolhapur-I	IntraState	26/09/2018	19.40	27/09/2018	13.26	T	Distance Protection
Deepnagar Taptitanda	IntraState	27/09/2018	08.25	27/09/2018	18.10	PO	Replacement of dead end & conductor wherever necessary.
Kala Kudus Ckt-I	IntraState	27/09/2018	08.31	27/09/2018	21.05	PO	Insulator replacement work.
Main Bus-II @ Koradi III	IntraState	27/09/2018	08.51	27/09/2018	12.58	PO	Routine Maintenance Work
Koradi-Khaperkheda I	IntraState	27/09/2018	09.09	27/09/2018	19.04	PO	Attend discrepancies observed on newly erected tower.
Nagothane - Dabhol-II	IntraState	27/09/2018	16.00	27/09/2018	16.57	T	Dabhol end DT received at Dabhol.
Khadka-Aurangabad (Waluj)	IntraState	27/09/2018	18.18		Continued.	HT	Over Voltage
Khadka- Deepnagar Ckt 2	IntraState	27/09/2018	19.14	27/09/2018	21.16	EO	Attending Hot Spot
400 KV ICT Outages/Trippings							
400/220KV 500MVA ICT 2@koradi 2	IntraState	18/09/2018	09.47		Continued.	HT	Emergency Hand Tripped due to R Phase Buchholz alarm Indication on ICT
400/220/33 Kv 315 MVA ICT II @Chandrapur	IntraState	26/09/2018	08.14	26/09/2018	21.50	PO	Replacement of cops of Y PH unit.
400/220 Kv 600 MVA ICT-II @Kalwa	IntraState	27/09/2018	05.34	27/09/2018	08.18	EO	Replacement of B-Phase neutral earthing L Plate.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Nasik Navsari I	InterState	26/09/2018	09.45	26/09/2018	18.29	PO	Tree chopping work by navsari.
Nasik Navsari II	InterState	27/09/2018	11.10	27/09/2018	18.07	PO	Routine Maintenance Work
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa 52B Interconnector CB	IntraState	19/08/2018	18.25		Continued.	HT	Taken In Service To Control Load Of Temghar Ckt At Kalwa 1 S/5 In Lieu Of 220kv Bus Outage At Padgha.
Nerul-Trombay	IntraState	31/08/2018	22.04		Continued.	PO	Conductor Replacement
Deoli(Pgcil)-Badnera	IntraState	25/09/2018	19.07	26/09/2018	06.38	HT	System Constraint By WR.
Bus Coupler at Bhusawal	IntraState	26/09/2018	09.15	26/09/2018	14.16	PO	Routine Maintenance Work
Ongc Uran - Jnpt	IntraState	26/09/2018	11.20	26/09/2018	15.25	PO	Breaker overhauling at ONGC end.
Kharepatan -Pawas Line	IntraState	26/09/2018	12.10	26/09/2018	12.50	T	C Phase Earth Fault.
Topworth - Kharghar	IntraState	26/09/2018	12.12	26/09/2018	16.50	PO	Y PH CT to CB jumper replacement.
Virur - Gadchiroli	IntraState	26/09/2018	12.30	26/09/2018	17.00	PO	Testing Work
Nanded-Parbhani	IntraState	26/09/2018	12.33	26/09/2018	14.25	PO	To attend Hot Spot
Bus Coupler @ Abhijeet	IntraState	26/09/2018	15.19	26/09/2018	17.56	PO	Tan Delta Measurment of CTs
Dhule-Chalisagaon	IntraState	26/09/2018	15.25	26/09/2018	21.37	T	To control ICT loading.
Butibori-Abhijeet	IntraState	26/09/2018	15.29	26/09/2018	17.56	PO	Tan Delta Measurment of CTs
Uran - Ongc Uran	IntraState	26/09/2018	15.36	26/09/2018	18.16	PO	Breaker overhauling at ONGC end.
Talandge(400)- Mudshingi 2 Line	IntraState	26/09/2018	18.42	26/09/2018	22.11	T	Distance Protection
Boisar II - Tarapur	IntraState	26/09/2018	19.20	26/09/2018	20.04	PO	Normalising the zone-3 power supply.
Pedhambe - Oni	IntraState	26/09/2018	21.52	27/09/2018	03.55	T	Distance Protection
New Koyna - Niwali	IntraState	27/09/2018	01.23	27/09/2018	02.39	T	Distance Protection
Jamde-Dondaicha 1	IntraState	27/09/2018	06.01	27/09/2018	07.17	HT	Due to overloading of Dhule ICT.
Dhule-Amalner(220kv)	IntraState	27/09/2018	06.09	27/09/2018	08.24	T	Due to loading of Dhule ICT.
Ghatghar - Jindal	IntraState	27/09/2018	10.12	27/09/2018	15.42	PO	Flashover insulator replacement at LOC no 154&155.
Karad-Nerle	IntraState	27/09/2018	11.11	27/09/2018	17.17	PO	Routine Maintenance Work
Nagothane-Wadkhal-I	IntraState	27/09/2018	16.40	27/09/2018	17.10	T	On B/C protn, R PH.
Pophali - New Koyna	IntraState	27/09/2018	16.58	27/09/2018	17.15	T	O/C due to tripping of nagothane dabhol both ckts.
New Koyna - Pedambe	IntraState	27/09/2018	16.58	27/09/2018	17.08	T	O/C due to tripping of nagothane dabhol both ckts.
New Koyna - Loteparshuram	IntraState	27/09/2018	16.58	27/09/2018	17.13	T	O/C due to tripping of Nagothane Dabhol both ckts.
Nagothane - Ipcl	IntraState	27/09/2018	17.02	27/09/2018	18.45	T	Distance Protection
Harangul-Parly	IntraState	27/09/2018	18.04	27/09/2018	21.29	EO	Attending R-PH wave trap hot spot.
Bhugaon- Wardha	IntraState	27/09/2018	18.40		Continued.	HT	At Deoli end for power regulation.
220 KV ICT Outages/Trippings							
220/33kv 125 Mva Transformer 4 @Ghodbunder R/S	IntraState	24/09/2018	09.26	27/09/2018	02.11	PO	Isolator Earth Switch Shifting Work Of TF.
220/132 Kv Ict 1 200 Mva @Parbhani	IntraState	25/09/2018	11.52		Continued.	PO	Repairing / Servicing Of Intank OLTC.
220/22kv 100MVA T/F-I @ Nalasopara	IntraState	26/09/2018	07.30	26/09/2018	08.15	T	H/T For Airing Due To Main Buchholz Alarm Activated.
220/132 Kv 100 Mva Emco Ict 2 @Dondaicha	IntraState	26/09/2018	09.25	26/09/2018	12.21	PO	Tan Delta Measurment of CTs
220/22 Kv 50 Mva Bb Ptr 2 @Kalwa	IntraState	26/09/2018	12.18	26/09/2018	14.35	T	Differential protn, 22KV Yph LA burst, 16.07 MW load affected for 20 minutes. load shifted to PTR I.
220/33 Kv 100 Mva Alstom Ptr 2 @Jamde	IntraState	27/09/2018	10.36	27/09/2018	16.32	PO	Quarterly Maintainance Work
220/100 Kv 100 MVA ICT II	IntraState	27/09/2018	16.20	27/09/2018	17.30	T	Fault on 100 kv roha ckt 2 CB not

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
@Kandalgaon							tripped.
100 MVA ICT I at Kandalgaon	IntraState	27/09/2018	16.20	27/09/2018	18.05	T	Fault on 100 kv roha ckt 2 CB not tripped.
132 KV LINE Outages/Trippings							
Mouda-Bhandara	IntraState	26/09/2018	10.50	26/09/2018	16.20	T	Distance Protection
Chalisgaon- Dhule	IntraState	27/09/2018	15.20	27/09/2018	17.50	HT	View of overloading of Dhule ICT.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage