

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Sep/2021 SUNDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 112.620        | 2729.757        | 1) Gujrat                      | -7.897         | -247.370         |
| 2) Hydro            | 16.511         | 456.033         | 2) Madhya Pradesh              | 10.209         | 190.587          |
| 3) Gas              | 5.378          | 169.372         | 3) Chattisgarh                 | 4.410          | 129.400          |
| <b>Total MSPGCL</b> | <b>134.509</b> | <b>3355.162</b> | 4) Maharashtra                 | 150.322        | 3813.154         |
| B) 1) APML          | 46.777         | 1276.194        | 5) Goa (Amona)                 | -0.653         | -27.904          |
| 2) JSWEL            | 13.810         | 343.245         | <b>Total</b>                   | <b>156.391</b> | <b>3857.867</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 21.246         | 647.515          |
| 4) RPL(AMT)         | 19.134         | 589.436         | b) Mumbai Drawl                | 19.769         | 613.380          |
| 5) SWPGPL           | 6.008          | 140.620         | c) MSEDCL Bilateral *          | 57.048         | 1141.931         |
| 6) Other IPP        | 4.877          | 145.144         | Include PX                     | 28.408         | 390.542          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 21.246         | 647.515          |
| C) 1) TPCL Thermal  | 15.076         | 356.229         | Include PX                     | 7.494          | 225.807          |
| 2) TPCL Hydro       | 2.721          | 99.527          | Standby                        | 0.000          | 0.000            |
| 3) TPCL Gas         | 2.492          | 72.454          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 10.983         | 288.772         | 1) MSEDCL                      | 377.950        | 9941.758         |
| D) STATE            |                |                 | 2) Mumbai Discoms              | 51.041         | 1430.363         |
| 1) Thermal          | 229.285        | 5869.397        | <b>TOTAL STATE</b>             | <b>428.991</b> | <b>11372.121</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 19.232         | 555.560         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 7.870          | 241.826         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 11.344         | 697.892         |                                |                |                  |
| 6) SOLAR            | 4.869          | 149.578         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>272.600</b> | <b>7514.253</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 11 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4589                      | 4531                  | 5002                      | 4657                      |
| MSPGCL Hydro             | 369                       | 395                   | 1311                      | 538                       |
| MSPGCL Gas               | 237                       | 216                   | 305                       | 210                       |
| MSPGCL Total Generation  | 5195                      | 5142                  | 6618                      | 5405                      |
| Central Sector Receipt   | 8096                      | 7833                  | 6322                      | 5351                      |
| WIND                     | 427                       | 368                   | 435                       | 501                       |
| CPP / IPP Thermal        | 3783                      | 3741                  | 3866                      | 3802                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 638                       | 714                   | 0                         | 0                         |
| Exchange with Mumbai     | -1062                     | -1473                 | -561                      | -594                      |
| <b>MSEDCL DEMAND MET</b> | <b>17077</b>              | <b>16325</b>          | <b>16680</b>              | <b>14465</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 17077                     | 16325                 | 16680                     | 14465                     |
| TPCL GENERATION          | 781                       | 527                   | 1236                      | 851                       |
| AEML GENERATION          | 490                       | 321                   | 497                       | 494                       |
| <b>MUMBAI DEMAND</b>     | <b>2333</b>               | <b>2321</b>           | <b>2294</b>               | <b>1939</b>               |
| STATE DEMAND MET         | 19410                     | 18646                 | 18974                     | 16404                     |
| <b>STATE DEMAND</b>      | <b>19410</b>              | <b>18646</b>          | <b>18974</b>              | <b>16404</b>              |
| Frequency (Hz)           | 50.02                     | 50.00                 | 50.03                     | 50.02                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.18 Hz at 18.02 Hrs | 49.88 Hz at 23.18 Hrs | 50.01         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 26/Sep/2021

| Generating unit    | Generation   |               |          |          |
|--------------------|--------------|---------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus) | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |               |          |          |
| Unit 6             | 3.03         | 54.04         | 175      | 0        |
| Unit 7             | 0.00         | 0.00          | 0        | 0        |
| Unit 8             | 11.78        | 203.25        | 540      | 440      |
| Unit 9             | 0.96         | 124.19        | 311      | 0        |
| Unit 10            | 8.87         | 230.72        | 375      | 365      |
| <b>Total</b>       | <b>24.64</b> | <b>612.20</b> |          |          |
| <b>Bhusawal</b>    |              |               |          |          |
| Unit 3             | 0.00         | 17.05         | 0        | 0        |
| Unit 4             | 9.70         | 220.42        | 425      | 380      |
| Unit 5             | 9.60         | 162.60        | 420      | 360      |
| <b>Total</b>       | <b>19.30</b> | <b>400.08</b> |          |          |
| <b>Parli</b>       |              |               |          |          |
| Unit 6             | 0.00         | 0.00          | 0        | 0        |
| Unit 7             | 4.39         | 92.07         | 248      | 169      |
| Unit 8             | 4.28         | 112.65        | 206      | 158      |
| <b>Total</b>       | <b>8.67</b>  | <b>204.72</b> |          |          |
| <b>Chandrapur</b>  |              |               |          |          |
| Unit 3             | 0.00         | 11.53         | 0        | 0        |
| Unit 4             | 0.00         | 25.91         | 0        | 0        |
| Unit 5             | 5.97         | 157.95        | 290      | 225      |
| Unit 6             | 5.21         | 108.37        | 300      | 150      |
| Unit 7             | 6.69         | 182.58        | 313      | 253      |
| Unit 8             | 6.97         | 220.34        | 350      | 270      |
| Unit 9             | 6.84         | 153.12        | 360      | 242      |
| <b>Total</b>       | <b>31.67</b> | <b>859.79</b> |          |          |
| <b>Paras</b>       |              |               |          |          |
| Unit 3             | 3.97         | 29.78         | 202      | 116      |
| Unit 4             | 1.44         | 100.09        | 193      | 0        |
| <b>Total</b>       | <b>5.40</b>  | <b>129.88</b> |          |          |
| <b>Khaparkheda</b> |              |               |          |          |
| Unit 1             | 2.48         | 29.93         | 110      | 100      |
| Unit 2             | 2.70         | 40.99         | 120      | 110      |
| Unit 3             | 3.15         | 84.98         | 150      | 122      |
| Unit 4             | 3.24         | 84.64         | 165      | 130      |
| Unit 5             | 7.44         | 176.49        | 325      | 285      |
| <b>Total</b>       | <b>19.01</b> | <b>417.03</b> |          |          |
| <b>Nasik</b>       |              |               |          |          |
| Unit 3             | 0.00         | 0.00          | 0        | 0        |
| Unit 4             | 3.91         | 66.40         | 180      | 130      |
| Unit 5             | 0.00         | 39.67         | 0        | 0        |
| <b>Total</b>       | <b>3.91</b>  | <b>106.06</b> |          |          |
| <b>Uran</b>        |              |               |          |          |
| All Units          | 5.38         | 169.37        | 305      | 166      |
| <b>Total</b>       | <b>5.38</b>  | <b>169.37</b> |          |          |
| <b>PGPL</b>        |              |               |          |          |
| Unit 1             | 0.00         | 0.00          | 0        | 0        |
| Unit 2             | 0.00         | 0.00          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>   |          |          |
| <b>PENCH (MS)</b>  |              |               |          |          |
| Pench (MS)         | 0.08         | 7.72          | 16       | 0        |
| <b>Total</b>       | <b>0.08</b>  | <b>7.72</b>   |          |          |
| <b>Koyna</b>       |              |               |          |          |

| Generating unit | Generation   |                |          |          |
|-----------------|--------------|----------------|----------|----------|
|                 | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 1-2       | 2.94         | 89.83          | 440      | 40       |
| Stage 4         | 4.01         | 124.28         | 588      | 0        |
| Stage 3         | 1.90         | 55.08          | 240      | 0        |
| <b>Total</b>    | <b>8.86</b>  | <b>269.19</b>  |          |          |
| <b>Hydro</b>    |              |                |          |          |
| KDPH            | 0.00         | 4.44           | 0        | 0        |
| VTRNA           | 0.64         | 7.50           | 60       | 0        |
| TILLARI         | 0.54         | 7.03           | 40       | 0        |
| BHIRA T.R.      | 0.36         | 9.89           | 40       | 0        |
| SMLHY_PTN       | 6.00         | 141.20         | 263      | 237      |
| GHATGHAR        | 0.12         | 16.78          | 83       | 0        |
| <b>Total</b>    | <b>7.66</b>  | <b>186.84</b>  |          |          |
| <b>Wind</b>     |              |                |          |          |
| Total           | 11.34        | 697.89         | 0        | 0        |
| <b>Total</b>    | <b>11.34</b> | <b>697.89</b>  |          |          |
| <b>CPP</b>      |              |                |          |          |
| APML(Mus)       | 46.78        | 1276.19        | 0        | 0        |
| JSWEL(Mus)      | 13.81        | 343.24         | 0        | 0        |
| VIPL(Mus)       | 0.00         | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 19.13        | 589.44         | 0        | 0        |
| SWPGPL-Mus      | 6.01         | 140.62         | 0        | 0        |
| Other(Mus)      | 4.88         | 145.14         | 0        | 0        |
| <b>Total</b>    | <b>90.61</b> | <b>2494.64</b> |          |          |
| <b>SOLAR</b>    |              |                |          |          |
| Total           | 4.87         | 149.58         | 0        | 0        |
| <b>Total</b>    | <b>4.87</b>  | <b>149.58</b>  |          |          |
| <b>Tata</b>     |              |                |          |          |
| Trombay 5       | 10.18        | 233.36         | 484      | 279      |
| Trombay 6       | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A      | 1.38         | 44.68          | 75       | 53       |
| Trombay 7B      | 1.11         | 27.78          | 54       | 43       |
| Trombay 8       | 4.90         | 122.87         | 225      | 137      |
| TATA Hydro      | 2.72         | 99.53          | 424      | 0        |
| <b>Total</b>    | <b>20.29</b> | <b>528.21</b>  |          |          |
| <b>AEMIL</b>    |              |                |          |          |
| DTPS U-1&2      | 10.98        | 288.77         | 499      | 314      |
| <b>Total</b>    | <b>10.98</b> | <b>288.77</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 112.62      | 2729.76       | MSPGCL Total        | 134.51      | 3355.16       |
|                |             |         | MSPGCL Thml+Gas | 118.00      | 2899.13       | Koyna 1,2 & 4 Total | 6.96        | 214.11        |
|                |             |         | MSPGCL Hydro    | 16.51       | 456.03        | State Total         | 272.60      | 7514.25       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 26/Sep/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |       |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|-------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY    | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4604        | 860   | 200  | 5664   | 624   | 3853      | 0    | 0     | 5211        | 5213        | -704                 | 14650                 | 0                    | 14650                     | 2162             | 16812           | 50.03         |
| 2                  | 4602        | 634   | 200  | 5436   | 595   | 3845      | 0    | 0     | 5357        | 5185        | -630                 | 14431                 | 0                    | 14431                     | 2037             | 16468           | 50.02         |
| 3                  | 4657        | 538   | 210  | 5405   | 501   | 3802      | 0    | 0     | 5153        | 5351        | -594                 | 14465                 | 0                    | 14465                     | 1939             | 16404           | 50.02         |
| 4                  | 4718        | 484   | 211  | 5413   | 444   | 3810      | 0    | 0     | 5554        | 5545        | -543                 | 14669                 | 0                    | 14669                     | 1854             | 16523           | 49.98         |
| 5                  | 4715        | 622   | 200  | 5537   | 420   | 3825      | 0    | 0     | 5630        | 5665        | -524                 | 14923                 | 0                    | 14923                     | 1837             | 16760           | 49.97         |
| 6                  | 4687        | 776   | 201  | 5664   | 514   | 3851      | 0    | 0     | 6303        | 6312        | -570                 | 15771                 | 0                    | 15771                     | 1891             | 17662           | 50.00         |
| 7                  | 4651        | 653   | 200  | 5504   | 592   | 3794      | 0    | 17    | 7135        | 7198        | -601                 | 16504                 | 0                    | 16504                     | 1902             | 18406           | 50.00         |
| 8                  | 4682        | 737   | 240  | 5659   | 557   | 3736      | 0    | 189   | 7393        | 7369        | -596                 | 16914                 | 0                    | 16914                     | 1951             | 18865           | 50.01         |
| 9                  | 4505        | 420   | 249  | 5174   | 505   | 3790      | 0    | 377   | 8060        | 7927        | -773                 | 17000                 | 0                    | 17000                     | 2069             | 19069           | 50.02         |
| 10                 | 4586        | 349   | 228  | 5163   | 436   | 3797      | 0    | 435   | 8270        | 8132        | -909                 | 17054                 | 0                    | 17054                     | 2220             | 19274           | 50.04         |
| 11                 | 4589        | 369   | 237  | 5195   | 427   | 3783      | 0    | 638   | 8069        | 8096        | -1062                | 17077                 | 0                    | 17077                     | 2333             | 19410           | 50.02         |
| 12                 | 4555        | 373   | 226  | 5154   | 446   | 3787      | 0    | 704   | 8291        | 8012        | -1496                | 16607                 | 0                    | 16607                     | 2356             | 18963           | 50.00         |
| 13                 | 4531        | 395   | 216  | 5142   | 368   | 3741      | 0    | 714   | 7820        | 7833        | -1473                | 16325                 | 0                    | 16325                     | 2321             | 18646           | 50.00         |
| 14                 | 4547        | 410   | 166  | 5123   | 474   | 3705      | 0    | 635   | 7354        | 7207        | -1318                | 15826                 | 0                    | 15826                     | 2246             | 18072           | 50.03         |
| 15                 | 4542        | 384   | 227  | 5153   | 427   | 3552      | 0    | 522   | 7621        | 7156        | -1308                | 15502                 | 0                    | 15502                     | 2178             | 17680           | 50.03         |
| 16                 | 4558        | 580   | 228  | 5366   | 437   | 3509      | 0    | 344   | 7191        | 6773        | -1222                | 15207                 | 0                    | 15207                     | 2135             | 17342           | 49.97         |
| 17                 | 4739        | 425   | 241  | 5405   | 446   | 3710      | 0    | 221   | 7242        | 6482        | -742                 | 15522                 | 0                    | 15522                     | 2120             | 17642           | 50.02         |
| 18                 | 4674        | 783   | 220  | 5677   | 410   | 3778      | 0    | 72    | 6961        | 6923        | -898                 | 15962                 | 0                    | 15962                     | 2107             | 18069           | 50.04         |
| 19                 | 4985        | 1431  | 277  | 6693   | 430   | 3856      | 0    | 1     | 6606        | 6416        | -672                 | 16724                 | 0                    | 16724                     | 2226             | 18950           | 50.03         |
| 20                 | 5002        | 1311  | 305  | 6618   | 435   | 3866      | 0    | 0     | 6457        | 6322        | -561                 | 16680                 | 0                    | 16680                     | 2294             | 18974           | 50.03         |
| 21                 | 5032        | 1150  | 252  | 6434   | 421   | 3863      | 0    | 0     | 5641        | 5280        | -561                 | 15437                 | 0                    | 15437                     | 2288             | 17725           | 50.01         |
| 22                 | 4779        | 1495  | 242  | 6516   | 471   | 3796      | 0    | 0     | 5301        | 5261        | -652                 | 15392                 | 0                    | 15392                     | 2249             | 17641           | 50.02         |
| 23                 | 4793        | 863   | 201  | 5857   | 460   | 3765      | 0    | 0     | 5530        | 5399        | -656                 | 14825                 | 0                    | 14825                     | 2177             | 17002           | 49.98         |
| 24                 | 4887        | 469   | 201  | 5557   | 504   | 3792      | 0    | 0     | 5429        | 5334        | -704                 | 14483                 | 0                    | 14483                     | 2149             | 16632           | 49.98         |
| MUs                | 112.62      | 16.51 | 5.38 | 134.51 | 11.34 | 90.61     | 0.00 | 4.87  | 159.58      | 156.39      | -19.77               | 377.95                | 0.00                 | 377.95                    | 51.04            | 428.99          | 50.01         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Sep/2021**

**Position as on 6.30 Hrs of 27/Sep/2021**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                            | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-----------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                             |               |
| MSPGCL                | Chandrapur Unit 3       | 210      | 04/09/2021   | 23.58        |            | Continued. | Annual Overhaul                                                             |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                             |               |
| IPP                   | SWPGPL U-1              | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                     |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule (NO PPA)                                                        |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule.(NO PPA)                                                        |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                      |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage. (NO PPA From 20.05.2019)                                     |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal shortage.(NO PPA From 20.05.2019)                                      |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                       |               |
| MSPGCL                | Koradi Unit 7           | 210      | 27/04/2021   | 20.03        |            | Continued. | Retired (04/08/2021 At 00.00)                                               |               |
| IPP                   | SWPGPL U-4              | 135      | 05/08/2021   | 03.04        |            | Continued. | Turbine Vibration High.                                                     |               |
| MSPGCL                | Parli Unit 6            | 250      | 26/08/2021   | 21.06        |            | Continued. | Coal Shortage (Converted to AOH 00.00Hrs from Dt.01/09/2021)                |               |
| MSPGCL                | Nasik Unit 3            | 210      | 30/08/2021   | 22.51        |            | Continued. | Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021 |               |
| IPP                   | JSW (J) U1              | 300      | 02/09/2021   | 08.41        |            | Continued. | Turbine vibrations high.                                                    |               |
| IPP                   | JSW (J) U3              | 300      | 07/09/2021   | 10.20        | 27/09/2021 | 05.11      | Non availability of load scheduling.                                        |               |
| MSPGCL                | Uran Unit A0            | 120      | 10/09/2021   | 01.54        |            | Continued. | Turbine bearing Vabration high                                              |               |
| MSPGCL                | Koradi Unit 9           | 660      | 15/09/2021   | 05.19        | 26/09/2021 | 19.12      | Air pre-heater work.                                                        |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 15/09/2021   | 23.54        |            | Continued. | Poor coal receipt                                                           |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 18/09/2021   | 03.30        |            | Continued. | Coal Shortage                                                               |               |
| IPP                   | Adani U-5               | 660      | 19/09/2021   | 03.47        |            | Continued. | Abnormal Sound in Turbine governing system.                                 |               |
| MSPGCL                | Nasik Unit 5            | 210      | 19/09/2021   | 20.50        |            | Continued. | Coal Shortage.                                                              |               |
| IPP                   | RPL(AMT) U-3            | 270      | 22/09/2021   | 03.54        |            | Continued. | Coal Shortage                                                               |               |
| IPP                   | RPL(AMT) U-5            | 270      | 23/09/2021   | 00.44        |            | Continued. | Bottom Ash Prob.(conv. to coal shortage 18.00hrs,28.09.2021)                |               |
| MSPGCL                | Uran Unit 5             | 108      | 25/09/2021   | 20.04        | 26/09/2021 | 18.17      | Gas shortage                                                                |               |
| MSPGCL                | Koradi Unit 6           | 210      | 25/09/2021   | 23.15        | 26/09/2021 | 02.06      | Flame Failure                                                               |               |
| MSPGCL                | Paras Unit 4            | 250      | 26/09/2021   | 07.47        |            | Continued. | Coal Shortage                                                               |               |
| MSPGCL                | Uran Unit 5             | 108      | 26/09/2021   | 20.23        |            | Continued. | Gas shortage.                                                               |               |
| MSPGCL                | Chandrapur Unit 7       | 500      | 27/09/2021   | 20.31        |            | Continued. | Feed Station Valve Leakage                                                  |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Sep/2021**

**Statement-VII**

Position as on 6.30 Hrs of 27/Sep/2021

| Name of Line                               | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                        |
|--------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                         |
| Karad Solapur (PG)                         | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 25/09/2021   | 20.27        | 27/09/2021 | 09.48      | HT          | Over Voltage                                                                                                            |
| Koradi 2-IEPL                              | IntraState                | 26/09/2021   | 07.00        |            | Continued. | PO          | For for height raising work across.                                                                                     |
| koaradi II - Wardha(PG)                    | IntraState                | 26/09/2021   | 07.29        |            | Continued. | PO          | For for height raising work across Samruddhi highway at chainage No.23+650 (tower no 192 & 193)                         |
| Khadka-Aurangabad (Waluj)                  | IntraState                | 27/09/2021   | 22.18        |            | Continued. | HT          | Over Voltage                                                                                                            |
| <b>400 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                         |
| 400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2 | IntraState                | 07/09/2021   | 20.23        |            | Continued. | T           | Differential protection.                                                                                                |
| 400/220/33 Kv 315 Mva Ict 2 @Koradi        | IntraState                | 27/09/2021   | 10.30        | 27/09/2021 | 16.00      | EO          | Attending Hot Spot                                                                                                      |
| <b>220 KV LINE Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                         |
| Mudshingi Chikodi                          | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                             |
| Talandage - Chikodi                        | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                  |
| PAL DOMBIVALI - PALAVA                     | IntraState                | 26/09/2021   | 10.20        | 26/09/2021 | 13.15      | PO          | Providing Additional Jumpers To Cut-point locations.                                                                    |
| Urse-Chinchwad (ST tap)                    | IntraState                | 26/09/2021   | 13.40        | 26/09/2021 | 19.55      | PO          | Relay Testing Work.                                                                                                     |
| Tata Borivli MSETCL Borivli 4              | IntraState                | 26/09/2021   | 20.49        |            | Continued. | PO          | for shifting to Spare bay in GIS.                                                                                       |
| Theur-Phursungi ckt-2                      | IntraState                | 27/09/2021   | 09.50        | 27/09/2021 | 17.50      | PO          | Testing of distance relay                                                                                               |
| Karad(400kv) - Ogalewadi Ckt 1             | IntraState                | 27/09/2021   | 10.07        | 27/09/2021 | 14.01      | PO          | Replacement of flashover insulator string at Loc no.3(B-ph) & 21(R-ph)                                                  |
| Adlabs - Pedambe                           | IntraState                | 27/09/2021   | 10.15        | 27/09/2021 | 18.20      | PO          | Routine maintenance & emergency tree cutting work                                                                       |
| Talandge(400kv)- Ichalkaranji ckt-1        | IntraState                | 27/09/2021   | 10.17        | 27/09/2021 | 15.15      | EO          | Attending Hot Spot                                                                                                      |
| Chalisgaon - Babhaleshwar                  | IntraState                | 27/09/2021   | 11.07        | 27/09/2021 | 15.45      | PO          | Nut bolt tightening of railway crossing tower                                                                           |
| Nanded - Parli Ext. Ckt II                 | IntraState                | 27/09/2021   | 12.12        | 27/09/2021 | 21.25      | PO          | Routine Maintenance Work                                                                                                |
| Bombay Dyeing - Sahara                     | IntraState                | 27/09/2021   | 13.09        | 27/09/2021 | 17.13      | T           | Distance Protection                                                                                                     |
| Apta - Hoc                                 | IntraState                | 27/09/2021   | 13.22        | 27/09/2021 | 15.17      | EO          | Attending Hot Spot on Y-phase jumper.                                                                                   |
| Talandge-Mudshingi Ckt-I                   | IntraState                | 27/09/2021   | 15.30        | 27/09/2021 | 18.55      | EO          | Jumper replacement work at tower Loc no.312, R-ph to Attending hot spot                                                 |
| 220KV Chalisagaon-Kopergaon                | IntraState                | 27/09/2021   | 17.23        | 27/09/2021 | 20.30      | PO          | Nut bolt tightening of railway crossing tower work.                                                                     |
| Adlabs - Pedambe                           | IntraState                | 27/09/2021   | 23.10        | 27/09/2021 | 23.55      | T           | Distance Protection                                                                                                     |
| <b>220 KV ICT Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                         |
| 220/22kV 100MVA T/F-I @ Nalasopara         | IntraState                | 26/09/2021   | 10.16        | 26/09/2021 | 13.05      | PO          | Replacement of deteriorated HV Breaker to Isolator-D Y-phase Jumper & also attending hot Spot of LV-2 B-Ph drop jumper. |
| 220/100 Kv 200 Mva ICT III @Kalwa          | IntraState                | 27/09/2021   | 13.05        | 27/09/2021 | 19.10      | PO          | Diagnostic & Routine maintenance work                                                                                   |
| 220/100 Kv 200 Mva Aval Ict 2 @Taloja      | IntraState                | 27/09/2021   | 14.58        | 27/09/2021 | 16.52      | PO          | Attending urgent oil leakages of B-phase HV CT.                                                                         |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage