

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 26/Sep/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	126.760	2958.587	1) Gujrat	11.231	256.512
2) Hydro	9.690	298.377	2) Madhya Pradesh	9.701	115.283
3) Gas	1.901	67.643	3) Chattisgarh	4.550	94.950
Total MSPGCL	138.351	3324.607	4) Maharashtra	152.240	3887.932
B) 1) APLM	63.240	1630.646	5) Goa (Amona)	-1.384	-31.399
2) JSWEL	19.001	467.839	Total	176.338	4323.278
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.274	842.277
4) RPL(AMT)	19.550	431.847	b) Mumbai Drawl	35.211	929.399
5) SWPGPL	7.351	123.378	c) MSEDCL Bilateral *	60.716	1506.872
6) Other IPP	5.019	143.962	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.274	842.062
C) 1) TPCL Thermal	10.305	289.795	Include PX	0.000	0.000
2) TPCL Hydro	3.718	132.126	Standby	0.000	0.215
3) TPCL Gas	3.005	16.885	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.810	231.144	1) MSEDCL	402.879	10074.173
D) STATE			2) Mumbai Discoms	61.049	1599.350
1) Thermal	260.036	6277.198	3) Other Discoms	9.254	233.682
(A1+C1+C4+(B1-B6))			TOTAL STATE	473.182	11907.205
2) Hydro (A2+C2)	13.408	430.503			
3) Gas (A3+B7+C3)	4.906	84.528			
4) Wind	9.567	562.401			
6) SOLAR	8.927	229.296			
TOTAL STATE	296.844	7583.926			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5433	5235	5678	5024
MSPGCL Hydro	560	276	1194	238
MSPGCL Gas	87	86	86	89
MSPGCL Total Generation	6080	5597	6958	5351
Central Sector Receipt	8968	8524	6376	6153
WIND	187	198	638	287
CPP / IPP Thermal	4380	4408	5745	4332
CPP / IPP Gas	0	0	0	0
SOLAR	1044	1167	0	0
Exchange with Mumbai	-1944	-2048	-1305	-1063
MSEDCL DEMAND MET	18296	17432	17986	14752
Load Shedding	0	0	0	0
MSEDCL DEMAND	18296	17432	17986	14752
TPCL GENERATION	608	586	1137	621
AEML GENERATION	387	310	488	297
MUMBAI DEMAND	2939	2944	2930	1981
OTHER DISCOM DEMAND	419	414	426	308
STATE DEMAND MET	21654	20790	21342	17041
STATE DEMAND	21654	20790	21342	17041
Frequency (Hz)	49.91	50.02	49.99	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 13.00 Hrs	49.56 Hz at 18.26 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 26/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	9.55	253.99	465	279
Unit 9	9.38	48.46	435	301
Unit 10	9.24	258.59	460	302
Total	28.17	600.39		
Bhusawal				
Unit 3	1.86	57.75	130	0
Unit 4	7.92	214.11	425	205
Unit 5	9.66	65.67	450	320
Total	19.45	337.53		
Parli				
Unit 6	4.76	112.07	227	155
Unit 7	4.46	92.91	209	151
Unit 8	3.62	95.72	180	126
Total	12.85	300.70		
Chandrapur				
Unit 3	3.25	76.09	155	125
Unit 4	3.07	77.97	153	113
Unit 5	7.19	141.55	340	280
Unit 6	7.35	148.43	370	275
Unit 7	7.29	151.79	326	281
Unit 8	0.00	49.00	0	0
Unit 9	9.45	240.64	435	301
Total	37.61	885.46		
Paras				
Unit 3	4.82	114.83	227	158
Unit 4	0.00	86.15	0	0
Total	4.82	200.98		
Khaparkheda				
Unit 1	3.00	68.81	135	115
Unit 2	0.04	38.86	25	0
Unit 3	3.46	81.74	166	126
Unit 4	3.20	77.68	147	122
Unit 5	8.32	209.55	420	260
Total	18.03	476.64		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.86	51.11	136	99
Unit 5	2.97	73.22	137	115
Total	5.83	156.89		
Uran				
All Units	1.90	67.64	89	0
Total	1.90	67.64		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	13.30	26	24
Total	0.60	13.30		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.54	57.40	380	35
Stage 4	1.99	47.42	580	0
Stage 3	1.00	27.51	240	0
Total	5.54	132.33		
Hydro				
KDPH	0.43	6.55	18	18
VTRNA	0.50	19.47	60	0
TILLARI	0.52	12.40	58	0
BHIRA T.R.	0.21	10.25	40	0
SMLHY_PTN	1.87	98.70	85	69
GHATGHAR	0.03	5.38	29	0
Total	3.56	152.76		
Wind				
Total	9.57	562.40	0	0
Total	9.57	562.40		
CPP				
APML(Mus)	63.24	1630.65	0	0
JSWEL(Mus)	19.00	467.84	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.55	431.85	0	0
SWPGPL-Mus	7.35	123.38	0	0
Other(Mus)	5.02	143.96	0	0
Total	114.16	2797.67		
SOLAR				
Total	8.93	229.30	0	0
Total	8.93	229.30		
Tata				
Trombay 5	6.95	194.94	430	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.83	10.95	115	41
Trombay 7B	1.18	5.93	66	6
TATA Hydro	3.72	132.13	423	21
Trombay 8	3.36	94.85	209	130
Total	17.03	438.81		
AEMIL				
DTPS U-1&2	8.81	231.14	499	281
Total	8.81	231.14		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	126.76	2958.59	MSPGCL Total	138.35	3324.61
			MSPGCL Thml+Gas	128.66	3026.23	Koyna 1,2 & 4 Total	4.54	104.82
			MSPGCL Hydro	9.69	298.38	State Total	296.84	7583.93

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 26/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4667	449	89	5205	361	4223	0	0	6269	6679	-1200	14931	0	14931	2130	337	17398	50.00
2	5024	238	89	5351	287	4332	0	0	6235	6153	-1063	14752	0	14752	1981	308	17041	50.01
3	5203	164	89	5456	328	4564	0	0	6145	6077	-979	15154	0	15154	1878	292	17324	50.02
4	5195	159	89	5443	366	4414	0	0	6362	6069	-921	15081	0	15081	1819	290	17190	50.01
5	5341	160	89	5590	405	4609	0	0	6530	6452	-909	15841	0	15841	1808	306	17955	50.02
6	5341	159	33	5533	376	4769	0	1	7169	7002	-987	16358	0	16358	1929	336	18623	50.00
7	5487	899	0	6386	304	4942	0	52	7149	7364	-1131	17541	0	17541	2126	376	20043	49.97
8	5538	480	51	6069	244	5154	0	322	8047	8124	-1391	18131	0	18131	2335	391	20857	50.00
9	5436	639	82	6157	170	4435	0	719	8532	8521	-1742	17847	0	17847	2699	413	20959	49.90
10	5433	560	87	6080	187	4380	0	1044	8983	8968	-1944	18296	0	18296	2939	419	21654	49.91
11	5361	362	86	5809	138	4454	0	1188	9458	9033	-1980	18209	0	18209	2973	433	21615	49.99
12	5136	279	87	5502	152	4431	0	1174	9457	9155	-2149	17832	0	17832	3114	433	21379	50.00
13	5235	276	86	5597	198	4408	0	1167	8800	8524	-2048	17432	0	17432	2944	414	20790	50.02
14	5062	270	85	5417	321	4444	0	1212	8536	8003	-2011	16983	0	16983	2865	403	20251	50.04
15	4808	268	83	5159	376	4366	0	996	8715	8577	-1994	17074	0	17074	2897	406	20377	50.00
16	4913	272	83	5268	465	4261	0	628	8530	8661	-1956	16908	0	16908	2923	419	20250	50.01
17	5362	268	84	5714	569	4509	0	308	8099	8031	-1861	16844	0	16844	2930	426	20200	49.99
18	5481	279	84	5844	564	5132	0	113	7415	7312	-1661	16874	0	16874	2891	430	20195	49.93
19	5612	1188	85	6885	622	5745	0	3	6671	6586	-1431	17992	0	17992	2925	418	21335	49.81
20	5678	1194	86	6958	638	5745	0	0	6710	6376	-1305	17986	0	17986	2930	426	21342	49.99
21	5652	419	88	6159	668	5746	0	0	6337	5945	-1131	16954	0	16954	2709	433	20096	50.03
22	5443	252	88	5783	654	5606	0	0	6116	6050	-1135	16564	0	16564	2556	394	19514	50.03
23	5156	159	89	5404	632	4843	0	0	6526	6576	-1185	15880	0	15880	2428	390	18698	50.02
24	5196	297	89	5582	542	4649	0	0	6000	6100	-1097	15414	0	15414	2320	362	18096	50.00
MUs	126.76	9.69	1.90	138.35	9.57	114.16	0.00	8.93	178.79	176.34	-35.21	402.88	0.00	402.88	61.05	9.25	473.18	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 26/Sep/2022

Position as on 6.30 Hrs of 27/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-1	270	08/09/2022	11:58	26/09/2022	16:59	Furnace Pressure High(under coal shortage wef 18:00hrs of 10.09.22)	28/09/2022
MSPGCL	Uran Unit 5	108	11/09/2022	21:03	27/09/2022	10:07	Gas shortage	
TPC-G	Trombay 7B	60	14/09/2022	05:50	26/09/2022	00:33	Gas shortage	
MSPGCL	Khaparkheda Unit 2	210	17/09/2022	13:00	26/09/2022	22:30	wet coal	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022
MSPGCL	Uran Unit 6	108	26/09/2022	05:33	26/09/2022	07:08	Gas shortage	26/09/2022
MSPGCL	Bhusawal Unit 3	210	26/09/2022	16:08		Continued.	Boiler Tube Leakage	30/09/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 26/Sep/2022

Position as on 6.30 Hrs of 27/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	27/09/2022	10:32		Continued.	HOT SPOT IN SWITCHYARD	29/09/2022
MSPGCL	Chandrapur Unit 5	500	27/09/2022	17:30		Continued.	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/09/2022	00:39	26/09/2022	03:41	EO	A] HVDC TL O&M Sub-Division, Babhaleshwar:- 1. Cold line washing of bird shit insulator string at Loc No. 1441.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/09/2022	00:45	27/09/2022	06:49	EO	A] HVDC TL O&M Sub-Division, Babhaleshwar:- 1. Cold line washing of bird shit insulator string at Loc No. 1436 to 1439 = 4 Locs.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/09/2022	00:45	27/09/2022	06:49	HT	EMERGENCY OUTAGE AVAILABLE FOR COLD LINE WASHING OF INSULATOR STRINGS.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
KORADI 2-WARDHA (PG)	InterState	21/09/2022	08:55	26/09/2022	18:31	PO	Diversion of 400 kV Koradi- Wardha Line through 6 nos of Newly constructed tower of POWERGRID. Configuration of 400 kV Koradi Bays at Wardha shall remain the same. MSETCL 400 kV IEPL-Warora Line shall be in non- A/R Mode for safety precautions
KORADI - SATPUR	InterState	26/09/2022	08:53	26/09/2022	18:35	HT	OUTAGE AVAILABLE FOR JUMPER REPLACEMENT WORK
KHADKA-AURANGABAD (WALUJ)	IntraState	25/09/2022	20:58	26/09/2022	06:53	HT	H/T for Over Voltage.
KHADKA-AURANGABAD (WALUJ)	IntraState	26/09/2022	22:39	27/09/2022	07:44	HT	H/T FOR O/V
KARAD - TALANDGE CKT - 1	IntraState	27/09/2022	09:33	27/09/2022	16:45	PO	1. Quarterly Maintenance of bay 2. Annual testing of bay
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	26/09/2022	10:45	26/09/2022	19:31	PO	1) HV breaker and IV CTs Testing work.(2) Bay maintenance work.
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32				Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
105 MVA SPARE ICT @ CHAKAN	IntraState	26/09/2022	11:46	26/09/2022	17:29	PO	Diagnostic Testing and maintenance
400/220 KV 500 MVA ICT @ ALKUD	IntraState	27/09/2022	14:12	27/09/2022	19:45	PO	Replacement work of TCIV of all 3 Phases of ICT
220 KV MAINBAY Outages/Trippings							
TBC @ BHOSARI-1	IntraState	26/09/2022	11:05	27/09/2022	19:03	PO	CT erection work at 220kV TBC Bay
TBC @ BHOSARI-1	IntraState	27/09/2022	00:45	27/09/2022	19:03	EO	CT erection work at 220kV TBC Bay
220 KV LINE Outages/Trippings							
KHARGHAR - BORIVALI CKT - 2	IntraState	25/09/2022	20:36	26/09/2022	09:18	PO	Outage required for safety purpose To carry out the work of making LILO arrangement at Loc no. 40 of 220KV Kalwa-TFIPL Line as both lines are on same M/C tower.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - TFIPL	IntraState	25/09/2022	20:54	26/09/2022	10:31	PO	For removing of bunching arrangement at Loc no.45 and connecting jumpers at Loc no.45 to newly proposed 220/22KV GIS S/stn at Pawane Mahape.
KHARGHAR - NET MAGIC GIS	IntraState	26/09/2022	04:03	26/09/2022	09:20	PO	Outage required for safety purpose To carry out the work of making LILO arrangement at Loc no. 40 of 220KV Kalwa-TFIPL Line as both lines are on same M/C tower.
EKLAHARE (OCR) - PADGHE	IntraState	26/09/2022	07:44			HT	for load management on Nashik BBLR
KARAD - VITA CKT- 1	IntraState	26/09/2022	09:10	26/09/2022	16:11	PO	Insulator string replacement work at STN LILO Loc No. 27 R, 65 R, 76 B. SSN LILO Loc No.44 Y, 62 B, 64 B LILO Loc No.01 T replacement
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	26/09/2022	09:59	26/09/2022	21:04	HT	For Load management
PEDAMBE-KALAMBANI(TSS)	IntraState	26/09/2022	10:50	26/09/2022	12:40	PO	Bypassed Y phase LA replacement of 220KV Pedhambe line Bay at Kalambani TSS end & Maintenance work.
PARGAON(KATHAPUR)- LONIKAND	IntraState	26/09/2022	11:55	26/09/2022	16:55	PO	Sf6 gas leakage attending work in CB
KANDALGAON - PIRANGUT	IntraState	26/09/2022	13:13	26/09/2022	19:39	EO	Dismantling of hanging conductor piece from double conductor by restringing new conductor at Loc.No.01 to gantry near kgaon SS.
TROMBAY - CARNAC - 7	IntraState	26/09/2022	20:30	26/09/2022	21:45	EO	For Test Charging of 220 KV NEW SIEMENS make breaker of Trombay Carnac-7 line after replacement at Trombay generating station.
BUS SECTION-6 @ TROMBAY	IntraState	26/09/2022	23:10	27/09/2022	06:30	EO	for connecting Trombay Carnac -7 Main bus isolator jumper after breaker replacement work.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	26/09/2022	23:15	27/09/2022	02:32	T	TRIPPED ON DISTANCE PROTECTION.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	27/09/2022	08:21	27/09/2022	21:47	HT	for load management
MAHAPE - TFIPL	IntraState	27/09/2022	09:15	27/09/2022	12:17	EO	Line Breaker B-Phase Pole Nut bolts having hotspot
TPC BORIVALI - AAREY	IntraState	27/09/2022	09:23	27/09/2022	19:04	PO	Under MMRC Line Diversion scheme for Metro-3 project Tighting of jumper connection loose connection observed during routine inspection.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	27/09/2022	10:45	27/09/2022	16:29	HT	for load management
THEUR-JEJURI	IntraState	27/09/2022	11:06	27/09/2022	17:25	PO	LA'S JUMP CRIMPING WORK AT JEJURI END
MAIN BUS - 1 @ AAREY	IntraState	27/09/2022	12:16	27/09/2022	17:57	EO	During outage of 220 kv Aarey & TPC Borivali Line, it is observed that 1089-A Isolator is not getting opened With thorough investigation, it is observed that the pin of isolator is broken and unable to open. Outage required to rectify the same.
220 KV ICT Outages/Trippings							
220 / 110 / 22KV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 26/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 27/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132KV 100MVA PTR 2 @ KHAREPATAN	IntraState	26/09/2022	08:10	26/09/2022	09:26	T	Tripped on PRV. Charged with PRV disconnected.
220/33 KV 50 MVA PTR NO 1 @ BHIGWAN	IntraState	26/09/2022	10:05	26/09/2022	19:15	PO	Oil leakage attending work.
220/33 KV 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	26/09/2022	10:34	26/09/2022	16:42	PO	HV Breaker Overhauling work in presence of M/S Siemens engineer,
220/110 KV 200 MVA ICT 2 @ MUDSHINGI	IntraState	27/09/2022	09:45	27/09/2022	17:55	PO	HV breaker overhauling in presence of M/S Siemens Engineer & Quarterly Maintenance work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	27/09/2022	11:27	27/09/2022	19:57	PO	Relay Testing work. Routine maintenance work.
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	27/09/2022	11:57	27/09/2022	12:50	PO	for CB Timing measurment
220/33 KV 50MVA PTR 2 @ JEJURI	IntraState	27/09/2022	12:46		Continued.	PO	HV SIDE BUS ISOLATOR REPLACEMENT WORK.
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	27/09/2022	13:08	27/09/2022	13:59	PO	for CB Timing measurment
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	27/09/2022	14:13	27/09/2022	14:59	PO	for CB Timing measurment
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	27/09/2022	15:08	27/09/2022	15:52	PO	for CB Timing measurment
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage