

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Oct/2024 SATURDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 141.067        | 3794.303        | 1) Gujrat                      | 1.970          | 191.643          |
| 2) Hydro            | 6.503          | 220.194         | 2) Madhya Pradesh              | 3.412          | 95.854           |
| 3) Gas              | 6.849          | 170.573         | 3) Chattisgarh                 | 5.720          | 100.050          |
| <b>Total MSPGCL</b> | <b>154.419</b> | <b>4185.070</b> | 4) Maharashtra                 | 206.534        | 5173.933         |
| B) 1) APML          | 56.158         | 1477.838        | 5) Goa (Amona)                 | -2.706         | -59.476          |
| 2) JSWEL            | 25.424         | 644.740         | <b>Total</b>                   | <b>214.930</b> | <b>5502.004</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 48.391         | 1279.249         |
| 4) RPL(AMT)         | 24.527         | 493.360         | b) Mumbai Drawl                | 50.602         | 1354.014         |
| 5) SWPGPL           | 8.804          | 232.701         | c) MSEDCL Bilateral *          | 99.896         | 2338.061         |
| 6) Other IPP        | 9.286          | 272.320         | Include PX                     | 0.000          | 0.000            |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 48.391         | 1274.916         |
| C) 1) TPCL Thermal  | 4.326          | 114.411         | Include PX                     | 0.000          | 0.000            |
| 2) TPCL Hydro       | 3.651          | 100.485         | Standby                        | 0.000          | 4.334            |
| 3) TPCL Gas         | 4.208          | 108.971         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 7.804          | 221.959         | 1) MSEDCL                      | 458.852        | 11820.688        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 70.591         | 1899.828         |
| 1) Thermal          | 277.396        | 7251.632        | 3) Other Discoms               | 12.090         | 317.709          |
| (A1+C1+C4+(B1-B6))  |                |                 | <b>TOTAL STATE</b>             | <b>541.533</b> | <b>14038.225</b> |
| 2) Hydro            | 10.154         | 320.679         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 11.057         | 279.544         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 6.144          | 207.361         |                                |                |                  |
| 6) SOLAR            | 21.852         | 477.017         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>326.603</b> | <b>8536.233</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS                | A. Morning Peak at 11 Hrs | B. Day Peak at 18 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 4 Hrs |
|----------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal             | 4875                      | 6163                  | 6200                      | 6056                      |
| MSPGCL Hydro               | 241                       | 177                   | 918                       | 163                       |
| MSPGCL Gas                 | 288                       | 276                   | 277                       | 292                       |
| MSPGCL Total Generation    | 5404                      | 6616                  | 7395                      | 6511                      |
| Central Sector Receipt     | 9558                      | 9848                  | 10182                     | 7741                      |
| WIND                       | 300                       | 174                   | 274                       | 310                       |
| CPP / IPP Thermal          | 4456                      | 6162                  | 6211                      | 4783                      |
| CPP / IPP Gas              | 0                         | 0                     | 0                         | 0                         |
| SOLAR                      | 2855                      | 181                   | 1                         | 0                         |
| Exchange with Mumbai       | -2363                     | -2355                 | -2157                     | -1620                     |
| <b>MSEDCL DEMAND MET</b>   | <b>19653</b>              | <b>20078</b>          | <b>21346</b>              | <b>17337</b>              |
| Load Shedding              | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND              | 19653                     | 20078                 | 21346                     | 17337                     |
| TPCL GENERATION            | 522                       | 580                   | 790                       | 436                       |
| AEML GENERATION            | 322                       | 313                   | 332                       | 328                       |
| <b>MUMBAI DEMAND</b>       | <b>3207</b>               | <b>3248</b>           | <b>3279</b>               | <b>2384</b>               |
| <b>OTHER DISCOM DEMAND</b> | <b>557</b>                | <b>548</b>            | <b>560</b>                | <b>388</b>                |
| STATE DEMAND MET           | 23417                     | 23874                 | 25185                     | 20109                     |
| <b>STATE DEMAND</b>        | <b>23417</b>              | <b>23874</b>          | <b>25185</b>              | <b>20109</b>              |
| Frequency (Hz)             | 50.00                     | 49.96                 | 49.97                     | 49.97                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.4 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.15 Hz at 06:02 Hrs | 49.82 Hz at 18:14 Hrs | 49.99         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

## Daily and Progressive Generation,Maximum,Minimum for 26/Oct/2024

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.87         | 86.15          | 178      | 121      |
| Unit 8             | 0.00         | 273.06         | 0        | 0        |
| Unit 9             | 11.57        | 303.79         | 547      | 391      |
| Unit 10            | 11.73        | 300.32         | 540      | 385      |
| <b>Total</b>       | <b>27.17</b> | <b>963.31</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 67.40          | 0        | 0        |
| Unit 4             | 9.50         | 197.66         | 495      | 285      |
| Unit 5             | 8.98         | 219.10         | 480      | 280      |
| <b>Total</b>       | <b>18.47</b> | <b>484.15</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 6             | 4.09         | 99.04          | 236      | 143      |
| Unit 7             | 0.37         | 85.92          | 166      | 0        |
| Unit 8             | 4.05         | 99.32          | 216      | 148      |
| <b>Total</b>       | <b>8.51</b>  | <b>284.28</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.32         | 80.22          | 160      | 120      |
| Unit 4             | 3.54         | 81.33          | 159      | 130      |
| Unit 5             | 7.30         | 197.86         | 380      | 125      |
| Unit 6             | 6.85         | 118.41         | 350      | 250      |
| Unit 7             | 8.45         | 196.33         | 404      | 283      |
| Unit 8             | 8.76         | 248.36         | 458      | 285      |
| Unit 9             | 5.93         | 92.36          | 495      | 0        |
| <b>Total</b>       | <b>44.15</b> | <b>1014.86</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 4.61         | 116.72         | 224      | 143      |
| Unit 4             | 4.32         | 109.32         | 221      | 143      |
| <b>Total</b>       | <b>8.93</b>  | <b>226.04</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.92         | 78.89          | 195      | 115      |
| Unit 2             | 4.17         | 101.62         | 191      | 119      |
| Unit 3             | 3.92         | 92.32          | 172      | 133      |
| Unit 4             | 4.20         | 105.18         | 190      | 130      |
| Unit 5             | 10.90        | 251.25         | 495      | 300      |
| <b>Total</b>       | <b>27.11</b> | <b>629.26</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 3.40         | 84.93          | 161      | 118      |
| Unit 4             | 3.32         | 83.04          | 157      | 124      |
| Unit 5             | 0.00         | 24.42          | 0        | 0        |
| <b>Total</b>       | <b>6.72</b>  | <b>192.39</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.85         | 170.57         | 298      | 272      |
| <b>Total</b>       | <b>6.85</b>  | <b>170.57</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.50         | 20.08          | 53       | 0        |
| <b>Total</b>       | <b>0.50</b>  | <b>20.08</b>   |          |          |
| <b>Koyna</b>       |              |                |          |          |
| Stage 1-2          | 1.82         | 48.48          | 165      | 40       |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| Stage 4         | 0.41          | 31.19          | 403      | 0        |
| Stage 3         | 0.44          | 18.60          | 240      | 0        |
| <b>Total</b>    | <b>2.67</b>   | <b>98.28</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.00          | 9.31           | 0        | 0        |
| VTRNA           | 0.00          | 0.00           | 0        | 0        |
| TILLARI         | 0.23          | 6.95           | 57       | 0        |
| BHIRA T.R.      | 0.34          | 7.36           | 40       | 0        |
| SMLHY_PTN       | 2.95          | 90.11          | 129      | 114      |
| GHATGHAR        | 0.31          | 8.18           | 125      | 0        |
| <b>Total</b>    | <b>3.83</b>   | <b>121.92</b>  |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.14          | 207.36         | 0        | 0        |
| <b>Total</b>    | <b>6.14</b>   | <b>207.36</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 56.16         | 1477.84        | 0        | 0        |
| JSWEL(Mus)      | 25.42         | 644.74         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT-Mus      | 24.53         | 493.36         | 0        | 0        |
| SWPGPL-Mus      | 8.80          | 232.70         | 0        | 0        |
| Dhariwal        | 0.00          | 0.00           | 0        | 0        |
| IEPL            | 5.53          | 146.57         | 269      | 183      |
| Other(Mus)      | 0.50          | 11.57          | 0        | 0        |
| JPL             | 3.25          | 114.17         | 138      | 133      |
| <b>Total</b>    | <b>124.20</b> | <b>3120.96</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 21.85         | 477.02         | 0        | 0        |
| <b>Total</b>    | <b>21.85</b>  | <b>477.02</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 0.00          | 0.00           | 0        | 0        |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.67          | 68.96          | 112      | 111      |
| Trombay 7B      | 1.54          | 40.02          | 65       | 64       |
| TATA Hydro      | 3.65          | 100.48         | 396      | 55       |
| Trombay 8       | 4.33          | 114.41         | 225      | 150      |
| <b>Total</b>    | <b>12.18</b>  | <b>323.87</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 7.80          | 221.96         | 458      | 300      |
| <b>Total</b>    | <b>7.80</b>   | <b>221.96</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 141.07      | 3794.30       | MSPGCL Total        | 154.42      | 4185.07       |
|                |             |         | MSPGCL Thml+Gas | 147.92      | 3964.88       | Koyna 1,2 & 4 Total | 2.24        | 79.67         |
|                |             |         | MSPGCL Hydro    | 6.50        | 220.19        | State Total         | 326.60      | 8536.23       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 26/Oct/2024

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLA<br>R | CS<br>SHAR<br>E | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDC<br>L DEM.<br>MET | Load<br>Shedding |                                         | MSEDC<br>L DEM.<br>WITH<br>LS | MUMBAI<br>DEMAN<br>D | OTHER<br>DISCOM<br>DEMAN<br>D | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-----------|-----------------|-------------|----------------------|------------------------|------------------|-----------------------------------------|-------------------------------|----------------------|-------------------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |           |                 |             |                      |                        | Planne<br>d      | *Trans<br>missio<br>n<br>Constr<br>aint |                               |                      |                               |                 |               |
| 1                  | 6576        | 168  | 291  | 7035   | 158  | 5268      | 0    | 0         | 8222            | 7924        | -2093                | 17806                  | 0                | 0                                       | 17806                         | 2951                 | 486                           | 21243           | 50.00         |
| 2                  | 6256        | 163  | 291  | 6710   | 253  | 4943      | 0    | 0         | 8223            | 8129        | -1879                | 17719                  | 0                | 0                                       | 17719                         | 2704                 | 437                           | 20860           | 50.01         |
| 3                  | 6123        | 168  | 291  | 6582   | 331  | 4991      | 0    | 0         | 7882            | 7662        | -1724                | 17423                  | 0                | 0                                       | 17423                         | 2509                 | 419                           | 20351           | 50.03         |
| 4                  | 6056        | 163  | 292  | 6511   | 310  | 4783      | 0    | 0         | 7774            | 7741        | -1620                | 17337                  | 0                | 0                                       | 17337                         | 2384                 | 388                           | 20109           | 49.97         |
| 5                  | 6309        | 168  | 292  | 6769   | 321  | 5041      | 0    | 0         | 7665            | 8074        | -1549                | 18265                  | 0                | 0                                       | 18265                         | 2321                 | 391                           | 20977           | 49.97         |
| 6                  | 6589        | 168  | 292  | 7049   | 354  | 5121      | 0    | 0         | 8557            | 8608        | -1589                | 19114                  | 0                | 0                                       | 19114                         | 2347                 | 429                           | 21890           | 49.99         |
| 7                  | 6533        | 230  | 296  | 7059   | 369  | 5242      | 0    | 55        | 9281            | 9239        | -1664                | 19818                  | 0                | 0                                       | 19818                         | 2377                 | 482                           | 22677           | 50.01         |
| 8                  | 6249        | 279  | 296  | 6824   | 293  | 5195      | 0    | 654       | 8765            | 9128        | -1744                | 19837                  | 0                | 0                                       | 19837                         | 2447                 | 513                           | 22797           | 50.02         |
| 9                  | 5774        | 261  | 298  | 6333   | 155  | 4847      | 0    | 1570      | 8427            | 8739        | -1924                | 19187                  | 0                | 0                                       | 19187                         | 2663                 | 533                           | 22383           | 50.03         |
| 10                 | 5270        | 348  | 289  | 5907   | 178  | 4480      | 0    | 2317      | 8761            | 9053        | -2174                | 19219                  | 0                | 0                                       | 19219                         | 2945                 | 542                           | 22706           | 49.96         |
| 11                 | 4875        | 241  | 288  | 5404   | 300  | 4456      | 0    | 2855      | 9014            | 9558        | -2363                | 19653                  | 0                | 0                                       | 19653                         | 3207                 | 557                           | 23417           | 50.00         |
| 12                 | 4825        | 161  | 279  | 5265   | 396  | 4264      | 0    | 3055      | 8912            | 9044        | -2461                | 19032                  | 0                | 0                                       | 19032                         | 3327                 | 531                           | 22890           | 49.96         |
| 13                 | 4796        | 168  | 273  | 5237   | 358  | 3918      | 0    | 3049      | 8873            | 8851        | -2505                | 18368                  | 0                | 0                                       | 18368                         | 3329                 | 540                           | 22237           | 49.96         |
| 14                 | 4851        | 213  | 273  | 5337   | 294  | 4032      | 0    | 2916      | 8602            | 9039        | -2480                | 18625                  | 0                | 0                                       | 18625                         | 3245                 | 513                           | 22383           | 50.00         |
| 15                 | 5283        | 227  | 274  | 5784   | 244  | 4459      | 0    | 2515      | 8973            | 9334        | -2522                | 19308                  | 0                | 0                                       | 19308                         | 3314                 | 506                           | 23128           | 50.00         |
| 16                 | 5852        | 313  | 272  | 6437   | 209  | 4769      | 0    | 1811      | 9220            | 9375        | -2553                | 19526                  | 0                | 0                                       | 19526                         | 3373                 | 522                           | 23421           | 49.96         |
| 17                 | 6126        | 209  | 274  | 6609   | 182  | 5714      | 0    | 873       | 9404            | 9569        | -2518                | 19886                  | 0                | 0                                       | 19886                         | 3334                 | 543                           | 23763           | 49.95         |
| 18                 | 6163        | 177  | 276  | 6616   | 174  | 6162      | 0    | 181       | 9974            | 9848        | -2355                | 20078                  | 0                | 0                                       | 20078                         | 3248                 | 548                           | 23874           | 49.96         |
| 19                 | 6200        | 918  | 277  | 7395   | 274  | 6211      | 0    | 1         | 10238           | 10182       | -2157                | 21346                  | 0                | 0                                       | 21346                         | 3279                 | 560                           | 25185           | 49.97         |
| 20                 | 6217        | 575  | 281  | 7073   | 300  | 6213      | 0    | 0         | 10237           | 10319       | -2223                | 21125                  | 0                | 0                                       | 21125                         | 3233                 | 557                           | 24915           | 50.03         |
| 21                 | 6057        | 486  | 285  | 6828   | 224  | 6109      | 0    | 0         | 9414            | 9540        | -2242                | 19917                  | 0                | 0                                       | 19917                         | 3122                 | 542                           | 23581           | 50.00         |
| 22                 | 6130        | 199  | 288  | 6617   | 171  | 6288      | 0    | 0         | 8875            | 8797        | -2022                | 19328                  | 0                | 0                                       | 19328                         | 3033                 | 523                           | 22884           | 49.99         |
| 23                 | 5889        | 279  | 289  | 6457   | 152  | 5860      | 0    | 0         | 8700            | 8793        | -2133                | 18603                  | 0                | 0                                       | 18603                         | 2953                 | 526                           | 22082           | 49.96         |
| 24                 | 6068        | 221  | 292  | 6581   | 144  | 5833      | 0    | 0         | 8449            | 8384        | -2108                | 18333                  | 0                | 0                                       | 18333                         | 2946                 | 501                           | 21780           | 49.99         |
| MUs                | 141.07      | 6.50 | 6.85 | 154.42 | 6.14 | 124.20    | 0.00 | 21.85     | 212.44          | 214.93      | -50.60               | 458.85                 | 0.00             | 0.00                                    | 458.85                        | 70.59                | 12.09                         | 541.53          | 49.99         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

\*Load Shedding due to Transmission Constraint :-

| Maximum Demand scenario for the date 26/Oct/2024 |                                  |                                   |
|--------------------------------------------------|----------------------------------|-----------------------------------|
| State Demand                                     | MSEDC Non-Coincident Peak Demand | Mumbai Non-Coincident Peak Demand |
| 25185 MW                                         | 21346 MW                         | 3373 MW                           |
| 19 Hrs                                           | 19 Hrs                           | 16 Hrs                            |
| Includes LS - 0 MW                               | Includes LS - 0 MW               | --                                |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Oct/2024**

Position as on 6.30 Hrs of 27/Oct/2024

| Generating Company            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                                                                                                        | Expected Date |
|-------------------------------|-------------------------|----------|--------------|--------------|------------|------------|---------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| PLANNED OUTAGE                |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Koyna Unit 2            | 70       | 26/10/2024   | 08:35        | 26/10/2024 | 17:25      | Preventive maintenance work.                                                                                                                            |               |
| Total Capacity MSPGCL         |                         | 70       |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | SWPGPL U-3              | 135      | 09/10/2024   | 01:00        |            | Continued. | Annual Overhaul                                                                                                                                         | 29/10/2024    |
| Total Capacity IPP            |                         | 135      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity PLANNED OUTAGE |                         | 205      |              |              |            |            |                                                                                                                                                         |               |
| FORCED OUTAGE                 |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        |                         |          |              |              |            |            |                                                                                                                                                         |               |
| MSPGCL                        | Uran Unit A0            | 120      | 07/09/2022   | 16:30        |            | Continued. | TURBINE TRIPPED ON HIGH VIBRATIONS                                                                                                                      | 31/10/2024    |
| MSPGCL                        | Ghatghar Unit-2         | 125      | 26/05/2024   | 13:17        |            | Continued. | Stator Earth Fault                                                                                                                                      | 26/11/2024    |
| MSPGCL                        | Koradi Unit 8           | 660      | 24/10/2024   | 01:30        |            | Continued. | Boiler Tube Leakage                                                                                                                                     | 28/10/2024    |
| MSPGCL                        | Koyna STG-IV Unit-2     | 250      | 25/10/2024   | 10:45        | 26/10/2024 | 17:25      | Not available due to SUT problem                                                                                                                        |               |
| MSPGCL                        | Nasik Unit 5            | 210      | 25/10/2024   | 22:26        | 27/10/2024 | 11:55      | ID Fan 5A Problem                                                                                                                                       | 27/10/2024    |
| MSPGCL                        | Chandrapur Unit 9       | 500      | 26/10/2024   | 16:00        |            | Continued. | Suspected BTL                                                                                                                                           | 28/10/2024    |
| MSPGCL                        | Nasik Unit 5            | 210      | 27/10/2024   | 21:05        |            | Continued. | ID Fan 5A problem                                                                                                                                       | 30/10/2024    |
| Total Capacity MSPGCL         |                         | 2075     |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         |                         |          |              |              |            |            |                                                                                                                                                         |               |
| TPC-G                         | Trombay 5               | 500      | 22/09/2024   | 16:14        |            | Continued. | Emergency withdrwan due to fire in cable vault.                                                                                                         |               |
| Total Capacity TPC-G          |                         | 500      |              |              |            |            |                                                                                                                                                         |               |
| IPP                           |                         |          |              |              |            |            |                                                                                                                                                         |               |
| IPP                           | RPL(AMT) U-3            | 270      | 23/07/2024   | 00:47        |            | Continued. | Turbine Vibration High                                                                                                                                  | 31/10/2024    |
| IPP                           | JPL Unit 1              | 150      | 20/10/2024   | 15:11        |            | Continued. | Turbine bearing Vabration high                                                                                                                          | 03/11/2024    |
| IPP                           | Adani U-5               | 660      | 23/10/2024   | 10:21        | 26/10/2024 | 05:19      | APH-A HOT PA bellow leakage                                                                                                                             | 26/10/2024    |
| Total Capacity IPP            |                         | 1080     |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   |                         |          |              |              |            |            |                                                                                                                                                         |               |
| CENT.SECTOR                   | Tarapur 1               | 160      | 08/01/2020   | 10:37        |            | Continued. | Refueling. While refueling preparation, some repair works identified which are being executed before refueling.                                         | 30/12/2024    |
| CENT.SECTOR                   | Tarapur 2               | 160      | 13/07/2020   | 04:38        |            | Continued. | For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling. | 30/11/2024    |
| Total Capacity CENT.SECTOR    |                         | 320      |              |              |            |            |                                                                                                                                                         |               |
| Total Capacity FORCED OUTAGE  |                         | 3975     |              |              |            |            |                                                                                                                                                         |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Oct/2024**

Position as on 6.30 Hrs of 27/Oct/2024

| Generating Company                            | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                      | Expected Date |
|-----------------------------------------------|-------------------------|----------|--------------|--------------|-----------|------------|-------------------------------------------------------|---------------|
| UNIT UNDER ZERO SCHEDULE / RSD                |                         |          |              |              |           |            |                                                       |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                       |               |
| MSPGCL                                        | Uran Unit 5             | 108      | 24/10/2024   | 20:00        |           | Continued. | No Schedule ..It is taken on Bar as per requirement   |               |
| MSPGCL                                        | Uran Unit 6             | 108      | 24/10/2024   | 20:14        |           | Continued. | No schedule .. It is taken on Bar as per requirement. |               |
| MSPGCL                                        | Parli Unit 7            | 250      | 26/10/2024   | 02:36        |           | Continued. | Zero Schedule.                                        |               |
| Total Capacity MSPGCL                         |                         | 466      |              |              |           |            |                                                       |               |
| Total Capacity UNIT UNDER ZERO SCHEDULE / RSD |                         | 466      |              |              |           |            |                                                       |               |
| UNIT OUT ON TOLLING *                         |                         |          |              |              |           |            |                                                       |               |
| MSPGCL                                        |                         |          |              |              |           |            |                                                       |               |
| MSPGCL                                        | Bhusawal Unit 3         | 210      | 25/10/2024   | 17:00        |           | Continued. | withdrawn under Tolling.                              |               |
| Total Capacity MSPGCL                         |                         | 210      |              |              |           |            |                                                       |               |
| Total Capacity UNIT OUT ON TOLLING *          |                         | 210      |              |              |           |            |                                                       |               |
| FORCED OUTAGE DUE TO NO PPA                   |                         |          |              |              |           |            |                                                       |               |
| IPP                                           |                         |          |              |              |           |            |                                                       |               |
| IPP                                           | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule.(NO PPA)                                  |               |
| IPP                                           | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule (NO PPA)                                  |               |
| IPP                                           | VIPL U-1                | 300      | 29/12/2018   | 00.30        |           | Continued. | Coal Shortage. (NO PPA From 20.05.2019)               |               |
| IPP                                           | VIPL U-2                | 300      | 17/01/2019   | 00.15        |           | Continued. | Coal shortage.(NO PPA From 20.05.2019)                |               |
| Total Capacity IPP                            |                         | 988      |              |              |           |            |                                                       |               |
| Total Capacity FORCED OUTAGE DUE TO NO PPA    |                         | 988      |              |              |           |            |                                                       |               |

\* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Oct/2024

| Name of Line                              | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                                                                                                                   |
|-------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 765/400kV 1500MVA ICT @ AKOLA 2           | IntraState                | 27/10/2024   | 10:28        | 27/10/2024 | 20:44      | PO          | Annual Maintenance of ICT at Akola-II SS.                                                                                                                                                                                                                                                                                                                                                          |
| <b>400 KV MAINBAY Outages/Trippings</b>   |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| MAIN BAY - 412 OF WARDHA PGCIL @ KORADI 2 | IntraState                | 16/10/2024   | 10:19        |            |            | PO          | Overhauling of CB by Agency                                                                                                                                                                                                                                                                                                                                                                        |
| <b>400 KV LINE Outages/Trippings</b>      |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| 400 KV AKOLA - AURANGABAD(PG) CKT -1      | InterState                | 25/10/2024   | 10:00        | 26/10/2024 | 00:00      | PO          | For Amp of Line Bay                                                                                                                                                                                                                                                                                                                                                                                |
| KUDUS - KALA CKT - 1                      | InterState                | 26/10/2024   | 09:11        | 26/10/2024 | 16:55      | HT          | Emergency outage for string replacement.                                                                                                                                                                                                                                                                                                                                                           |
| BUS REACTOR (50MVAR) @ PARLI              | IntraState                | 27/09/2023   | 15:30        |            |            | PO          | Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.                                                                                                                                                                                                                                                                                                                                |
| AURANGABAD(MS) - PUNE (GIS) CKT - 1       | IntraState                | 04/10/2024   | 08:31        |            |            | HT          | H/T for load management.                                                                                                                                                                                                                                                                                                                                                                           |
| PADGHE - KALWA CKT - 2                    | IntraState                | 23/10/2024   | 03:47        |            |            | PO          | During this outage, Kalwa Padghe Ckt -2 for the work of erection of 1 Nos of QD+9 towers and stringing on newly erected towers in Loc. No 1096 for the work of shifting/height rising of various EHV (400/220kV) Transmission lines infringing in Mumbai-Ahmedabad High Speed Rail Corporation Ltd. (NHSRCL) corridor under ORC                                                                    |
| NEW KOYNA-KARAD CKT - 1                   | IntraState                | 25/10/2024   | 02:16        | 26/10/2024 | 16:29      | T           | Tripped on Bus bar protection optd. due to 400kV New koyna-Karad ckt-1 CT burst at New Kona end.                                                                                                                                                                                                                                                                                                   |
| KHADKA-AURANGABAD (WALUJ)                 | IntraState                | 26/10/2024   | 01:37        | 26/10/2024 | 09:13      | HT          | Overvoltage Control                                                                                                                                                                                                                                                                                                                                                                                |
| AKOLA - KHADKA (BHUSAWAL)                 | IntraState                | 26/10/2024   | 10:04        | 26/10/2024 | 18:40      |             | Spacer fixing at loc Rph 69-70,94-95,95-96 Y ph 68-69, 69-70,95-96 ,B ph 64-65,66-67,67-68 , corona rings fixing at loc 37,41,64,91 , earth wire damper at loc 14                                                                                                                                                                                                                                  |
| AKOLA - KHADKA (BHUSAWAL)                 | IntraState                | 26/10/2024   | 10:04        | 26/10/2024 | 18:40      | PO          | Diagnostic Testing Work DCRM of Line CB                                                                                                                                                                                                                                                                                                                                                            |
| LONIKAND 2 - KARJAT CKT - 2               | IntraState                | 26/10/2024   | 22:24        | 27/10/2024 | 06:29      | PO          | Insulator string replacement by long rod porcelain insulators                                                                                                                                                                                                                                                                                                                                      |
| KHADKA-AURANGABAD (WALUJ)                 | IntraState                | 27/10/2024   | 01:16        |            |            | HT          | Overvoltage Control                                                                                                                                                                                                                                                                                                                                                                                |
| JEJURI- KOYNA STAGE-IV                    | IntraState                | 27/10/2024   | 08:15        | 27/10/2024 | 19:45      |             | scheme PID Faulty insulator string replacement work                                                                                                                                                                                                                                                                                                                                                |
| <b>400 KV ICT Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| STATION TF No 3 @ CHANDRAPUR GCR          | IntraState                | 01/03/2023   | 15:07        |            |            | PO          | 1) Oil filtration work<br>2) Testing of Station transformer<br>3) Preventive maintenance work.                                                                                                                                                                                                                                                                                                     |
| 400/132 KV 200 MVA ICT - 2 @ KHADKA       | IntraState                | 03/06/2024   | 23:26        |            |            | T           | Differential protection                                                                                                                                                                                                                                                                                                                                                                            |
| <b>400 KV BR Outages/Trippings</b>        |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                                                                                                                    |
| BUS REACTOR (80 MVar) - 1 @ BABHALESHWAR  | IntraState                | 07/10/2024   | 09:40        |            |            | PO          | The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Oct/2024

| Name of Line                                  | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                 |
|-----------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>220 KV MAINBAY Outages/Trippings</b>       |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| 220KV BUS SECTION BAY @ PEDAMBE               | IntraState                | 03/04/2024   | 15:55        |            |            | T           | Tripped due to Y ph CT burst                                                                                                                                                                                                                                                     |
| 220KV PADEGAON WALUJ CKT 3                    | IntraState                | 26/10/2024   | 10:02        | 26/10/2024 | 14:59      | PO          | Diagnostic testing and Bay Maintenance work                                                                                                                                                                                                                                      |
| <b>220 KV LINE Outages/Trippings</b>          |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                  |
| BALE - SOLAPUR (PG)                           | InterState                | 19/06/2024   | 08:56        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A)<br>2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37) |
| OSMANABAD - SOLAPUR (BALE)                    | IntraState                | 19/06/2024   | 09:15        |            |            | PO          | 1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)    |
| WAGHIVALI (MSETCL) - ULWE GIS CKT - 2         | IntraState                | 25/06/2024   | 08:05        |            |            | T           | Tripped on differential protection.                                                                                                                                                                                                                                              |
| GHODBUNDER - GORAI                            | IntraState                | 29/07/2024   | 12:14        |            |            | PO          | Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.                                                                                                                                              |
| 220kV Koradi-2 - Uppalwadi ckt 2              | IntraState                | 28/08/2024   | 00:14        |            |            | T           | Distance Protection                                                                                                                                                                                                                                                              |
| EKLAHARE (OCR) - PADGHE                       | IntraState                | 24/09/2024   | 07:48        |            |            | HT          | For load mgmt                                                                                                                                                                                                                                                                    |
| 220KV KORADI II (400KV)- BUTIBORI 3 CKT I     | IntraState                | 01/10/2024   | 13:10        |            |            | HT          | H/T From Butibori 3 end                                                                                                                                                                                                                                                          |
| 220KV KORADI II(400KV) - BUTIBORI 3 CKT II    | IntraState                | 01/10/2024   | 13:11        |            |            | HT          | H/T From Koradi 2 end                                                                                                                                                                                                                                                            |
| EKLAHARE (OCR) - NAVASARI CKT - 1             | IntraState                | 07/10/2024   | 15:10        |            |            | HT          | H/T For load management.                                                                                                                                                                                                                                                         |
| EKLAHARE (OCR) - NAVASARI CKT - 2             | IntraState                | 09/10/2024   | 12:00        | 26/10/2024 | 14:21      | PO          | 1) PLCC, CVT, WT Foundation , Erection, Testing & Commissioning work at 220kV Navsari substation 2) PLCC, CVT, WT Erection, Testing & Commissioning work at 220kV Eklahare (OCR) substation                                                                                      |
| KARAD - DASGAON                               | IntraState                | 14/10/2024   | 15:46        |            |            | PO          | i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line.<br>ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3).<br>iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyna line                                          |
| KALWA - PRINT HOUSE LINE                      | IntraState                | 15/10/2024   | 16:31        |            |            | HT          | Hand tripped at Kalwa end for load management.                                                                                                                                                                                                                                   |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1 | IntraState                | 16/10/2024   | 16:01        |            |            | HT          | Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no 1.                                                                                                                                                                                                        |
| WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2 | IntraState                | 17/10/2024   | 06:26        |            |            | HT          | H/T for controlling load of 220kV Ulve-Waghivali ckt-1                                                                                                                                                                                                                           |
| KALWA - PANCHANAND                            | IntraState                | 17/10/2024   | 12:10        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.                                                                                                                                                            |



**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Oct/2024

| Name of Line                           | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                                                                                                                                                                                |
|----------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| KALWA - PRINT HOUSE LINE               | IntraState                | 17/10/2024   | 12:23        |            |            | EO          | For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Talaja.                                                                                                                                                                           |
| ALEPHATA-PARGAON(KATHAPUR)             | IntraState                | 23/10/2024   | 06:57        |            |            | HT          | Load management .                                                                                                                                                                                                                                                                               |
| TIFIL - NEXTRA GIS                     | IntraState                | 26/10/2024   | 07:17        | 26/10/2024 | 10:06      | PO          | Replacement of B Ph LA of 220kV TFIPL-Nxtra Line bay                                                                                                                                                                                                                                            |
| HINJAWADI I- CHINCHWAD                 | IntraState                | 26/10/2024   | 07:39        | 26/10/2024 | 21:37      | HT          | For Load Management                                                                                                                                                                                                                                                                             |
| KORADI-KHAPERKHEDA                     | IntraState                | 26/10/2024   | 09:12        | 26/10/2024 | 17:00      | PO          | For CT Tan Delta                                                                                                                                                                                                                                                                                |
| 220kV Koradi-2 - Uppalwadi ckt 1       | IntraState                | 26/10/2024   | 10:27        | 26/10/2024 | 18:48      | PO          | Safety reason, Scaffolding installation for cable termination is going on at CTT2                                                                                                                                                                                                               |
| PARAS-CHIKHALI CKT NO-I                | IntraState                | 26/10/2024   | 11:04        | 26/10/2024 | 19:24      | PO          | Testing and R.M work                                                                                                                                                                                                                                                                            |
| PADEGAON-SAWANGI                       | IntraState                | 26/10/2024   | 15:07        | 26/10/2024 | 18:28      | PO          | Testing and Bay Maintenance work                                                                                                                                                                                                                                                                |
| KHAPARKHEDA-AMBAZARI-I                 | IntraState                | 26/10/2024   | 15:10        | 26/10/2024 | 20:06      | T           | Distance protection                                                                                                                                                                                                                                                                             |
| KALWA - MULUND 1                       | IntraState                | 26/10/2024   | 18:09        | 26/10/2024 | 19:02      | PO          | Ashida Make BCU's faulty DI Card Replacement work through OEM on Urgent basis                                                                                                                                                                                                                   |
| KALWA - MULUND 2                       | IntraState                | 26/10/2024   | 19:05        | 26/10/2024 | 20:02      | PO          | Ashida Make BCU's faulty DI Card Replacement work through OEM on Urgent basis                                                                                                                                                                                                                   |
| PANVEL TSS - TIMBER MARKET             | IntraState                | 27/10/2024   | 08:21        | 27/10/2024 | 20:12      | PO          | 220kV Panvel Timber Market - Panvel TSS line for diversion on ERS tower between loc no. 2&3.                                                                                                                                                                                                    |
| KALWA - SALESETTE CKT - 5              | IntraState                | 27/10/2024   | 10:51        | 27/10/2024 | 15:53      | EO          | Bird nest removal at Kalwa MSETCL premises gantry                                                                                                                                                                                                                                               |
| MAHALAXMI - BACKBAY                    | IntraState                | 27/10/2024   | 23:46        |            | Continued. | PO          | Protection testing.                                                                                                                                                                                                                                                                             |
| <b>220 KV ICT Outages/Trippings</b>    |                           |              |              |            |            |             |                                                                                                                                                                                                                                                                                                 |
| 220/132 KV 100 MVA ICT 1@ BABHALESHWAR | IntraState                | 12/07/2024   | 13:35        |            |            | PO          | Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.                                                                                                                                                                                                                             |
| 220/22KV 50MVA PTR 3 @ BHOSARI 2       | IntraState                | 24/07/2024   | 23:02        |            |            | T           | Tripped due to caught fire.                                                                                                                                                                                                                                                                     |
| 220/132 KV 100 MVA ICT II @ UPPALWADI  | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                                                                                     |
| 220/132 KV 100 MVA ICT I @ UPPALWADI   | IntraState                | 28/08/2024   | 12:52        |            |            | HT          | H/T LV for load management.                                                                                                                                                                                                                                                                     |
| 220/33KV 25MVA PTR 1 @ NIWALI          | IntraState                | 25/10/2024   | 09:49        | 27/10/2024 | 19:03      | PO          | CB overhauling work.                                                                                                                                                                                                                                                                            |
| 220/132 KV 150 MVA ICT-2 @BHENDA       | IntraState                | 26/10/2024   | 09:25        | 26/10/2024 | 18:27      | PO          | 1. To attain the mal operation of RPRR trip relay and replacement of cable of CTR with help of Agency.<br>2. To attain the oil leakage from Main Tank , Radiator , oil pump , thermal cyphane filter etc. with help of Agency.<br>3. For quarterly maintenance work of 220/132kV 150 MVA ICT II |
| 220/132KV 100MVA ICT 2 @ JEUR          | IntraState                | 26/10/2024   | 12:05        | 26/10/2024 | 14:05      | PO          | Outage is required for To attend problem observed in TCIV of NIFPS CTR                                                                                                                                                                                                                          |
| 220/132 KV 100 MVA ICT 2 @ TULJAPUR    | IntraState                | 26/10/2024   | 18:20        | 26/10/2024 | 20:34      | PO          | LA Replacement work                                                                                                                                                                                                                                                                             |
| 220/100 KV 100 MVA ICT 1 @ VASAI-II    | IntraState                | 27/10/2024   | 09:10        | 27/10/2024 | 21:19      | PO          | for service & maintenance of SERGI Nitrogen Injection Fire Fighting System of 100MVA, 220/100kV ICT-1 by agency, OLTC Overhauling by agency & Diagnostic Testing and Bay Maintenance work.                                                                                                      |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Oct/2024**

**Statement-VII**

Position as on 6.30 Hrs of 27/Oct/2024

| Name of Line                                   | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                         |
|------------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------------------|
| <b>132 KV LINE Outages/Trippings</b>           |                              |                 |                 |            |               |                |                                          |
| MANSAR-PENCH                                   | InterState                   | 26/09/2024      | 14:40           |            |               | HT             | H/T at 132KV Pench end                   |
| CHAKAN- CHINCHWAD- BAJAJ<br>AUTO CHAKAN TAP    | IntraState                   | 16/10/2024      | 07:02           |            |               | HT             | For Load Management                      |
| <b>110 KV LINE Outages/Trippings</b>           |                              |                 |                 |            |               |                |                                          |
| NERAL - AMBERNATH                              | IntraState                   | 26/10/2024      | 08:03           | 26/10/2024 | 12:37         | PO             | R/M                                      |
| KOLSHET - BMC - BORIVALI (T) -<br>BORIVALI (M) | IntraState                   | 26/10/2024      | 10:30           | 26/10/2024 | 12:21         | PO             | BMC end work                             |
| <b>110 KV BUSBAR Outages/Trippings</b>         |                              |                 |                 |            |               |                |                                          |
| BUS ZONE - 2 @ BHOKARPADA                      | IntraState                   | 26/10/2024      | 13:25           | 26/10/2024 | 17:40         | PO             | R/M of bus and bus side GODS             |
| ZONE 1 (BUS SECTION 1+2+3) @<br>BHIVPURI       | IntraState                   | 27/10/2024      | 05:47           | 27/10/2024 | 12:38         | PO             | R/M of bus side GODs and PT 1<br>testing |

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage