

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 26/Nov/2018 MONDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 128.457        | 3426.415        | 1) Gujrat                      | -2.727         | -40.599          |
| 2) Hydro            | 2.971          | 108.788         | 2) Madhya Pradesh              | 9.404          | 281.854          |
| 3) Gas              | 6.925          | 172.895         | 3) Chattisgarh                 | 6.550          | 176.380          |
| <b>Total MSPGCL</b> | <b>138.353</b> | <b>3708.098</b> | 4) Maharashtra Net             | 111.714        | 3143.787         |
| B) 1) APML          | 71.393         | 1759.893        | 5) Goa (Amona)                 | -0.198         | -12.122          |
| 2) JSWEL            | 23.519         | 633.149         | <b>Total</b>                   | <b>124.743</b> | <b>3549.300</b>  |
| 3) VIPL             | 11.983         | 189.251         | a) Mumbai Schedule             | 22.690         | 561.146          |
| 4) RPL(AMT)         | 11.222         | 206.664         | b) Mumbai Drawl                | 28.443         | 742.741          |
| 5) WPCL             | 4.601          | 112.140         | c) MSEDCL Bilateral *          | 28.594         | 1127.993         |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -0.441         | 272.878          |
| 7) Other IPP        | 16.600         | 359.211         | d) Mumbai Bilateral *          | 22.690         | 548.961          |
| C) 1) TPCL Thermal  | 13.953         | 340.310         | Include PX                     | 0.706          | 105.022          |
| 2) TPCL Hydro       | 2.149          | 82.075          | Include Standby                | 0.000          | 12.185           |
| 3) TPCL Gas         | 4.418          | 113.811         | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 10.340         | 251.614         | 1) MSEDCL                      | 386.260        | 10120.495        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 59.303         | 1530.548         |
| 1) Thermal          | 292.068        | 7278.647        | <b>TOTAL STATE</b>             | <b>445.563</b> | <b>11651.043</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 5.120          | 190.863         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 11.343         | 286.706         |                                |                |                  |
| (A3+B6+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 6.935          | 204.800         |                                |                |                  |
| 6) SOLAR            | 5.354          | 140.730         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>320.820</b> | <b>8101.746</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 19 Hrs | D. Night Minimum at 2 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 5812                      | 5794                  | 5627                      | 4869                      |
| MSPGCL Hydro             | 274                       | 244                   | 134                       | 40                        |
| MSPGCL Gas               | 197                       | 195                   | 286                       | 307                       |
| MSPGCL Total Generation  | 6284                      | 6234                  | 6048                      | 5216                      |
| Central Sector Receipt   | 6347                      | 6057                  | 4944                      | 4044                      |
| WIND                     | 246                       | 178                   | 161                       | 331                       |
| CPP / IPP Thermal        | 6297                      | 6243                  | 6442                      | 4950                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 760                       | 777                   | 0                         | 0                         |
| Exchange with Mumbai     | -1493                     | -1453                 | -1327                     | -867                      |
| <b>MSEDCL DEMAND MET</b> | <b>18441</b>              | <b>18036</b>          | <b>16267</b>              | <b>13674</b>              |
| Load Shedding            | 0                         | 8                     | 0                         | 0                         |
| MSEDCL DEMAND            | 18441                     | 18044                 | 16267                     | 13674                     |
| TPCL GENERATION          | 1002                      | 1005                  | 1076                      | 693                       |
| R-INFRA GENERATION       | 502                       | 502                   | 497                       | 375                       |
| <b>MUMBAI DEMAND</b>     | <b>2997</b>               | <b>2960</b>           | <b>2900</b>               | <b>1935</b>               |
| STATE DEMAND MET         | 21438                     | 20996                 | 19167                     | 15609                     |
| <b>STATE DEMAND</b>      | <b>21438</b>              | <b>21004</b>          | <b>19167</b>              | <b>15609</b>              |
| Frequency (Hz)           | 49.99                     | 49.98                 | 50.02                     | 49.99                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.13 Hz at 13.03 Hrs | 49.77 Hz at 06.13 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 26/Nov/2018

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 0.00         | 20.96          | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 7.49         | 188.01         | 350      | 297      |
| Unit 9             | 6.98         | 200.90         | 348      | 245      |
| Unit 10            | 7.39         | 198.46         | 330      | 294      |
| <b>Total</b>       | <b>21.86</b> | <b>608.33</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 9.71         | 229.00         | 455      | 350      |
| Unit 5             | 9.76         | 227.07         | 460      | 350      |
| <b>Total</b>       | <b>19.47</b> | <b>456.07</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 5.38         | 126.43         | 250      | 190      |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 5.34         | 127.54         | 245      | 194      |
| <b>Total</b>       | <b>10.72</b> | <b>253.96</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.21         | 50.09          | 187      | 162      |
| Unit 4             | 0.00         | 23.01          | 0        | 0        |
| Unit 5             | 9.32         | 244.60         | 420      | 340      |
| Unit 6             | 9.89         | 221.36         | 450      | 355      |
| Unit 7             | 9.70         | 247.38         | 435      | 360      |
| Unit 8             | 8.24         | 218.79         | 438      | 0        |
| Unit 9             | 0.00         | 249.57         | 0        | 0        |
| <b>Total</b>       | <b>41.36</b> | <b>1254.79</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 5.47         | 123.97         | 250      | 193      |
| <b>Total</b>       | <b>5.47</b>  | <b>123.97</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 3.92         | 103.49         | 175      | 140      |
| Unit 3             | 3.82         | 96.45          | 167      | 145      |
| Unit 4             | 4.10         | 107.94         | 180      | 156      |
| Unit 5             | 9.41         | 225.24         | 435      | 379      |
| <b>Total</b>       | <b>21.25</b> | <b>533.12</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 4.14         | 71.42          | 192      | 156      |
| Unit 4             | 4.19         | 102.38         | 200      | 158      |
| Unit 5             | 0.00         | 22.37          | 0        | 0        |
| <b>Total</b>       | <b>8.33</b>  | <b>196.17</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 6.92         | 172.90         | 318      | 195      |
| <b>Total</b>       | <b>6.92</b>  | <b>172.90</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.02         | 2.03           | 17       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.02</b>   | <b>2.03</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 0.48          | 29.10          | 45       | 5        |
| Stage 4         | 0.00          | 12.56          | 0        | 0        |
| Stage 3         | 0.00          | 9.61           | 0        | 0        |
| <b>Total</b>    | <b>0.48</b>   | <b>51.26</b>   |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.44          | 13.66          | 19       | 19       |
| VTRNA           | 0.47          | 11.88          | 61       | 0        |
| TILLARI         | 0.36          | 0.72           | 60       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.10          | 4.10           | 60       | 0        |
| RNGR+BHTSA      | 0.36          | 9.72           | 16       | 15       |
| BHANDARDRA      | 0.00          | 4.62           | 0        | 0        |
| ELDARY          | 0.00          | 0.00           | 0        | 0        |
| SMLHY_PTN       | 0.08          | 4.49           | 12       | 1        |
| GHATGHAR        | 0.67          | 8.33           | 125      | 0        |
| <b>Total</b>    | <b>2.49</b>   | <b>57.52</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.94          | 204.80         | 0        | 0        |
| <b>Total</b>    | <b>6.94</b>   | <b>204.80</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 71.39         | 1759.89        | 0        | 0        |
| JSWEL(Mus)      | 23.52         | 633.15         | 0        | 0        |
| VIPL(Mus)       | 11.98         | 189.25         | 0        | 0        |
| RPLAMT(Mus)     | 11.22         | 206.66         | 0        | 0        |
| WPCL(Mus)       | 4.60          | 112.14         | 0        | 0        |
| Other(Mus)      | 16.60         | 359.21         | 0        | 0        |
| <b>Total</b>    | <b>139.32</b> | <b>3260.31</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 5.35          | 140.73         | 0        | 0        |
| <b>Total</b>    | <b>5.35</b>   | <b>140.73</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 9.02          | 216.22         | 477      | 304      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.80          | 72.33          | 118      | 116      |
| Trombay 7B      | 1.61          | 41.48          | 69       | 66       |
| Trombay 8       | 4.93          | 124.10         | 224      | 201      |
| TATA Hydro      | 2.15          | 82.08          | 203      | 0        |
| <b>Total</b>    | <b>20.52</b>  | <b>536.20</b>  |          |          |
| <b>R-INFRA</b>  |               |                |          |          |
| DTPS U-1&2      | 10.34         | 251.61         | 504      | 374      |
| <b>Total</b>    | <b>10.34</b>  | <b>251.61</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 128.46      | 3426.42       | MSPGCL Total        | 138.35      | 3708.10       |
|                |             |         | MSPGCL Thml+Gas | 135.38      | 3599.31       | Koyna 1,2 & 4 Total | 0.48        | 41.65         |
|                |             |         | MSPGCL Hydro    | 2.97        | 108.79        | State Total         | 320.82      | 8101.75       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

### Hourly Load Data As on 26/Nov/2018

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5000        | 40   | 298  | 5338   | 179  | 5069      | 0    | 0     | 4487        | 4119        | -1012                | 13694                 | 0                    | 13694                     | 2079             | 15773           | 50.00         |
| 2                  | 4869        | 40   | 307  | 5216   | 331  | 4950      | 0    | 0     | 4127        | 4044        | -867                 | 13674                 | 0                    | 13674                     | 1935             | 15609           | 49.99         |
| 3                  | 4645        | 40   | 308  | 4994   | 406  | 4999      | 0    | 0     | 4280        | 4456        | -760                 | 14095                 | 0                    | 14095                     | 1829             | 15924           | 49.99         |
| 4                  | 4639        | 40   | 309  | 4988   | 495  | 5215      | 0    | 0     | 4353        | 4303        | -682                 | 14320                 | 0                    | 14320                     | 1749             | 16069           | 50.01         |
| 5                  | 4660        | 40   | 309  | 5010   | 561  | 5226      | 0    | 0     | 4585        | 4448        | -661                 | 14584                 | 0                    | 14584                     | 1731             | 16315           | 50.01         |
| 6                  | 5077        | 46   | 310  | 5432   | 554  | 5345      | 0    | 0     | 4987        | 5114        | -754                 | 15692                 | 0                    | 15692                     | 1821             | 17513           | 49.93         |
| 7                  | 5619        | 40   | 310  | 5968   | 592  | 5931      | 0    | 4     | 5174        | 5468        | -900                 | 17064                 | 0                    | 17064                     | 1975             | 19039           | 49.91         |
| 8                  | 5711        | 40   | 311  | 6062   | 547  | 6051      | 0    | 126   | 5316        | 5521        | -1017                | 17290                 | 0                    | 17290                     | 2121             | 19411           | 49.98         |
| 9                  | 5808        | 130  | 318  | 6256   | 416  | 6067      | 0    | 383   | 5340        | 5734        | -1202                | 17654                 | 0                    | 17654                     | 2411             | 20065           | 50.00         |
| 10                 | 5819        | 230  | 294  | 6342   | 385  | 6207      | 0    | 626   | 5438        | 5672        | -1263                | 17970                 | 0                    | 17970                     | 2718             | 20688           | 50.01         |
| 11                 | 5767        | 334  | 298  | 6398   | 364  | 6334      | 0    | 709   | 5985        | 6021        | -1416                | 18410                 | 0                    | 18410                     | 2930             | 21340           | 49.98         |
| 12                 | 5812        | 274  | 197  | 6284   | 246  | 6297      | 0    | 760   | 6220        | 6347        | -1493                | 18441                 | 0                    | 18441                     | 2997             | 21438           | 49.99         |
| 13                 | 5794        | 244  | 195  | 6234   | 178  | 6243      | 0    | 777   | 5994        | 6057        | -1453                | 18036                 | 8                    | 18044                     | 2960             | 21004           | 49.98         |
| 14                 | 5687        | 244  | 252  | 6184   | 118  | 6255      | 0    | 686   | 5815        | 5854        | -1363                | 17734                 | 20                   | 17754                     | 2854             | 20608           | 50.03         |
| 15                 | 5604        | 244  | 279  | 6128   | 127  | 6277      | 0    | 628   | 5893        | 6024        | -1410                | 17773                 | 11                   | 17784                     | 2901             | 20685           | 49.95         |
| 16                 | 5695        | 166  | 278  | 6140   | 117  | 6355      | 0    | 421   | 5690        | 5450        | -1438                | 17045                 | 14                   | 17059                     | 2936             | 19995           | 49.92         |
| 17                 | 5642        | 70   | 280  | 5992   | 113  | 6377      | 0    | 210   | 5190        | 5322        | -1370                | 16644                 | 15                   | 16659                     | 2917             | 19576           | 49.92         |
| 18                 | 5614        | 80   | 293  | 5986   | 138  | 6503      | 0    | 24    | 4898        | 4870        | -1350                | 16172                 | 0                    | 16172                     | 2874             | 19046           | 49.96         |
| 19                 | 5627        | 134  | 286  | 6048   | 161  | 6442      | 0    | 0     | 5131        | 4944        | -1327                | 16267                 | 0                    | 16267                     | 2900             | 19167           | 50.02         |
| 20                 | 5386        | 134  | 289  | 5810   | 169  | 6071      | 0    | 0     | 5186        | 5220        | -1415                | 15855                 | 0                    | 15855                     | 2787             | 18642           | 50.01         |
| 21                 | 5024        | 130  | 301  | 5454   | 193  | 5490      | 0    | 0     | 5043        | 5112        | -1412                | 14838                 | 0                    | 14838                     | 2648             | 17486           | 49.99         |
| 22                 | 5007        | 74   | 292  | 5374   | 192  | 5222      | 0    | 0     | 4832        | 4999        | -1347                | 14439                 | 0                    | 14439                     | 2501             | 16940           | 50.01         |
| 23                 | 4986        | 74   | 304  | 5364   | 192  | 5215      | 0    | 0     | 4621        | 4838        | -1288                | 14322                 | 0                    | 14322                     | 2403             | 16725           | 49.98         |
| 24                 | 4965        | 80   | 307  | 5352   | 161  | 5173      | 0    | 0     | 4551        | 4806        | -1243                | 14249                 | 0                    | 14249                     | 2326             | 16575           | 50.02         |
| MUs                | 128.46      | 2.97 | 6.92 | 138.35 | 6.94 | 139.32    | 0.00 | 5.35  | 123.14      | 124.74      | -28.44               | 386.26                | 0.07                 | 386.33                    | 59.30            | 445.63          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 26/Nov/2018**

**Position as on 6.30 Hrs of 27/Nov/2018**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                    | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|-------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                     |               |
| CPP                   | SWPGL U-3               | 135      | 01/11/2018   | 00.28        |            | Continued. | Annual Overhaul                     |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                     |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17:08        |            | Continued. | Economic shutdown                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                             |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                   |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |            | Continued. | Economic shutdown                   |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                         |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                         |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 21/05/2018   | 18.46        |            | Continued. | Coal Swapping IEPL                  |               |
| MSPGCL                | Uran Unit 7             | 108      | 20/07/2018   | 12.53        |            | Continued. | Compressor & Turbine Blade Failure. |               |
| MSPGCL                | Koradi Unit 7           | 210      | 03/08/2018   | 15.54        |            | Continued. | Poor Coal Receipt.                  |               |
| MSPGCL                | Khaparkhedda Unit 1     | 210      | 11/08/2018   | 23.57        |            | Continued. | Poor coal Receipt                   |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | Poor Coal Receipt                   |               |
| MSPGCL                | Uran Unit 8             | 108      | 08/09/2018   | 22.08        |            | Continued. | Withdrawn due to B0 & U-7           |               |
| MSPGCL                | Paras Unit 3            | 250      | 15/09/2018   | 00.55        |            | Continued. | Stator Earth Fault                  |               |
| IPP                   | RPL(AMT) U-4            | 270      | 20/09/2018   | 00.01        |            | Continued. | Poor Coal Receipt                   |               |
| IPP                   | RPL(AMT) U-5            | 270      | 21/09/2018   | 00.05        |            | Continued. | Poor Coal Receipt                   |               |
| IPP                   | RPL(AMT) U-3            | 270      | 25/09/2018   | 0.00         |            | Continued. | Poor Coal Receipt                   |               |
| MSPGCL                | Parli Unit 7            | 250      | 19/10/2018   | 00.23        |            | Continued. | Poor Coal Receipt.                  |               |
| MSPGCL                | Nasik Unit 5            | 210      | 22/11/2018   | 03.50        |            | Continued. | Boiler Tube Leakage                 |               |
| MSPGCL                | Koradi Unit 6           | 210      | 22/11/2018   | 18.53        | 27/11/2018 | 01.42      | heavy steam leakage of deaerator.   |               |
| MSPGCL                | Chandrapur Unit 4       | 210      | 23/11/2018   | 14.04        |            | Continued. | Boiler Tube Leakage                 |               |
| MSPGCL                | Chandrapur Unit 9       | 500      | 25/11/2018   | 23.25        |            | Continued. | Boiler Tube Leakage                 |               |
| MSPGCL                | Chandrapur Unit-8       | 500      | 26/11/2018   | 01.40        | 26/11/2018 | 04.59      | MS VALVE CLOSED.                    |               |
| IPP                   | SWPGL U-2               | 135      | 27/11/2018   | 00.00        |            | Continued. | No Schedule.                        |               |
| MSPGCL                | Koradi Unit 6           | 210      | 27/11/2018   | 02.50        | 27/11/2018 | 06.00      | Turbine Protection.                 |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Nov/2018**

**Statement-VII**

Position as on 6.30 Hrs of 27/Nov/2018

| Name of Line                                   | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                                       |
|------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------|
| <b>765 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                        |
| Main Bus-II @ Akola-II                         | IntraState                | 26/11/2018   | 10.03        | 26/11/2018 | 18.57      | PO          | Annual outage for year 2018-19                                                                                                         |
| <b>500 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                        |
| Chandrapur - Padghe Hvdc Pole 1                | IntraState                | 19/11/2018   | 09.07        | 26/11/2018 | 19.10      | PO          | Annual outage for year 2018-19                                                                                                         |
| <b>400 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                        |
| Karad Solapur (PG)                             | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kv Solapur (PG)- Jeur from LOC 403                                                                               |
| Dhule Sar'Sarovar II                           | InterState                | 24/11/2018   | 17.21        | 26/11/2018 | 10.37      | HT          | Over Voltage                                                                                                                           |
| Akola Wardha li                                | InterState                | 26/11/2018   | 10.44        | 26/11/2018 | 16.31      | PO          | Routine Maintenance Work                                                                                                               |
| Dhule Sar'Sarovar I                            | InterState                | 26/11/2018   | 18.08        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| Khadka-Aurangabad (Waluj)                      | IntraState                | 25/11/2018   | 18.18        | 26/11/2018 | 06.41      | HT          | Over Voltage                                                                                                                           |
| Khadka- Deepnagar Ckt 1                        | IntraState                | 26/11/2018   | 10.40        | 26/11/2018 | 17.42      | EO          | Hot Spot In Y PH Bus Isolator.                                                                                                         |
| Khadka-Aurangabad (Waluj)                      | IntraState                | 26/11/2018   | 17.17        |            | Continued. | HT          | Over Voltage                                                                                                                           |
| <b>400 KV ICT Outages/Trippings</b>            |                           |              |              |            |            |             |                                                                                                                                        |
| 400/11.5 KV 90MVA Station T/F III @ Chandrapur | IntraState                | 30/10/2018   | 16.48        | 26/11/2018 | 12.04      | T           | In View To Shift GT 7 On Tbc 2.                                                                                                        |
| 400/220/33 Kv 315 Mva ICT 1 @Padghe            | IntraState                | 15/11/2018   | 10.07        |            | Continued. | T           | Differential protection                                                                                                                |
| 400/220kv 315MVA ICT-III @ Kharghar            | IntraState                | 23/11/2018   | 08.09        | 26/11/2018 | 09.37      | PO          | Internal Inspection & Rectification Of Fault.                                                                                          |
| 400/220/33kv 500MVA ICT 5 @ Padghe             | IntraState                | 25/11/2018   | 00.54        |            | Continued. | T           | Differential protection Bucholz, REF. PRV. CTR Relay.                                                                                  |
| 400/220 Kv 315 MVA ICT -I @New Koyna           | IntraState                | 26/11/2018   | 09.37        | 27/11/2018 | 01.25      | PO          | Fire Detector Alaram Indication And CT Healthiness Attended Work.                                                                      |
| 400/220/33 Kv 315 MVA ICT- 2 @Nagothane        | IntraState                | 26/11/2018   | 10.10        | 26/11/2018 | 19.30      | PO          | LA Backup And Diagnostic Work.                                                                                                         |
| 400/220kv 315 MVA ICT I @ Kolhapur             | IntraState                | 26/11/2018   | 11.05        | 26/11/2018 | 18.58      | PO          | Routine Maintenance Work                                                                                                               |
| <b>220 KV LINE Outages/Trippings</b>           |                           |              |              |            |            |             |                                                                                                                                        |
| Talandage - Chikodi                            | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | No Schedule                                                                                                                            |
| Mudshingi - Chikodi                            | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | No Schedule.                                                                                                                           |
| Chandrapur GCR - Warora - I                    | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.                   |
| Chandrapur GCR - Wani                          | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107. |
| BOISAR BORIVALI                                | IntraState                | 24/07/2018   | 13.18        |            | Continued. | HT          | To control line loading.                                                                                                               |
| Uran - Kharghar I                              | IntraState                | 22/11/2018   | 11.39        |            | Continued. | PO          | Conductor dismantling work.                                                                                                            |
| Padgha - Temghar I                             | IntraState                | 25/11/2018   | 10.43        |            | Continued. | HT          | To Control ICT Loading At Padghe.                                                                                                      |
| Padgha-Temghar-II                              | IntraState                | 25/11/2018   | 10.43        |            | Continued. | HT          | To Control ICT Loading At Padghe.                                                                                                      |
| TPC Borivali Aarey Line 1                      | IntraState                | 26/11/2018   | 00.22        | 26/11/2018 | 05.13      | PO          | Pier Cap Erection Work By DMRC.                                                                                                        |
| Kalwa - Airoli Knowledge Park                  | IntraState                | 26/11/2018   | 08.32        | 26/11/2018 | 22.05      | T           | Distance Protection A/R Lock Out R-PH 0.9KM 33.5KA                                                                                     |
| Talandage(400kv) - Five Star Midc              | IntraState                | 26/11/2018   | 10.10        | 26/11/2018 | 19.41      | PO          | String Erection Work.                                                                                                                  |
| Badnera - Amravati                             | IntraState                | 26/11/2018   | 10.35        | 26/11/2018 | 14.51      | PO          | Diagnostic Testing Work.                                                                                                               |
| Paras-Balapur Iv                               | IntraState                | 26/11/2018   | 11.20        | 26/11/2018 | 15.37      | PO          | Diagnostic Testing Work.                                                                                                               |
| Kalwa-TIFIL                                    | IntraState                | 27/11/2018   | 06.06        |            | Continued. | EO          | Tapping Of Tifil Substation On 220KV Kharghar-Borivali Line                                                                            |
| Kharghar-Borivali ckt II                       | IntraState                | 27/11/2018   | 06.08        |            | Continued. | EO          | Tapping Of Tifil Substation On 220KV Kharghar-Borivali Line                                                                            |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 26/Nov/2018**

**Statement-VII**

Position as on 6.30 Hrs of 27/Nov/2018

| Name of Line                            | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage             |
|-----------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|------------------------------|
| <b>220 KV ICT Outages/Trippings</b>     |                              |                 |                 |            |               |                |                              |
| 220/132 KV 150MVA ICT II@ GCR<br>Nashik | IntraState                   | 24/11/2018      | 10.11           |            | Continued.    | PO             | Replacement of Line Isolator |