

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Jan/2020 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.296	3384.074	1) Gujrat	4.837	133.805
2) Hydro	11.526	328.133	2) Madhya Pradesh	11.180	337.267
3) Gas	6.944	145.452	3) Chattisgarh	5.760	182.350
Total MSPGCL	158.766	3857.659	4) Maharashtra	119.744	3167.655
B) 1) APMIL	69.760	1918.411	5) Goa (Amona)	-0.858	-14.234
2) JSWEL	24.398	654.886	Total	140.663	3806.843
3) VIPL	0.000	0.000	a) Mumbai Schedule	25.021	585.717
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	26.860	617.448
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	28.461	763.540
6) Other IPP	15.117	413.368	Include PX	5.234	148.055
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	25.021	584.792
C) 1) TPCL Thermal	14.361	389.895	Include PX	10.378	216.078
2) TPCL Hydro	3.522	88.622	Standby	0.000	0.925
3) TPCL Gas	3.288	55.815	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.294	168.092	1) MSEDCL	401.423	10417.098
D) STATE			2) Mumbai Discoms	53.325	1319.874
1) Thermal	269.226	6928.726	TOTAL STATE	454.748	11736.972
(A1+C1+C4+(B1-B6))					
2) Hydro	15.048	416.755			
(A2+C2)					
3) Gas	10.232	201.267			
(A3+B7+C3)					
4) Wind	13.144	225.534			
6) SOLAR	6.435	157.845			
TOTAL STATE	314.085	7930.127			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5983	5961	5727	5450
MSPGCL Hydro	1651	1033	226	105
MSPGCL Gas	282	280	285	292
MSPGCL Total Generation	7916	7274	6238	5847
Central Sector Receipt	7303	7208	5766	4320
WIND	395	523	830	186
CPP / IPP Thermal	4998	5012	4818	3656
CPP / IPP Gas	0	0	0	0
SOLAR	926	992	0	0
Exchange with Mumbai	-1482	-1389	-1404	-752
MSEDCL DEMAND MET	20056	19620	16248	13257
Load Shedding	0	0	0	0
MSEDCL DEMAND	20056	19620	16248	13257
TPCL GENERATION	1088	1083	919	637
AEML GENERATION	250	250	196	192
MUMBAI DEMAND	2820	2722	2519	1581
STATE DEMAND MET	22876	22342	18767	14838
STATE DEMAND	22876	22342	18767	14838
Frequency (Hz)	50.03	50.00	49.91	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.17 Hz at 13.01 Hrs	49.76 Hz at 14.12 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 27/Jan/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.49	299.23	570	310
Unit 9	10.49	295.70	525	300
Unit 10	11.08	260.58	540	350
Total	32.06	855.52		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.24	68.59	250	190
Unit 7	5.35	74.77	249	192
Unit 8	5.40	122.48	250	177
Total	15.98	265.83		
Chandrapur				
Unit 3	4.28	112.73	188	163
Unit 4	0.00	96.53	0	0
Unit 5	7.59	210.72	340	290
Unit 6	10.21	274.36	480	355
Unit 7	9.10	63.35	452	331
Unit 8	8.58	288.78	475	172
Unit 9	10.62	283.59	470	365
Total	50.38	1330.05		
Paras				
Unit 3	5.31	129.04	252	190
Unit 4	5.44	139.49	255	195
Total	10.74	268.53		
Khaparkheda				
Unit 1	3.92	64.82	180	140
Unit 2	4.07	65.49	185	160
Unit 3	4.31	67.38	195	158
Unit 4	4.33	72.61	200	160
Unit 5	10.31	286.42	490	360
Total	26.95	556.71		
Nasik				
Unit 3	4.18	103.13	196	160
Unit 4	0.00	4.30	0	0
Unit 5	0.00	0.00	0	0
Total	4.18	107.43		
Uran				
All Units	6.94	145.45	303	269
Total	6.94	145.45		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.17	4.53	50	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.17	4.53		
Koyna				
Stage 1-2	3.81	92.35	480	40
Stage 4	2.91	125.06	750	0
Stage 3	1.39	46.78	240	0
Total	8.11	264.19		
Hydro				
KDPH	0.89	6.93	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.48	12.64	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.10	3.82	77	0
RNGR+BHTSA	0.35	9.41	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.05	0	0
SMLHY_PTN	0.39	9.50	27	13
GHATGHAR	1.21	21.60	125	0
Total	3.42	63.94		
Wind				
Total	13.14	225.53	0	0
Total	13.14	225.53		
CPP				
APML(Mus)	69.76	1918.41	0	0
JSWEL(Mus)	24.40	654.89	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	15.12	413.37	0	0
Total	109.28	2986.66		
SOLAR				
Total	6.44	157.84	0	0
Total	6.44	157.84		
Tata				
Trombay 5	9.29	251.54	474	289
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.97	31.81	85	78
Trombay 7B	1.32	24.01	57	53
Trombay 8	5.07	138.36	242	182
TATA Hydro	3.52	88.62	269	10
Total	21.17	534.33		
AEML				
DTPS U-1&2	5.29	168.09	250	191
Total	5.29	168.09		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.30	3384.07	MSPGCL Total	158.77	3857.66
			MSPGCL Thml+Gas	147.24	3529.53	Koyna 1,2 & 4 Total	6.72	217.41
			MSPGCL Hydro	11.53	328.13	State Total	314.08	7930.13

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/Jan/2020

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5444	105	291	5840	95	3657	0	0	5009	4761	-948	13405	0	13405	1776	15181	50.05
2	5448	110	302	5860	153	3669	0	0	4563	4521	-818	13385	0	13385	1650	15035	50.01
3	5450	105	292	5847	186	3656	0	0	4583	4320	-752	13257	0	13257	1581	14838	50.02
4	5454	110	293	5857	147	3677	0	0	4536	4458	-723	13416	0	13416	1543	14959	50.02
5	5544	195	303	6042	150	3783	0	0	4734	4737	-746	13966	0	13966	1549	15515	50.01
6	5998	185	293	6476	128	4183	0	0	5208	5544	-853	15478	0	15478	1667	17145	50.00
7	6552	325	303	7180	152	4637	0	0	5689	5506	-860	16615	0	16615	1866	18481	49.97
8	6577	868	295	7740	160	4946	0	61	6031	6132	-859	18180	0	18180	2064	20244	49.98
9	6480	820	303	7603	142	5036	0	307	6294	6473	-1071	18490	0	18490	2339	20829	50.01
10	6129	1079	290	7498	146	5015	0	567	6669	6806	-1277	18755	0	18755	2599	21354	49.94
11	6054	1539	284	7877	207	4994	0	800	7165	7300	-1432	19746	0	19746	2773	22519	49.99
12	5983	1651	282	7916	395	4998	0	926	7445	7303	-1482	20056	0	20056	2820	22876	50.03
13	5961	1033	280	7274	523	5012	0	992	7388	7208	-1389	19620	0	19620	2722	22342	50.00
14	6081	747	279	7107	698	5003	0	920	7249	7057	-1285	19500	0	19500	2566	22066	50.04
15	6175	344	269	6788	860	5014	0	832	7283	7230	-1251	19473	0	19473	2581	22054	49.92
16	6086	375	279	6740	968	4979	0	584	6992	7090	-1262	19099	0	19099	2589	21688	50.00
17	6020	480	280	6780	1052	5005	0	352	6525	6253	-1241	18201	0	18201	2577	20778	49.95
18	5910	115	283	6308	914	4954	0	94	5992	5893	-1216	16947	0	16947	2539	19486	50.01
19	5727	226	285	6238	830	4818	0	0	5757	5766	-1404	16248	0	16248	2519	18767	49.91
20	5543	524	286	6353	995	4748	0	0	5559	5476	-1353	16219	0	16219	2444	18663	50.03
21	5263	212	290	5765	1091	4481	0	0	5433	5194	-1263	15268	0	15268	2364	17632	49.99
22	5396	153	291	5840	1090	4350	0	0	5352	5534	-1180	15634	0	15634	2244	17878	50.00
23	5524	120	301	5945	1005	4354	0	0	5258	5161	-1155	15310	0	15310	2057	17367	49.99
24	5497	105	290	5892	1057	4306	0	0	5154	4940	-1040	15155	0	15155	1896	17051	50.02
MUs	140.30	11.53	6.94	158.77	13.14	109.27	0.00	6.43	141.87	140.66	-26.86	401.42	0.00	401.42	53.32	454.75	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Jan/2020

Position as on 6.30 Hrs of 28/Jan/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
AEML	AEML Unit 2	250	06/01/2020	18.44		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-3	250	20/01/2020	09.00		Continued.	Maintenance work	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	30/11/2019	19.14	28/01/2020	22.21	Over Speed Bolt Trip.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)	
MSPGCL	Bhusawal Unit 5	500	23/12/2019	22.05		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 22.00Hrs DT. 26-12-2019)	
MSPGCL	Uran Unit B0	120	28/12/2019	22:48	28/01/2020	09.52	Gas shortage	
MSPGCL	Uran Unit 7	108	28/12/2019	22:48	28/01/2020	02.10	Gas shortage	
MSPGCL	Bhusawal Unit 4	500	29/12/2019	00.57		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Koyna Unit 9	80	18/01/2020	08.00	28/01/2020	11.15	Transformer shifting work.	
MSPGCL	Nasik Unit 4	210	21/01/2020	10.30		Continued.	Zero schedule	
IPP	RPL(AMT) U-1	270	25/01/2020	0:00		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Chandrapur Unit 4	210	26/01/2020	07.00		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Jan/2020

Position as on 6.30 Hrs of 28/Jan/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	28/01/2020	01.40		Continued.	Routine Operating Hour Equalization Of Units.	
MSPGCL	Uran Unit 5	108	28/01/2020	05.12	28/01/2020	05.38	Turbine Vibration	
MSPGCL	Koradi Unit-8	660	28/01/2020	17.03	28/01/2020	23.29	BFP Tripped	
MSPGCL	Uran Unit A0	120	28/01/2020	22.03		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	28/01/2020	22.03		Continued.	Gas shortage	
MSPGCL	Uran Unit 8	108	28/01/2020	22.44		Continued.	Tripped	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jan/2020

Statement-VII

Position as on 6.30 Hrs of 28/Jan/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 1	IntraState	27/01/2020	15.19	27/01/2020	16.08	T	Main Circuit Flow Low Trip Alaram Due To Aux Supply Trip.
Chandrapur - Padghe Hvdc Pole 1	IntraState	27/01/2020	16.35	27/01/2020	20.40	T	Thyristor valve cooling motor supply failure.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar II	InterState	25/01/2020	19.17	27/01/2020	08.16	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	27/01/2020	19.03	28/01/2020	06.41	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	28/01/2020	17.59		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	25/01/2020	18.15	27/01/2020	06.35	HT	Over Voltage
Karad-Jaigad - I	IntraState	26/01/2020	22.02	27/01/2020	11.13	HT	Over Voltage
Deepnagar - Aurangabad	IntraState	27/01/2020	06.46	27/01/2020	18.34	PO	Replacement Of Faulty String.
Main Bus I @ Chandrapur Sw	IntraState	27/01/2020	08.17	27/01/2020	19.12	PO	CT Jumpering Work Of Bay 413.
Chandrapur - Khaperkheda	IntraState	27/01/2020	14.18	27/01/2020	17.31	PO	To Attend Y-Phase Decaping At Location No-159.
Khadka-Aurangabad (Waluj)	IntraState	27/01/2020	19.00	28/01/2020	06.17	HT	Over Voltage
Deepnagar Waluj 1	IntraState	28/01/2020	09.12	28/01/2020	17.38	PO	Bird Guard Fixing
Khadka-Aurangabad (Waluj)	IntraState	28/01/2020	18.05		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential protection,Declared faulty.
400/220 Kv 315 Mva Ict -2 @New Koyana	IntraState	27/01/2020	08.29	28/01/2020	00.26	PO	Routine Maintenance Work
400/220 Kv 500 MVA ICT 3 @KOLHAPUR-III (TALANDGE)	IntraState	27/01/2020	09.09	27/01/2020	20.16	PO	Attending Oil Leakage
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	27/01/2020	13.45	27/01/2020	14.10	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
400/220kv 315MVA ICT 2 @ KOLHAPUR-III (TALANDGE)	IntraState	27/01/2020	13.45	27/01/2020	15.00	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	27/01/2020	20.16	28/01/2020	09.25	PO	For Main Bus Outage.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	27/01/2020	20.19	28/01/2020	09.27	PO	For Main Bus Outage.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	28/01/2020	00.01	28/01/2020	08.48	PO	Painting Work.
167 Mva Spare Ict @Lamboti	IntraState	28/01/2020	09.49		Continued.	PO	SFRA Testing.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	25/01/2020	08.45		Continued.	PO	Work At Tarapur End.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Kalwa-TIFIL	IntraState	27/12/2019	18.40		Continued.	PO	normalizing the Direct Circuit.
MAHAPE - RELIANCE GIS	IntraState	08/01/2020	10:44		Continued.	HT	At Mahape End For New Configuration.
Tambati - Adlabs	IntraState	27/01/2020	08.44	27/01/2020	09.35	PO	Distance Relay Replacement Work.
Talandge-Mudshingi Ckt-I	IntraState	27/01/2020	08.45		Continued.	PO	Construction Work.
Miraj-Ichalkaranji I	IntraState	27/01/2020	09.06	27/01/2020	18.44	PO	Replacement Of Disc Insulator.
Mumewadi -Halkarni ckt-I	IntraState	27/01/2020	09.11	27/01/2020	14.20	PO	Quarterly Maintenance Work
Padghe - Nalasopara	IntraState	27/01/2020	09.20	27/01/2020	17.28	PO	Stringing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jan/2020

Statement-VII

Position as on 6.30 Hrs of 28/Jan/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Bhira Dharavi 8	IntraState	27/01/2020	09.55	27/01/2020	16.02	PO	Conductor Shifting Work.
Main Bus @ Dasturi	IntraState	27/01/2020	10.25	27/01/2020	18.50	PO	Quarterly Maintenance Work
Trombay - Kalwa	IntraState	27/01/2020	10.54		Continued.	PO	Stringing Work.
Kolhapur - 5 Star Ckt I	IntraState	27/01/2020	11.39	27/01/2020	12.16	EO	To Attend Isolator Problem.
Boisar Versova Line	IntraState	27/01/2020	12.18	27/01/2020	19.36	PO	Removal Of Cable Termination For Bus-2.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	27/01/2020	13.45	27/01/2020	14.19	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Talandge(400kv)- Ichalkaranji ckt-2	IntraState	27/01/2020	13.45	27/01/2020	14.13	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Talandge(400)- Mudshingi 2 Line	IntraState	27/01/2020	13.45	27/01/2020	15.03	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Talandage - Sawantwadi I	IntraState	27/01/2020	13.45	27/01/2020	14.20	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Kolhapur-Bidri	IntraState	27/01/2020	13.45	27/01/2020	14.39	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Talandge-Hamidwada	IntraState	27/01/2020	1345	27/01/2020	14.24	T	220KV A Bus Bar Opereted. Due To Y-phase String Flashover Occured.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	28/01/2020	08.21	28/01/2020	18.38	PO	Replacement of Disc Insulator String with Antifogg
Adlabs - Pedambe	IntraState	28/01/2020	09.17	28/01/2020	19.30	PO	Cold washing of Insulator Strings
Bhira Dharavi 8	IntraState	28/01/2020	09.17	28/01/2020	16.26	PO	Maintenance work
Mumewadi -Halkarni ckt-II	IntraState	28/01/2020	09.31	28/01/2020	14.47	PO	CT Tan Delta
Karad - Vita Ckt- II	IntraState	28/01/2020	10.52	28/01/2020	17.27	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita - Ghatnandre	IntraState	28/01/2020	10.52	28/01/2020	17.32	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita-Khanapur(Mahuli Tap)	IntraState	28/01/2020	10.52	28/01/2020	17.29	PO	DC Contactor of 220KV Battery charger replacement and TBC bay Main Bus Isolator Alignment work
Vita-Wayphale	IntraState	28/01/2020	10.52	28/01/2020	17.52	PO	DC Contactor of 220KV Battery charger replacement and TBC bay Main Bus Isolator Alignment work
Vita - Mhaishal	IntraState	28/01/2020	10.52	28/01/2020	17.50	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita-Hiwarwadi	IntraState	28/01/2020	10.52	28/01/2020	17.31	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita Alkud	IntraState	28/01/2020	10.52	28/01/2020	17.30	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Karad-Nerle	IntraState	28/01/2020	11.03	28/01/2020	17.43	PO	Testing Work
Kalwa - Mulund 2	IntraState	28/01/2020	17.35	28/01/2020	19.03	EO	To attend Hot Spot
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-I @Borivali	IntraState	27/01/2020	09.51	27/01/2020	16.51	PO	CTR Work.
220/100 kV 200 MVA ICT III @Apta	IntraState	27/01/2020	12.20	27/01/2020	18.25	EO	Abnormal Sound From TF Tank Testing Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jan/2020

Statement-VII

Position as on 6.30 Hrs of 28/Jan/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33kv 50mva Bbl Ptr 1 @Talandage 5 Star Midc,Kagal)	IntraState	27/01/2020	12.45	27/01/2020	13.10	PO	Routine Maintenance Work
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/01/2020	10.24	28/01/2020	19.09	PO	Overhauling of LV CB
220/132 Kv 200 Mva Vijai lct 2 @Bale (Solapur 2)	IntraState	28/01/2020	10.52	28/01/2020	13.34	HT	Abnormal sound
220/132 KV 100MVA ICT-II @ Bhokar	IntraState	28/01/2020	11.40	28/01/2020	18.18	PO	Tan Delta and Capacitance Measurement of Bushing