

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Feb/2016 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.511	2935.029	1) Gujrat	-3.026	-85.850
2) Hydro	4.448	158.030	2) Madhya Pradesh	9.635	249.268
3) Gas	10.750	265.114	3) Chattisgarh	5.670	144.550
Total MSPGCL	123.709	3358.173	4) Maharashtra Net	82.924	2070.078
B) 1) APML	65.503	1673.632	5) Goa (Amona)	-0.560	-12.932
2) JSWEL	24.804	675.491	6) TAPS 1&2 Injection	3.496	93.056
3) VIPL	12.412	278.464	7) RGPPL Injection	11.671	313.806
4) RPL(AMT)	16.556	525.365	8) Pench (MS)	0.140	12.871
5) WPCL	4.914	122.391	9) Pench (Excess)	-0.140	-12.807
6) Other IPP	9.011	244.898	Total	109.670	2759.169
C) 1) TPCL Thermal	9.836	231.809	a) Mumbai Schedule	17.926	449.398
2) TPCL Hydro	2.202	95.575	b) Mumbai Drawl	23.731	614.495
3) TPCL Gas	4.145	103.875	c) MSEDCL Bilateral *	32.112	796.775
4) R-INFRA Thermal	11.236	287.827	Include PX	-1.010	-72.672
D) STATE			d) Mumbai Bilateral *	17.926	449.398
1) Thermal	262.783	6974.906	Include PX	2.068	33.175
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	6.650	253.605	H) ENERGY CATERED (MUs)		
3) Gas	14.895	368.989	1) MSEDCL	349.298	9239.554
4) Wind	5.241	183.089	2) Mumbai Discoms	51.150	1333.573
6) SOLAR	1.209	33.377	TOTAL STATE	400.448	10573.127
TOTAL STATE	290.778	7813.966			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4892	4871	4606	4083
MSPGCL Hydro	613	460	106	93
MSPGCL Gas	444	430	445	460
MSPGCL Total Generation	5949	5761	5157	4636
Central Sector Receipt	4960	4917	4730	3768
WIND	101	75	211	312
CPP / IPP	6014	5986	5706	4940
SOLAR	180	188	0	0
Exchange with Mumbai	-1257	-1202	-1250	-579
MSEDCL DEMAND MET	15947	15725	14554	13077
Load Shedding	4	4	25	4
MSEDCL DEMAND	15951	15729	14579	13081
TPCL GENERATION	831	875	755	515
R-INFRA GENERATION	515	518	514	402
MUMBAI DEMAND	2603	2595	2519	1496
STATE DEMAND MET	18550	18320	17073	14573
STATE DEMAND	18554	18324	17098	14577
Frequency (Hz)	50.01	49.94	49.94	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.25 Hz at 18.02 Hrs	49.72 Hz at 21.08 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 27/Feb/2016

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	62.24	0	0
Unit 6	0.00	0.00	0	0
Unit 7	3.10	34.25	150	120
Unit 8	8.41	169.73	355	350
Total	11.51	266.22		
Bhusawal				
Unit 2	4.02	108.36	185	160
Unit 3	4.09	98.55	180	160
Unit 4	0.00	121.46	0	0
Unit 5	9.91	221.08	510	350
Total	18.02	549.44		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	4.38	98.27	199	163
Unit 4	4.19	112.80	190	160
Unit 5	0.28	245.10	285	0
Unit 6	8.98	211.48	420	320
Unit 7	9.91	197.77	452	355
Total	27.74	865.41		
Paras				
Unit 3	5.50	138.53	254	186
Unit 4	5.56	141.13	256	190
Total	11.06	279.66		
Khaparkheda				
Unit 1	4.06	104.02	180	155
Unit 2	4.11	105.78	185	160
Unit 3	4.36	87.67	210	160
Unit 4	4.33	106.98	203	160
Unit 5	10.83	270.80	520	368
Total	27.69	675.24		
Nasik				
Unit 3	4.18	78.28	195	160
Unit 4	4.09	110.85	190	158
Unit 5	4.21	106.67	202	160
Total	12.48	295.79		
Uran				
All Units	10.75	265.11	476	413
Total	10.75	265.11		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.14	12.87	26	0
Total	0.14	12.87		
Koyna				
Stage 1-2	1.64	59.34	235	40
Stage 4	0.70	16.49	200	0
Stage 3	0.92	16.92	160	0
Total	3.25	92.75		
Hydro				
KDPH	0.42	12.01	18	17
VTRNA	0.00	0.28	0	0
TILLARI	0.00	2.42	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.00	5.69	0	0
RNGR+BHTSA	0.26	6.05	11	10
BHANDARDRA	0.00	4.89	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.52	18.76	22	21
GHATGHAR	0.00	15.18	0	0
Total	1.20	65.28		
Wind				
Total	5.24	183.09	0	0
Total	5.24	183.09		
CPP				
APML(Mus)	65.50	1673.63	0	0
JSWEL(Mus)	24.80	675.49	0	0
VIPL(Mus)	12.41	278.46	0	0
RPLAMT(Mus)	16.56	525.36	0	0
WPCL(Mus)	4.91	122.39	0	0
Other(Mus)	9.01	244.90	0	0
Total	133.20	3520.24		
SOLAR				
Total	1.21	33.38	0	0
Total	1.21	33.38		
Tata				
Trombay 5	9.84	196.04	492	312
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	63.91	113	87
Trombay 7B	1.56	39.97	67	58
Trombay 8	0.00	35.77	0	0
TATA Hydro	2.20	95.58	222	24
Total	16.18	431.26		
R-INFRA				
1-2	11.24	287.83	520	402
Total	11.24	287.83		

Infirm Power	Chandrapur 8	0.00	Koradi 9	0.00
---------------------	--------------	------	----------	------

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	108.51	2935.03
MSPGCL Thml+Gas	119.26	3200.14

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	4.45	158.03
MSPGCL Total	123.71	3358.17

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	2.34	75.83
State Total	290.78	7813.97

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Feb/2016

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4358	98	459	4915	474	4943	0	4280	4118	-886	13564	4	13568	1791	15359	50.00
2	4073	93	459	4625	288	4928	0	4156	4212	-702	13351	4	13355	1624	14979	49.97
3	4079	98	459	4636	314	4942	0	4055	4024	-627	13289	4	13293	1546	14839	49.99
4	4083	93	460	4636	312	4940	0	3993	3768	-579	13077	4	13081	1496	14577	49.99
5	4089	99	460	4648	327	4943	0	4031	3946	-584	13280	4	13284	1504	14788	49.97
6	4100	94	463	4657	481	5050	0	4414	4508	-677	14019	4	14023	1599	15622	49.93
7	4465	104	463	5032	394	5558	0	4713	4885	-697	15172	4	15176	1711	16887	50.01
8	4586	104	465	5155	252	5853	9	4843	5207	-660	15816	4	15820	1840	17660	49.99
9	4769	89	476	5334	144	5931	63	4866	5394	-829	16037	4	16041	2063	18104	49.98
10	4818	388	441	5647	117	5953	108	4871	4949	-933	15841	4	15845	2286	18131	49.98
11	4874	645	446	5965	110	5972	135	4938	4980	-1176	15986	4	15990	2542	18532	50.07
12	4892	613	444	5949	101	6014	180	4958	4960	-1257	15947	4	15951	2603	18554	50.01
13	4871	460	430	5761	75	5986	188	5014	4917	-1202	15725	4	15729	2595	18324	49.94
14	4886	133	425	5444	54	5942	174	4986	4832	-1111	15335	4	15339	2474	17813	49.96
15	4908	95	422	5425	43	5934	150	4961	5013	-1101	15464	4	15468	2471	17939	49.95
16	4920	96	413	5429	60	5973	112	4945	4775	-1071	15278	4	15282	2482	17764	49.97
17	4866	91	431	5388	96	5911	70	4813	4848	-1084	15229	4	15233	2450	17683	49.96
18	4677	101	444	5222	112	5770	20	3675	3673	-1145	13652	4	13656	2420	16076	49.94
19	4637	96	445	5178	154	5695	0	4016	3867	-1178	13716	25	13741	2416	16157	49.95
20	4606	106	445	5157	211	5706	0	4962	4730	-1250	14554	25	14579	2519	17098	49.94
21	4392	91	439	4922	341	5665	0	4715	4664	-1426	14166	11	14177	2377	16554	49.95
22	4233	193	455	4881	293	5535	0	4583	4393	-1295	13807	4	13811	2235	16046	49.94
23	4188	235	457	4880	228	5142	0	4721	4436	-1193	13493	4	13497	2106	15603	49.89
24	4141	233	449	4823	260	4911	0	4834	4573	-1068	13499	4	13503	2000	15503	49.88
MUs	108.51	4.45	10.75	123.71	5.24	133.20	1.21	110.34	109.67	-23.73	349.30	0.15	349.45	51.15	400.60	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Feb/2016

Position as on 6.30 Hrs of 28/Feb/2016

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CENT.SECTOR	Tarapur 2	160	10/09/2015	12.55		Continued.	Refuelling work	
MSPGCL	Koyna Unit 10	80	29/12/2015	08:00		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	No schedule	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Koradi Unit 6	210	20/03/2015	01.02		Continued.	Economic shutdown	
MSPGCL	Parli Unit 3	210	14/06/2015	12.58		Continued.	Water Shortage	
MSPGCL	Parli Unit 6	250	25/06/2015	15.03		Continued.	Water Shortage	
MSPGCL	Parli Unit 4	210	05/07/2015	18.45		Continued.	Water Shortage	
MSPGCL	Parli Unit 5	210	06/07/2015	14.55		Continued.	Water Shortage.	
MSPGCL	Parli Unit 7	250	08/07/2015	12.08		Continued.	Water Shortage	
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown	
MSPGCL	Chandrapur Unit-8	500	10/11/2015	12.10		Continued.	Drum level low	
RGPL	Dabhol 3B	230	07/01/2016	17:51		Continued.	Change Over.	
MSPGCL	Chandrapur Unit 2	210	12/01/2016	04.47		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 5	108	19/01/2016	14.34		Continued.	Overhauling	
RGPL	Dabhol 3X	290	03/02/2016	15:36		Continued.	Change Over	
TPC_G	Trombay 8	250	07/02/2016	17.40		Continued.	Boiler Maintenance Work,Bearing Inspection.	
MSPGCL	Ghatghar Unit-2	125	09/02/2016	18.00		Continued.	oil filtration work.	
MSPGCL	Bhusawal Unit 4	500	14/02/2016	12.10		Continued.	Zero Schedule Given by MSEDCL.	
MSPGCL	Ghatghar Unit-1	125	15/02/2016	00.00		Continued.	Attending Water valve Leakage.	
IPP	RPL(AMT) U-2	270	16/02/2016	01.14		Continued.	Due to Zero Schedule Given by MSEDCL.	
IPP	RPL(AMT) U-3	270	16/02/2016	01.17		Continued.	Due to Zero Schedule Given by MSEDCL.	
CPP	WPCL U-1	135	16/02/2016	17.09		Continued.	Change Over , No Schedule	
MSPGCL	Koradi Unit 5	200	18/02/2016	11.21		Continued.	MSEDCL Zero Shedule.	
CENT.SECTOR	TARAPUR 4	540	21/02/2016	10:33		Continued.	Transient Electric fault in Nuclear reactor.	
IPP	WPCL U-3	135	23/02/2016	07.28		Continued.	Botom Ash Conveyer belt problem.	
MSPGCL	Chandrapur Unit 5	500	27/02/2016	00.46	28/02/2016	18.16	Casing Diff.Temp. very high	
MSPGCL	Paras Unit 4	250	28/02/2016	11.53		Continued.	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Feb/2016

Statement-VII

Position as on 6.30 Hrs of 28/Feb/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
HVDC Pole-I	IntraState	28/02/2016	15.46	28/02/2016	20.39	T	Tripped @ C'pur End TC-1 High Oil Flow.
400 KV LINE Outages/Trippings							
Dhule Sar'Sarovar I	InterState	26/02/2016	17.15	27/02/2016	06.46	HT	Over Voltage
Kolhapur Solapur(PG) I	InterState	26/02/2016	20.48	27/02/2016	06.54	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	27/02/2016	17.12		Continued.	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	27/02/2016	17.31	28/02/2016	06.43	HT	Over Voltage
Dhule Khandwa II	InterState	28/02/2016	08.16	28/02/2016	09.24	T	Bus Bar Operated @ Dhule.
Dhule(MS)- Dhule(BDTCL) -1	InterState	28/02/2016	08.16	28/02/2016	09.34	T	Bus Bar Operated @ Dhule.
Dhule(MS)- Dhule(BDTCL) -1	InterState	28/02/2016	09.39	28/02/2016	12.21	T	Bus Bar Operated @ Dhule.
Dhule Khandwa II	InterState	28/02/2016	09.39	28/02/2016	12.31	T	Bus Bar Operated @ Dhule.
Kolhapur Solapur(PG) I	InterState	28/02/2016	16.43		Continued.	HT	Over Voltage
Akola II - Taptitanda ckt-II	IntraState	31/12/2015	18.16		Continued.	HT	Change over
Babhaleshwar-Taptitanda ckt-II	IntraState	11/02/2016	18.40		Continued.	HT	CHANGE OVER
Lonikand I - Koyna stage-IV	IntraState	25/02/2016	21.57		Continued.	HT	Over Voltage
Padghe - Nagothane - II	IntraState	26/02/2016	08.44	27/02/2016	08.06	PO	Repl.of Faulty Disc Insulator(RFC 17.27Hrs)
karad -kolhapur-I	IntraState	26/02/2016	16.37	27/02/2016	09.18	HT	Over Voltage
Karad - Jaigad - II	IntraState	26/02/2016	16.40	27/02/2016	09.22	HT	Over Voltage
Bhusawal-Aurangabad	IntraState	26/02/2016	17.08		Continued.	HT	Over Voltage
Chandrapur - Khaperkheda	IntraState	26/02/2016	22.42	27/02/2016	14.08	T	Distance Protection
Akola - Bhusawal	IntraState	27/02/2016	09.42	27/02/2016	22.37	PO	Testing Work
karad -kolhapur-II	IntraState	27/02/2016	16.13	28/02/2016	08.56	HT	Over Voltage
Karad-Jaigad - I	IntraState	27/02/2016	16.17	28/02/2016	08.59	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	28/02/2016	08.14		Continued.	PO	Insulator Replacement work(RFC @ 16.48 Hrs).
Dhule- Bableswhar - I	IntraState	28/02/2016	08.16	28/02/2016	12.13	T	Bus Bar Operated @ Dhule.
Chandrapur-II - Nanded	IntraState	28/02/2016	09.19	28/02/2016	19.25	PO	Fixing & Replacement of Broken Spacer Cum Vibration Damper.
Koradi-Bhusawal	IntraState	28/02/2016	15.34	28/02/2016	18.47	T	Distance Protection
karad -kolhapur-I	IntraState	28/02/2016	16.08		Continued.	HT	Over Voltage
Karad - Jaigad - II	IntraState	28/02/2016	16.31		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220kV 315 MVA ICT-I @ Lamboti	IntraState	27/02/2016	16.54	27/02/2016	19.23	PO	Testing Work
400/220/33 Kv 500 Mva Ict 3 @Dhule	IntraState	28/02/2016	08.16	28/02/2016	09.12	T	Bus Bar Operated @ Dhule.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/02/2016	08.26	28/02/2016	15.22	PO	Diagnostic Testing.
400/220/33 Kv 500 Mva Ict 3 @Dhule	IntraState	28/02/2016	09.39	28/02/2016	12.25	T	Bus Bar Operated @ Dhule.
220 KV LINE Outages/Trippings							
Hingoli- Girawali	InterState	14/02/2016	12.37		Continued.	HT	To Improve Voltage @ Hingoli.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Kalwa - Borivali	IntraState	10/01/2016	09:15		Continued.	PO	Tower Erection Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Feb/2016

Statement-VII

Position as on 6.30 Hrs of 28/Feb/2016

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GIS Bhandup - Borivali	IntraState	11/01/2016	07.42		Continued.	PO	Tower Erection Work.
Padghe - Vasai	IntraState	24/01/2016	08.32		Continued.	PO	For Formation of Temp. Padgha-Borivali (Charge upto 51/1).
Bableshwar- Alephata	IntraState	03/02/2016	06.28		Continued.	HT	controlling bblsr ICT Overloading
Bableshwar- Ranjangaon	IntraState	03/02/2016	07.12		Continued.	HT	controlling bblsr ICT Overloading
Chakan-Chinchwad	IntraState	26/02/2016	20.37	27/02/2016	05.17	PO	Erection of Narrow Base M/C Tower
Telco- Chinchwad	IntraState	26/02/2016	20.40	27/02/2016	05.19	PO	Erection of Narrow Base M/C Tower
Kandalgaon - Bhira	IntraState	27/02/2016	02.00		Continued.	T	CT Burst at Bhira end
Nasik - Raymond	IntraState	27/02/2016	09.30	27/02/2016	18.19	PO	Faulty Insulator string repl.work
Bableshwar- Bableshwar-II	IntraState	27/02/2016	11.40	27/02/2016	15.15	PO	Testing Work
Aurangabad (Waluj)-Bhenda	IntraState	27/02/2016	14.52	27/02/2016	18.10	PO	Isolator problem
Pusad-Ghatodi	IntraState	27/02/2016	16.54	27/02/2016	17.20	T	Distance Protection
Nanded-Ghatodi	IntraState	27/02/2016	16.56	27/02/2016	19.15	T	Distance Protection
Chakan-Chinchwad	IntraState	27/02/2016	20.36	28/02/2016	05.37	PO	Erection of Narrow Base M/C Tower
Telco- Chinchwad	IntraState	27/02/2016	20.38	28/02/2016	05.39	PO	Erection of Narrow Base M/C Tower
Parli 3 (Oldgr)-Harangul Ckt I	IntraState	27/02/2016	22.37	27/02/2016	22.57	T	Distance Protection
Trombay Salsette 1 Backbay	IntraState	28/02/2016	07.57		Continued.	PO	Routine Maintenance Work
Dhule-Chalisgaon	IntraState	28/02/2016	08.16	28/02/2016	09.17	T	LTS Operated for 400/220 KV 315 MVA ICT I & II.
Dhule-Amalner(220kv)	IntraState	28/02/2016	08.56	28/02/2016	09.28	HT	To Control ICT I & II Loading.
REL Borivali MSETCL Borivali Line-1	IntraState	28/02/2016	09.20	28/02/2016	13.12	PO	Annual Bay Maintenance.
Dahanu-Viraj	IntraState	28/02/2016	10.45	28/02/2016	20.18	PO	Local Scada Testing.
Matardevi - Loyd Metals	IntraState	28/02/2016	11.15	28/02/2016	12.35	T	Distance Protection
REL Borivali MSETCL Borivali Line-2	IntraState	28/02/2016	13.20		Continued.	PO	Annual Bay Maintenance.
Lamboti-Vita	IntraState	28/02/2016	17.01	28/02/2016	17.35	T	Distance Protection
Badnera - Amravati	IntraState	28/02/2016	17.15	28/02/2016	17.38	T	Distance Protection
Chinchwad-Hinjewadi I	IntraState	28/02/2016	20.04		Continued.	HT	For Chinchwad Outage.
Chakan-Chinchwad	IntraState	28/02/2016	20.18		Continued.	PO	Erection of Narow Base M/C Tower.
Telco- Chinchwad	IntraState	28/02/2016	20.20		Continued.	PO	Erection of Narow Base M/C Tower.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/132 Kv 200 Mva Ict - 2 @Harangul	IntraState	15/02/2016	13.04		Continued.	PO	Work of Oil Filtration of ICT.
220/33kv 100 MVA ICT-II @ Boisar	IntraState	20/02/2016	14.51		Continued.	T	Differential Protn.Optd./Internal Fault.Declared Faulty.
220/132 kv 200MVA ICT II @ Girwali	IntraState	27/02/2016	09.01	27/02/2016	17.51	EO	To attend Hot Spot
220/132 Kv 100 Mva T&R Ict-1 @Bambhori	IntraState	27/02/2016	09.06	27/02/2016	15.36	PO	Attending Oil Leakage
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	27/02/2016	11.35	27/02/2016	14.30	PO	Attending Oil Leakage
132 KV LINE Outages/Trippings							
Pusad-Jambazar	IntraState	27/02/2016	16.54	27/02/2016	21.12	T	Distance Protection
Waghala (Nanded2) - Tamsa	IntraState	27/02/2016	18.50	27/02/2016	20.11	T	Distance Protection
Kaulewada-Gondia-I	IntraState	27/02/2016	23.08		Continued.	T	Distance Protection
Raimoha - Pathardi	IntraState	28/02/2016	20.05	28/02/2016	20.15	T	Distance Protection
Beed(220kv) -Telgaon	IntraState	28/02/2016	20.39	28/02/2016	22.03	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage