

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Feb/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.783	4210.309	1) Gujrat	2.747	-37.931
2) Hydro	23.345	433.453	2) Madhya Pradesh	2.591	94.196
3) Gas	4.025	118.847	3) Chattisgarh	4.000	119.080
Total MSPGCL	187.153	4762.609	4) Maharashtra	160.208	4562.425
B) 1) APML	75.930	1994.459	5) Goa (Amona)	-0.844	-34.062
2) JSWEL	25.843	568.737	Total	168.702	4703.708
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.238	776.830
4) RPL(AMT)	25.578	797.600	b) Mumbai Drawl	35.457	949.828
5) SWPGPL	8.386	213.351	c) MSEDCL Bilateral *	75.136	1943.296
6) Other IPP	47.133	1166.895	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.237	776.377
C) 1) TPCL Thermal	14.076	241.926	Include PX	0.000	0.000
2) TPCL Hydro	4.808	104.073	Standby	0.001	0.453
3) TPCL Gas	0.000	31.445	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.713	274.839	1) MSEDCL	517.687	13667.473
D) STATE			2) Mumbai Discoms	66.054	1602.108
1) Thermal	368.442	9468.116	3) Other Discoms	10.198	268.524
(A1+C1+C4+(B1-B6))			TOTAL STATE	593.939	15538.105
2) Hydro (A2+C2)	28.153	537.526			
3) Gas (A3+B7+C3)	4.025	150.292			
4) Wind	9.374	253.213			
6) SOLAR	15.243	425.253			
TOTAL STATE	425.237	10834.400			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6709	6659	6576	6694
MSPGCL Hydro	1301	774	1754	159
MSPGCL Gas	124	169	214	130
MSPGCL Total Generation	8134	7602	8544	6983
Central Sector Receipt	8588	9005	6717	6522
WIND	304	180	212	452
CPP / IPP Thermal	7756	7302	7714	7335
CPP / IPP Gas	0	0	0	0
SOLAR	2094	2161	0	0
Exchange with Mumbai	-2048	-2129	-1470	-1212
MSEDCL DEMAND MET	24366	23675	21249	19754
Load Shedding	0	0	0	0
MSEDCL DEMAND	24366	23675	21249	19754
TPCL GENERATION	777	658	1064	406
AEML GENERATION	455	475	470	497
MUMBAI DEMAND	3280	3262	3004	2115
OTHER DISCOM DEMAND	462	446	468	326
STATE DEMAND MET	28108	27383	24721	22195
STATE DEMAND	28108	27383	24721	22195
Frequency (Hz)	49.97	49.96	49.98	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.33 Hz at 02:56 Hrs	49.66 Hz at 08:52 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.86	116.93	210	200
Unit 8	14.20	369.86	633	527
Unit 9	13.79	355.68	610	530
Unit 10	12.50	330.80	605	455
Total	45.35	1173.26		
Bhusawal				
Unit 3	3.58	90.74	165	125
Unit 4	11.36	279.56	500	350
Unit 5	11.28	277.88	495	415
Total	26.23	648.18		
Parli				
Unit 6	0.00	97.35	0	0
Unit 7	5.67	93.64	252	176
Unit 8	0.82	88.38	105	0
Total	6.49	279.36		
Chandrapur				
Unit 3	3.93	98.30	170	155
Unit 4	2.84	80.84	130	113
Unit 5	0.00	76.31	0	0
Unit 6	9.47	235.09	405	375
Unit 7	0.00	0.00	0	0
Unit 8	11.83	307.52	499	485
Unit 9	11.92	223.59	500	483
Total	40.00	1021.66		
Paras				
Unit 3	4.57	131.70	207	173
Unit 4	5.18	152.83	238	188
Total	9.75	284.53		
Khaparkheda				
Unit 1	2.87	52.44	125	115
Unit 2	2.84	77.28	145	95
Unit 3	4.04	102.96	183	148
Unit 4	4.20	94.23	180	164
Unit 5	10.73	292.42	500	400
Total	24.66	619.32		
Nasik				
Unit 3	0.00	91.66	0	0
Unit 4	3.54	19.01	161	128
Unit 5	3.76	73.32	173	117
Total	7.30	183.99		
Uran				
All Units	4.02	118.85	231	124
Total	4.02	118.85		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.11	10.04	47	0
Total	0.11	10.04		
Koyna				
Stage 1-2	6.24	116.06	475	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	9.83	133.18	759	0
Stage 3	3.12	52.88	320	0
Total	19.19	302.13		
Hydro				
KDPH	0.86	19.90	36	36
VTRNA	1.00	19.00	60	0
TILLARI	0.00	10.29	0	0
BHIRA T.R.	0.16	6.05	40	0
SMLHY_PTN	2.02	61.42	88	79
GHATGHAR	0.00	4.64	0	0
Total	4.04	121.29		
Wind				
Total	9.37	253.21	0	0
Total	9.37	253.21		
CPP				
APML(Mus)	75.93	1994.46	0	0
JSWEL(Mus)	25.84	568.74	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.58	797.60	0	0
SWPGPL-Mus	8.39	213.35	0	0
Dhariwal	6.30	50.08	276	203
IEPL	6.07	143.87	263	228
Other(Mus)	34.77	972.94	0	0
Total	182.87	4741.04		
SOLAR				
Total	15.24	425.25	0	0
Total	15.24	425.25		
Tata				
Trombay 5	9.40	129.79	464	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	17.51	0	0
Trombay 7B	0.00	13.94	0	0
TATA Hydro	4.81	104.07	424	7
Trombay 8	4.68	112.13	223	132
Total	18.88	377.44		
AEML				
DTPS U-1&2	11.71	274.84	502	455
Total	11.71	274.84		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.78	4210.31	MSPGCL Total	187.15	4762.61
			MSPGCL Thml+Gas	163.81	4329.16	Koyna 1,2 & 4 Total	16.07	249.24
			MSPGCL Hydro	23.34	433.45	State Total	425.24	10834.40

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	6699	360	126	7185	181	7701	0	0	5907	6176	-1369	19497	0	19497	2375	377	22249	50.00
2	6683	265	129	7077	240	7452	0	0	6543	6596	-1304	19705	0	19705	2231	356	22292	50.01
3	6694	159	130	6983	452	7335	0	0	6731	6522	-1212	19754	0	19754	2115	326	22195	50.01
4	6581	158	128	6867	635	7341	0	0	6907	6563	-1138	19948	0	19948	2045	320	22313	50.01
5	6631	155	130	6916	694	7391	0	0	6883	6751	-1120	20286	0	20286	2031	346	22663	50.02
6	6707	377	131	7215	771	7660	0	0	6814	6697	-1069	20889	0	20889	2152	385	23426	50.03
7	6806	1048	128	7982	827	7769	0	10	6439	6426	-1047	21558	0	21558	2298	409	24265	49.99
8	6814	1665	129	8608	675	7779	0	265	6445	6607	-1127	22372	0	22372	2479	435	25286	50.01
9	6835	1337	130	8302	550	7776	0	869	6665	6845	-1365	22524	0	22524	2767	453	25744	50.03
10	6893	1334	129	8356	613	7770	0	1473	7149	7410	-1622	23549	0	23549	3040	451	27040	49.98
11	6773	1435	129	8337	548	7752	0	1923	7646	7889	-1846	24140	0	24140	3229	463	27832	49.96
12	6709	1301	124	8134	304	7756	0	2094	8087	8588	-2048	24366	0	24366	3280	462	28108	49.97
13	6659	774	169	7602	180	7302	0	2161	8857	9005	-2129	23675	0	23675	3262	446	27383	49.96
14	6650	493	197	7340	110	7254	0	2055	8704	8828	-2001	23154	0	23154	3144	432	26730	49.94
15	6614	855	195	7664	110	7372	0	1828	8766	8609	-2058	23080	0	23080	3201	445	26726	49.90
16	6577	1480	199	8256	109	7695	0	1421	7970	8209	-1956	23279	0	23279	3249	455	26983	49.95
17	6529	1619	195	8343	195	7703	0	844	6988	7784	-1653	22736	42	22778	3226	480	26484	49.88
18	6445	1732	198	8375	165	7727	0	283	6739	6732	-1531	21267	80	21347	3133	484	24964	50.02
19	6523	1625	207	8355	169	7725	0	17	6455	6530	-1469	20861	0	20861	3034	466	24361	49.95
20	6576	1754	214	8544	212	7714	0	0	6481	6717	-1470	21249	0	21249	3004	468	24721	49.98
21	6631	1091	222	7944	281	7720	0	0	6036	5975	-1350	20113	0	20113	2858	457	23428	50.02
22	6644	737	226	7607	429	7712	0	0	5658	5822	-1250	19876	0	19876	2730	444	23050	50.01
23	6572	638	229	7439	517	7726	0	0	5558	5613	-1184	19683	0	19683	2630	428	22741	49.94
24	6538	953	231	7722	407	7738	0	0	5467	5808	-1139	20139	0	20139	2541	397	23077	49.96
MUs	159.78	23.35	4.03	187.15	9.37	182.87	0.00	15.24	165.89	168.70	-35.46	517.70	0.12	517.82	66.05	10.18	594.06	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Feb/2023

Position as on 6.30 Hrs of 28/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/03/2023
IPP	SWPGPL U-2	135	08/02/2023	00:01		Continued.	Bag Filter replacement work	02/03/2023
MSPGCL	Chandrapur Unit 5	500	12/02/2023	00:05		Continued.	Boiler validity work	27/02/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30	28/02/2023	14:36	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	28/02/2023
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	30/04/2023
TPC-G	Trombay 7B	60	15/02/2023	16:54		Continued.	Gas shortage	
MSPGCL	Parli Unit 6	250	21/02/2023	20:15		Continued.	Air heater problem	28/02/2023
TPC-G	Trombay 7A	120	21/02/2023	20:26		Continued.	Gas shortage	
MSPGCL	Uran Unit B0	120	25/02/2023	06:53	28/02/2023	10:58	CTO temperature high	
MSPGCL	Nasik Unit 3	210	25/02/2023	12:00		Continued.	Boiler Tube Leakage	28/02/2023
IPP	RPL(AMT) U-4	270	25/02/2023	17:00		Continued.	Bottom Ash evacuation problem	28/02/2023
MSPGCL	Uran Unit 6	108	25/02/2023	19:41	27/02/2023	12:18	Gas shortage	
MSPGCL	Parli Unit 8	250	26/02/2023	06:38	27/02/2023	13:50	Oil Pressure Low and Coal Mill Problem.	
MSPGCL	Koyna Unit 8	80	27/02/2023	09:00	28/02/2023	14:40	attending problem of needle no.1	28/02/2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 28/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (416) OF STATION TF 4A @ DEEPNAGAR	IntraState	27/02/2023	09:37	27/02/2023	20:34	PO	for removing all phases both side C.B. pad clamp for cleaning purpose & again fixing the said clamp for measurement of CRM.
BUS COUPLER @ NAGOTHANE	IntraState	27/02/2023	20:25	27/02/2023	23:56	EO	Emergency outage of 400kV Bus Coupler at 400 kV R.S. O&M DIV.Nagothane to attain the Trip circuit-1 Faulty problem due to low N2 pressure and oil leakage.
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	27/02/2023	08:49	27/02/2023	19:53	PO	For Replacement of PID Suspected insulator disc & Cold line washing work.
DHULE - SSNNL CKT - 1	InterState	28/02/2023	10:43			PO	For Replacement of PID suspected insulator disc & Cold line washing work.
PADGHE - KALWA CKT - 1	IntraState	20/02/2023	14:26	27/02/2023	19:28	PO	1) CB pole Overhauling work as Bph pole SF6 gas contents SO2 beyond permissible limit . 2) Replacement of B bus PG isolator under LES scheme as HTLS conductor work in progress of Kalwa line 3) 400kV Kalwa -1 in service through TBC at Padghe end
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	20/02/2023	15:36			HT	HAND TRIPPED FOR LOAD MANAGEMENT
KHADKA-AURANGABAD (WALUJ)	IntraState	27/02/2023	06:32	27/02/2023	17:38	PO	replacement for faulty disc insulator strings detected in PID & Monkey Patrolling
MAIN BUS - 2 @ KUMBHARGAON (NANDED)	IntraState	28/02/2023	11:23			PO	400kV Bus Isolator & BPI erection for Bus-2 for 400 kV Reactor Bay.
EKTUNI - BABLESHWAR CKT - 2	IntraState	28/02/2023	11:35	28/02/2023	13:10	PO	MTAMC work. No outage required only permission for shorting metering core to replace MFM meter outage not required.
KHADKA - BABLESHWAR	IntraState	28/02/2023	13:19			PO	replacement of faulty disc insulator strings detected in PID & Monkey Patrolling
LONIKAND 2 - KARJAT CKT - 2	IntraState	28/02/2023	13:38	28/02/2023	16:24	T	Tripped on Dist. Protection.
400 KV ICT Outages/Trippings							
400/220KV 315 MVA ICT - 2 @ NEW KOYNA	IntraState	27/02/2023	09:01	27/02/2023	20:21	PO	Diagnostic testing & Relay testing work & Routine maint. Work ICT & CTR, CT oil leakage attending work
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	28/02/2023	11:29	28/02/2023	15:12	PO	220kv(IV) bay CB testing work
105 MVA SPARE ICT @ AKOLA	IntraState	28/02/2023	11:52	28/02/2023	15:30	PO	DCRM, Tandelata & routine maintenance work
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ RANJANGAON	IntraState	25/02/2023	16:02	27/02/2023	18:44	EO	220kV Isolator alignment work is going on in co-ordination with hot line unit & M/s Bimco.Hot Line unit given clearance today dt 24.02.2023 evening to carry out above work.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/02/2023	17:54			HT	HT for Load Management
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 28/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR - VERSOVA	IntraState	13/02/2023	15:28			PO	1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
DAHANU - VERSOVA	IntraState	13/02/2023	15:34			PO	Project activity 1) Modification / relocation of existing tower no LS 216 to 223 at Vasai for NHSRCL Project. 2) Modification / relocation of existing tower no LS 223 to 226 at Vasai for DFCCIL project.
KAMBA - VASAI	IntraState	26/02/2023	21:41	27/02/2023	03:48	EO	To carry out the height raising work of AEMLS existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village Gokhivare (Vasai) in connection with DFC project of Govt of India.
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/02/2023	21:52	27/02/2023	03:54	EO	To carry out the height raising work of AEMLS existing 220 KV, Double Circuit, LS-Line section, between Tower Locations LS-223 & LS-226, along the existing corridor/ROW of AEML, at Village - Gokhivare (Vasai) in connection with DFC project of Govt of India.
TROMBAY - SALSETTE CKT - 1	IntraState	27/02/2023	00:20	27/02/2023	04:35	PO	Work in vicinity for A ph cable jumper connection of 110 kV Dharavi Vikhroli Ckt on new monopole loc. 4B.
CHIKHALI-JALNA I	IntraState	27/02/2023	03:21	27/02/2023	09:32	HT	Control loading On Akola ICT.
KHAREPATAN -PAWAS LINE	IntraState	27/02/2023	07:31	27/02/2023	09:58	PO	For CT to gantry Y ph insulator string replacement of Kharepatan bay at Pawas end. It is necessary to replace the insulator string due to heavy chattering & sparking observed on it in evening humid weather condition.
BORIVALI - TARAPUR	IntraState	27/02/2023	08:52			PO	Replacement of rusted Hardware between the loc no. 28 to 50 under Scheme.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	27/02/2023	10:20	28/02/2023	00:19	HT	Hand tripped due to 220KV Nashik-BBLSR line Loading
APTA - BOMBAY DYEING	IntraState	27/02/2023	12:34	27/02/2023	16:47	PO	C T Tan delta and diagnostic testing work at Apta end and Bombay dyeing end CB Trip coil problem attending work
ADLABS - PEDAMBE	IntraState	27/02/2023	13:07	27/02/2023	17:25	PO	For replacement of damaged insulator string (ball rod rusted very badly) at loc no. 47A SSN top ph.
BHUGAON - WARDHA (PG)	IntraState	27/02/2023	16:30	27/02/2023	20:56	HT	To control state OD
BHUGAON - WARDHA (PG)	IntraState	27/02/2023	16:30	27/02/2023	20:56	HT	OD-955 F-49.87
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 1	IntraState	27/02/2023	17:05	27/02/2023	20:55	HT	To control state OD
CHALISGAON - SAYNE	IntraState	27/02/2023	20:37	28/02/2023	04:41	EO	Attending CT Leakage.
TROMBAY SALSETTE LINE-2	IntraState	28/02/2023	04:03	28/02/2023	04:03	PO	400 KV KVPTL WORK
KANDALGAON - KOYNA (POPHALI)	IntraState	28/02/2023	08:45	28/02/2023	16:20	HT	Tripped on Y-ph conductor snap in Swichyard pophali.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 28/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	28/02/2023	10:56			HT	To control line loading
CHINCHWAD-2 - TELCO	IntraState	28/02/2023	11:13	28/02/2023	11:23	HT	To control line loading
LONIKAND (400 KV)-THEUR II	IntraState	28/02/2023	13:45			T	Tripped on Dist. Protection.
BHUGAON - WARDHA (PG)	IntraState	28/02/2023	15:56			HT	H/T for Overdrawal Control
NAGOTHANE - WADKHAL (GIS) CKT-1	IntraState	28/02/2023	16:29			T	Tripped on Dist. Protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	27/02/2023	10:08	27/02/2023	17:54	EO	Emergency outage for attending the OLTC problem, detected as current imbalance observed in all phases
220/132 KV 150 MVA ICT @ BOISAR-II	IntraState	27/02/2023	14:56	27/02/2023	15:20	HT	sparking was observed at HV side -220kv B Bus Isolator of 150MVA
220/132KV 150MVA ICT - 1 @ MALINAGAR	IntraState	27/02/2023	16:58	27/02/2023	19:20	PO	Outage is required for Testing work by Testing Division Solapur
220/132/11KV 200 MVA ICT 2 @ MALINAGAR	IntraState	27/02/2023	19:30	27/02/2023	21:59	PO	Outage is required for Testing work by Testing Division Solapur
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	10/02/2023	23:17			PO	for 400KV Project work of KVPTL
DHARAVI POWAI	IntraState	10/02/2023	23:35			PO	For 400KV project work on KVPTL
WAGHIVALI - MANKHURD	IntraState	27/02/2023	23:46	28/02/2023	04:56	PO	PROJECT WORK-Movement of jack up barge in the vicinity

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage