

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 27/Mar/2020 FRIDAY**

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	78.199	3940.333	1) Gujrat	7.082	190.671
2) Hydro	14.788	243.254	2) Madhya Pradesh	15.012	362.038
3) Gas	6.196	184.798	3) Chattisgarh	6.020	149.360
<b>Total MSPGCL</b>	<b>99.183</b>	<b>4368.385</b>	4) Maharashtra	105.323	3171.412
B) 1) APLM	50.687	1769.258	5) Goa (Amona)	0.000	-8.470
2) JSWEL	9.077	417.101	<b>Total</b>	<b>133.437</b>	<b>3865.011</b>
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.536	566.975
4) RPL(AMT)	0.000	64.411	b) Mumbai Drawl	17.023	587.541
5) WPCL	5.552	91.406	c) MSEDCL Bilateral *	33.481	937.149
6) Other IPP	9.509	365.128	Include PX	13.785	164.281
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.536	566.975
C) 1) TPCL Thermal	12.891	345.632	Include PX	6.934	159.497
2) TPCL Hydro	4.031	95.511	Standby	0.000	0.000
3) TPCL Gas	2.588	77.852	<b>H) ENERGY CATERED (MUs)</b>		
4) AEML Thermal	6.709	259.201	1) MSEDCL	305.033	10894.640
D) STATE			2) Mumbai Discoms	43.242	1365.742
1) Thermal	172.624	7252.470	<b>TOTAL STATE</b>	<b>348.275</b>	<b>12260.382</b>
(A1+C1+C4+(B1-B6))					
2) Hydro	18.819	338.765			
(A2+C2)					
3) Gas	8.784	262.650			
(A3+B7+C3)					
4) Wind	7.839	341.698			
6) SOLAR	6.772	199.783			
<b>TOTAL STATE</b>	<b>214.838</b>	<b>8395.366</b>			

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3080	3043	3259	3291
MSPGCL Hydro	296	300	1007	333
MSPGCL Gas	271	269	276	278
MSPGCL Total Generation	3647	3612	4542	3902
Central Sector Receipt	6769	6858	4838	4912
WIND	302	234	230	427
CPP / IPP Thermal	3189	3128	3235	2885
CPP / IPP Gas	0	0	0	0
SOLAR	933	924	0	0
Exchange with Mumbai	-827	-864	-872	-460
<b>MSEDCL DEMAND MET</b>	<b>14013</b>	<b>13892</b>	<b>11973</b>	<b>11666</b>
Load Shedding	0	0	0	0
MSEDCL DEMAND	14013	13892	11973	11666
TPCL GENERATION	786	786	804	805
AEML GENERATION	193	192	192	502
<b>MUMBAI DEMAND</b>	<b>1806</b>	<b>1842</b>	<b>1868</b>	<b>1767</b>
STATE DEMAND MET	15819	15734	13841	13433
<b>STATE DEMAND</b>	<b>15819</b>	<b>15734</b>	<b>13841</b>	<b>13433</b>
Frequency (Hz)	49.98	49.99	49.99	49.96

**FREQUENCY PARTICULARS**

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.22 Hz at 06.03 Hrs	49.73 Hz at 00.08 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation, Maximum, Minimum for 27/Mar/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Koradi</b>				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.10	288.02	364	302
Unit 9	10.11	302.90	505	350
Unit 10	9.44	289.70	430	375
<b>Total</b>	<b>27.66</b>	<b>880.63</b>		
<b>Bhusawal</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	211.68	0	0
Unit 5	0.00	212.19	0	0
<b>Total</b>	<b>0.00</b>	<b>423.87</b>		
<b>Parli</b>				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	77.26	0	0
Unit 7	0.00	69.80	0	0
Unit 8	0.00	120.48	0	0
<b>Total</b>	<b>0.00</b>	<b>267.54</b>		
<b>Chandrapur</b>				
Unit 3	0.00	107.76	0	0
Unit 4	0.00	102.86	0	0
Unit 5	0.00	162.73	0	0
Unit 6	0.00	221.38	0	0
Unit 7	9.70	234.36	461	360
Unit 8	10.32	240.80	486	360
Unit 9	9.33	266.27	440	360
<b>Total</b>	<b>29.35</b>	<b>1336.16</b>		
<b>Paras</b>				
Unit 3	5.51	129.59	258	190
Unit 4	5.49	133.28	256	195
<b>Total</b>	<b>11.00</b>	<b>262.87</b>		
<b>Khaparkhedda</b>				
Unit 1	0.00	96.24	0	0
Unit 2	0.00	101.78	0	0
Unit 3	0.00	100.65	0	0
Unit 4	0.00	95.80	0	0
Unit 5	10.19	273.75	500	360
<b>Total</b>	<b>10.19</b>	<b>668.21</b>		
<b>Nasik</b>				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	101.06	0	0
Unit 5	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>101.06</b>		
<b>Uran</b>				
All Units	6.20	184.80	289	145
<b>Total</b>	<b>6.20</b>	<b>184.80</b>		
<b>PGPL</b>				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		
<b>PENCH (MS)</b>				
Pench (MS)	0.03	1.43	17	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
<b>Total</b>	<b>0.03</b>	<b>1.43</b>		
<b>Koyna</b>				
Stage 1-2	6.24	82.16	565	45
Stage 4	3.76	61.32	745	0
Stage 3	2.22	31.77	218	0
<b>Total</b>	<b>12.22</b>	<b>175.24</b>		
<b>Hydro</b>				
KDPH	0.89	19.82	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.27	10.08	60	0
BHTGR/VEER	0.00	0.36	0	0
BHIRA T.R.	0.12	4.37	63	0
RNGR+BHTSA	0.33	8.61	14	13
BHANDARDRA	0.47	9.44	29	13
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.49	13.86	31	17
GHATGHAR	0.00	1.49	0	0
<b>Total</b>	<b>2.57</b>	<b>68.01</b>		
<b>Wind</b>				
Total	7.84	341.70	0	0
<b>Total</b>	<b>7.84</b>	<b>341.70</b>		
<b>CPP</b>				
APML(Mus)	50.69	1769.26	0	0
JSWEL(Mus)	9.08	417.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	64.41	0	0
WPCL(Mus)	5.55	91.41	0	0
Other(Mus)	9.51	365.13	0	0
<b>Total</b>	<b>74.82</b>	<b>2707.30</b>		
<b>SOLAR</b>				
Total	6.77	199.78	0	0
<b>Total</b>	<b>6.77</b>	<b>199.78</b>		
<b>Tata</b>				
Trombay 5	8.12	222.16	432	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.44	45.96	65	59
Trombay 7B	1.15	31.89	52	47
Trombay 8	4.78	123.47	240	154
TATA Hydro	4.03	95.51	284	41
<b>Total</b>	<b>19.51</b>	<b>519.00</b>		
<b>AEML</b>				
DTPS U-1&2	6.71	259.20	503	189
<b>Total</b>	<b>6.71</b>	<b>259.20</b>		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	78.20	3940.33	MSPGCL Total	99.18	4368.38
			MSPGCL Thml+Gas	84.40	4125.13	Koyna 1,2 & 4 Total	10.00	143.48
			MSPGCL Hydro	14.79	243.25	State Total	214.84	8395.37

# State Load Despatch Center, Airoli (MSETCL)

# Annexure-2

## Hourly Load Data As on 27/Mar/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDING	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3382	1086	267	4735	568	2905	0	0	4593	4619	-665	12162	0	12162	2018	14180	49.95
2	3305	628	277	4210	436	2900	0	0	5008	4926	-590	11882	0	11882	1908	13790	49.97
3	3324	534	276	4134	410	2893	0	0	5033	4845	-539	11743	0	11743	1828	13571	49.98
4	3291	333	278	3902	427	2885	0	0	5109	4912	-460	11666	0	11666	1767	13433	49.96
5	3331	423	267	4021	443	2882	0	0	5063	5103	-405	12044	0	12044	1723	13767	49.99
6	3357	843	273	4473	412	2931	0	0	5292	5567	-433	12950	0	12950	1729	14679	50.05
7	3374	1344	145	4863	216	3020	0	73	5993	6182	-585	13769	0	13769	1684	15453	50.06
8	3465	1605	166	5236	150	3172	0	184	5673	5861	-635	13968	0	13968	1672	15640	49.99
9	3524	1124	177	4825	251	3266	0	399	5642	5429	-560	13610	0	13610	1710	15320	49.97
10	3570	443	210	4223	277	3280	0	586	6233	5804	-618	13552	0	13552	1770	15322	49.98
11	3255	335	242	3832	306	3241	0	808	6455	6077	-818	13446	0	13446	1793	15239	50.00
12	3080	296	271	3647	302	3189	0	933	6873	6769	-827	14013	0	14013	1806	15819	49.98
13	3043	300	269	3612	234	3128	0	924	7035	6858	-864	13892	0	13892	1842	15734	49.99
14	3033	563	270	3866	213	3121	0	849	6627	6657	-830	13876	0	13876	1812	15688	50.03
15	3045	285	277	3607	195	3115	0	793	6911	6793	-812	13691	0	13691	1776	15467	49.99
16	3036	458	267	3761	198	3126	0	649	6738	6632	-779	13587	0	13587	1744	15331	49.94
17	3008	553	279	3840	337	3127	0	403	6154	5910	-750	12867	0	12867	1716	14583	49.93
18	2980	308	283	3571	244	3138	0	161	5593	5456	-729	11841	0	11841	1696	13537	49.97
19	2995	468	284	3747	235	3135	0	10	4768	4862	-755	11234	0	11234	1721	12955	49.93
20	3259	1007	276	4542	230	3235	0	0	4569	4838	-872	11973	0	11973	1868	13841	49.99
21	3327	565	276	4168	334	3273	0	0	4796	4658	-878	11555	0	11555	1883	13438	50.00
22	3410	316	288	4014	531	3269	0	0	4801	4906	-892	11828	0	11828	1907	13735	49.97
23	3418	320	289	4027	471	3288	0	0	4791	4900	-833	11853	0	11853	1924	13777	50.03
24	3387	651	289	4327	419	3306	0	0	4735	4873	-894	12031	0	12031	1945	13976	49.97
<b>MUs</b>	<b>78.20</b>	<b>14.79</b>	<b>6.20</b>	<b>99.18</b>	<b>7.84</b>	<b>74.82</b>	<b>0.00</b>	<b>6.77</b>	<b>134.49</b>	<b>133.44</b>	<b>-17.02</b>	<b>305.03</b>	<b>0.00</b>	<b>305.03</b>	<b>43.24</b>	<b>348.28</b>	<b>49.98</b>

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center, Airoli (MSETCL) Statement-VI**  
**Details of Generating Unit Outages/Trippings for 27/Mar/2020**

Position as on 6.30 Hrs of 28/Mar/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
<b>FORCED OUTAGE</b>								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 10.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)	
IPP	RPL(AMT) U-3	270	11/02/2020	18.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	11/02/2020	19.30		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Nasik Unit 3	210	17/02/2020	00:00		Continued.	C W PUMP High Vibrations(convert to Zero Schedule from 00.00Hrs DT. 18-02-2020)	
MSPGCL	Ghatghar Unit-1	125	18/02/2020	00.25		Continued.	Severe Hunting In Hydro Conduit Across MIV	
IPP	JSW (J) U1	300	01/03/2020	06.10		Continued.	Governor Valve Replacement.	
MSPGCL	Uran Unit 8	108	01/03/2020	20.57		Continued.	Gas shortage	
IPP	RPL(AMT) U-1	270	04/03/2020	19.30		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Ghatghar Unit-2	125	09/03/2020	10:50		Continued.	Expansion joint leakage.	
IPP	RPL(AMT) U-2	270	09/03/2020	20.15		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 6	108	21/03/2020	15.15	27/03/2020	07.14	Gas shortage	
MSPGCL	Parli Unit 6	250	21/03/2020	17.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	22/03/2020	10.45		Continued.	Zero Schedule. (R S D FROM 10:45 TO 16:00 Hrs.)	
MSPGCL	Bhusawal Unit 4	500	22/03/2020	18.30		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	23/03/2020	01.13		Continued.	Zero schedule.	
MSPGCL	Parli Unit 8	250	23/03/2020	18.00		Continued.	Zero Schedule.	
IPP	Adani U-4	660	23/03/2020	18.27	27/03/2020	05.22	Hot PA bellow leakage.	
MSPGCL	Chandrapur Unit 6	500	23/03/2020	21.59		Continued.	Clinker Removal Work.	
IPP	Adani U-1	660	25/03/2020	01.30		Continued.	APH-A Hot PA Bellow Leakage.	

**State Load Despatch Center, Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 27/Mar/2020**

Position as on 6.30 Hrs of 28/Mar/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Khaparkheda Unit 2	210	25/03/2020	18.02		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 1	210	25/03/2020	18.03		Continued.	Reserve Shut Down.	
MSPGCL	Nasik Unit 4	210	25/03/2020	19.45		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 3	210	25/03/2020	23.55		Continued.	Reserve Shut Down.	
MSPGCL	Khaparkheda Unit 4	210	25/03/2020	23.58		Continued.	Reserve Shut Down.	
IPP	JSW (J) U2	300	26/03/2020	00.13		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	26/03/2020	14.31		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 4	210	26/03/2020	16.06		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Chandrapur Unit 5	500	26/03/2020	20.29		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Uran Unit 5	108	27/03/2020	05.53		Continued.	Mal Function	
MSPGCL	Chandrapur Unit 7	500	28/03/2020	23.56		Continued.	Zero Schedule.	

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 27/Mar/2020**

**Statement-VII**

Position as on 6.30 Hrs of 28/Mar/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
<b>400 KV LINE Outages/Trippings</b>							
Karad Solapur (PG)	InterState	03/05/2017	11:49			Continued.	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	23/03/2020	17.19	28/03/2020	06.18	HT	Over Voltage
Padgha Tarapur I	InterState	25/03/2020	17.12	28/03/2020	13.18	T	Over Voltage
Padgha - Boisar (PG)	InterState	25/03/2020	18.00			Continued.	T Over Voltage
Dhule Sar'Sarovar II	InterState	28/03/2020	10.08			Continued.	HT Over Voltage
Dabhol Nagothane I	InterState	28/03/2020	13.13			Continued.	T Over Voltage
Babhaleshwar - Padghe-II	IntraState	22/03/2020	08.19			Continued.	T Over Voltage
Padghe - Kalwa-II	IntraState	22/03/2020	16.57			Continued.	HT Over Voltage
Karad - Jaigad - II	IntraState	23/03/2020	18.12			Continued.	HT Over Voltage
karad -kolhapur-I	IntraState	23/03/2020	20:37			Continued.	HT Over Voltage
Dhule- Bableswhar - I	IntraState	24/03/2020	20.20			Continued.	HT Over Voltage
Bhusawal-Aurangabad	IntraState	25/03/2020	15.38			Continued.	HT Over Voltage
Padghe - Nagothane - I	IntraState	25/03/2020	16.10			Continued.	T Over Voltage
Padghe - Kalwa- I	IntraState	25/03/2020	17.12	27/03/2020	15.17	T	Over Voltage
New Koyna - Dabhol-I	IntraState	25/03/2020	18.01			Continued.	T Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	25/03/2020	18.01			Continued.	T Over Voltage
Koradi-Khaperkheda I	IntraState	25/03/2020	20.21			Continued.	T Over Voltage
Koradi-Bhusawal	IntraState	25/03/2020	20.21			Continued.	T Distance Protection
Padghe - Kalwa- I	IntraState	27/03/2020	17.07	28/03/2020	12.33	HT	Over Voltage
Kalwa - Talegaon(PG)	IntraState	28/03/2020	16.47			Continued.	PO Over Voltage
Lonikand I - Koyna stage-IV	IntraState	28/03/2020	18.10			Continued.	HT Over Voltage
<b>400 KV ICT Outages/Trippings</b>							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07			Continued.	T Differential Protection,Declared Faulty.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	09/03/2020	12.57			Continued.	EO Testing work (Bushing Tan Delta problem hence kept out.)
400/220 Kv 500 MVA ICT-IV @Kalwa	IntraState	22/03/2020	10.13			Continued.	HT Hand tripped from LV end to control Over Voltage.
400/220/33 Kv 315 Mva Ict- 2 @Kharghar	IntraState	25/03/2020	13.59			Continued.	EO CT Tan Delta High.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/03/2020	16.32			Continued.	HT LV Side CB Hand Tripped For Voltage.
400/220 KV 315 MVA ICT-I @ Nagothane	IntraState	25/03/2020	17.57			Continued.	HT LV Side CB Hand Tripped For Voltage.
400/220/33 Kv 500 MVA ICT-II @Lonikand 2	IntraState	25/03/2020	22.00			Continued.	HT LV Side CB Hand Tripped For Voltage.
400/220/33kv 315mva Ict3 @Lonikand	IntraState	25/03/2020	22.01			Continued.	HT LV Side CB Hand Tripped For Voltage.
400/220 Kv 500 MVA ICT-III @Kalwa	IntraState	28/03/2020	18.07			Continued.	HT Over Voltage
400/132 Kv 200 Mva Ict 1 @Khadka	IntraState	28/03/2020	19.15	28/03/2020	23.16	T	OSR Operated.
<b>220 KV LINE Outages/Trippings</b>							
Mudshingi Chikodi	InterState	24/09/2019	17.12			Continued.	PO No Schedule.
Talandage - Chikodi	InterState	01/10/2019	17.10			Continued.	PO No Schedule.(close at Chikodi end only)
BOISAR BORIVALI	IntraState	24/07/2018	13.18			Continued.	HT To Control Line Loading(H/T from Boisar end)
Borivali - Ghodbunder	IntraState	30/01/2020	12.05			Continued.	PO Isolation of 220KV Cables on MSETCL Tower NO.240
Lonand-Baramati	IntraState	16/02/2020	09.37			Continued.	PO Erection of CTT-2 Tower Work For 220Kv Baramati-Lonand & Baramati Jejuri Cables Emanating from 220Kv Baramati S/Stn.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Tripping for 27/Mar/2020**

**Statement-VII**

Position as on 6.30 Hrs of 28/Mar/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage	
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	02/03/2020	11.12			Continued.	PO	Stringing Of New Earth Wire at loc no.112 to 132.
Hinjewadi2 - Hinjewadi 3 ckt II	IntraState	26/03/2020	10.20			Continued.	HT	Over Voltage
Hinjewadi2 - Hinjewadi 3 ckt 1	IntraState	26/03/2020	10.20			Continued.	HT	Over Voltage
Padghe - Nalasopara	IntraState	27/03/2020	10.42	27/03/2020	11.59		T	Distance Protection
Mahad - Pedambe	IntraState	28/03/2020	09.46	28/03/2020	14.37		PO	Replacement Of Insulator String
Balapur-Malegaon	IntraState	28/03/2020	12.15	28/03/2020	17.22		PO	Urggent Tree Cutting Work.
Deepnagar Khadaka 2	IntraState	28/03/2020	16.17	28/03/2020	17.45		EO	For Providing pilot string.
Chandrapur(MIDC)-Ballarshah II	IntraState	28/03/2020	19.20	28/03/2020	20.10		T	5.2KM, B PH, 6.7KA.
<b>220 KV ICT Outages/Tripping</b>								
Carnac : 220 / 110 / 33 315 MVA ICT 5	IntraState	14/03/2020	11.00			Continued.	PO	Shifting 220KV Side to New GIS

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage