

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Mar/2024 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	179.716	4374.096	1) Gujrat	2.804	110.962
2) Hydro	10.698	236.291	2) Madhya Pradesh	12.199	329.268
3) Gas	6.974	183.546	3) Chattisgarh	5.110	127.780
Total MSPGCL	197.388	4793.933	4) Maharashtra	205.680	4841.324
B) 1) APLM	66.936	1717.067	5) Goa (Amona)	-3.094	-54.465
2) JSWEL	20.510	692.256	Total	222.699	5354.869
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.713	823.016
4) RPL(AMT)	28.880	769.610	b) Mumbai Drawl	39.417	918.882
5) SWPGPL	12.313	320.535	c) MSEDCL Bilateral *	112.546	2666.573
6) Other IPP	31.032	1097.368	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.713	823.016
C) 1) TPCL Thermal	10.653	295.132	Include PX	0.000	0.000
2) TPCL Hydro	6.112	115.435	Standby	0.000	0.000
3) TPCL Gas	4.152	97.469	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.719	247.112	1) MSEDCL	554.911	14362.170
D) STATE			2) Mumbai Discoms	71.053	1674.025
1) Thermal	360.759	9513.176	3) Other Discoms	10.917	291.321
(A1+C1+C4+(B1-B6))			TOTAL STATE	636.881	16327.516
2) Hydro (A2+C2)	16.810	351.726			
3) Gas (A3+B7+C3)	11.126	281.015			
4) Wind	9.396	348.275			
6) SOLAR	16.091	461.956			
TOTAL STATE	414.182	10956.148			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7286	7370	7625	8043
MSPGCL Hydro	552	767	519	181
MSPGCL Gas	285	285	290	297
MSPGCL Total Generation	8123	8422	8434	8521
Central Sector Receipt	10047	10247	9420	8410
WIND	234	278	407	384
CPP / IPP Thermal	6424	6886	7023	6570
CPP / IPP Gas	0	0	0	0
SOLAR	1874	1051	8	0
Exchange with Mumbai	-1967	-2011	-1702	-1201
MSEDCL DEMAND MET	24248	24377	23096	22346
Load Shedding	0	0	0	0
MSEDCL DEMAND	24248	24377	23096	22346
TPCL GENERATION	954	921	1066	684
AEML GENERATION	501	500	467	308
MUMBAI DEMAND	3422	3432	3235	2193
OTHER DISCOM DEMAND	487	496	494	338
STATE DEMAND MET	28157	28305	26825	24877
STATE DEMAND	28157	28305	26825	24877
Frequency (Hz)	49.95	49.89	49.90	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 06:03 Hrs	49.74 Hz at 16:23 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.32	105.06	195	150
Unit 8	13.73	365.54	631	530
Unit 9	13.80	279.07	639	502
Unit 10	12.55	228.23	545	500
Total	44.40	977.90		
Bhusawal				
Unit 3	3.59	93.24	180	125
Unit 4	10.65	229.44	500	295
Unit 5	10.95	185.98	500	315
Total	25.19	508.66		
Parli				
Unit 6	4.43	110.11	236	143
Unit 7	1.04	105.17	216	0
Unit 8	4.59	91.49	245	145
Total	10.06	306.78		
Chandrapur				
Unit 3	3.43	88.75	156	120
Unit 4	3.67	82.80	175	122
Unit 5	8.68	224.78	435	280
Unit 6	8.46	225.13	415	280
Unit 7	9.07	223.94	442	297
Unit 8	10.02	257.48	425	400
Unit 9	10.96	277.08	491	396
Total	54.29	1379.95		
Paras				
Unit 3	5.48	147.91	242	200
Unit 4	5.67	152.56	250	197
Total	11.15	300.48		
Khaparkheda				
Unit 1	3.50	100.68	175	120
Unit 2	4.37	109.69	199	160
Unit 3	4.09	104.40	177	159
Unit 4	4.28	109.91	194	158
Unit 5	10.88	288.19	475	425
Total	27.13	712.86		
Nasik				
Unit 3	3.74	35.46	176	127
Unit 4	3.77	96.41	172	123
Unit 5	0.00	55.61	0	0
Total	7.51	187.48		
Uran				
All Units	6.97	183.55	301	277
Total	6.97	183.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.20	2.84	47	0
Total	0.20	2.84		
Koyna				
Stage 1-2	2.24	50.97	325	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.36	36.22	380	0
Stage 3	1.13	19.89	160	0
Total	5.73	107.08		
Hydro				
KDPH	0.86	23.33	36	36
VTRNA	0.83	18.27	60	0
TILLARI	0.50	13.48	63	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.65	69.25	121	105
GHATGHAR	0.12	4.89	121	0
Total	4.97	129.21		
Wind				
Total	9.40	348.28	0	0
Total	9.40	348.28		
CPP				
APML(Mus)	66.94	1717.07	0	0
JSWEL(Mus)	20.51	692.26	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	28.88	769.61	0	0
SWPGPL-Mus	12.31	320.54	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.13	150.98	267	246
Other(Mus)	21.11	859.16	0	0
JPL	3.80	87.22	201	144
Total	159.67	4596.84		
SOLAR				
Total	16.09	461.96	0	0
Total	16.09	461.96		
Tata				
Trombay 5	7.02	194.59	378	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.60	59.55	109	108
Trombay 7B	1.55	37.92	65	64
TATA Hydro	6.11	115.44	436	108
Trombay 8	3.63	100.54	220	127
Total	20.92	508.04		
AEML				
DTPS U-1&2	10.72	247.11	501	306
Total	10.72	247.11		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	179.72	4374.10	MSPGCL Total	197.39	4793.93
			MSPGCL Thml+Gas	186.69	4557.64	Koyna 1,2 & 4 Total	4.59	87.19
			MSPGCL Hydro	10.70	236.29	State Total	414.18	10956.15

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7338	199	296	7833	666	6789	0	0	9081	8669	-1428	22128	0	0	22128	2643	401	25172	49.99
2	7559	181	296	8036	602	6645	0	0	8553	8832	-1296	22435	0	0	22435	2449	384	25268	49.99
3	8113	187	297	8597	469	6555	0	0	8280	8360	-1237	22380	0	0	22380	2303	364	25047	50.00
4	8043	181	297	8521	384	6570	0	0	8558	8410	-1201	22346	0	0	22346	2193	338	24877	49.99
5	7980	187	298	8465	478	6551	0	0	8802	8840	-1189	22783	0	0	22783	2167	362	25312	50.01
6	7980	185	301	8466	411	6560	0	0	9538	9369	-1209	23204	0	9	23204	2272	393	25869	50.04
7	7910	398	296	8604	319	6585	0	17	9944	9591	-1145	23545	0	139	23545	2407	426	26378	50.06
8	7365	490	294	8149	246	6566	0	254	9685	9227	-1213	22781	0	165	22781	2559	448	25788	50.06
9	7019	641	295	7955	220	6414	0	779	9242	9434	-1620	22713	0	143	22713	2868	469	26050	50.01
10	6893	735	287	7915	233	6134	0	1369	9881	9948	-1889	23230	0	147	23230	3181	480	26891	49.98
11	7286	552	285	8123	234	6424	0	1874	10118	10047	-1967	24248	0	247	24248	3422	487	28157	49.95
12	7036	560	277	7873	233	6530	0	2152	10160	9913	-2051	24161	0	273	24161	3499	489	28149	49.99
13	6987	256	282	7525	182	6511	0	2302	9958	9775	-2073	23712	0	247	23712	3504	510	27726	50.04
14	6838	276	283	7397	271	6115	0	2209	9803	9773	-2054	23215	0	143	23215	3383	496	27094	50.01
15	7103	399	281	7783	280	6308	0	1950	10310	10275	-2076	24018	0	118	24018	3384	502	27904	49.92
16	7301	465	283	8049	246	6755	0	1514	10418	10206	-2101	24175	0	167	24175	3471	494	28140	49.96
17	7370	767	285	8422	278	6886	0	1051	10240	10247	-2011	24377	0	105	24377	3432	496	28305	49.89
18	7619	669	287	8575	358	6846	0	472	9966	9364	-2007	23109	0	66	23109	3443	499	27051	50.02
19	7216	476	287	7979	436	6925	0	140	9305	9273	-1802	22443	0	0	22443	3282	508	26233	49.99
20	7625	519	290	8434	407	7023	0	8	9491	9420	-1702	23096	0	0	23096	3235	494	26825	49.90
21	7783	515	295	8593	535	6956	0	0	8902	8839	-1722	22714	0	0	22714	3196	487	26397	49.95
22	7787	410	293	8490	639	6978	0	0	8452	8471	-1564	22533	0	0	22533	2979	481	25993	49.97
23	7790	607	294	8691	663	7014	0	0	8347	8115	-1469	22556	0	0	22556	2904	458	25918	49.93
24	7775	843	295	8913	606	7031	0	0	8273	8301	-1391	23007	0	0	23007	2877	453	26337	49.98
MUs	179.72	10.70	6.97	197.39	9.40	159.67	0.00	16.09	225.31	222.70	-39.42	554.91	0.00	1.97	554.91	71.05	10.92	636.88	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132 kV BBLR TO Rahuri Line Over Load Alarm 488 Amp/104 MW.2)Due to overloading of 400 kV Chakan-Talegaon line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Mar/2024

Position as on 6.30 Hrs of 28/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 5	210	19/03/2024	17:40		Continued.	Withdrawn On Tolling.	
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	28/03/2024
MSPGCL	Uran Unit 6	108	12/03/2024	20:15		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Parli Unit 7	250	27/03/2024	05:38		Continued.	Boiler Tube Leakage	30/03/2024
MSPGCL	Nasik Unit 3	210	28/03/2024	05:31		Continued.	Boiler Tube Leakage	31/03/2024
Total Capacity MSPGCL		813						
IPP								
IPP	JSW (J) U1	300	24/03/2024	00:06		Continued.	CW duct leakage.	29/03/2024
IPP	Adani U-5	660	27/03/2024	01:36	27/03/2024	10:11	HP Bypass Steam Leakage	27/03/2024
IPP	RPL(AMT) U-2	270	27/03/2024	13:35		Continued.	Bottom Ash Evacuation Problem.	
Total Capacity IPP		1230						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2363						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Mar/2024

Position as on 6.30 Hrs of 28/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 28/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	26/03/2024	10:41			PO	Overhauling of Circuit breaker
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	19/03/2024	12:23			PO	Major maintenance of GIS bay no.18
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	27/03/2024	10:05	27/03/2024	21:56	PO	AMP
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	27/03/2024	14:07	27/03/2024	17:49	T	Distance Protection
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	27/03/2024	19:17	28/03/2024	01:59	PO	flash over disc replacement work at loc 549, broken disc at loc 555
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/220/33 KV 500MVA ICT - 3 @ BABHALESHWAR	IntraState	25/03/2024	09:27	27/03/2024	05:11	PO	Rapid Restoration Scheme work;DFRA;Quarterly bay maintenance work
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	28/03/2024	06:23			PO	For RRS testing trial work
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	28/03/2024	06:26			PO	For RRS testing trial work
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ SOUTH SOLAPUR	IntraState	27/03/2024	11:23	27/03/2024	13:20	PO	Quarterly Maintenance
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
KARAD - DASGAON	IntraState	28/02/2024	18:03	27/03/2024	20:12	PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped
KARAD - WATHAR	IntraState	25/03/2024	11:11			PO	For foundation work of 220kV Narrow base multi ckt tower loc no. 200A of New 220kV Karad-Koyana line
VARKUTI- HIWARWADI	IntraState	25/03/2024	15:07			PO	Old Insulator replacement work by long rod at Loc No 166 to 230
POPHLI PEDHMBE LINE- 2	IntraState	26/03/2024	10:15	27/03/2024	03:25	T	Tripped on distance protection
MIRAJ - MHAISHAL	IntraState	26/03/2024	16:15	27/03/2024	01:19	PO	Ploymer Insulator Replacement Work
KHARGHAR - BORIVALI CKT - 2	IntraState	26/03/2024	22:11	27/03/2024	07:02	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 28/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - BORIVALI	IntraState	26/03/2024	22:12	27/03/2024	06:59	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
BORIVALI - CTRLS CKT	IntraState	26/03/2024	22:16	27/03/2024	07:05	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
GIS BHANDUP - BORIVALI	IntraState	26/03/2024	22:18	27/03/2024	06:57	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
WANI-WARORA 1	IntraState	27/03/2024	07:36	27/03/2024	13:45	HT	For fixing of bird diverter on r, y & b-ph conductor & earthwire by agency m/s. trafotech system pvt. ltd. mumbai
PARAS-BALAPUR I	IntraState	27/03/2024	08:58	27/03/2024	12:47	HT	Outage is proposed for isolator maintenance work by outside agency at 220 kv balapur substation.
220KV PANDHARKAWDA - WANI CKT I	IntraState	27/03/2024	09:13			HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
220KV PANDHARKAWDA - WANI CKT II	IntraState	27/03/2024	09:29			HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
GHATODI-NANDED	IntraState	27/03/2024	09:42	27/03/2024	17:01	HT	Replacement of broken disc insulators at loc no.43,53,63,64,68,72.
132 KV KANHAN (220KV) - BHANDARA CKT	IntraState	27/03/2024	10:01	27/03/2024	13:03	HT	Testing.
132 KV JALGAON JAMOD - BALAPUR - CKT 2	IntraState	27/03/2024	10:22	27/03/2024	14:35	HT	Line maintenance.
220 KV DEVGAONRANGARI - BABHALESHWAR CKT	IntraState	27/03/2024	11:17	27/03/2024	18:32	PO	1) Commissioning of new Numerical back up relay 2) Bus side (89A) isolator alignment work
220 KV DEVGAONRANGARI - BABHALESHWAR CKT	IntraState	27/03/2024	11:17	27/03/2024	18:32	HT	1) commissioning of new numerical back up relay 2) bus side (89a) isolator alignment work.
132 KV VIHIGAON ACHALPUR	IntraState	27/03/2024	11:52	27/03/2024	15:25	HT	Flash over disc replacement at location no. 25 (r) 2. fixing of non conductive turbo wind driven conical bird guard.
MANMAD - MALEGAON CKT - 1	IntraState	27/03/2024	11:57	27/03/2024	15:26	PO	Relay Testing work
PEDAMBE-KALAMBANI(TSS)	IntraState	27/03/2024	12:14	27/03/2024	16:12	PO	For replacement of flashover insulator strings at loc no 2 108A top ph & 79B R, & Y ph both Pedhambe side.
PARAS-BALAPUR IV	IntraState	27/03/2024	13:45	27/03/2024	18:10	HT	Line maintenance.
132 KV JALGAON JAMOD - BALAPUR - CKT 1	IntraState	27/03/2024	14:53	27/03/2024	19:25	HT	For cold line insulator washing from loc no 26 to 48,61 to 67, 90 to 95,128 to 136, 198 to 202 & 227 to 232 under ehv line maintenance sub division, khamgaon.
MANMAD - MALEGAON CKT - 2	IntraState	27/03/2024	15:35	27/03/2024	16:51	PO	Relay testing work.
MAIN BUS @ VAIRAG	IntraState	27/03/2024	16:05	27/03/2024	19:28	PO	Quarterly Maintenance.
LAMBOTI - VAIRAG	IntraState	27/03/2024	16:05	27/03/2024	19:28	PO	Quarterly Maintenance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 28/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AURANGABAD (WALUJ)-BHENDA	IntraState	27/03/2024	17:56	27/03/2024	21:02	HT	ES at bhenda
220KV PANDHARKAWDA - WANI CKT I	IntraState	27/03/2024	21:56			HT	W.END--RY IF-2.8 KA IY-2.899 KA ZCOM 48.90 KM.
BORIVALI - CTRLS CKT	IntraState	27/03/2024	22:50	28/03/2024	07:55	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KHARGHAR - BORIVALI CKT - 2	IntraState	27/03/2024	22:54	28/03/2024	07:50	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
KALWA - BORIVALI	IntraState	27/03/2024	22:57	28/03/2024	07:52	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
GIS BHANDUP - BORIVALI	IntraState	27/03/2024	23:02	28/03/2024	07:57	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
220 KV ICT Outages/Trippings							
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/33 KV 50MVA PTR 2	IntraState	27/03/2024	10:27			HT	Overhauling of hv gis hybrid pass (abb make) .
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	27/03/2024	23:23	28/03/2024	03:30	PO	Normalization of 110 kV Parel Mankhurd line and waghivali Chembur line

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage