

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Apr/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	159.931	4442.637	1) Gujrat	-3.262	-90.400
2) Hydro	11.252	520.093	2) Madhya Pradesh	10.161	246.481
3) Gas	6.157	81.630	3) Chattisgarh	5.040	126.950
Total MSPGCL	177.340	5044.360	4) Maharashtra	191.663	4967.911
B) 1) APLM	56.656	1908.155	5) Goa (Amona)	-1.287	-39.862
2) JSWEL	25.493	684.150	Total	202.315	5211.080
3) VIPL	0.000	0.000	a) Mumbai Schedule	38.713	950.312
4) RPL(AMT)	30.688	809.127	b) Mumbai Drawl	43.485	1049.740
5) SWPGPL	12.296	315.404	c) MSEDCL Bilateral *	93.558	2679.568
6) Other IPP	16.336	550.077	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	38.713	950.312
C) 1) TPCL Thermal	10.494	318.325	Include PX	0.000	0.000
2) TPCL Hydro	3.015	137.705	Standby	0.000	0.000
3) TPCL Gas	3.258	88.743	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.299	254.732	1) MSEDCL	491.308	13943.075
D) STATE			2) Mumbai Discoms	70.551	1849.243
1) Thermal	322.193	9282.607	3) Other Discoms	10.466	276.888
(A1+C1+C4+(B1-B6))			TOTAL STATE	572.325	16069.206
2) Hydro (A2+C2)	14.267	657.798			
3) Gas (A3+B7+C3)	9.415	170.373			
4) Wind	8.550	335.482			
6) SOLAR	15.585	411.868			
TOTAL STATE	370.010	10858.128			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6600	6713	6679	6770
MSPGCL Hydro	210	560	310	536
MSPGCL Gas	237	234	255	268
MSPGCL Total Generation	7047	7507	7244	7574
Central Sector Receipt	9667	9644	8108	7735
WIND	106	138	732	144
CPP / IPP Thermal	5301	5817	6643	5752
CPP / IPP Gas	0	0	0	0
SOLAR	2217	1648	0	0
Exchange with Mumbai	-2301	-2166	-1860	-1361
MSEDCL DEMAND MET	21563	22138	20391	19510
Load Shedding	0	0	0	0
MSEDCL DEMAND	21563	22138	20391	19510
TPCL GENERATION	658	728	805	609
AEML GENERATION	499	494	406	362
MUMBAI DEMAND	3458	3388	3071	2332
OTHER DISCOM DEMAND	474	450	476	334
STATE DEMAND MET	25495	25976	23938	22176
STATE DEMAND	25495	25976	23938	22176
Frequency (Hz)	49.97	49.96	50.00	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 15.37 Hrs	49.69 Hz at 09.54 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.46	103.84	195	175
Unit 8	12.83	329.66	566	442
Unit 9	0.00	154.40	0	0
Unit 10	10.48	349.44	475	350
Total	27.78	937.33		
Bhusawal				
Unit 3	3.49	91.30	160	120
Unit 4	10.94	253.26	490	415
Unit 5	11.17	288.70	495	430
Total	25.60	633.27		
Parli				
Unit 6	5.15	140.60	248	138
Unit 7	5.24	130.86	248	151
Unit 8	4.87	103.79	238	147
Total	15.26	375.25		
Chandrapur				
Unit 3	3.90	103.55	167	150
Unit 4	3.94	79.74	169	161
Unit 5	9.67	250.75	410	375
Unit 6	9.87	218.37	430	385
Unit 7	10.11	228.83	440	395
Unit 8	11.79	303.96	502	473
Unit 9	0.00	211.09	0	0
Total	49.29	1396.30		
Paras				
Unit 3	4.48	126.14	230	142
Unit 4	4.98	129.14	218	199
Total	9.47	255.28		
Khaparkheda				
Unit 1	3.17	74.70	150	115
Unit 2	3.26	69.44	146	116
Unit 3	3.09	106.17	184	0
Unit 4	4.29	115.03	192	138
Unit 5	10.69	268.03	460	400
Total	24.50	633.37		
Nasik				
Unit 3	0.00	67.03	0	0
Unit 4	4.13	78.12	180	141
Unit 5	3.90	66.68	172	132
Total	8.04	211.83		
Uran				
All Units	6.16	81.63	275	234
Total	6.16	81.63		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.03	1.80	20	0
Total	0.03	1.80		
Koyna				
Stage 1-2	3.50	124.82	545	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.37	205.43	715	0
Stage 3	0.97	70.83	212	0
Total	6.84	401.08		
Hydro				
KDPH	0.77	22.03	32	32
VTRNA	1.16	31.94	60	0
TILLARI	0.46	4.36	58	0
BHIRA T.R.	0.13	7.97	47	0
SMLHY_PTN	1.86	50.92	96	70
GHATGHAR	0.00	0.00	0	0
Total	4.38	117.22		
Wind				
Total	8.55	335.48	0	0
Total	8.55	335.48		
CPP				
APML(Mus)	56.66	1908.16	0	0
JSWEL(Mus)	25.49	684.15	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.69	809.13	0	0
SWPGPL-Mus	12.30	315.40	0	0
Dhariwal	5.83	162.92	265	203
IEPL	4.30	142.22	269	0
Other(Mus)	6.20	244.94	0	0
Total	141.47	4266.91		
SOLAR				
Total	15.58	411.87	0	0
Total	15.58	411.87		
Tata				
Trombay 5	6.85	207.13	337	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.95	53.41	107	50
Trombay 7B	1.31	35.33	64	42
TATA Hydro	3.02	137.70	232	28
Trombay 8	3.65	111.20	230	133
Total	16.77	544.77		
AEML				
DTPS U-1&2	10.30	254.73	500	355
Total	10.30	254.73		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	159.93	4442.64	MSPGCL Total	177.34	5044.36
			MSPGCL Thml+Gas	166.09	4524.27	Koyna 1,2 & 4 Total	5.87	330.25
			MSPGCL Hydro	11.25	520.09	State Total	370.01	10858.13

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planne d	Trans missio n Constr aint					
1	6720	297	275	7292	574	6824	0	0	7938	7611	-1627	20272	0	0	20272	2840	402	23514	49.97
2	6759	238	272	7269	448	6376	0	0	7954	7630	-1476	19870	0	10	19870	2641	377	22888	49.99
3	6736	345	270	7351	237	5757	0	0	8132	8163	-1404	19760	0	4	19760	2457	344	22561	49.96
4	6770	536	268	7574	144	5752	0	0	8090	7735	-1361	19510	0	14	19510	2332	334	22176	49.96
5	6686	716	270	7672	164	5862	0	0	8384	7788	-1327	19822	0	32	19822	2290	337	22449	49.98
6	6577	983	270	7830	173	5413	0	0	8562	8299	-1314	20031	0	22	20031	2321	370	22722	50.01
7	6796	597	268	7661	225	5846	0	104	8541	8409	-1355	20482	0	0	20482	2374	408	23264	50.01
8	6485	695	267	7447	272	5362	0	517	8399	8410	-1585	19994	0	19	19994	2514	429	22937	49.94
9	6496	550	263	7309	266	5306	0	1116	8589	8652	-1838	20357	0	65	20357	2808	454	23619	49.96
10	6676	389	256	7321	159	5615	0	1739	8784	8815	-1988	21191	0	51	21191	3152	471	24813	49.92
11	6649	309	237	7195	129	5391	0	2111	9529	9425	-2241	21539	0	172	21539	3388	471	25398	49.93
12	6600	210	237	7047	106	5301	0	2217	9916	9667	-2301	21563	0	205	21563	3458	474	25495	49.97
13	6628	424	241	7293	124	5350	0	2093	9258	9489	-2118	21762	0	42	21762	3448	469	25679	49.98
14	6640	395	239	7274	126	5522	0	1957	9112	9278	-1999	21713	0	6	21713	3342	445	25500	49.98
15	6713	560	234	7507	138	5817	0	1648	9193	9644	-2166	22138	0	9	22138	3388	450	25976	49.96
16	6679	426	245	7350	166	6521	0	1111	9270	9167	-2191	21632	0	44	21632	3409	492	25533	50.08
17	6676	259	244	7179	426	6358	0	675	9293	9021	-2288	20869	0	61	20869	3350	502	24721	50.05
18	6613	431	249	7293	565	6284	0	256	8540	8277	-2100	20080	0	17	20080	3246	495	23821	49.97
19	6629	310	250	7189	680	6480	0	41	8059	7864	-1901	19875	0	6	19875	3088	478	23441	50.01
20	6679	310	255	7244	732	6643	0	0	8074	8108	-1860	20391	0	0	20391	3071	476	23938	50.00
21	6734	249	262	7245	990	6141	0	0	7955	7496	-1850	19555	0	0	19555	2983	467	23005	50.00
22	6691	202	263	7156	682	5955	0	0	7626	7528	-1716	19161	0	0	19161	2873	444	22478	49.99
23	6674	532	262	7468	570	5810	0	0	7727	7903	-1723	19589	0	0	19589	2870	439	22898	49.99
24	6625	1289	260	8174	454	5783	0	0	7834	7936	-1756	20154	0	0	20154	2908	437	23499	49.98
MUs	159.93	11.25	6.16	177.34	8.55	141.47	0.00	15.59	204.76	202.32	-43.49	491.31	0.00	0.78	491.31	70.55	10.47	572.33	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1)LTS stage 1 &2 operated at 220kv Ionand-jejuri line overloading & FLS done due to 400kv Talandge S/s ICT overloading.2)LTS operated & DLS done due to overloading of 220kv jejuri-Ionand line.3) 132kv BBLR-Sangamner line

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Apr/2023

Position as on 6.30 Hrs of 28/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-3	660	27/04/2023	22:35		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	
MSPGCL	Uran Unit 6	108	20/04/2023	19:15		Continued.	No Schedule.	
MSPGCL	Koradi Unit 9	660	22/04/2023	20:27		Continued.	Boiler Tube Leakage	28/04/2023
MSPGCL	Chandrapur Unit 9	500	24/04/2023	10:09		Continued.	Boiler Tube Leakage	28/04/2023
MSPGCL	Khaparkheda Unit 3	210	27/04/2023	13:39	27/04/2023	18:56	SUSPECTED MALFUNCTION OF FIRE PROTECTION	
IPP	IEPL Unit 1	270	27/04/2023	20:31	27/04/2023	23:57	Due to Operation of GT Backup (51NGT) over current earth fault protection	
MSPGCL	Khaparkheda Unit 3	210	28/04/2023	01:51		Continued.	Tripped on Fire Protection Fault	
MSPGCL	Koradi Unit 8	660	28/04/2023	01:51		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ KORADI 3	IntraState	27/04/2023	09:22	27/04/2023	19:13	PO	Annual Maintenance of Bus Equipments
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/04/2023	22:32	28/04/2023	02:37	EO	Emergency Outage on HVDC Pole-2 Non Base filter Z21-Z3/Z4 for attending Hotspots at various locations in Z21-Z3/Z4, Respective images are also attached.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	28/04/2023	02:50	28/04/2023	04:37	HT	Attending hot spot in Base filter
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF KARAD LINE AND 400/220KV 315MVA ICT - 1 @ SOLAPUR (PG)	InterState	15/04/2023	09:39			PO	411-Bay Y.Ph CT Replacement due to oil seepage from porcelain and cementing joint
TIE BAY (415) OF YELWAN CKT - 1 @ AKOLA	IntraState	27/04/2023	17:41	27/04/2023	20:28	EO	For reactor testing work to investigate reason for tripping of 125 MVAR Bus shunt reactor on differential protection.
400 KV MAINBAY Outages/Trippings							
MAIN BAY 416 OF 400KV 125MVAR BUS REACTOR	InterState	26/04/2023	08:28	27/04/2023	07:14	PO	For balance testing work and charging of 125 MVAR bus shunt reactor.
MAIN BAY 416 OF 400KV 125MVAR BUS REACTOR	InterState	27/04/2023	17:41	27/04/2023	20:28	EO	For reactor testing work to investigate reason for tripping of 125 MVAR Bus shunt reactor on differential protection.
MAIN BAY (410) OF FUTURE BAY @ JEJURI	IntraState	27/04/2023	11:31	27/04/2023	17:27	PO	Annual testing & maintenance.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
GTR - 9 @ CHANDRAPUR SWITCHING SS	IntraState	26/04/2023	10:05				for Diagnostic testing & allied bay maintenance work
PADGHE - KALWA CKT - 1	IntraState	27/04/2023	00:32	27/04/2023	05:59	HT	Emergency outage
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	27/04/2023	12:16	27/04/2023	21:01	EO	On dt.26.04.2023, red hot spot is observed on Y-ph PG-2 (Bus-2) Isolator of 400KV GCR CHD-CHD -2 CKT-1. The temperature of hot spot is more than 300 Degree celsius. Hence, it is very necessary to attend the same on top priority. Images are attached herewith.
JEJURI- KOYNA STAGE-IV	IntraState	27/04/2023	12:52	27/04/2023	18:36	PO	PID Faulty disc insulator replacement work & Cold line washing work
CHANDRAPUR 2 - WARORA CKT-2	IntraState	28/04/2023	06:06			HT	Emergency outage to replace flash over string
NEW KOYNA-KARAD CKT - 2	IntraState	28/04/2023	08:27			PO	Cold line washing work
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	25/04/2023	10:41			PO	For termination of power cable

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
STATION TRANSFORMER - 2 @ NANDGAON PETH	IntraState	25/04/2023	13:16			PO	ST-2 TRANSFORMER OIL LEAKAGE ARRESTING , MAINTENANCE AND DIAGNOSTIC TESTING WORK.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	27/04/2023	11:02	27/04/2023	15:42	PO	Replacement of spring charge motor by M/s Areva representative.
220 KV TBC Outages/Trippings							
BUS COUPLER @ NAGOTHANE	IntraState	27/04/2023	20:23	28/04/2023	06:06	EO	TO ATTEND THE OIL LEAKAGE FROM CT STUD OF Y& FROM TANK B-PH CT
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
220KV KURUNDA - GIRWALI CKT	IntraState	27/04/2023	01:10	27/04/2023	02:02	T	Distance Protection.
WARDHA-YEOTMAL	IntraState	27/04/2023	03:18	27/04/2023	09:40	T	Distance Protection
KARAD - NIGADE	IntraState	27/04/2023	09:32	27/04/2023	12:03	T	TRIPPED ON DISTANCE PROTECTION
220 KV ANJANGAON (VIHIGAON) - AKOLA CKT I	IntraState	27/04/2023	09:46	27/04/2023	12:12	EO	Flash over disc replacement work at loc. no. 18 & 19 R PH.
URSE - TALEGAON (AMBI) CKT 2	IntraState	27/04/2023	10:45	27/04/2023	11:02	PO	Bunching of 220kV Chinchwad bay & 220kV Talegaon-2 bay will be done via Auxiliary Bus at Urse for keeping 220kV Chinchwad line in service
NAGOTHANE - MSL	IntraState	27/04/2023	10:52	27/04/2023	18:26	EO	HOT-SPOT AND BUS ISILATOR ALIGNMENT WORK BY HOTLINE METHOD.
BHIGWAN-BARAMATI AGRO	IntraState	27/04/2023	11:05	27/04/2023	12:32	PO	For hotspot attending work
CHALISGAON - SAYNE	IntraState	27/04/2023	14:22	27/04/2023	19:05	PO	premonsoon bay maintenance and diagnostic testing work`
CHALISGAON - SAYNE	IntraState	27/04/2023	14:22	27/04/2023	19:05	PO	Work at Sayne end.
220 KV BAMBHORI - DEEPNAGAR CKT	IntraState	27/04/2023	15:18	27/04/2023	18:47	PO	Attending Hotspot Work.
GHATODI-NANDED	IntraState	27/04/2023	16:06	27/04/2023	19:47	T	Distance Protection
URSE - TALEGAON (AMBI) CKT 2	IntraState	27/04/2023	17:30	27/04/2023	17:46	PO	Bunching of 220kV Chinchwad bay & 220kV Talegaon-2 bay will be done via Auxiliary Bus at Urse for keeping 220kV Chinchwad line in service
KARAD -MUDSHINGI CKT- 4	IntraState	27/04/2023	19:15	28/04/2023	03:47	EO	Replacement of R,Y& B ph SCT make CT due to Higher Tan Delta values
PADGHE - PAL DOMBIVALI	IntraState	28/04/2023	09:07			PO	Replacement of existing distance relay by distance cum Differential relay (SIEMENS-SIPROTEC-7SD5) at 220kV Padgha s/s & 220kV Pal S/s (Both side substation)
HAMIDWADA - MUMEWADI	IntraState	28/04/2023	09:25			PO	For repalcement of 220KV Bus sevtionalizer CT having Higher Tan Delta value by new CT and quartely maintenance work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132 KV 200MVA PTR NO 3 @ CHINCHWAD	IntraState	27/04/2023	08:31	27/04/2023	17:57	PO	Half yearly maintenance & Diagnostic testing work.
220/132 KV 150 MVA ICT 3 @ EKLAHRE (OCR)	IntraState	27/04/2023	09:32	27/04/2023	11:35	PO	To attend Red Hot at HV Side R-Ph Isolator ICT side Jaw and Blade.
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	27/04/2023	09:56	27/04/2023	12:10	PO	CB Diagnostic & RM Work.
220/22 KV 50 MVA PTR 1 @ CHAKAN	IntraState	27/04/2023	10:39	27/04/2023	14:06	EO	For attending Hotspot at Y phase LV CT and attending OLTC driver Motor tripping problem.
220/100 KV 200 MVA ICT 2 @ BORIVALI	IntraState	27/04/2023	10:48	27/04/2023	14:54	PO	For R/M & Testing
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	27/04/2023	11:35	27/04/2023	16:44	PO	For OSR replacement
220/100 KV 200 MVA ICT 2 @ TALOJA	IntraState	28/04/2023	07:06			PO	R & Y Phase 100 KV LV CT Replacement Work.
220 KV BUSBAR Outages/Trippings							
MAIN BUS SECTION - 1 @ URSE	IntraState	27/04/2023	11:18	27/04/2023	16:56	PO	Jumping work of 245kV Hybrid PASS bushing to 220kV Main Bus for charging of 245kV Hybrid Pass at 220kV Urse S/stn. 2) Removal of 220kV Main Bus to bus jump & BPI from top of beam of gantry at Urse S/stn.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - KARANJADE	IntraState	27/04/2023	06:50	27/04/2023	09:11	EO	For Bird nest removal at loc 190 to 193 and 168.
KHOPOLI - BHOKARPADA	IntraState	28/04/2023	07:37			PO	For Routine Maintenance and Testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage