

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Apr/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	190.610	4693.964	1) Gujrat	0.109	81.759
2) Hydro	24.762	365.715	2) Madhya Pradesh	3.130	300.452
3) Gas	7.483	200.013	3) Chattisgarh	2.060	102.140
Total MSPGCL	222.855	5259.692	4) Maharashtra	179.449	5078.144
B) 1) APLM	67.709	1784.071	5) Goa (Amona)	-2.298	-70.559
2) JSWEL	27.594	722.412	Total	182.450	5491.936
3) VIPL	0.000	0.000	a) Mumbai Schedule	35.855	1031.701
4) RPL(AMT)	31.714	829.316	b) Mumbai Drawl	39.455	1101.921
5) SWPGPL	11.019	295.253	c) MSEDCL Bilateral *	80.270	2413.175
6) Other IPP	20.477	613.271	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	35.855	1031.701
C) 1) TPCL Thermal	14.353	345.932	Include PX	0.000	0.000
2) TPCL Hydro	5.226	133.199	Standby	0.000	0.000
3) TPCL Gas	4.135	108.618	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.294	262.815	1) MSEDCL	541.862	14369.598
D) STATE			2) Mumbai Discoms	74.463	1952.482
1) Thermal	374.770	9547.034	3) Other Discoms	11.137	294.402
(A1+C1+C4+(B1-B6))			TOTAL STATE	627.462	16616.482
2) Hydro	29.988	498.914			
3) Gas	11.618	308.631			
4) Wind	12.116	342.123			
6) SOLAR	16.520	427.847			
TOTAL STATE	445.012	11124.549			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	7334	8117	8163	7707
MSPGCL Hydro	476	784	2278	168
MSPGCL Gas	273	271	367	289
MSPGCL Total Generation	8083	9172	10808	8164
Central Sector Receipt	9149	9290	7299	7040
WIND	285	184	280	849
CPP / IPP Thermal	5346	6762	7118	6568
CPP / IPP Gas	0	0	0	0
SOLAR	2253	1363	6	569
Exchange with Mumbai	-2080	-2149	-1528	-1442
MSEDCL DEMAND MET	22521	24127	23471	21279
Load Shedding	0	0	215	0
MSEDCL DEMAND	22521	24127	23686	21279
TPCL GENERATION	849	1058	1260	636
AEML GENERATION	483	502	490	426
MUMBAI DEMAND	3412	3709	3278	2504
OTHER DISCOM DEMAND	515	495	512	469
STATE DEMAND MET	26448	28331	27261	24252
STATE DEMAND	26448	28331	27476	24252
Frequency (Hz)	49.98	50.02	49.93	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.2 Hz at 18:03 Hrs	49.73 Hz at 22:52 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Apr/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.36	98.52	190	170
Unit 8	14.20	379.17	606	560
Unit 9	14.11	377.35	591	570
Unit 10	14.38	259.89	640	570
Total	47.05	1114.93		
Bhusawal				
Unit 3	3.48	96.08	165	120
Unit 4	11.18	224.12	490	370
Unit 5	11.16	255.08	495	350
Total	25.83	575.28		
Parli				
Unit 6	3.60	118.73	245	0
Unit 7	4.74	121.26	234	144
Unit 8	4.96	105.99	250	142
Total	13.30	345.97		
Chandrapur				
Unit 3	0.94	77.27	138	0
Unit 4	3.78	89.56	168	133
Unit 5	9.01	210.32	440	275
Unit 6	8.67	225.98	410	285
Unit 7	10.02	234.53	476	291
Unit 8	10.37	239.45	455	396
Unit 9	11.43	308.68	500	429
Total	54.22	1385.79		
Paras				
Unit 3	5.49	132.98	245	196
Unit 4	4.43	146.91	254	123
Total	9.91	279.90		
Khaparkheda				
Unit 1	3.84	101.44	170	140
Unit 2	4.43	115.29	202	145
Unit 3	4.18	108.11	176	172
Unit 4	4.55	105.75	195	178
Unit 5	11.48	276.56	485	471
Total	28.48	707.16		
Nasik				
Unit 3	4.08	86.88	181	128
Unit 4	3.94	102.46	174	123
Unit 5	3.80	95.61	170	117
Total	11.81	284.94		
Uran				
All Units	7.48	200.01	472	270
Total	7.48	200.01		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.57	5.84	47	0
Total	0.57	5.84		
Koyna				
Stage 1-2	5.44	87.38	550	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	11.07	121.31	1007	0
Stage 3	3.52	45.61	320	0
Total	20.02	254.29		
Hydro				
KDPH	0.74	21.77	31	31
VTRNA	0.79	22.09	60	0
TILLARI	0.74	2.36	62	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.20	58.82	98	87
GHATGHAR	0.27	6.38	166	0
Total	4.74	111.42		
Wind				
Total	12.12	342.12	0	0
Total	12.12	342.12		
CPP				
APML(Mus)	67.71	1784.07	0	0
JSWEL(Mus)	27.59	722.41	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.71	829.32	0	0
SWPGPL-Mus	11.02	295.25	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.82	144.25	270	210
Other(Mus)	9.26	352.42	0	0
JPL	5.40	116.60	282	183
Total	158.51	4244.32		
SOLAR				
Total	16.52	427.85	0	0
Total	16.52	427.85		
Tata				
Trombay 5	9.44	226.50	462	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.58	67.68	108	107
Trombay 7B	1.55	40.94	65	64
TATA Hydro	5.23	133.20	399	58
Trombay 8	4.92	119.44	230	136
Total	23.71	587.75		
AEML				
DTPS U-1&2	11.29	262.82	503	326
Total	11.29	262.82		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	190.61	4693.96	MSPGCL Total	222.86	5259.69
			MSPGCL Thml+Gas	198.09	4893.98	Koyna 1,2 & 4 Total	16.51	208.69
			MSPGCL Hydro	24.76	365.72	State Total	445.01	11124.55

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Apr/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	8246	1877	286	10409	548	7169	0	0	6588	6486	-1500	22686	0	0	22686	3172	426	26284	49.94
2	8323	1508	288	10119	657	7175	0	0	6424	6222	-1322	22460	0	0	22460	2962	391	25813	50.02
3	8288	993	287	9568	758	7152	0	0	6310	6009	-1187	21923	0	0	21923	2752	377	25052	49.99
4	8281	429	288	8998	987	7054	0	0	6348	6149	-1109	21716	0	0	21716	2605	363	24684	49.98
5	8047	367	289	8703	957	7104	0	0	6658	6588	-1128	21852	0	0	21852	2507	372	24731	49.94
6	8217	327	290	8834	1028	6824	0	0	6594	6827	-1180	21930	0	0	21930	2502	403	24835	49.99
7	8241	314	291	8846	997	7034	0	100	6955	7006	-1146	22402	0	0	22402	2460	435	25297	50.01
8	7707	168	289	8164	849	6568	0	569	7513	7040	-1442	21279	0	0	21279	2504	469	24252	50.02
9	7228	198	282	7708	808	5732	0	1131	7990	7983	-1696	21180	0	0	21180	2680	486	24346	49.98
10	7393	221	281	7895	674	5595	0	1731	8460	8309	-1809	21905	0	0	21905	2967	490	25362	49.96
11	7452	383	275	8110	447	5444	0	2109	9048	8743	-2050	22302	0	0	22302	3246	501	26049	49.99
12	7334	476	273	8083	285	5346	0	2253	9278	9149	-2080	22521	0	4	22521	3412	515	26448	49.98
13	7159	660	270	8089	178	5344	0	2272	9316	9224	-2156	22438	0	1	22438	3499	513	26450	49.97
14	7466	474	271	8211	136	5455	0	2090	9134	9126	-2154	22385	0	0	22385	3518	479	26382	50.00
15	7918	759	270	8947	125	6217	0	1723	9188	9336	-2257	23598	0	9	23598	3646	493	27737	49.98
16	8117	784	271	9172	184	6762	0	1363	9529	9290	-2149	24127	0	12	24127	3709	495	28331	50.02
17	8147	1268	274	9689	239	6881	0	797	8803	8677	-1984	23809	0	17	23809	3570	490	27869	50.02
18	8188	1347	271	9806	282	7015	0	346	8034	7966	-1918	22987	0	10	22987	3378	510	26875	50.01
19	8134	1791	284	10209	287	7100	0	30	7257	7024	-1696	22432	0	15	22432	3258	522	26212	49.99
20	8163	2278	367	10808	280	7118	0	6	7078	7299	-1528	23471	215	58	23686	3278	512	27476	49.93
21	8202	2057	392	10651	268	7116	0	0	6873	6889	-1496	22930	75	12	23005	3231	498	26734	50.00
22	8143	2006	466	10615	297	7135	0	0	6532	6818	-1471	22913	0	0	22913	3178	481	26572	50.02
23	8131	2061	472	10664	349	7118	0	0	6417	7062	-1456	23271	138	0	23409	3182	466	27057	49.94
24	8085	2016	456	10557	496	7055	0	0	6850	7228	-1541	23343	455	0	23798	3247	452	27497	49.97
MUs	190.61	24.76	7.48	222.85	12.12	158.51	0.00	16.52	183.18	182.45	-39.45	541.86	0.88	0.14	542.75	74.46	11.14	628.34	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) ELR carried out due to Overload of 220kV BBLR-Alephata line and 100kV Khopoli-Bhokarpada line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Apr/2024

Position as on 6.30 Hrs of 28/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 3	210	25/04/2024	01:57	27/04/2024	13:25	Boiler Tube Leakage	28/04/2024
MSPGCL	Parli Unit 6	250	27/04/2024	18.53	28/04/2024	04:17	Due to suspected foreign material in APH.	
MSPGCL	Uran Unit 5	108	27/04/2024	19:19	27/04/2024	20:08	Thrust Bearing protection operated.	
MSPGCL	Nasik Unit 4	210	28/04/2024	08:40		Continued.	ID Fan Problem	30/04/2024
Total Capacity MSPGCL		898						
IPP								
IPP	JSW (J) U3	300	27/04/2024	23:52		Continued.	CW Duct heavy leakage.	30/04/2024
Total Capacity IPP		300						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1518						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	26/04/2024	22:30	27/04/2024	18:15	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	26/04/2024	22:52	27/04/2024	18:51	Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	28/04/2024	07:00	28/04/2024	17:18	Zero Sch Given By MSEDCL	
MSPGCL	Uran Unit 5	108	28/04/2024	07:15	28/04/2024	17:38	Zero Sch Given By MSEDCL	
Total Capacity MSPGCL		432						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		432						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Apr/2024

Position as on 6.30 Hrs of 28/Apr/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
CHANDRAPUR - BHADRAVATI CKT - 4	InterState	27/04/2024	09:09	27/04/2024	19:02	PO	AMP WORKS of Line at both end
DHULE - KHANDWA CKT - 2	InterState	27/04/2024	09:26	28/04/2024	03:10	PO	Simultaneous outage of TIE BAY - 400KV-KHANDWA-DHULE-MS-2 , 400KV-KHANDWA-DHULE-MS-2 and 400KV B/R 2 is required for LBB retrofitting work, Line Outage, DIA to be kept open and Line-1 Auto Recloser Non-auto Mode
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
BABHALESHWAR - PADGHE CKT-1	IntraState	27/04/2024	09:26			PO	1)Replacement of A Bus All Phase PG Isolator under LES Scheme. 2) Line will be in service on TBC.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
200 MVA 220/132 KV ICT - 5 @ KHADKA	IntraState	27/04/2024	07:20	27/04/2024	17:27	PO	Maintenance work and relay retrofitting work
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	27/04/2024	08:36	27/04/2024	12:44	PO	For attending the oil leakage from top plate of 33 kV Tertiary PT of R-ph & top up oil level.
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	28/04/2024	11:10	28/04/2024	23:00	PO	To take 400/220/33kV 167 MVA Rph unit in service in place of 167 MVA Spare unit
220 KV TIEBAY Outages/Trippings							
220 KV PT I	IntraState	25/04/2024	08:48			HT	Replacement of pts under les scheme.
MAIN BUS SECTIONALIZER -2 @ GHODBUNDER (GIS)	IntraState	27/04/2024	09:09	27/04/2024	09:57	PO	Attending issue of CB's spring charging motor.
220 KV TBC Outages/Trippings							
TBC @ PADGHE	IntraState	26/04/2024	10:42			PO	Replacement of A Bus PT in upper section & making twin bus arrangement
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
KHARGHAR - ULWE GIS CKT-1	IntraState	19/04/2024	15:22			T	Wavetrap uncoiled at Kharghar end
BOISAR II - BOISAR (PG) CKT - 1	IntraState	27/04/2024	04:43	27/04/2024	09:41	PO	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
PARAS-BALAPUR IV	IntraState	27/04/2024	10:48	27/04/2024	16:49	PO	Circuit breaker overhauling work
URSE-CHINCHWAD	IntraState	27/04/2024	12:20	27/04/2024	13:33	T	Line trips on distance protection.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARA(GCR)(NASIK)-BABLESHWAR 1	IntraState	27/04/2024	22:34	28/04/2024	06:35	PO	Replacement of old disc insulator with porcelain long rod insulator strings, Suspension nut bolt tightening work.
TROMBAY - VIKHROLI (GIS) CKT - 4	IntraState	27/04/2024	23:22	28/04/2024	07:49	PO	B-Phase CVT testing & replacement
TROMBAY DHARAVI - 5	IntraState	27/04/2024	23:31	28/04/2024	05:01	PO	Work in vicinity of 220KV Trombay Vikhroli 4 line
URSE - TALEGAON (AMBI) CKT 2	IntraState	28/04/2024	01:09	28/04/2024	04:30	PO	For replacement of faulty PID detected insulator strings at various locations.
BOISAR II - BOISAR (PG) CKT - 1	IntraState	28/04/2024	04:42	28/04/2024	12:17	PO	Work of replacement of existing 0.4 ACSR Zebra Conductor and all its Hardware by equivalent CCC HTLS Conductor and suitable Hardware for 220kV Boisar - PGCIL (Dead Line). Outage required of 220kV PGCIL - Boisar Line No. 1 for safety purpose only.
VSNL- KHADKI	IntraState	28/04/2024	08:29	28/04/2024	18:52	PO	Erection of Monopole tower at loc 29A alongwith cut point formation.
220KV BADNERA -NER CKT	IntraState	28/04/2024	09:07	28/04/2024	11:20	HT	B PH CT jump open P2 side at Ner end.
220 KV PARAS - MALKAPUR CKT	IntraState	28/04/2024	10:36	28/04/2024	18:25	PO	Bus, Auxiliary and Line isolator overhauling work and Tan delta of CT & CRM timing of CB of 220kV Paras-Malkapur bay at 220kV Paras s/s.
AEML BORIVALI - TPC BORIVALI LINE	IntraState	28/04/2024	12:30	28/04/2024	17:00	PO	For testing reverse power relay M1 and M2
PETH- MUDSHINGI 1 LINE	IntraState	28/04/2024	16:17	28/04/2024	21:10	PO	For SSN to DSN string work at loc no. 176 & 177 road crossing towers for safety purpose.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	28/04/2024	19:20	28/04/2024	19:47	HT	To facilitate outage on BBLR Alephata
BABLESHWAR- ALEPHATA CKT - 1	IntraState	28/04/2024	19:45		Continued.	PO	Damaged conductor will be replacement at location No 82-83 B ph (Alephata side) & armouring of conductor will be carried at 83-84 R ph (Babhaleshwar side) & 131-132 Y Ph. Also repair sleeve fixed at damage conductor at 17 (Y Ph BBLR side), 69 (R Ph both side ,Y Ph BBLR side, B Ph both side), 83 (R Ph BBLR side). The above said work is not feasible by hot line method. Also, Hot spot observed at location No-6 Y PH (Bblr side -98 C)131 Y PH (Bblr side -64.7 C & Alephata side 107 C) ,hence the jumper nut bolt replacement & tightening work is required to be carried out at above mentioned location and location 5,143, where by pass jump provided by hot line .
220 KV ICT Outages/Trippings							
220/33KV 25MVA PTR 2 @ NEW KOYNA	IntraState	25/04/2024	08:44			PO	Replacement of Diaphragm (oil leakage found) of OLTC ,Radiator valve repairing work,33 KV Neutral bushing gasket replacement ,Oil filtration etc
220/100 KV 200 MVA ICT 2 @ TALOJA	IntraState	27/04/2024	09:35	27/04/2024	11:35	PO	Hot spot attending work on Rph CB bottom pad (88 ₂ C)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Apr/2024

Statement-VII

Position as on 6.30 Hrs of 28/Apr/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220 / 110 / 33kV 250MVA ICT 2 @ BORIVALI (TATA)	IntraState	27/04/2024	10:08	27/04/2024	14:22	PO	Installation of Bird spikes in Gantry
220/132 KV 200 MVA ICT 1	IntraState	27/04/2024	10:55	27/04/2024	12:32	PO	REPL of WTI and OTI meter
220/132 KV 150 MVA ICT 2 @ SATANA	IntraState	27/04/2024	11:08	27/04/2024	19:02	PO	For OLTC Overhauling work
220 / 110 / 33kV 250MVA ICT 3 @ BORIVALI (TATA)	IntraState	27/04/2024	14:46	27/04/2024	19:15	PO	Installation of Bird spikes in Gantry
220/33kV 50MVA TF-2 @ KOPARGAON	IntraState	27/04/2024	16:10	27/04/2024	18:10	PO	For attending Hotspot on LV side CT and CB.
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	28/04/2024	09:21	28/04/2024	10:38	PO	Attending Oil leakage from LV neutral bushing.
220/132KV 100MVA ICT 1 @ KATHAPUR	IntraState	28/04/2024	19:09	28/04/2024	19:32	HT	To facilitate outage on BBLR Alephata
220/132KV 100MVA ICT 2 @ KATHAPUR	IntraState	28/04/2024	19:10	28/04/2024	19:32	HT	To facilitate outage on BBLR Alephata
220/132 KV 100 MVA ICT - 1 @ ALEPHATA	IntraState	28/04/2024	19:43	28/04/2024	19:47	HT	To facilitate outage on BBLR Alephata
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	28/04/2024	19:43	28/04/2024	19:47	HT	To facilitate outage on BBLR Alephata
132 KV LINE Outages/Trippings							
KANHAN-MANSAR	IntraState	27/04/2024	08:58	27/04/2024	15:05	PO	Routine Maint. Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BUSBAR Outages/Trippings							
ZONE 2 (BUS SECTION 2&3) @ KHOPOLI	IntraState	28/04/2024	07:35	28/04/2024	14:08	PO	R/M of Bus and GODs

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage