

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/May/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	172.292	4500.455	1) Gujrat	-4.936	-155.675
2) Hydro	23.294	599.089	2) Madhya Pradesh	5.143	141.039
3) Gas	6.463	152.777	3) Chattisgarh	2.810	93.300
Total MSPGCL	202.049	5252.321	4) Maharashtra	156.425	4932.275
B) 1) APLM	65.999	1745.449	5) Goa (Amona)	-1.417	-36.319
2) JSWEL	16.443	486.936	Total	158.025	4974.620
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.241	961.817
4) RPL(AMT)	19.113	650.284	b) Mumbai Drawl	38.116	1031.265
5) SWPGPL	9.369	228.649	c) MSEDCL Bilateral *	85.532	2062.647
6) Other IPP	14.739	529.319	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.241	961.662
C) 1) TPCL Thermal	16.018	391.498	Include PX	0.000	0.000
2) TPCL Hydro	4.627	112.274	Standby	0.000	0.156
3) TPCL Gas	1.978	60.507	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.880	302.570	1) MSEDCL	492.222	13694.929
D) STATE			2) Mumbai Discoms	72.619	1898.098
1) Thermal	325.853	8835.160	3) Other Discoms	9.580	252.425
(A1+C1+C4+(B1-B6))			TOTAL STATE	574.421	15845.452
2) Hydro (A2+C2)	27.921	711.363			
3) Gas (A3+B7+C3)	8.441	213.284			
4) Wind	43.200	862.447			
6) SOLAR	10.981	248.594			
TOTAL STATE	416.396	10870.848			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 21 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6727	7007	7456	6814
MSPGCL Hydro	979	666	1199	1653
MSPGCL Gas	267	257	268	268
MSPGCL Total Generation	7973	7930	8923	8735
Central Sector Receipt	8432	8048	5509	6002
WIND	1059	1367	2314	2102
CPP / IPP Thermal	4864	5401	5284	4860
CPP / IPP Gas	0	0	0	0
SOLAR	1396	1227	0	0
Exchange with Mumbai	-2064	-2110	-1556	-1153
MSEDCL DEMAND MET	21232	21433	20051	20252
Load Shedding	0	0	0	0
MSEDCL DEMAND	21232	21433	20051	20252
TPCL GENERATION	892	872	1001	856
AEML GENERATION	499	499	499	501
MUMBAI DEMAND	3455	3481	3056	2510
OTHER DISCOM DEMAND	429	430	422	294
STATE DEMAND MET	25115	25344	23530	23056
STATE DEMAND	25115	25344	23530	23056
Frequency (Hz)	50.02	49.93	49.99	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 08:01 Hrs	49.75 Hz at 19:52 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.88	101.84	155	0
Unit 7	0.00	0.00	0	0
Unit 8	14.17	362.20	605	572
Unit 9	12.34	333.42	537	467
Unit 10	13.51	345.53	601	528
Total	40.90	1142.99		
Bhusawal				
Unit 3	0.00	74.35	0	0
Unit 4	10.38	217.32	475	350
Unit 5	10.26	240.40	470	355
Total	20.64	532.08		
Parli				
Unit 6	4.96	80.16	244	151
Unit 7	4.77	111.90	244	144
Unit 8	3.10	73.42	138	126
Total	12.82	265.48		
Chandrapur				
Unit 3	3.54	100.54	160	115
Unit 4	3.05	92.92	132	118
Unit 5	8.78	199.52	375	320
Unit 6	8.67	220.21	390	280
Unit 7	9.25	242.97	424	338
Unit 8	10.36	270.93	459	415
Unit 9	10.48	272.31	447	423
Total	54.14	1399.40		
Paras				
Unit 3	4.43	114.40	224	145
Unit 4	4.20	117.84	210	113
Total	8.63	232.24		
Khaparkheda				
Unit 1	3.06	80.04	135	110
Unit 2	3.53	94.76	150	135
Unit 3	4.19	97.69	180	161
Unit 4	3.41	85.99	152	136
Unit 5	10.00	296.10	473	375
Total	24.20	654.58		
Nasik				
Unit 3	3.93	85.61	188	125
Unit 4	3.62	93.40	175	127
Unit 5	3.42	94.68	163	118
Total	10.97	273.68		
Uran				
All Units	6.46	152.78	279	257
Total	6.46	152.78		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	3.01	17	0
Total	0.04	3.01		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	5.83	125.84	525	40
Stage 4	8.41	202.50	815	0
Stage 3	3.16	72.94	240	0
Total	17.41	401.27		
Hydro				
KDPH	0.59	14.53	25	24
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.21	5.13	77	0
SMLHY_PTN	5.05	140.30	222	196
GHATGHAR	0.00	9.26	0	0
Total	5.85	194.80		
Wind				
Total	43.20	862.45	0	0
Total	43.20	862.45		
CPP				
APML(Mus)	66.00	1745.45	0	0
JSWEL(Mus)	16.44	486.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.11	650.28	0	0
SWPGPL-Mus	9.37	228.65	0	0
Other(Mus)	14.74	529.32	0	0
Total	125.66	3640.64		
SOLAR				
Total	10.98	248.59	0	0
Total	10.98	248.59		
Tata				
Trombay 5	10.55	255.15	459	420
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	37.54	51	42
Trombay 7B	0.91	22.97	42	36
TATA Hydro	4.63	112.27	441	58
Trombay 8	5.46	136.35	231	225
Total	22.62	564.28		
AEML				
DTPS U-1&2	11.88	302.57	501	447
Total	11.88	302.57		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	172.29	4500.46	MSPGCL Total	202.05	5252.32
			MSPGCL Thml+Gas	178.76	4653.23	Koyna 1,2 & 4 Total	14.24	328.33
			MSPGCL Hydro	23.29	599.09	State Total	416.40	10870.85

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7467	765	268	8500	2446	5936	0	0	5864	5640	-1298	20871	0	20871	3011	353	24235	50.01
2	7343	745	278	8366	2370	5728	0	0	6031	5939	-1155	20932	0	20932	2831	316	24079	50.02
3	7228	1171	278	8677	2338	5148	0	0	6118	5958	-1211	20603	0	20603	2640	307	23550	49.98
4	6814	1653	268	8735	2102	4860	0	0	5919	6002	-1153	20252	0	20252	2510	294	23056	50.01
5	7358	1459	268	9085	2121	5161	0	0	5938	5986	-1102	20932	0	20932	2446	319	23697	50.01
6	7413	1011	279	8703	2048	5531	0	2	6199	6266	-1108	21085	0	21085	2441	357	23883	50.02
7	7285	1107	268	8660	1484	5549	0	97	6223	6500	-1102	20793	0	20793	2426	395	23614	50.03
8	7330	657	277	8264	1332	5506	0	373	6417	6432	-1211	20281	0	20281	2527	415	23223	50.12
9	6810	356	268	7434	1498	5196	0	775	7284	6938	-1462	19953	0	19953	2810	426	23189	50.07
10	6705	497	267	7469	1367	4842	0	1096	7726	7742	-1769	20310	0	20310	3122	436	23869	50.03
11	6751	489	267	7507	1166	4872	0	1373	8021	7822	-1985	20301	0	20301	3363	454	24118	50.00
12	6727	979	267	7973	1059	4864	0	1396	8198	8432	-2064	21232	0	21232	3455	429	25115	50.02
13	6844	769	267	7880	1029	4984	0	1457	8358	8338	-2081	21161	0	21161	3455	445	25062	50.01
14	6840	488	266	7594	988	5080	0	1385	8306	8145	-2013	20755	0	20755	3367	424	24546	50.01
15	7007	666	257	7930	1367	5401	0	1227	8278	8048	-2110	21433	0	21433	3481	430	25344	49.93
16	7253	773	267	8293	1333	5599	0	898	7924	7647	-2131	21208	0	21208	3541	430	25180	49.98
17	7209	1083	277	8569	1845	5088	0	589	7421	6955	-2086	20520	0	20520	3491	440	24451	50.05
18	7327	1358	267	8952	1542	4928	0	275	6916	6753	-1919	20088	0	20088	3341	443	23872	50.03
19	7298	948	258	8504	2184	5033	0	38	6138	5806	-1715	19413	0	19413	3162	437	23012	50.00
20	7403	1495	268	9166	2264	5274	0	0	5521	5015	-1541	19752	0	19752	3122	426	23300	49.95
21	7456	1199	268	8923	2314	5284	0	0	5684	5509	-1556	20051	0	20051	3056	422	23530	49.99
22	7468	975	277	8720	2326	5288	0	0	5251	5324	-1397	19848	0	19848	2976	413	23237	49.96
23	7491	1013	268	8772	2342	5304	0	0	5633	5562	-1424	20158	0	20158	2982	399	23538	49.98
24	7465	1638	270	9373	2335	5208	0	0	5710	5266	-1523	20290	0	20290	3063	369	23722	49.95
MUs	172.29	23.29	6.46	202.05	43.20	125.66	0.00	10.98	161.08	158.02	-38.12	492.22	0.00	492.22	72.62	9.58	574.42	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/May/2022

Position as on 6.30 Hrs of 28/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	28/05/2022	02:09		Continued.	no schedule	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
IPP	RPL(AMT) U-3	270	24/05/2022	02:23		Continued.	Flame Failure	31/05/2022
MSPGCL	Bhusawal Unit 3	210	24/05/2022	17:31		Continued.	CVSM Control Valve Problem	30/05/2022
MSPGCL	Koradi Unit 6	210	27/05/2022	06:05		Continued.	Boiler Tube Leakage	29/05/2022
IPP	Adani U-3	660	27/05/2022	16:13		Continued.	APH-A HOT PA BELOW LEAKAGE.	31/05/2022
MSPGCL	Chandrapur Unit 7	500	28/05/2022	12:18		Continued.	Air heater problem	29/05/2022
MSPGCL	Koradi Unit 8	660	28/05/2022	17:27	28/05/2022	19:54	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2022

Statement-VII

Position as on 6.30 Hrs of 28/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	27/05/2022	12:06	27/05/2022	18:12	PO	Replacement of damaged earthwire, replacement of PID suspicious disc insulator strings and other routine maintenance work.400kV SSNNL Ckt-2 A/R switch will be kept on non auto mode.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	26/05/2022	11:07	27/05/2022	16:31	HT	H/T FOR LOAD MANAGEMENT
KARAD - LONIKAND I	IntraState	26/05/2022	23:42	27/05/2022	02:08	HT	load management
KHARGHAR - TALEGAON (PG)	IntraState	26/05/2022	23:42	27/05/2022	01:59	HT	Line Maintenance at Loc No-100
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	27/05/2022	06:21	27/05/2022	16:32	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
LONIKAND I - KOYNA STAGE-IV	IntraState	27/05/2022	09:43	27/05/2022	10:30	T	Tripped on Distance protection.
KARAD - TALANDGE CKT - 2	IntraState	27/05/2022	14:45	27/05/2022	19:04	PO	Replacement of Decapped cut point string at loc no 30.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/05/2022	16:21	27/05/2022	18:22	T	TRIPPED ON DIST.PROTECTION
NEW KOYNA-KARAD CKT - 1	IntraState	27/05/2022	19:32	27/05/2022	23:24	EO	attending hot spot at Y ph 29B PG isolator IPS clamp towards LA side having Temp 167 Degree
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	28/05/2022	06:14	28/05/2022	17:47	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
400 KV ICT Outages/Trippings							
400/220/33 KV 500 MVA ICT - 2 @ JEJURI	IntraState	26/05/2022	22:05	27/05/2022	05:58	PO	For pre-monsoon maintenance,CTR work & testing
400/220/33 KV 500 MVA ICT - 3 @ WALUJ	IntraState	27/05/2022	09:37	27/05/2022	17:48	PO	1. To carry out DFRA Test on Yph Unit 2. Diagnostic Testing Work 3. Maintenance Work.
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	27/05/2022	14:46	27/05/2022	17:23	PO	For cleaning of tertiary winding external delta of 400/220/33kV 3*105MVA ICT-1 to avoid NDR tripping.
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	28/05/2022	09:54			PO	Work of Overhauling of OLTC of 315 MVA ICT-1
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
PANDHARPUR - MALINAGAR	IntraState	27/05/2022	16:32	27/05/2022	21:07	EO	For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.
DAHANU - GHODBUNDER CKT - 2	IntraState	27/05/2022	17:06	27/05/2022	18:18	T	TRIPPED ON DIST.PROTECTION
KHARGHAR - NERUL	IntraState	27/05/2022	22:37	28/05/2022	00:51	EO	To attend hotspot on B ph CB pole to D isolator jumper by replacing twin Jumper
BOISAR II - BOISAR (PG) CKT - 2	IntraState	28/05/2022	03:27	28/05/2022	05:46	EO	Hot spot attending work Yph CT to D-Isolator jumper crimping at D-Isolator end. (102.9 OC, Image.IR00549)
BOISAR II - BOISAR (PG) CKT - 2	IntraState	28/05/2022	05:46	28/05/2022	06:30	EO	Hot spot attending work 1. Bph T-Jumper crimping at A-Isolator end. (128.8 OC, Image.IR00550) 2.Yph T-Jumper crimping at A-Isolator end.(113 OC, lmg.IR00551)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2022

Statement-VII

Position as on 6.30 Hrs of 28/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PEDHAMBE ONI LINE	IntraState	28/05/2022	09:30	28/05/2022	17:05	EO	Outage for attending Hot spot at Loc. no. 141 Pedhambe side Y phase
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	28/05/2022	11:58	28/05/2022	19:34	EO	For attending low line clearance at loc 5 6
CHAKAN-BHOSARI 1	IntraState	28/05/2022	13:19	28/05/2022	19:08	PO	Double Jumpering Work
PANDHARPUR - MALINAGAR	IntraState	28/05/2022	16:20	28/05/2022	21:26	PO	Outage is required for For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132 KV 100 MVA ICT - 2 @ ALEPHATA	IntraState	26/05/2022	22:57	27/05/2022	01:24	PO	For Pre-monsoon maintenance work.
220/22 KV 50 MVA PTR 2 @ MAHAPE	IntraState	27/05/2022	07:20	27/05/2022	11:36	PO	Power Transformer Pre-Monsoon Maintenance work and Bay Maintenance works along with hotspot attending work
220/100 KV 100 MVA ICT 1 @ TALOJA	IntraState	27/05/2022	08:12	27/05/2022	12:51	PO	100 kV Bus Section-1 (100KV DFPCL,100KV FGIL,200MVA EMCO ICT)
220/33 KV 50 MVA PTR 1 @ MALEGAON	IntraState	27/05/2022	08:25	27/05/2022	09:40	PO	For pre-monsoon work activity
220/33 KV 50 MVA PTR @ PHALTAN MIDC	IntraState	27/05/2022	09:05	27/05/2022	17:04	PO	For tan delta testing, SFRA of transformer & tan delta testing of HV CTs, quarterly and premonsoon maintenance work
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	27/05/2022	09:05	27/05/2022	11:20	PO	PRE MONSOON MAINTENANCE WORK.
220/22 KV 50 MVA PTR 2 @ TEMGHAR	IntraState	27/05/2022	09:20	27/05/2022	18:50	PO	For pre-monsoon and diagnostic testing work
220/22 KV 50 MVA PTR 3 @ KAMBA	IntraState	27/05/2022	09:30	27/05/2022	12:23	PO	1) Pre-monsoon maintenance work 2) Cooling fan maintenance work
220/132 KV 200 MVA ICT 2@ BALE(SOLAPUR)	IntraState	27/05/2022	09:31	27/05/2022	15:45	PO	Outage is required for Oil leakage attending work to be carried out by agency.
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	27/05/2022	09:55	27/05/2022	11:12	PO	Premansoon & Bay maintenance work
220/22 KV 50 MVA PTR 3 @ KOLSHET	IntraState	27/05/2022	10:07	27/05/2022	13:24	PO	1) Pre-monsoon maintenance work. 2) Removal of Bird nest near Buchholz. 3) LV B ph bushing red hot attending work.
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	IntraState	27/05/2022	10:07	27/05/2022	14:11	PO	1)Pre-monsoon Maintenance work 2)Earth pit Resistance Measurement Work..
220/132 KV 200MVA ICT 2 @ KURKUMBH	IntraState	27/05/2022	11:30	27/05/2022	13:10	PO	PRE MONSOON MAINTENANCE WORK
220/22-22 KV 100 MVA PTR 1 @ WADA	IntraState	27/05/2022	14:10	27/05/2022	19:42	PO	For replacement of Differential relay and Bay maintenance work
220/22 KV 50 MVA PTR 2 @ KAMBA	IntraState	27/05/2022	14:20	27/05/2022	15:52	PO	1) Pre-monsoon maintenance work 2) Cooling fan maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2022

Statement-VII

Position as on 6.30 Hrs of 28/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 1 @ MAHAPE	IntraState	27/05/2022	14:31	27/05/2022	18:07	PO	Power Transformer Pre-Monsoon Maintenance work and Bay Maintenance works along with hotspot attending work
220/100 KV 200 MVA ICT 2 @ TALOJA	IntraState	27/05/2022	14:32	27/05/2022	19:11	PO	100 KV BUS SECTION-2 (100KV TALOJA LINE-2, 100KV BOC,200MVA ADITYA ICT)
220/22 KV 50 MVA PTR 2 @ PAL-DOMBIVALI	IntraState	27/05/2022	14:38	27/05/2022	17:45	PO	1]Pre-monsoon Maintenance work 2]Earth pit Resistance Measurement Work..
220/33 KV 50 MVA PTR 2 @ BHENDA	IntraState	28/05/2022	08:00	28/05/2022	12:30	PO	Quarterly maintenance work / pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.
220 / 110 / 23kv 250 MVA ICT 3 @ SALSETTE	IntraState	28/05/2022	08:07	28/05/2022	12:01	PO	Attending Oil leakage from conservator flange
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	28/05/2022	08:16	28/05/2022	14:53	PO	For Half yearly maintenance and diagnostic testing work.
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	28/05/2022	08:36	28/05/2022	10:50	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon
220/22 KV 50 MVA PTR 1 @ AIROLI KNOWLEDGE PARK	IntraState	28/05/2022	08:36	28/05/2022	11:12	PO	Pre monsoon maintenance & Hotspot attending work
220/33 KV 50MVA PTR @ KALWAN	IntraState	28/05/2022	09:03	28/05/2022	11:50	PO	for premonsoon maintenance work
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	28/05/2022	09:25	28/05/2022	17:15	PO	Diagnosis of testing work and pre-monsoon maintenance work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	28/05/2022	09:38	28/05/2022	12:19	PO	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	28/05/2022	09:45	28/05/2022	18:55	PO	PREMONSOON MAINTENANCE AND 2. BAY MAINTENANCE WORK
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	28/05/2022	10:15	28/05/2022	11:35	PO	Pre-Monsoon Maintenance Work
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	28/05/2022	11:15	28/05/2022	13:05	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	28/05/2022	12:31	28/05/2022	15:25	PO	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	28/05/2022	13:10	28/05/2022	16:51	PO	PRE MONSOON MAINTENANCE WORK
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	28/05/2022	13:21	28/05/2022	16:05	PO	For Premonsoon maintenance work.
220/33 KV 50 MVA PTR 1 @ BHENDA	IntraState	28/05/2022	13:50	28/05/2022	15:45	PO	Quarterly maintenance work / Pre Monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.
220/22 KV 50 MVA PTR 1 @ KALWA	IntraState	28/05/2022	14:25	28/05/2022	16:57	PO	For replacement of 22kv main bus isolator &RM Work at MSEDCL END.
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	28/05/2022	14:35	28/05/2022	14:35	PO	ATTENDING RED HOT SPOTS 2. BALANCE PREMONSOON MAINTENANCE WORK
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	28/05/2022	14:47	28/05/2022	16:01	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
220/33 KV 50 MVA PTR 3 @ BHENDA	IntraState	28/05/2022	16:01	28/05/2022	17:51	PO	Quarterly maintenace work/ pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2022

Statement-VII

Position as on 6.30 Hrs of 28/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	IntraState	28/05/2022	16:22	28/05/2022	17:19	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
132 KV LINE Outages/Trippings							
NAGAR - SUPA	IntraState	28/05/2022	15:41	28/05/2022	19:05	PO	Outage Proposal of 132kV Ahmednagar- supa line for Removing of bunching arrangement between Loc 70-71
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	28/05/2022	13:49	28/05/2022	18:47	PO	For attending to hot-spot at loc-14

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage