

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/May/2024 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	156.883	4586.096	1) Gujrat	-2.225	0.236
2) Hydro	27.627	535.698	2) Madhya Pradesh	0.244	133.915
3) Gas	6.725	189.288	3) Chattisgarh	2.200	102.190
Total MSPGCL	191.235	5311.082	4) Maharashtra	180.150	5021.020
B) 1) APLM	52.052	1719.041	5) Goa (Amona)	-2.025	-54.257
2) JSWEL	25.420	727.574	Total	178.344	5203.104
3) VIPL	0.000	0.000	a) Mumbai Schedule	50.020	1184.863
4) RPL(AMT)	25.429	788.419	b) Mumbai Drawl	52.179	1225.447
5) SWPGPL	11.162	329.355	c) MSEDCL Bilateral *	75.685	2170.483
6) Other IPP	15.670	450.508	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	50.020	1184.863
C) 1) TPCL Thermal	12.418	343.183	Include PX	0.000	0.000
2) TPCL Hydro	3.368	127.782	Standby	0.000	0.000
3) TPCL Gas	3.955	104.293	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.768	270.856	1) MSEDCL	505.908	13939.095
D) STATE			2) Mumbai Discoms	81.688	2071.555
1) Thermal	308.802	9215.032	3) Other Discoms	12.111	313.592
(A1+C1+C4+(B1-B6))			TOTAL STATE	599.707	16324.242
2) Hydro	30.995	663.480			
(A2+C2)					
3) Gas	10.680	293.581			
(A3+B7+C3)					
4) Wind	57.015	501.761			
6) SOLAR	13.871	447.290			
TOTAL STATE	421.363	11121.144			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6171	6710	7190	6530
MSPGCL Hydro	641	685	1154	1763
MSPGCL Gas	284	258	274	286
MSPGCL Total Generation	7096	7653	8618	8579
Central Sector Receipt	8525	8669	6933	6687
WIND	1915	2383	2545	2278
CPP / IPP Thermal	4954	5154	6248	5073
CPP / IPP Gas	0	0	0	0
SOLAR	1748	1096	0	0
Exchange with Mumbai	-2458	-2422	-2017	-1956
MSEDCL DEMAND MET	21221	21989	21768	20265
Load Shedding	0	0	0	0
MSEDCL DEMAND	21221	21989	21768	20265
TPCL GENERATION	944	1051	1041	599
AEML GENERATION	504	501	410	294
MUMBAI DEMAND	3906	3974	3468	2849
OTHER DISCOM DEMAND	559	544	559	396
STATE DEMAND MET	25686	26507	25795	23510
STATE DEMAND	25686	26507	25795	23510
Frequency (Hz)	49.99	49.94	50.04	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.19 Hz at 18.02 Hrs	49.81 Hz at 21.25 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/May/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.21	99.34	189	128
Unit 8	11.95	241.89	559	407
Unit 9	12.38	359.89	535	409
Unit 10	12.43	366.04	540	460
Total	40.97	1067.16		
Bhusawal				
Unit 3	0.00	76.13	0	0
Unit 4	9.42	246.00	465	300
Unit 5	8.88	254.80	470	290
Total	18.29	576.92		
Parli				
Unit 6	3.66	120.23	210	137
Unit 7	3.67	115.27	220	137
Unit 8	3.71	113.36	216	140
Total	11.04	348.86		
Chandrapur				
Unit 3	3.34	95.85	160	125
Unit 4	3.36	98.84	162	128
Unit 5	8.38	237.24	430	270
Unit 6	7.85	184.86	413	270
Unit 7	7.88	215.56	398	283
Unit 8	9.88	277.70	465	308
Unit 9	0.02	253.21	15	0
Total	40.71	1363.26		
Paras				
Unit 3	4.99	126.08	243	149
Unit 4	5.05	146.63	253	148
Total	10.04	272.72		
Khaparkheda				
Unit 1	3.67	94.80	170	115
Unit 2	4.18	115.10	196	121
Unit 3	3.86	106.29	169	132
Unit 4	4.12	106.04	187	132
Unit 5	10.63	272.38	500	360
Total	26.45	694.59		
Nasik				
Unit 3	3.21	83.35	163	123
Unit 4	3.09	94.44	139	120
Unit 5	3.08	84.80	156	117
Total	9.38	262.58		
Uran				
All Units	6.72	189.29	289	258
Total	6.72	189.29		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	5.19	0	0
Total	0.00	5.19		
Koyna				
Stage 1-2	5.00	124.68	425	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	15.08	234.54	1011	69
Stage 3	4.49	80.11	320	0
Total	24.56	439.34		
Hydro				
KDPH	0.53	16.76	22	22
VTRNA	0.75	22.38	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.79	50.99	77	70
GHATGHAR	0.00	6.23	0	0
Total	3.07	96.36		
Wind				
Total	57.02	501.76	0	0
Total	57.02	501.76		
CPP				
APML(Mus)	52.05	1719.04	0	0
JSWEL(Mus)	25.42	727.57	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.43	788.42	0	0
SWPGPL-Mus	11.16	329.36	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.36	143.58	265	151
Other(Mus)	6.23	181.84	0	0
JPL	4.08	125.09	267	133
Total	129.73	4014.90		
SOLAR				
Total	13.87	447.29	0	0
Total	13.87	447.29		
Tata				
Trombay 5	8.37	233.73	469	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.46	64.56	108	66
Trombay 7B	1.50	39.73	65	53
TATA Hydro	3.37	127.78	329	21
Trombay 8	4.04	109.46	224	130
Total	19.74	575.26		
AEML				
DTPS U-1&2	9.77	270.86	504	293
Total	9.77	270.86		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	156.88	4586.10	MSPGCL Total	191.24	5311.08
			MSPGCL Thml+Gas	163.61	4775.38	Koyna 1,2 & 4 Total	20.07	359.22
			MSPGCL Hydro	27.63	535.70	State Total	421.36	11121.14

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/May/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7141	1251	286	8678	2137	6598	0	0	6736	6358	-2140	21189	0	0	21189	3371	442	25002	50.03
2	6714	1527	286	8527	2348	5719	0	0	7213	6776	-2226	20730	0	0	20730	3157	414	24301	50.00
3	6625	1795	285	8705	2407	5148	0	0	7135	6689	-2023	20518	0	0	20518	2985	408	23911	49.99
4	6530	1763	286	8579	2278	5073	0	0	6830	6687	-1956	20265	0	0	20265	2849	396	23510	49.95
5	6919	1622	287	8828	2406	5176	0	0	6740	6317	-1817	20516	0	0	20516	2773	394	23683	49.98
6	6732	1362	289	8383	2460	5092	0	1	7143	6840	-1792	20533	0	0	20533	2787	451	23771	49.99
7	6684	1439	286	8409	2525	5099	0	142	7140	6644	-1867	20477	0	2	20477	2761	475	23713	49.98
8	6018	1271	284	7573	2509	4912	0	535	7277	7113	-1960	20187	0	7	20187	2872	495	23554	49.98
9	5480	1262	289	7031	2443	4897	0	1017	7645	7726	-2251	20327	0	0	20327	3196	536	24059	50.02
10	5475	1212	283	6970	2289	4919	0	1367	8092	7964	-2575	20379	0	0	20379	3525	555	24459	50.00
11	6001	558	283	6842	2118	4970	0	1586	8726	8496	-2447	21011	0	0	21011	3800	554	25365	50.00
12	6171	641	284	7096	1915	4954	0	1748	8910	8525	-2458	21221	0	4	21221	3906	559	25686	49.99
13	6257	360	284	6901	1933	4964	0	1856	8936	8543	-2448	21188	0	9	21188	3888	561	25637	49.97
14	5910	344	268	6522	2004	4888	0	1804	8894	8654	-2423	20904	0	10	20904	3810	545	25259	50.01
15	5880	832	262	6974	2159	4955	0	1483	9190	9101	-2438	21700	0	14	21700	3925	534	26159	49.99
16	6710	685	258	7653	2383	5154	0	1096	9262	8669	-2422	21989	0	15	21989	3974	544	26507	49.94
17	6781	798	260	7839	2348	5269	0	789	8585	8321	-2205	21804	0	16	21804	3839	557	26200	49.98
18	6690	626	272	7588	2332	5522	0	396	8510	7947	-2263	20961	0	8	20961	3673	561	25195	50.00
19	6726	1315	274	8315	2443	5355	0	51	7954	7481	-2236	20854	0	0	20854	3493	555	24902	50.04
20	7190	1154	274	8618	2545	6248	0	0	7262	6933	-2017	21768	0	0	21768	3468	559	25795	50.04
21	7314	825	287	8426	2649	6577	0	0	6785	6694	-1957	21854	0	0	21854	3398	535	25787	49.99
22	6709	1657	284	8650	2795	5988	0	0	6602	6518	-2040	21389	0	0	21389	3363	522	25274	49.95
23	7095	1605	285	8985	2788	6320	0	0	6675	6455	-2029	22036	0	0	22036	3399	483	25918	50.00
24	7131	1723	289	9143	2801	5936	0	0	6982	6893	-2189	22107	0	0	22107	3476	477	26060	50.06
MUs	156.88	27.63	6.72	191.24	57.01	129.73	0.00	13.87	185.22	178.34	-52.18	505.91	0.00	0.09	505.91	81.69	12.11	599.71	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

132kV BBLR to Rahuri line Overload.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/May/2024

Position as on 6.30 Hrs of 28/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Chandrapur Unit 9	500	24/05/2024	01:59	27/05/2024	23:48	Boiler Tube Leakage	27/05/2024
MSPGCL	Bhusawal Unit 3	210	24/05/2024	15:37	28/05/2024	03:23	Boiler Tube Leakage	28/05/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	28/05/2024
MSPGCL	Koradi Unit 8	660	28/05/2024	01:14		Continued.	Boiler Tube Leakage	29/05/2024
Total Capacity MSPGCL		1615						
IPP								
IPP	RPL(AMT) U-2	270	25/05/2024	13:52		Continued.	ID Fan Tripped at high Vibration.	28/05/2024
IPP	SWPGPL U-1	135	27/05/2024	15:35		Continued.	ID Fan Problem	29/05/2024
Total Capacity IPP		405						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2340						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	24/05/2024	02:00		Continued.	Due to Zero schedule by MSEDCL.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO		988						

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/May/2024

Position as on 6.30 Hrs of 28/May/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
	NO PPA							

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2024

Statement-VII

Position as on 6.30 Hrs of 28/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	26/05/2024	23:21	27/05/2024	02:24	PO	Y-ph CVT jumper connection work.
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	26/05/2024	23:21	27/05/2024	02:24	PO	Y-ph CVT jumper connection work.
PADGHE - KALWA CKT - 2	IntraState	28/05/2024	03:28	28/05/2024	04:05	T	Tripped from Kalwa end only on PDR.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	27/05/2024	11:20	27/05/2024	16:39	PO	Pre-monsoon Maintenance work.
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	27/05/2024	11:27	27/05/2024	21:02	PO	DFRA SFRA testing, premonsoon maintenance and quarterly bay maintenace work.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	25/05/2024	13:25			HT	For load management

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2024

Statement-VII

Position as on 6.30 Hrs of 28/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/05/2024	01:27	27/05/2024	18:55	PO	B) As on dt: 25.05.2024 at 21:00Hrs to 27.05.2024 at 06:00Hrs. outage on 220kV Padghe- Nalasopara for the work of erection of in-line Monopole , cut point formation and conductor de-stringing & stringing work. 1) Jumper at loc.52 of 220kV Padghe-Nalasopra line will be opened to avoid the backfeeding from 220kV Vasai-Nalasopara link line. 2) After opening the jumper at loc.no. 52, 220kV Nalasopara-Vasai link line will be charged at 23:00Hrs. on dt:-25.05.2024 for 02 days. 3) In-line monopole erection work will be carry out at loc.no.48,49 & 49A. 4) Cut point formation over newly erected Monopole work will be carrying out at loc.no. 48,49,&49A of 220kV Padghe-Nalasopara line and also related tower's conductor de-stringing and stringing work will be carry out of above said ckt. 5) After erection of Monopole tower, cut point formation and conductor stringing work, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on dt: 27.05.2024.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 3	IntraState	26/05/2024	15:40	27/05/2024	02:55	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
220 KV PARLI (OLD GCR)-GIRWALI (400 KV) CKT 4	IntraState	26/05/2024	15:40	27/05/2024	03:05	T	Tripped due earth wire strangling of 132kv Parli-Girwali ckt.
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	Tripped on distance protection
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	Tripped of distance protection
KHARGHAR - BORIVALI CKT - 2	IntraState	26/05/2024	22:03	27/05/2024	02:34	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 66 sets are to be installed)
MULUND - GIS BHANDUP	IntraState	26/05/2024	22:05	27/05/2024	02:08	PO	For the installation of saver assembly sets at TL no. 20 & 21 (Total 6 sets out of 6 sets are to be installed)
WARDHA-D-GAON NEW	IntraState	27/05/2024	07:42	27/05/2024	09:53	PO	For replacement of faulty middle stack of 220kv BPH LA the stack is having low IR value(4.6MOHM) top to earth IR value is(8.54 GOHM).
220 KV KEKATNIBHORA - KHADKA (400 KV) CKT	IntraState	27/05/2024	08:25	27/05/2024	20:51	PO	For Work of restringing of conductor From loc no 299 to 313.
KHAREPATAN -PAWAS LINE	IntraState	27/05/2024	08:39	27/05/2024	10:49	PO	For Premonsoon activity.
THEUR-PHURSUNGI CKT I	IntraState	27/05/2024	09:12	27/05/2024	21:42	PO	Dist. relay retrofitting, commissioning and testing work by agency GE
OSMANABAD - BARSHI	IntraState	27/05/2024	09:21	27/05/2024	13:41	PO	Replacement of LA's under LE scheme along with quarterly bay maintenance work.
OSMANABAD - BARSHI	IntraState	27/05/2024	09:21	27/05/2024	13:41	PO	Work at Barshi end.
TALANDAGE - FIVE STAR MIDC 1	IntraState	27/05/2024	10:40	27/05/2024	20:41	PO	Retrofitting of O/C E/F Relay

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/May/2024

Statement-VII

Position as on 6.30 Hrs of 28/May/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NEW KOYNA - NIWALI	IntraState	27/05/2024	11:27	27/05/2024	13:39	PO	For replacement of flashover insulator string at loc no 125 middle ph Niwali side
132 KV PADEGAON (220 KV) - SAWANGI (220 KV) CKT	IntraState	27/05/2024	12:35	27/05/2024	16:49	EO	Tree cutting in urban, forest , military area.
SATANA - GANGAPUR	IntraState	27/05/2024	13:05	28/05/2024	18:30	HT	Unbalanced current R-PH jump open at 314 loc.
PEDHAMBE ONI LINE	IntraState	27/05/2024	14:08	27/05/2024	17:17	PO	For replacement of flashover strings at loc no 125 top ph Oni side and broken insulator string at loc no 125 bottom ph Oni side.
KARAD - KADEGAON	IntraState	27/05/2024	15:04	27/05/2024	20:35	PO	Replacement of faulty disc insulator strings at various locations
PADGHE - NALASOPARA - VASAI (T)	IntraState	27/05/2024	17:10	27/05/2024	18:55	PO	As on dt:27.05.2024 at 04:00Hrs. to 06:00 Hrs. outage on 220kV Nalasopara-Vasai link line for the work of re-connect the jumper atloc.no.52 of 220kV Padghe-Nalasopara line. 1) To re-connecting the jumper at loc.no.52 of 220kV Padghe-Nalasopara-Vasai tap line. 2) After re-connecting the jumper at loc.no.52, 220kV Padghe-Nalasopara-Vasai tap line will be charged at 06:00 Hrs. on Dt: - 27.05. 2024.
POPHLI PEDHMBE LINE- 1	IntraState	28/05/2024	06:56			PO	R phase CT oil level top up work.
THEUR-PHURSUNGI CKT II	IntraState	28/05/2024	09:01			PO	Dist. relay retrofitting commissioning and testing work by agency GE
220 KV ICT Outages/Trippings							
220 / 11 KV 200 MVA GT @ BHIRA (T)	IntraState	26/05/2024	23:40	27/05/2024	06:35	PO	REPLACEMENT OF OIL COOLER
220/132 KV 200 MVA ICT 2	IntraState	27/05/2024	08:00	27/05/2024	09:48	PO	Pre-monsoon Work.
220/110 KV 100 MVA PTR 1 @ BIDRI	IntraState	27/05/2024	08:35	27/05/2024	14:10	PO	Diagnostic testing work. Quarterly maintenance work.
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	27/05/2024	09:09	27/05/2024	16:16	PO	Quarterly Maintenance works.
220/33 kv 50 MVA CGL PTR 1 @ MUDSHINGI	IntraState	27/05/2024	09:16	27/05/2024	17:26	PO	"Transformer painting work."
220/132 KV, 100MVA ICT 1 @ ANJANGAON(VIHIGAON)	IntraState	27/05/2024	09:25	27/05/2024	18:45	PO	Pre-monsoon work.
220/132KV 200MVA ICT 5 @ EKLAHARE (OCR)	IntraState	27/05/2024	10:07	27/05/2024	13:30	PO	Pre monsoon maintenance work
220/33KV 50MVA PTR 1 @ 5 STAR MIDC, KAGAL	IntraState	27/05/2024	10:23	27/05/2024	12:38	PO	for premonsoon maintenance work
220/132 KV 100 MVA ICT 3 @ RANJANGAON	IntraState	27/05/2024	10:28	27/05/2024	15:57	PO	For Premonsoon Bay maintenance work.
220/33 KV 50 MVA PTR - 1 @ PHALTAN MIDC	IntraState	28/05/2024	09:05			PO	Quarterly Maintenance Work
220/33KV 50MVA PTR 1 @ MIRAJ	IntraState	28/05/2024	09:38			PO	Premonsoon Maintenance Work
110 KV LINE Outages/Trippings							
KHOPOLI - KARANJADE	IntraState	27/05/2024	10:05	27/05/2024	11:17	PO	BIRD NEST REMOVAL
AMBERNATH - KALYAN CKT - 1	IntraState	27/05/2024	15:22	27/05/2024	20:32	PO	CT STABILITY

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage