

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Jun/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.174	4295.722	1) Gujrat	-5.617	-57.946
2) Hydro	8.009	315.355	2) Madhya Pradesh	5.090	162.310
3) Gas	0.000	114.922	3) Chattisgarh	3.540	81.510
Total MSPGCL	156.183	4725.999	4) Maharashtra	166.615	5569.599
B) 1) APLM	55.828	1789.665	5) Goa (Amona)	-1.182	-36.207
2) JSWEL	17.756	627.579	Total	168.446	5719.266
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.151	1154.148
4) RPL(AMT)	24.249	714.951	b) Mumbai Drawl	43.533	1260.131
5) SWPGPL	10.497	284.676	c) MSEDCL Bilateral *	92.707	3232.795
6) Other IPP	6.464	155.837	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.151	1153.649
C) 1) TPCL Thermal	9.570	327.072	Include PX	0.000	0.000
2) TPCL Hydro	2.398	135.092	Standby	0.000	0.499
3) TPCL Gas	3.308	51.425	H) ENERGY CATERED (MUs)		
4) AEML Thermal	6.582	248.501	1) MSEDCL	437.430	13879.384
D) STATE			2) Mumbai Discoms	65.391	2022.221
1) Thermal	279.120	8444.003	3) Other Discoms	9.828	284.658
(A1+C1+C4+(B1-B6))			TOTAL STATE	512.649	16186.263
2) Hydro	10.407	450.447			
(A2+C2)					
3) Gas	3.308	166.347			
(A3+B7+C3)					
4) Wind	44.405	1005.613			
6) SOLAR	6.963	400.587			
TOTAL STATE	344.203	10466.997			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6184	6084	6431	6169
MSPGCL Hydro	402	215	467	296
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	6586	6299	6898	6465
Central Sector Receipt	8658	8363	6723	5690
WIND	1909	1804	2120	1752
CPP / IPP Thermal	4476	4516	5362	4485
CPP / IPP Gas	0	0	0	0
SOLAR	851	764	0	0
Exchange with Mumbai	-2349	-2350	-1908	-1136
MSEDCL DEMAND MET	19662	18943	18755	16955
Load Shedding	0	0	0	0
MSEDCL DEMAND	19662	18943	18755	16955
TPCL GENERATION	616	604	808	565
AEML GENERATION	414	362	217	313
MUMBAI DEMAND	3379	3316	2933	2014
OTHER DISCOM DEMAND	469	453	440	301
STATE DEMAND MET	23510	22712	22128	19270
STATE DEMAND	23510	22712	22128	19270
Frequency (Hz)	50.04	50.15	50.01	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.34 Hz at 13.02 Hrs	49.69 Hz at 16.29 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	2.94	120.50	150	75
Unit 8	13.51	295.11	604	505
Unit 9	11.51	272.34	504	438
Unit 10	12.45	342.86	544	490
Total	40.41	1030.80		
Bhusawal				
Unit 3	3.15	69.14	145	110
Unit 4	9.41	274.30	475	335
Unit 5	10.96	293.67	500	345
Total	23.52	637.10		
Parli				
Unit 6	3.74	118.99	213	135
Unit 7	3.75	123.41	205	144
Unit 8	0.00	71.84	0	0
Total	7.49	314.24		
Chandrapur				
Unit 3	3.34	84.25	157	122
Unit 4	2.96	84.29	128	115
Unit 5	0.00	0.00	0	0
Unit 6	7.60	219.13	380	285
Unit 7	7.74	242.83	368	285
Unit 8	10.18	295.11	467	274
Unit 9	10.60	298.06	493	360
Total	42.41	1223.68		
Paras				
Unit 3	3.83	127.40	203	123
Unit 4	4.30	114.62	205	147
Total	8.12	242.02		
Khaparkheda				
Unit 1	1.12	67.42	95	0
Unit 2	2.22	75.96	106	78
Unit 3	3.23	87.88	144	125
Unit 4	3.02	104.00	147	105
Unit 5	10.16	293.51	450	398
Total	19.76	628.77		
Nasik				
Unit 3	0.00	10.09	0	0
Unit 4	3.36	106.15	166	121
Unit 5	3.09	102.86	147	117
Total	6.46	219.11		
Uran				
All Units	0.00	114.92	0	0
Total	0.00	114.92		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	2.03	0	0
Total	0.00	2.03		
Koyna				
Stage 1-2	2.17	79.12	410	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	81.22	0	0
Stage 3	0.54	37.36	160	0
Total	2.71	197.69		
Hydro				
KDPH	0.36	6.47	15	15
VTRNA	1.22	30.86	60	0
TILLARI	0.46	5.40	58	0
BHIRA T.R.	0.20	7.99	40	0
SMLHY_PTN	3.05	62.16	136	121
GHATGHAR	0.00	2.76	0	0
Total	5.30	115.63		
Wind				
Total	44.40	1005.61	0	0
Total	44.40	1005.61		
CPP				
APML(Mus)	55.83	1789.66	0	0
JSWEL(Mus)	17.76	627.58	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.25	714.95	0	0
SWPGPL-Mus	10.50	284.68	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.46	100.68	199	154
Other(Mus)	2.01	55.16	0	0
Total	114.79	3572.71		
SOLAR				
Total	6.96	400.59	0	0
Total	6.96	400.59		
Tata				
Trombay 5	6.36	219.39	301	230
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.96	28.55	108	43
Trombay 7B	1.34	22.87	65	40
TATA Hydro	2.40	135.09	277	7
Trombay 8	3.21	107.68	174	127
Total	15.28	513.59		
AEML				
DTPS U-1&2	6.58	248.50	414	167
Total	6.58	248.50		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.17	4295.72	MSPGCL Total	156.18	4726.00
			MSPGCL Thml+Gas	148.17	4410.64	Koyna 1,2 & 4 Total	2.17	160.33
			MSPGCL Hydro	8.01	315.36	State Total	344.20	10467.00

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6110	297	0	6407	1717	4891	0	0	6661	6166	-1456	17354	0	0	17354	2391	371	20116	49.99
2	6221	297	0	6518	1831	4943	0	0	6026	5646	-1316	17286	0	0	17286	2205	336	19827	50.00
3	6210	296	0	6506	1755	4697	0	0	5801	5745	-1251	17147	0	0	17147	2087	305	19539	50.00
4	6169	296	0	6465	1752	4485	0	0	5838	5690	-1136	16955	0	0	16955	2014	301	19270	49.98
5	6340	296	0	6636	1879	4777	0	0	5945	6041	-1132	17869	0	0	17869	2007	332	20208	49.97
6	6384	345	0	6729	1882	4947	0	0	6416	6568	-1241	18499	0	0	18499	2112	386	20997	49.91
7	6423	608	0	7031	1726	4995	0	74	6766	7111	-1347	19187	0	0	19187	2241	403	21831	49.95
8	6537	611	0	7148	1570	5367	0	273	6880	7395	-1465	19876	0	0	19876	2419	412	22707	50.02
9	6487	298	0	6785	1846	5338	0	507	7796	7674	-1859	19835	0	0	19835	2748	456	23039	50.09
10	6216	276	0	6492	1750	4781	0	667	8604	8740	-2189	19794	0	0	19794	3056	447	23297	50.01
11	6079	237	0	6316	1717	4465	0	876	9111	8680	-2385	19213	0	0	19213	3276	456	22945	50.02
12	6184	402	0	6586	1909	4476	0	851	8894	8658	-2349	19662	0	0	19662	3379	469	23510	50.04
13	6084	215	0	6299	1804	4516	0	764	8668	8363	-2350	18943	0	0	18943	3316	453	22712	50.15
14	5489	186	0	5675	1788	4197	0	824	8655	8354	-2315	18101	0	0	18101	3113	422	21636	50.11
15	5628	185	0	5813	2017	4179	0	773	8379	8193	-2370	18193	0	0	18193	3113	412	21718	50.11
16	6127	189	0	6316	2055	4162	0	639	7884	7895	-2336	18310	0	0	18310	3114	421	21845	50.01
17	5855	343	0	6198	2173	4170	0	443	7599	7711	-2250	18005	0	0	18005	3048	440	21493	49.89
18	6379	265	0	6644	2189	4636	0	235	7189	6631	-2168	17731	0	0	17731	3010	436	21177	50.00
19	6316	456	0	6772	1944	4942	0	37	6930	6856	-2045	18044	0	0	18044	2960	462	21466	50.02
20	6431	467	0	6898	2120	5362	0	0	7240	6723	-1908	18755	0	0	18755	2933	440	22128	50.01
21	6224	412	0	6636	1925	5021	0	0	6838	6583	-1772	17966	0	0	17966	2845	427	21238	49.94
22	6108	412	0	6520	1896	5150	0	0	6029	5819	-1697	17275	0	0	17275	2740	413	20428	50.02
23	6128	315	0	6443	1668	5300	0	0	5982	5584	-1627	16962	0	0	16962	2654	406	20022	50.08
24	6045	305	0	6350	1492	4997	0	0	5975	5620	-1569	16468	0	0	16468	2610	422	19500	50.03
MUs	148.17	8.01	0.00	156.18	44.41	114.79	0.00	6.96	172.11	168.45	-43.53	437.43	0.00	0.00	437.43	65.39	9.83	512.65	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Jun/2023

Position as on 6.30 Hrs of 28/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Koyna STG-IV Unit-2	250	07/06/2023	15:30		Continued.	Due to water shortage.	
MSPGCL	Koyna STG-IV Unit-3	250	07/06/2023	15:30		Continued.	Due to water shortage.	
MSPGCL	Koyna STG-IV Unit-4	250	08/06/2023	10:45		Continued.	Water Shortage	
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	No Schedule	
MSPGCL	Khaparkheda Unit 1	210	27/06/2023	04:06	27/06/2023	12:44	Tripped on electrical fault	28/06/2023
AEML	AEML Unit 2	250	27/06/2023	13:55		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U2	300	27/06/2023	23:44		Continued.	No schedule	
MSPGCL	Chandrapur Unit 9	500	28/06/2023	06:36	28/06/2023	11:57	Flame Failure	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 28/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV BR Outages/Trippings							
BUS REACTOR (240 MVar) @ AKOLA 2	IntraState	28/06/2023	09:35	28/06/2023	14:51	PO	Changeover of R-Ph Reactor with Spare Reactor at Akola(2) SS as per CEA guideline
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/06/2023	16:47	27/06/2023	20:52	T	Tripped on DC differential protection
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/06/2023	21:14	28/06/2023	18:56	T	Tripped on DC differential protection
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV RPL-AKOLA2 CKT 1	InterState	27/06/2023	09:52	27/06/2023	11:12	T	Tripped at RPL end only Power swing detected.
SOLAPUR PG - ALKUD	InterState	28/06/2023	01:10	28/06/2023	09:30	T	Tripped on distance protection
DHULE - SSNNL CKT - 1	InterState	28/06/2023	02:26	28/06/2023	16:00	T	Tripped on distance protection
DHULE - SSNNL CKT - 2	InterState	28/06/2023	02:48	28/06/2023	19:56	T	Tripped on distance protection
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	26/06/2023	08:51	28/06/2023	17:13	PO	Diagnostic Testing of 400 kV NTPP I & NTPP II Bay's Outdoor Equipment & Relay.
BABHALESHWAR - PADGHE CKT - 2	IntraState	27/06/2023	01:35	27/06/2023	03:57	PO	Routine Line maintenance and Insulator cleaning work
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	27/06/2023	09:46		Continued.	HT	H/T for load Management.
JAIGAD - KARAD CKT - 1	IntraState	28/06/2023	03:50	28/06/2023	10:04	HT	To control system overvoltage
DEEPNAGAR - THAPTI TANDA	IntraState	28/06/2023	08:36		Continued.	T	Tripped on Distance Protection.
CHANDRAPUR GCR - CHANDRAPUR HVDC - 1	IntraState	28/06/2023	21:51		Continued.	EO	Replacement of damaged scissor assembly of B-ph Pole of PG-3 Isolator B-ph pole (Aux. Bus Isolator) of 400kV Chandrapur-HVDC Ckt. No-1 bay.
JAIGAD - KARAD CKT - 2	IntraState	28/06/2023	22:17		Continued.	HT	To control system voltages
LONIKAND I - KOYNA STAGE-IV	IntraState	28/06/2023	22:30		Continued.	HT	To control system voltages
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 315MVA ICT - 1 @ BABHALESHWAR	IntraState	28/06/2023	09:38	28/06/2023	19:34	EO	R phase oil top up and premonsoon work
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55		Continued.	HT	For load management
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14		Continued.	PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36		Continued.	PO	LILO and commissioning of 220kV Ulwe GIS
PURTI-BHUGAON	IntraState	27/06/2023	08:21	27/06/2023	11:19	PO	Testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 28/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TALANDGE - HAMIDWADA	IntraState	27/06/2023	09:53	27/06/2023	17:34	PO	Quarterly Maintenance and Diagnostic work
KARAD - OGALEWADI CKT 1	IntraState	27/06/2023	09:56	27/06/2023	15:24	PO	Fixing of repair sleeves between Loc No.6-7 Y ph & 20 B Ph
MURUD - TULJAPUR	IntraState	27/06/2023	10:26	27/06/2023	12:34	PO	Quarterly Maintenance work
BUTIBORI-BUTIBORI 3	IntraState	27/06/2023	11:30	27/06/2023	17:51	PO	CT Replacement work
MIRAJ - ICHALKARANJI	IntraState	27/06/2023	12:29	27/06/2023	17:19	PO	Earthwire stringing at Loc. No.71 to1
TROMBAY - SALSETTE CKT - 1	IntraState	27/06/2023	22:49	28/06/2023	01:40	PO	Attending hot spot of 220 kV Trombay - Salsette-1 at Trombay end gantry structure on B Ph 90 Deg. and C Ph 66 Deg
SALSETTE - SAHAR CKT	IntraState	28/06/2023	02:10	28/06/2023	03:32	PO	Attending critical hot spot at Loc. 28 on B Ph CT terminal
KALWA - COLOURCHEM	IntraState	28/06/2023	07:10	28/06/2023	14:01	PO	Work on CRP panel for module replacement at line differential relay at 400 KV Kalwa S/St end and removing of jumpures at Loc. No.04 for making LILO at 220 KV GIS DCHI S/St.
KARAD - WATHAR	IntraState	28/06/2023	09:45	28/06/2023	17:33	PO	For strings replacement as per PID testing report at loc no. 1 (R ph), 4 (B ph.), 5 (B ph), 7 (Y & Bph) , 10 (R ph) .
KHAPARKHEDA- BUTIBORI	IntraState	28/06/2023	10:06	28/06/2023	16:58	PO	Replacement of damaged jumper & flashover string at various locations.
MURUD - TULJAPUR	IntraState	28/06/2023	10:08	28/06/2023	13:00	EO	Replacement of R ph LA at Murud end.
220KV TULJAPUR-LAMBOTI(400KV)CKT 1	IntraState	28/06/2023	10:35	28/06/2023	13:37	PO	for tightening of jumper nut bolt at 98 Y
KANDALGAON - ONGC PANVEL	IntraState	28/06/2023	11:30	28/06/2023	17:59	PO	Routine maintenance & emergency tree cutting work .
220KV TULJAPUR - LAMBOTI(400KV) CKT 2	IntraState	28/06/2023	13:49	28/06/2023	17:13	PO	. fixing of suspension clamp bolt at 104
CARNAC BACKBAY - 4	IntraState	28/06/2023	23:11		Continued.	PO	220 kV Bay RTU replacement
CTRLS - NET MAGIC GIS	IntraState	28/06/2023	23:48		Continued.	HT	Hotspot attended on R-ph GIS bushing at CTT tower at CTRLS end
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA ICT 2 @ SATARA MIDC	IntraState	27/06/2023	09:30	27/06/2023	16:49	PO	Pre Monsoon & Quarterly maintenance work
220/132KV 100MVA ICT 1 @ 220KV GEORAI	IntraState	27/06/2023	11:08	27/06/2023	14:21	PO	Premonsoon maintenance work
220/132KV 100MVA ICT 2 @ 220KV GEORAI	IntraState	27/06/2023	14:38	27/06/2023	17:00	PO	Premonsoon maintenance work
220/132 KV 200 MVA ICT 3	IntraState	28/06/2023	09:31	28/06/2023	12:56	PO	Maintenance Work
220/132 KV 100 MVA ICT 2	IntraState	28/06/2023	10:25	28/06/2023	14:15	PO	Servicing and demonstration of CTR make NIFPS system installed for ICT-1
200 MVA 220/132 KV ICT 2 @ GIRWALI	IntraState	28/06/2023	10:48	28/06/2023	14:16	PO	OLTC Trial Work.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	28/06/2023	10:53	28/06/2023	11:22	EO	REMOVING BIRD NEST

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 28/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALYAN KALWA SALSETTE 2	IntraState	28/06/2023	16:43	28/06/2023	18:14	PO	Removal of bird nest at location 28,29,38,40,54

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage