

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 27/Jul/2017 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 97.748         | 2674.536        | 1) Gujrat                      | 5.451          | 25.519           |
| 2) Hydro            | 6.134          | 174.451         | 2) Madhya Pradesh              | 15.746         | 454.347          |
| 3) Gas              | 9.522          | 233.348         | 3) Chattisgarh                 | 8.320          | 211.890          |
| <b>Total MSPGCL</b> | <b>113.404</b> | <b>3082.335</b> | 4) Maharashtra Net             | 82.242         | 2329.288         |
| B) 1) APML          | 53.350         | 1510.623        | 5) Goa (Amona)                 | -0.594         | -12.474          |
| 2) JSWEL            | 15.022         | 351.997         | <b>Total</b>                   | <b>111.165</b> | <b>3008.570</b>  |
| 3) VIPL             | 5.650          | 159.101         | a) Mumbai Schedule             | 22.898         | 573.234          |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 31.463         | 759.991          |
| 5) WPCL             | 3.775          | 82.028          | c) MSEDCL Bilateral *          | 9.141          | 481.034          |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -4.054         | 15.058           |
| 7) Other IPP        | 3.299          | 83.144          | d) Mumbai Bilateral *          | 22.898         | 573.234          |
| C) 1) TPCL Thermal  | 13.488         | 359.759         | Include PX                     | 7.444          | 176.263          |
| 2) TPCL Hydro       | 6.383          | 131.431         | Include Standby                | 0.000          | 0.000            |
| 3) TPCL Gas         | 0.000          | 79.119          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 9.444          | 269.969         | 1) MSEDCL                      | 328.203        | 8855.938         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 60.775         | 1600.259         |
| 1) Thermal          | 201.776        | 5491.157        | <b>TOTAL STATE</b>             | <b>388.978</b> | <b>10456.197</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 12.517         | 305.882         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 9.522          | 312.467         |                                |                |                  |
| (A3+B6+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 52.615         | 1293.872        |                                |                |                  |
| 6) SOLAR            | 1.386          | 44.259          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>277.816</b> | <b>7447.637</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 9 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|--------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4172                     | 4250                  | 4147                      | 3741                      |
| MSPGCL Hydro             | 128                      | 135                   | 469                       | 231                       |
| MSPGCL Gas               | 409                      | 405                   | 407                       | 395                       |
| MSPGCL Total Generation  | 4709                     | 4790                  | 5023                      | 4367                      |
| Central Sector Receipt   | 5313                     | 4792                  | 4901                      | 3869                      |
| WIND                     | 2461                     | 2606                  | 1914                      | 2059                      |
| CPP / IPP Thermal        | 3829                     | 3601                  | 3221                      | 3206                      |
| CPP / IPP Gas            | 0                        | 0                     | 0                         | 0                         |
| SOLAR                    | 86                       | 193                   | 0                         | 0                         |
| Exchange with Mumbai     | -1120                    | -1836                 | -1496                     | -893                      |
| <b>MSEDCL DEMAND MET</b> | <b>15278</b>             | <b>14146</b>          | <b>13563</b>              | <b>12608</b>              |
| Load Shedding            | 0                        | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 15278                    | 14146                 | 13563                     | 12608                     |
| TPCL GENERATION          | 927                      | 861                   | 915                       | 591                       |
| R-INFRA GENERATION       | 497                      | 371                   | 372                       | 376                       |
| <b>MUMBAI DEMAND</b>     | <b>2544</b>              | <b>3068</b>           | <b>2783</b>               | <b>1860</b>               |
| STATE DEMAND MET         | 17822                    | 17214                 | 16346                     | 14468                     |
| <b>STATE DEMAND</b>      | <b>17822</b>             | <b>17214</b>          | <b>16346</b>              | <b>14468</b>              |
| Frequency (Hz)           | 49.99                    | 50.01                 | 49.88                     | 50.01                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.         | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|-----------------------|---------------|---------------------|
| 50.13 Hz at 16.31 Hrs | 49.73 Hz at 13.53 Hrs | 49.95         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 27/Jul/2017

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 10.51        | 237.80         | 500      | 382      |
| Unit 9             | 10.39        | 231.75         | 459      | 394      |
| Unit 10            | 10.55        | 257.02         | 520      | 400      |
| <b>Total</b>       | <b>31.45</b> | <b>726.57</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 52.33          | 0        | 0        |
| Unit 5             | 0.00         | 22.97          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>75.29</b>   |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.51         | 11.72          | 205      | 163      |
| Unit 4             | 0.00         | 107.27         | 0        | 0        |
| Unit 5             | 9.11         | 205.89         | 400      | 360      |
| Unit 6             | 9.27         | 252.33         | 412      | 360      |
| Unit 7             | 9.67         | 257.48         | 437      | 361      |
| Unit 8             | 9.89         | 241.00         | 470      | 357      |
| Unit 9             | 10.17        | 250.77         | 474      | 360      |
| <b>Total</b>       | <b>52.62</b> | <b>1326.47</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 4.92         | 136.21         | 250      | 188      |
| Unit 4             | 4.75         | 47.85          | 238      | 184      |
| <b>Total</b>       | <b>9.68</b>  | <b>184.06</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 0.00         | 13.54          | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| Unit 3             | 0.00         | 16.68          | 0        | 0        |
| Unit 4             | 0.00         | 21.01          | 0        | 0        |
| Unit 5             | 0.00         | 140.20         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>191.44</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 4.01         | 70.19          | 200      | 160      |
| Unit 4             | 0.00         | 41.20          | 0        | 0        |
| Unit 5             | 0.00         | 59.31          | 0        | 0        |
| <b>Total</b>       | <b>4.01</b>  | <b>170.70</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 9.52         | 233.35         | 409      | 322      |
| <b>Total</b>       | <b>9.52</b>  | <b>233.35</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |

| Generating unit   | Generation   |                |          |          |
|-------------------|--------------|----------------|----------|----------|
|                   | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |              |                |          |          |
| Pench (MS)        | 0.08         | 3.38           | 22       | 0        |
| <b>Total</b>      | <b>0.08</b>  | <b>3.38</b>    |          |          |
| <b>Koyna</b>      |              |                |          |          |
| Stage 1-2         | 2.48         | 68.98          | 435      | 40       |
| Stage 4           | 0.11         | 21.01          | 93       | 0        |
| Stage 3           | 1.15         | 39.74          | 160      | 0        |
| <b>Total</b>      | <b>3.73</b>  | <b>129.72</b>  |          |          |
| <b>Hydro</b>      |              |                |          |          |
| KDPH              | 0.00         | 0.00           | 0        | 0        |
| VTRNA             | 0.66         | 4.42           | 61       | 0        |
| TILLARI           | 0.23         | 6.69           | 60       | 0        |
| BHTGR/VEER        | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.42         | 11.40          | 80       | 0        |
| RNGR+BHTSA        | 0.42         | 1.93           | 19       | 17       |
| BHANDARDRA        | 0.34         | 11.32          | 15       | 14       |
| ELDARY            | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.34         | 3.54           | 15       | 14       |
| GHATGHAR          | 0.00         | 5.44           | 0        | 0        |
| <b>Total</b>      | <b>2.41</b>  | <b>44.73</b>   |          |          |
| <b>Wind</b>       |              |                |          |          |
| Total             | 52.62        | 1293.87        | 0        | 0        |
| <b>Total</b>      | <b>52.62</b> | <b>1293.87</b> |          |          |
| <b>CPP</b>        |              |                |          |          |
| APML(Mus)         | 53.35        | 1510.62        | 0        | 0        |
| JSWEL(Mus)        | 15.02        | 352.00         | 0        | 0        |
| VIPL(Mus)         | 5.65         | 159.10         | 0        | 0        |
| RPLAMT(Mus)       | 0.00         | 0.00           | 0        | 0        |
| WPCL(Mus)         | 3.78         | 82.03          | 0        | 0        |
| Other(Mus)        | 3.30         | 83.14          | 0        | 0        |
| <b>Total</b>      | <b>81.10</b> | <b>2186.89</b> |          |          |
| <b>SOLAR</b>      |              |                |          |          |
| Total             | 1.39         | 44.26          | 0        | 0        |
| <b>Total</b>      | <b>1.39</b>  | <b>44.26</b>   |          |          |
| <b>Tata</b>       |              |                |          |          |
| Trombay 5         | 8.48         | 230.28         | 486      | 315      |
| Trombay 6         | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A        | 0.00         | 49.72          | 0        | 0        |
| Trombay 7B        | 0.00         | 29.40          | 0        | 0        |
| Trombay 8         | 5.01         | 129.48         | 246      | 198      |
| TATA Hydro        | 6.38         | 131.43         | 435      | 75       |
| <b>Total</b>      | <b>19.87</b> | <b>570.31</b>  |          |          |
| <b>R-INFRA</b>    |              |                |          |          |
| DTPS U-1&2        | 9.44         | 269.97         | 497      | 370      |
| <b>Total</b>      | <b>9.44</b>  | <b>269.97</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 97.75       | 2674.54       | MSPGCL Total        | 113.40      | 3082.34       |
|                |             |         | MSPGCL Thml+Gas | 107.27      | 2907.88       | Koyna 1,2 & 4 Total | 2.58        | 89.98         |
|                |             |         | MSPGCL Hydro    | 6.13        | 174.45        | State Total         | 277.82      | 7447.64       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 27/Jul/2017

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 3963        | 259  | 322  | 4544   | 2298  | 3326      | 0    | 0     | 4211        | 3990        | -1074                | 13084                 | 0                    | 13084                     | 2141             | 15225           | 49.89         |
| 2                  | 3789        | 228  | 351  | 4368   | 2202  | 3210      | 0    | 0     | 4173        | 4109        | -996                 | 12894                 | 0                    | 12894                     | 1962             | 14856           | 49.97         |
| 3                  | 3741        | 231  | 395  | 4367   | 2059  | 3206      | 0    | 0     | 4094        | 3869        | -893                 | 12608                 | 0                    | 12608                     | 1860             | 14468           | 50.01         |
| 4                  | 3728        | 178  | 404  | 4310   | 2154  | 3131      | 0    | 0     | 4093        | 3979        | -826                 | 12749                 | 0                    | 12749                     | 1793             | 14542           | 49.99         |
| 5                  | 3792        | 178  | 395  | 4365   | 2222  | 3127      | 0    | 0     | 4374        | 4084        | -819                 | 12980                 | 0                    | 12980                     | 1787             | 14767           | 49.97         |
| 6                  | 4085        | 119  | 408  | 4612   | 2061  | 3447      | 0    | 0     | 4481        | 4400        | -785                 | 13735                 | 0                    | 13735                     | 1907             | 15642           | 49.96         |
| 7                  | 4143        | 97   | 406  | 4646   | 2141  | 3785      | 0    | 8     | 4727        | 4693        | -760                 | 14513                 | 0                    | 14513                     | 2049             | 16562           | 49.92         |
| 8                  | 4201        | 117  | 407  | 4725   | 2134  | 3832      | 0    | 35    | 4835        | 5123        | -911                 | 14937                 | 0                    | 14937                     | 2291             | 17228           | 50.01         |
| 9                  | 4172        | 128  | 409  | 4709   | 2461  | 3829      | 0    | 86    | 5047        | 5313        | -1120                | 15278                 | 0                    | 15278                     | 2544             | 17822           | 49.99         |
| 10                 | 4354        | 213  | 405  | 4972   | 2305  | 3828      | 0    | 132   | 5236        | 5151        | -1584                | 14804                 | 0                    | 14804                     | 2930             | 17734           | 49.97         |
| 11                 | 4281        | 226  | 393  | 4900   | 2680  | 3791      | 0    | 153   | 5106        | 4826        | -1790                | 14560                 | 0                    | 14560                     | 3073             | 17633           | 49.88         |
| 12                 | 4262        | 255  | 392  | 4909   | 2416  | 3671      | 0    | 174   | 5111        | 5028        | -1838                | 14360                 | 0                    | 14360                     | 3122             | 17482           | 49.99         |
| 13                 | 4250        | 135  | 405  | 4790   | 2606  | 3601      | 0    | 193   | 5045        | 4792        | -1836                | 14146                 | 0                    | 14146                     | 3068             | 17214           | 50.01         |
| 14                 | 4041        | 95   | 403  | 4539   | 2531  | 3223      | 0    | 187   | 4961        | 4933        | -1672                | 13741                 | 0                    | 13741                     | 2914             | 16655           | 49.92         |
| 15                 | 3917        | 285  | 401  | 4603   | 2595  | 3118      | 0    | 179   | 5017        | 5209        | -1661                | 14043                 | 0                    | 14043                     | 2940             | 16983           | 49.84         |
| 16                 | 3953        | 395  | 393  | 4741   | 2369  | 3116      | 0    | 114   | 5091        | 5356        | -1672                | 14024                 | 0                    | 14024                     | 2952             | 16976           | 49.98         |
| 17                 | 4260        | 145  | 405  | 4810   | 2262  | 3106      | 0    | 78    | 4815        | 4850        | -1672                | 13434                 | 0                    | 13434                     | 2933             | 16367           | 50.02         |
| 18                 | 4088        | 145  | 405  | 4638   | 2532  | 3106      | 0    | 39    | 4622        | 4309        | -1623                | 13002                 | 0                    | 13002                     | 2894             | 15896           | 50.06         |
| 19                 | 3910        | 272  | 399  | 4581   | 2201  | 3101      | 0    | 8     | 4798        | 4752        | -1590                | 13053                 | 0                    | 13053                     | 2813             | 15866           | 49.95         |
| 20                 | 4147        | 469  | 407  | 5023   | 1914  | 3221      | 0    | 0     | 5021        | 4901        | -1496                | 13563                 | 0                    | 13563                     | 2783             | 16346           | 49.88         |
| 21                 | 4125        | 424  | 405  | 4954   | 1795  | 3181      | 0    | 0     | 4979        | 4967        | -1363                | 13534                 | 0                    | 13534                     | 2669             | 16203           | 49.87         |
| 22                 | 4040        | 793  | 405  | 5238   | 1484  | 3210      | 0    | 0     | 4441        | 4563        | -1253                | 13242                 | 0                    | 13242                     | 2574             | 15816           | 49.85         |
| 23                 | 4183        | 521  | 407  | 5111   | 1556  | 3375      | 0    | 0     | 3924        | 4078        | -1128                | 12991                 | 0                    | 12991                     | 2429             | 15420           | 49.88         |
| 24                 | 4323        | 226  | 400  | 4949   | 1637  | 3553      | 0    | 0     | 3821        | 3889        | -1101                | 12927                 | 0                    | 12927                     | 2350             | 15277           | 49.94         |
| MUs                | 97.75       | 6.13 | 9.52 | 113.40 | 52.62 | 81.10     | 0.00 | 1.39  | 112.02      | 111.17      | -31.46               | 328.20                | 0.00                 | 328.20                    | 60.78            | 388.98          | 49.95         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 27/Jul/2017**

**Position as on 6.30 Hrs of 28/Jul/2017**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |           | Continued. | Economic shutdown.                                                                                                                                               |               |
| CENT.SECTOR           | TARAPUR 4               | 540      | 23/04/2017   | 19:55        |           | Continued. | Annual Maintenance                                                                                                                                               |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 04/06/2017   | 19.09        |           | Continued. | 3 months outage for refuelling.                                                                                                                                  |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 14/06/2017   | 23.16        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 21/06/2017   | 01.24        |           | Continued. | COH.                                                                                                                                                             |               |
| IPP                   | JSW (J) U4              | 300      | 04/07/2017   | 20.41        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| CENT.SECTOR           | TARAPUR-3               | 540      | 11/07/2017   | 16.30        |           | Continued. | Reactor Inspection Work                                                                                                                                          |               |
| IPP                   | Adani U-3               | 660      | 14/07/2017   | 23.48        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 15/07/2017   | 05.59        |           | Continued. | Zero Schedule By MSEDCL (Converted to AOH from 00:00Hrs of 20.07.2017)                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |           | Continued. | Gas Shortage.                                                                                                                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |           | Continued. | EE R&M LE Work                                                                                                                                                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                                                          |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |           | Continued. | No PPA                                                                                                                                                           |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |           | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 14/08/2016   | 07.56        |           | Continued. | Maintenance work                                                                                                                                                 |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |           | Continued. | Change Over.                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |           | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-1            | 270      | 24/05/2017   | 03.27        |           | Continued. | Flame Failure(converted to Zero Schedule from 00.00Hrs DT.13th Jun 17)                                                                                           |               |
| IPP                   | JSW (J) U2              | 300      | 31/05/2017   | 23.58        |           | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| IPP                   | Dhariwal                | 300      | 01/06/2017   | 00.01        |           | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| IPP                   | RPL(AMT) U-3            | 270      | 05/06/2017   | 14.31        |           | Continued. | swapping with unit-5(converted to Zero Schedule from 00.00Hrs DT.15th Jun 17)                                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 27/Jul/2017**

**Position as on 6.30 Hrs of 28/Jul/2017**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                     | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|-----------|------------|----------------------------------------------------------------------|---------------|
| IPP                | RPL(AMT) U-4            | 270      | 09/06/2017   | 00.20        |           | Continued. | Zero Schedule by MSEDCL                                              |               |
| IPP                | RPL(AMT) U-5            | 270      | 09/06/2017   | 01.39        |           | Continued. | Zero Schedule by MSEDCL                                              |               |
| IPP                | RPL(AMT) U-2            | 270      | 09/06/2017   | 04.24        |           | Continued. | Zero Schedule by MSEDCL                                              |               |
| MSPGCL             | Parli Unit 7            | 250      | 13/06/2017   | 00.04        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Bhusawal Unit 3         | 210      | 13/06/2017   | 06.01        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| IPP                | VIPL U-1                | 300      | 13/06/2017   | 08.30        |           | Continued. | GT WORK                                                              |               |
| MSPGCL             | Parli Unit 6            | 250      | 14/06/2017   | 00.02        |           | Continued. | Zero schedule by MSEDCL.                                             |               |
| MSPGCL             | Parli Unit 8            | 250      | 17/06/2017   | 00.08        |           | Continued. | Zero Schedule by MSEDCL                                              |               |
| MSPGCL             | Nasik Unit 4            | 210      | 10/07/2017   | 14.28        |           | Continued. | Boiler validity extention.on date 12/07/2017 converted zero schedule |               |
| MSPGCL             | Khaparkheda Unit 1      | 210      | 11/07/2017   | 23.53        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Khaparkheda Unit 3      | 210      | 12/07/2017   | 08.40        |           | Continued. | Boiler Tube Leakage. on date 13.07.2017 converted to zero schedule.  |               |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 13/07/2017   | 03.36        |           | Continued. | Drum level low. on Dated 14.07.2017 converted to zero schedule.      |               |
| MSPGCL             | Nasik Unit 5            | 210      | 16/07/2017   | 00.00        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 17/07/2017   | 23.46        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| TPC-G              | Trombay 7B              | 60       | 21/07/2017   | 23.20        |           | Continued. | Gas Path Inspection and CW Tunnel repairs (For 8 Days)               |               |
| TPC-G              | Trombay 7A              | 120      | 22/07/2017   | 02.51        |           | Continued. | Gas Path Inspection and CW Tunnel repairs (For 8 Days)               |               |
| MSPGCL             | Khaparkheda Unit 5      | 500      | 25/07/2017   | 00.00        |           | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 26/07/2017   | 13.36        |           | Continued. | Boiler Tube Leakage                                                  |               |
| CPP                | SWPGL U-3               | 135      | 27/07/2017   | 13.00        |           | Continued. | ID Fan Problem                                                       |               |
| MSPGCL             | Ghatghar Unit-1         | 125      | 28/07/2017   | 00.00        |           | Continued. | rbtv leakage attending work.                                         |               |
| MSPGCL             | Ghatghar Unit-2         | 125      | 28/07/2017   | 00.00        |           | Continued. | due to common pressure shaft with unit 1.                            |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 27/Jul/2017**

**Statement-VII**

Position as on 6.30 Hrs of 28/Jul/2017

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Karad Solapur (PG)                   | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                            |
| Dhule Sar'Sarovar I                  | InterState                | 25/07/2017   | 17.06        | 27/07/2017 | 06.58      | HT          | Over Voltage                                                                                                        |
| Dhule Khandwa II                     | InterState                | 26/07/2017   | 12.24        | 27/07/2017 | 11.35      | T           | Distance Protection                                                                                                 |
| Parli(MS)-Parli (PG) I               | InterState                | 26/07/2017   | 12.50        |            | Continued. | PO          | online installation of abt meter.                                                                                   |
| Dhule Sar'Sarovar II                 | InterState                | 27/07/2017   | 13.13        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Khadka-Aurangabad (Waluj)            | IntraState                | 12/07/2017   | 18.11        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Ektuni-Bableshtar ckt II             | IntraState                | 16/07/2017   | 16.05        |            | Continued. | HT          | To control load                                                                                                     |
| karad -kolhapur-I                    | IntraState                | 20/07/2017   | 09.38        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Akola II - RPL(Rattaniindia) Ckt-II  | IntraState                | 25/07/2017   | 13.26        | 27/07/2017 | 06.29      | T           | Distance Protection                                                                                                 |
| Nagothane - Dabhol I                 | IntraState                | 27/07/2017   | 11.15        | 27/07/2017 | 20.24      | PO          | Insulator string Replacement Work.                                                                                  |
| Jaigad-Karad Ckt-I                   | IntraState                | 27/07/2017   | 17.46        | 28/07/2017 | 06.42      | HT          | Over Voltage                                                                                                        |
| Jaigad-New Koyna Ckt-II              | IntraState                | 28/07/2017   | 06.02        |            | Continued. | T           | Distance Protection                                                                                                 |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 400/220 Kv 500 Mva Ict 1 @Lamboti    | IntraState                | 27/07/2017   | 16.43        | 28/07/2017 | 00.01      | PO          | outage for ctr commissioning.                                                                                       |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Talandage - Chikodi                  | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Mudshingi - Chikodi                  | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Tillari Amona                        | InterState                | 27/07/2017   | 12.56        | 27/07/2017 | 17.07      | PO          | Distance Relay Testing Work                                                                                         |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kharghar-Borivali ckt II             | IntraState                | 07/06/2017   | 12.23        |            | Continued. | T           | Distance Protection                                                                                                 |
| Vita - Mhaishal                      | IntraState                | 01/07/2017   | 14.19        |            | Continued. | PO          | Bunching Work                                                                                                       |
| Vita - Miraj                         | IntraState                | 01/07/2017   | 14.53        |            | Continued. | PO          | bunching work.                                                                                                      |
| Karad - Sadawagpur I                 | IntraState                | 21/07/2017   | 11.07        |            | Continued. | T           | Distance Protection                                                                                                 |
| Parli 2-(Girwali) -Murud             | IntraState                | 26/07/2017   | 17.02        | 27/07/2017 | 10.39      | T           | to control parly ict loading.                                                                                       |
| Jejuri (400 Kv)-Phurusungi           | IntraState                | 27/07/2017   | 09.38        | 27/07/2017 | 15.49      | PO          | Routine Maintenance Work                                                                                            |
| Kalwa - Siemens                      | IntraState                | 27/07/2017   | 09.56        | 27/07/2017 | 17.29      | PO          | safety purpose for construction work.                                                                               |
| Uran - Kharghar I                    | IntraState                | 27/07/2017   | 10.58        | 27/07/2017 | 16.14      | EO          | Attending Hot Spot                                                                                                  |
| Chakan-Bhosari                       | IntraState                | 27/07/2017   | 11.06        | 27/07/2017 | 20.58      | PO          | Routine Maintenance Work                                                                                            |
| Pedambe-Nerle                        | IntraState                | 27/07/2017   | 16.16        |            | Continued. | T           | Distance Protection                                                                                                 |
| Parli 3 (Oldgcr)-Harangul Ckt 2      | IntraState                | 27/07/2017   | 18.10        | 27/07/2017 | 21.00      | PO          | Isolator jaw Replacement work.                                                                                      |
| Jejuri- Ismt- Lonand                 | IntraState                | 27/07/2017   | 19.16        | 27/07/2017 | 17.43      | PO          | Replacement of Line Isolator                                                                                        |
| <b>220 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |
| 220/132KV 100MVA -1@Alephata         | IntraState                | 27/07/2017   | 12.55        | 27/07/2017 | 15.35      | PO          | Routine Maintenance Work                                                                                            |
| <b>132 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Kardha-Asgaon                        | IntraState                | 27/07/2017   | 19.12        | 27/07/2017 | 19.34      | T           | Distance Protection                                                                                                 |
| Waghala (Nanded2) - Narsi            | IntraState                | 27/07/2017   | 19.27        | 27/07/2017 | 19.40      | T           | Distance Protection                                                                                                 |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage