

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Aug/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	118.600	2794.989	1) Gujrat	10.740	249.113
2) Hydro	19.651	395.570	2) Madhya Pradesh	9.609	164.215
3) Gas	4.456	137.608	3) Chattisgarh	4.110	83.170
Total MSPGCL	142.707	3328.167	4) Maharashtra	175.488	3919.364
B) 1) APLM	61.510	1426.335	5) Goa (Amona)	-1.232	-44.015
2) JSWEL	19.512	386.051	Total	198.715	4371.847
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.793	812.114
4) RPL(AMT)	18.906	534.412	b) Mumbai Drawl	29.462	885.246
5) SWPGPL	5.602	163.325	c) MSEDCL Bilateral *	83.228	2056.685
6) Other IPP	5.277	153.814	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.793	811.830
C) 1) TPCL Thermal	11.963	281.759	Include PX	0.000	0.000
2) TPCL Hydro	7.888	169.931	Standby	0.000	0.284
3) TPCL Gas	0.677	50.669	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.560	236.512	1) MSEDCL	437.923	10504.278
D) STATE			2) Mumbai Discoms	60.550	1624.120
1) Thermal	251.930	5977.197	3) Other Discoms	8.851	235.393
(A1+C1+C4+(B1-B6))			TOTAL STATE	507.324	12363.791
2) Hydro (A2+C2)	27.539	565.501			
3) Gas (A3+B7+C3)	5.133	188.277			
4) Wind	13.501	1039.428			
6) SOLAR	10.506	221.538			
TOTAL STATE	308.609	7991.941			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4716	4877	5101	4931
MSPGCL Hydro	429	425	1563	521
MSPGCL Gas	222	231	107	229
MSPGCL Total Generation	5367	5533	6771	5681
Central Sector Receipt	10329	9647	7905	7093
WIND	253	262	1040	640
CPP / IPP Thermal	4396	4574	4827	4466
CPP / IPP Gas	0	0	0	0
SOLAR	1437	1319	0	0
Exchange with Mumbai	-1917	-1679	-1178	-865
MSEDCL DEMAND MET	19449	19261	18971	16723
Load Shedding	0	0	0	0
MSEDCL DEMAND	19449	19261	18971	16723
TPCL GENERATION	731	874	1158	703
AEML GENERATION	344	410	468	426
MUMBAI DEMAND	2992	2963	2804	1994
OTHER DISCOM DEMAND	416	395	394	292
STATE DEMAND MET	22857	22619	22169	19009
STATE DEMAND	22857	22619	22169	19009
Frequency (Hz)	49.91	49.93	49.88	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 09.46 Hrs	49.74 Hz at 12.13 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.00	71.25	195	135
Unit 7	0.00	0.00	0	0
Unit 8	2.89	105.96	476	0
Unit 9	0.00	46.51	0	0
Unit 10	10.67	278.96	480	370
Total	17.56	502.68		
Bhusawal				
Unit 3	1.51	8.74	110	0
Unit 4	9.47	221.97	445	340
Unit 5	0.00	55.81	0	0
Total	10.98	286.52		
Parli				
Unit 6	4.56	111.25	200	177
Unit 7	4.44	101.27	205	162
Unit 8	3.77	96.24	166	148
Total	12.76	308.76		
Chandrapur				
Unit 3	2.06	34.71	148	0
Unit 4	3.10	17.75	146	104
Unit 5	5.70	140.27	313	200
Unit 6	5.38	143.44	275	150
Unit 7	7.31	62.79	342	214
Unit 8	9.77	242.15	436	368
Unit 9	10.38	252.30	447	417
Total	43.70	893.40		
Paras				
Unit 3	4.90	98.82	238	180
Unit 4	4.82	103.01	220	185
Total	9.72	201.83		
Khaparkheda				
Unit 1	2.23	43.00	110	65
Unit 2	0.00	44.16	0	0
Unit 3	3.32	91.28	157	129
Unit 4	3.81	67.82	170	140
Unit 5	8.48	199.50	380	285
Total	17.84	445.77		
Nasik				
Unit 3	3.10	78.73	138	117
Unit 4	0.00	0.00	0	0
Unit 5	2.95	77.30	134	116
Total	6.04	156.03		
Uran				
All Units	4.46	137.61	239	107
Total	4.46	137.61		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.59	16.09	25	24
Total	0.59	16.09		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	3.73	70.68	450	35
Stage 4	5.29	69.56	1015	0
Stage 3	2.19	43.12	240	0
Total	11.22	183.36		
Hydro				
KDPH	0.00	11.91	0	0
VTRNA	0.63	16.53	61	0
TILLARI	0.58	14.45	58	0
BHIRA T.R.	0.47	12.68	80	0
SMLHY_PTN	6.00	135.44	262	242
GHATGHAR	0.16	5.12	125	0
Total	7.85	196.12		
Wind				
Total	13.50	1039.43	0	0
Total	13.50	1039.43		
CPP				
APML(Mus)	61.51	1426.34	0	0
JSWEL(Mus)	19.51	386.05	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.91	534.41	0	0
SWPGPL-Mus	5.60	163.32	0	0
Other(Mus)	5.28	153.81	0	0
Total	110.81	2663.94		
SOLAR				
Total	10.51	221.54	0	0
Total	10.51	221.54		
Tata				
Trombay 5	8.06	187.93	447	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.64	29.32	115	0
Trombay 7B	0.04	21.35	41	0
TATA Hydro	7.89	169.93	389	222
Trombay 8	3.91	93.83	222	130
Total	20.53	502.36		
AEMIL				
DTPS U-1&2	10.56	236.51	493	344
Total	10.56	236.51		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	118.60	2794.99	MSPGCL Total	142.71	3328.17
			MSPGCL Thml+Gas	123.06	2932.60	Koyna 1,2 & 4 Total	9.02	140.24
			MSPGCL Hydro	19.65	395.57	State Total	308.61	7991.94

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 27/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4890	824	239	5953	572	4458	0	0	6486	6677	-706	16617	0	16617	2291	337	19245	49.92
2	4888	579	227	5694	571	4459	0	0	6981	7036	-826	16615	0	16615	2119	319	19053	49.90
3	4931	521	229	5681	640	4466	0	0	7115	7093	-865	16723	0	16723	1994	292	19009	49.97
4	5004	352	227	5583	638	4474	0	0	7439	7493	-826	17065	0	17065	1924	297	19286	50.00
5	5056	319	238	5613	551	4465	0	0	7599	7493	-779	17062	0	17062	1908	281	19251	49.98
6	4853	1057	228	6138	403	4629	0	0	7680	7668	-739	17779	0	17779	1993	320	20092	50.00
7	4878	1936	228	7042	332	4668	0	51	7797	7868	-767	18833	0	18833	2097	361	21291	49.95
8	4827	1518	238	6583	220	4672	0	282	8714	8895	-955	19304	0	19304	2223	393	21920	49.98
9	4696	562	228	5486	207	4502	0	631	9821	9952	-1286	19085	0	19085	2474	407	21966	49.99
10	4769	598	236	5603	251	4336	0	996	9393	9660	-1648	18793	0	18793	2739	405	21937	50.07
11	4761	513	226	5500	265	4557	0	1266	9909	9906	-1855	19228	0	19228	2933	411	22572	50.06
12	4716	429	222	5367	253	4396	0	1437	10320	10329	-1917	19449	0	19449	2992	416	22857	49.91
13	4877	425	231	5533	262	4574	0	1319	9743	9647	-1679	19261	0	19261	2963	395	22619	49.93
14	4930	426	223	5579	311	4617	0	1223	9401	9303	-1590	19059	0	19059	2837	384	22280	49.98
15	4929	450	213	5592	344	4522	0	1220	9566	9683	-1725	19258	0	19258	2830	378	22466	50.00
16	4766	1042	154	5962	503	4635	0	1067	8893	8899	-1696	18976	0	18976	2839	394	22209	49.93
17	4775	685	107	5567	679	4682	0	671	9107	9069	-1606	18658	0	18658	2814	404	21876	49.95
18	4883	538	107	5528	867	4780	0	293	8776	8572	-1564	18087	0	18087	2771	389	21247	50.02
19	5138	1068	107	6313	1027	4782	0	50	7934	7512	-1312	17964	0	17964	2754	408	21126	49.94
20	5101	1563	107	6771	1040	4827	0	0	7833	7905	-1178	18971	0	18971	2804	394	22169	49.88
21	5203	1307	107	6617	935	4868	0	0	7526	7451	-1098	18383	0	18383	2714	390	21487	49.98
22	5151	1012	108	6271	854	4858	0	0	7169	7155	-1009	17751	0	17751	2603	378	20732	50.00
23	5266	1013	118	6397	902	4790	0	0	6592	6789	-874	17636	0	17636	2504	368	20508	49.96
24	5312	914	108	6334	874	4790	0	0	6694	6660	-962	17367	0	17367	2430	329	20126	49.91
MUs	118.60	19.65	4.46	142.71	13.50	110.81	0.00	10.51	198.49	198.72	-29.46	437.92	0.00	437.92	60.55	8.85	507.32	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Aug/2022

Position as on 6.30 Hrs of 28/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	20/09/2022
MSPGCL	Koradi Unit 9	660	07/08/2022	14:53		Continued.	Boiler Tube Leakage (Converted to Annual Overhaul from 11.08.2022 for 45 Days)	26/09/2022
MSPGCL	Bhusawal Unit 5	500	08/08/2022	12:31		Continued.	Bottom ash Hopper damaged due to felling of clinker in the boiler (Converted into Annual Overhaul for 33 Days.)	10/09/2022
MSPGCL	Koyna STG-IV Unit-3	250	27/08/2022	12:00		Continued.	Governing System Upgradation	05/09/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	31/08/2022
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
IPP	SWPGPL U-2	135	20/07/2022	01:00	28/08/2022	14:11	Coal Shortage	
IPP	SWPGPL U-4	135	16/08/2022	00:45		Continued.	Coal Shortage	
MSPGCL	Bhusawal Unit 3	210	16/08/2022	03:44	27/08/2022	02:44	Wet coal problem.	
MSPGCL	Khaparkheda Unit 2	210	19/08/2022	02:18	28/08/2022	13:27	Furnace Pressure High/poor coal receipt & wet coal.	
IPP	RPL(AMT) U-5	270	19/08/2022	11:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	24/08/2022	02:29		Continued.	Gas shortage	
IPP	Adani U-5	660	26/08/2022	00:06		Continued.	HOT PA-5A bellow leakage	30/08/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Aug/2022

Position as on 6.30 Hrs of 28/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
TPC-G	Trombay 7B	60	26/08/2022	00:53		Continued.	Due to Less availability of APM Gas.	
MSPGCL	Koradi Unit 8	660	26/08/2022	22:51	27/08/2022	03:03	Water separator drum level high.	
IPP	JSW (J) U1	300	26/08/2022	23:55	27/08/2022	03:18	EH oil leakage.	
TPC-G	Trombay 7A	120	27/08/2022	01:13	27/08/2022	17:31	Due to Less availability of APM Gas.	
MSPGCL	Koradi Unit 8	660	27/08/2022	04:57	27/08/2022	16:32	Control and Instrument supply failure.	
MSPGCL	Chandrapur Unit 3	210	27/08/2022	14:52	27/08/2022	17:53	HP HEATER HIGH LEVEL	
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
MSPGCL	Uran Unit 8	108	27/08/2022	15:26		Continued.	Gas shortage	
MSPGCL	Koyana STG-IV Unit-4	250	27/08/2022	18:40	27/08/2022	18:40	D.C.supply fail	
MSPGCL	Koyana STG-IV Unit-4	250	27/08/2022	18:41	28/08/2022	18:36	DC SUPPLY FAILED	
MSPGCL	Bhusawal Unit 3	210	27/08/2022	18:48	27/08/2022	20:59	Low Vacuum	
TPC-G	Trombay 7A	120	27/08/2022	23:14		Continued.	Due to Less availability of APM Gas.	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	
IPP	Adani U-3	660	28/08/2022	23:48		Continued.	APH Gear Box Abnormal Sound	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 28/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
KORADI III - AKOLA II Ckt - 2	IntraState	28/08/2022	09:03	28/08/2022	19:43	PO	Annual Maintenace of line
500 KV TBC Outages/Trippings							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	27/08/2022	12:30	27/08/2022	15:27	EO	For attending 02 nos of hotspots having temprature 246 & 140 deg cel. Fumes are visible at 246 & C location with naked eye due to which jumper may break any time causing tripping of Pole II Base Filter
500 KV LR Outages/Trippings							
Pole-1 Non base AC filter Z3 (120 MVAR) @ Chandrapur HVDC	IntraState	16/08/2022	15:11	27/08/2022	19:36	HT	This breaker put in lock out at 15:06hrs dt.15.08.2022 and this filter is under breakdown and expert service are required for
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	26/08/2022	22:07	27/08/2022	02:54	EO	For removing grass & herbs in base filter area
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	27/08/2022	01:57	27/08/2022	04:40	T	TRIPPED UNDER REDUCED VOLTAGE
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	28/08/2022	15:15	28/08/2022	20:23	T	DP
NAGOTHANE - DABHOL CKT - 2	IntraState	27/08/2022	11:55	27/08/2022	16:22	T	Distance Protection
400 KV ICT Outages/Trippings							
95 MVA STN TF - II @KORADI 2	IntraState	23/08/2022	12:26			PO	1)Transformer testing and oil filtration 2)Transformer bus duct inspection 3) Station switch gear checking , breaker and relay testing
400/220/33 KV 600 MVA ICT - 4 @ PADGHE	IntraState	28/08/2022	11:15	28/08/2022	19:30	EO	For attending/ Replacement of Bph LV Bushing due to Oil leakage
220 KV MAINBAY Outages/Trippings							
PT BAY @ COLOURCHEM	IntraState	28/08/2022	07:10	28/08/2022	13:55	EO	Emergency replacement of R and Y phase 200KV PT as both PTs found heavily rusted top & bottom tank.
220 KV LINE Outages/Trippings							
TROMBAY - SALSETTE CKT - 1	IntraState	27/08/2022	08:22	27/08/2022	11:52	PO	Protection Testing at Trombay Generating Station
URAN - APTA CKT - 1	IntraState	27/08/2022	09:51	27/08/2022	14:52	PO	For string insulator replacement work & hot spot attending work
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	27/08/2022	09:51	27/08/2022	12:52	PO	1) Attending the damaged conductor in between Loc.No.97 and Loc.No.97A.
MHAISHAL- JATH	IntraState	27/08/2022	10:41	27/08/2022	13:52	PO	Damaged conductor replacement work at Loc No.216
MAHAD-KALAMBANI(TSS)	IntraState	27/08/2022	11:56	27/08/2022	21:40	PO	Control panel and relay panel height rising work.
ADLABS - PEDAMBE	IntraState	27/08/2022	20:28	27/08/2022	21:25	T	DP
KALWA SALSETTE - 4	IntraState	28/08/2022	06:03	28/08/2022	09:39	PO	TREE TRIMMING AND PROTECTION TESTING

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 28/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
COLOURCHEM - TEMGHAR	IntraState	28/08/2022	06:39	28/08/2022	14:00	EO	Emergency replacement of R and Y phase 200KV PT as both PTs found heavily rusted top & bottom tank.
VILE BHAGAD - KANDHALGAON	IntraState	28/08/2022	09:51		Continued.	HT	Main Bus section I Outage
KANDALGAON - PIRANGUT	IntraState	28/08/2022	09:57		Continued.	HT	Main Bus section I Outage
KANDALGAON - KOYNA (POPHALI)	IntraState	28/08/2022	10:00		Continued.	HT	Main Bus section I Outage
BUS SECTION - 1 @ KANDALGAON	IntraState	28/08/2022	10:10		Continued.	PO	For Replacing Single Bus to Twin Bus of Bus section - 1
NANDED CITY-FLAGSHIP	IntraState	28/08/2022	11:27	28/08/2022	14:27	EO	For attending Hotspot of Y PH CB of 220 kv FLAGSHIP bay
MAHALAXMI - AMONA	IntraState	28/08/2022	12:18	28/08/2022	13:21	T	Distance Protection
ADLABS - PEDAMBE	IntraState	28/08/2022	16:05	28/08/2022	18:57	EO	Dismentaling of broken earth wire loc No. 249
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	25/08/2022	09:26	27/08/2022	17:18	PO	Commissioning of new HV & LV Relay & Control panel.
220/33kv 125 MVA TF 2 @ GORAI	IntraState	27/08/2022	10:58	27/08/2022	15:18	PO	Attending oil leakage from HV neutral bushing CT terminal enclosure
220/22 KV 50 MVA PTR 1 @ PAL-DOMBIVALI	IntraState	27/08/2022	11:28	27/08/2022	17:42	PO	HV & LV LA Insulation resistance measurement work & Bay RM work.
220/33KV 50MVA PTR 1 @ JEJURI	IntraState	27/08/2022	15:45	28/08/2022	15:10	PO	REPLACEMENT OF HV SIDE BUS ISOLATOR
220 KV BUSBAR Outages/Trippings							
MAIN BUS - 2 @ URAN	IntraState	27/08/2022	09:54	27/08/2022	18:29	PO	1) For MAIN BUS-2 insulator and stub Bus insulator string replacement work.
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage