

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Sep/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	124.696	3083.283	1) Gujrat	10.866	267.378
2) Hydro	10.097	308.474	2) Madhya Pradesh	7.736	123.019
3) Gas	2.124	69.767	3) Chattisgarh	3.680	98.630
Total MSPGCL	136.917	3461.524	4) Maharashtra	154.265	4042.197
B) 1) APLM	63.805	1694.451	5) Goa (Amona)	-0.884	-32.283
2) JSWEL	19.582	487.421	Total	175.663	4498.941
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.550	873.827
4) RPL(AMT)	25.363	457.210	b) Mumbai Drawl	35.433	964.832
5) SWPGPL	7.413	130.791	c) MSEDCL Bilateral *	58.608	1565.480
6) Other IPP	5.066	149.028	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.550	873.612
C) 1) TPCL Thermal	10.445	300.240	Include PX	0.000	0.000
2) TPCL Hydro	4.508	136.634	Standby	0.000	0.215
3) TPCL Gas	2.726	19.611	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.777	239.921	1) MSEDCL	407.338	10481.511
D) STATE			2) Mumbai Discoms	61.889	1661.239
1) Thermal	265.147	6542.345	3) Other Discoms	9.227	242.909
(A1+C1+C4+(B1-B6))			TOTAL STATE	478.454	12385.659
2) Hydro (A2+C2)	14.605	445.108			
3) Gas (A3+B7+C3)	4.850	89.378			
4) Wind	7.776	570.177			
6) SOLAR	10.413	239.709			
TOTAL STATE	302.791	7886.717			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4841	4801	5389	4915
MSPGCL Hydro	165	147	1859	150
MSPGCL Gas	88	91	82	91
MSPGCL Total Generation	5094	5039	7330	5156
Central Sector Receipt	9455	8697	6585	6013
WIND	117	97	568	422
CPP / IPP Thermal	4634	4599	5846	4531
CPP / IPP Gas	0	0	0	0
SOLAR	1391	1329	0	0
Exchange with Mumbai	-2307	-2129	-1253	-907
MSEDCL DEMAND MET	17980	17223	18649	14912
Load Shedding	0	0	0	0
MSEDCL DEMAND	17980	17223	18649	14912
TPCL GENERATION	553	546	1205	649
AEML GENERATION	287	433	494	297
MUMBAI DEMAND	3147	3108	2952	1853
OTHER DISCOM DEMAND	404	409	427	303
STATE DEMAND MET	21531	20740	22028	17068
STATE DEMAND	21531	20740	22028	17068
Frequency (Hz)	50.01	49.98	49.96	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.14 Hz at 07.54 Hrs	49.6 Hz at 18.25 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Sep/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	39.35	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.30	264.29	456	391
Unit 9	10.04	58.50	460	375
Unit 10	9.83	268.42	481	300
Total	30.17	630.56		
Bhusawal				
Unit 3	0.00	57.75	0	0
Unit 4	8.03	222.14	410	280
Unit 5	8.50	74.17	420	270
Total	16.53	354.06		
Parli				
Unit 6	4.58	116.66	232	145
Unit 7	3.92	96.83	198	134
Unit 8	3.23	98.95	144	123
Total	11.73	312.43		
Chandrapur				
Unit 3	3.29	79.38	160	122
Unit 4	3.11	81.08	148	117
Unit 5	4.92	146.46	310	0
Unit 6	7.00	155.42	330	250
Unit 7	7.35	159.14	370	265
Unit 8	0.00	49.00	0	0
Unit 9	8.67	249.32	447	280
Total	34.33	919.79		
Paras				
Unit 3	5.27	120.10	239	187
Unit 4	0.00	86.15	0	0
Total	5.27	206.25		
Khaparkheda				
Unit 1	3.00	71.82	145	120
Unit 2	2.74	41.60	140	70
Unit 3	3.60	85.34	177	130
Unit 4	3.53	81.22	175	126
Unit 5	8.22	217.77	420	275
Total	21.09	497.74		
Nasik				
Unit 3	0.00	32.57	0	0
Unit 4	2.65	53.76	120	99
Unit 5	2.91	76.13	140	109
Total	5.56	162.46		
Uran				
All Units	2.12	69.77	104	82
Total	2.12	69.77		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	13.89	25	24
Total	0.60	13.89		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.83	60.22	425	35
Stage 4	2.79	50.22	931	0
Stage 3	1.30	28.80	240	0
Total	6.92	139.24		
Hydro				
KDPH	0.43	6.98	18	18
VTRNA	0.00	19.47	0	0
TILLARI	0.00	12.40	0	0
BHIRA T.R.	0.27	10.52	60	0
SMLHY_PTN	1.69	100.39	76	67
GHATGHAR	0.19	5.57	104	0
Total	2.58	155.34		
Wind				
Total	7.78	570.18	0	0
Total	7.78	570.18		
CPP				
APML(Mus)	63.80	1694.45	0	0
JSWEL(Mus)	19.58	487.42	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.36	457.21	0	0
SWPGPL-Mus	7.41	130.79	0	0
Other(Mus)	5.07	149.03	0	0
Total	121.23	2918.90		
SOLAR				
Total	10.41	239.71	0	0
Total	10.41	239.71		
Tata				
Trombay 5	6.94	201.88	431	257
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.59	12.54	113	39
Trombay 7B	1.14	7.07	66	34
TATA Hydro	4.51	136.63	427	37
Trombay 8	3.51	98.36	223	131
Total	17.68	456.48		
AEMIL				
DTPS U-1&2	8.78	239.92	496	283
Total	8.78	239.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	124.70	3083.28	MSPGCL Total	136.92	3461.52
			MSPGCL Thml+Gas	126.82	3153.05	Koyna 1,2 & 4 Total	5.62	110.44
			MSPGCL Hydro	10.10	308.47	State Total	302.79	7886.72

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/Sep/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5099	153	89	5341	463	4616	0	0	6150	6038	-1040	15058	0	15058	2134	360	17552	50.02
2	4979	155	90	5224	465	4571	0	0	6142	6039	-992	14988	0	14988	1969	319	17276	50.03
3	4915	150	91	5156	422	4531	0	0	6076	6013	-907	14912	0	14912	1853	303	17068	50.01
4	5008	149	90	5247	363	4562	0	0	6044	6174	-872	15202	0	15202	1780	272	17254	49.99
5	5032	145	90	5267	352	4731	0	0	6410	6606	-861	15795	0	15795	1782	300	17877	49.99
6	5439	397	91	5927	332	4807	0	0	6752	6960	-928	16783	0	16783	1902	315	19000	50.02
7	5525	753	90	6368	309	5649	0	47	6810	7189	-1004	18188	0	18188	2097	370	20655	50.01
8	5507	360	91	5958	256	5740	0	323	8062	8317	-1326	18879	0	18879	2313	389	21581	50.07
9	5560	272	90	5922	217	5594	0	799	8033	8024	-1799	18339	0	18339	2663	418	21420	50.04
10	5302	211	88	5601	151	5215	0	1140	8639	8541	-2117	18114	0	18114	2970	417	21501	50.02
11	4841	165	88	5094	117	4634	0	1391	9385	9455	-2307	17980	0	17980	3147	404	21531	50.01
12	4954	147	88	5189	83	4627	0	1472	9162	8753	-2167	17562	0	17562	3176	395	21133	50.01
13	4801	147	91	5039	97	4599	0	1329	8621	8697	-2129	17223	0	17223	3108	409	20740	49.98
14	4757	377	91	5225	133	4473	0	1274	8071	8180	-2125	16750	0	16750	2971	410	20131	49.99
15	5133	152	90	5375	131	4597	0	1137	8275	8325	-2129	17030	0	17030	2976	406	20412	49.98
16	5048	146	89	5283	215	4652	0	843	8675	8610	-2094	17098	0	17098	2994	411	20503	50.02
17	5489	146	104	5739	262	5041	0	507	8252	7822	-1970	16971	0	16971	2988	430	20389	50.00
18	5387	549	83	6019	335	5280	0	148	7450	7243	-1620	16969	0	16969	2958	436	20363	49.96
19	5339	1755	82	7176	496	5795	0	3	6505	6575	-1305	18297	0	18297	2961	443	21701	49.82
20	5389	1859	82	7330	568	5846	0	0	6582	6585	-1253	18649	0	18649	2952	427	22028	49.96
21	5470	829	83	6382	583	5823	0	0	6322	6297	-1135	17530	0	17530	2813	420	20763	50.01
22	5414	379	82	5875	509	5695	0	0	6382	6367	-1112	16923	0	16923	2587	411	19921	50.01
23	5207	367	85	5659	468	5105	0	0	6406	6634	-1115	16367	0	16367	2446	384	19197	49.98
24	5101	334	86	5521	449	5046	0	0	6252	6219	-1126	15732	0	15732	2349	377	18458	49.97
MUs	124.70	10.10	2.12	136.92	7.78	121.23	0.00	10.41	175.46	175.66	-35.43	407.34	0.00	407.34	61.89	9.23	478.45	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Sep/2022

Position as on 6.30 Hrs of 28/Sep/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koyna Unit 4	70	05/08/2022	17:20		Continued.	Generator winding differential protection	29/09/2022
MSPGCL	Chandrapur Unit 8	500	06/09/2022	00:52		Continued.	COH	05/10/2022
MSPGCL	Koradi Unit 6	210	14/09/2022	14:35		Continued.	Tripped on Furnace Pressure High(converted to Overhaul)	03/10/2022
MSPGCL	Paras Unit 4	250	21/09/2022	00:08		Continued.	Annual Overhaul	16/10/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	30/09/2022
MSPGCL	Uran Unit B0	120	27/08/2022	15:26		Continued.	Gas shortage	
IPP	SWPGPL U-3	135	28/08/2022	19:04		Continued.	Boiler SSC chain broken problem.	30/09/2022
MSPGCL	Uran Unit 8	108	01/09/2022	00:00		Continued.	Gas shortage	
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	11/09/2022	21:03	27/09/2022	10:07	Gas shortage	
MSPGCL	Nasik Unit 3	210	17/09/2022	23:59		Continued.	wet coal	
IPP	RPL(AMT) U-2	270	18/09/2022	13:44		Continued.	Bottom Ash Evacuation problem.	29/09/2022
MSPGCL	Bhusawal Unit 3	210	26/09/2022	16:08		Continued.	Boiler Tube Leakage	30/09/2022
MSPGCL	Uran Unit 6	108	27/09/2022	10:32	27/09/2022	16:45	HOT SPOT IN SWITCHYARD	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 5	500	27/09/2022	17:30	28/09/2022	07:56	Air heater problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/09/2022	00:45	27/09/2022	06:49	EO	A] HVDC TL O&M Sub-Division, Babhaleshwar:- 1. Cold line washing of bird shit insulator string at Loc No. 1436 to 1439 = 4 Locs.
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	27/09/2022	00:45	27/09/2022	06:49	HT	EMERGENCY OUTAGE AILED FOR COLD LINE WASHING OF INSULATOR STRINGS.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (413) OF KARJAT CKT - 1 @ LONIKAND 2	IntraState	28/09/2022	09:19			PO	To carry out Diagnostic testing and maintenance work.
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -1	InterState	28/09/2022	11:36			PO	AMP of line terminal equipment at Parli SS. Dia to be kept open for relay testing at Parli SS. A/R of 400kv Parli-Parli M-2 to be in non Auto.
KHADKA-AURANGABAD (WALUJ)	IntraState	26/09/2022	22:39	27/09/2022	07:44	HT	H/T FOR O/V
KARAD - TALANDGE CKT - 1	IntraState	27/09/2022	09:33	27/09/2022	16:45	PO	1. Quarterly Maintenance of bay 2. Annual testing of bay
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	27/09/2022	10:25			HT	for load management
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	28/09/2022	05:44	28/09/2022	06:54	T	TRIPPED ON DISTANCE PROTECTION
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	28/09/2022	06:56	28/09/2022	11:01	HT	H/T DUE TO HEAVY SPARKING OBSERVED AT CHANDRAPUR-2 END
NEW KOYNA-KARAD CKT - 2	IntraState	28/09/2022	09:19			PO	Diagnostic testing & Relay testing work
400 KV ICT Outages/Trippings							
STATION TRANSFORMER - 8A @ CHANDRAPUR SWITCHING SS	IntraState	26/09/2022	11:32				Oil filtration, Oil leakage attending, Electrical Testing and painting of Station Transformer -8A Station Transformer -8A Bus duct servicing, maintenance and below replacement
400/220 KV 500 MVA ICT @ ALKUD	IntraState	27/09/2022	14:12	27/09/2022	19:45	PO	Replacement work of TCIV of all 3 Phases of ICT
400/220/33 KV 500MVA ICT - 2 @ KHAPARKHEDA	IntraState	28/09/2022	11:02			PO	Post Monsoon Maintenance Work
220 KV TBC Outages/Trippings							
TBC @ CHAKAN	IntraState	28/09/2022	11:30			PO	CB AND CT TESTING
220 KV MAINBAY Outages/Trippings							
TBC @ BHOSARI-1	IntraState	26/09/2022	11:05	27/09/2022	19:03	PO	CT erection work at 220kv TBC Bay
TBC @ BHOSARI-1	IntraState	27/09/2022	00:45	27/09/2022	19:03	EO	CT erection work at 220kv TBC Bay
BUS COUPLER @ SOUTH SOLAPUR	IntraState	28/09/2022	11:33			PO	Outage is required for Quarterly Maintenance
220 KV LINE Outages/Trippings							
JEUR - SOLAPUR PG	InterState	28/09/2022	12:17			PO	Outage is required for Quarterly Maintenance
EKLAHARE (OCR) - PADGHE	IntraState	26/09/2022	07:44			HT	for load management on Nashik BBLR
BUS SECTION-6 @ TROMBAY	IntraState	26/09/2022	23:10	27/09/2022	06:30	EO	for connecting Trombay Carnac -7 Main bus isolator jumper after breaker replacement work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	26/09/2022	23:15	27/09/2022	02:32	T	TRIPPED ON DISTANCE PROTECTION.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	27/09/2022	08:21	27/09/2022	21:47	HT	for load management
MAHAPE - TFIPL	IntraState	27/09/2022	09:15	27/09/2022	12:17	EO	Line Breaker B-Phase Pole Nut bolts having hotspot
TPC BORIVALI - AAREY	IntraState	27/09/2022	09:23	27/09/2022	19:04	PO	Under MMRC Line Diversion scheme for Metro-3 project Tighting of jumper connection loose connection observed during routine inspection.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	27/09/2022	10:45	27/09/2022	16:29	HT	for load management
THEUR-JEJURI	IntraState	27/09/2022	11:06	27/09/2022	17:25	PO	LA'S JUMP CRIMPING WORK AT JEJURI END
MAIN BUS - 1 @ AAREY	IntraState	27/09/2022	12:16	27/09/2022	17:57	EO	During outage of 220 kV Aarey & TPC Borivali Line, it is observed that 1089-A Isolator is not getting opened With thorough investigation, it is observed that the pin of isolator is broken and unable to open. Outage required to rectify the same.
AAREY - AEML BORIVALI	IntraState	28/09/2022	09:26			PO	Under MMRC Line Diversion scheme for Metro-3 project Tightening of loose jumper connection observed during routine inspection.
CHINCHWAD- PARVATI	IntraState	28/09/2022	11:01			PO	R' phase Flashover insulator string replacement work at location no-30
BOMBAY DYEING - SAHARA	IntraState	28/09/2022	12:30			PO	Removing of rusted earthwire from Loc No. 141 to 149.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/110 kV 200 MVA ICT 2 @ MUDSHINGI	IntraState	27/09/2022	09:45	27/09/2022	17:55	PO	HV breaker overhauling in presence of M/S Siemens Engineer & Quarterly Maintenance work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	27/09/2022	11:27	27/09/2022	19:57	PO	Relay Testing work. Routine maintenance work.
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	27/09/2022	11:57	27/09/2022	12:50	PO	for CB Timing measurment
220/33 KV 50MVA PTR 2 @ JEJURI	IntraState	27/09/2022	12:46	28/09/2022	00:12	PO	HV SIDE BUS ISOLATOR REPLACEMENT WORK.
220/132KV 100MVA ICT 2 @ CHAKAN PHASE II	IntraState	27/09/2022	13:08	27/09/2022	13:59	PO	for CB Timing measurment
220/22KV 50MVA PTR 1 @ CHAKAN PHASE II	IntraState	27/09/2022	14:13	27/09/2022	14:59	PO	for CB Timing measurment
220/22KV 50MVA PTR 2 @ CHAKAN PHASE II	IntraState	27/09/2022	15:08	27/09/2022	15:52	PO	for CB Timing measurment
220/100 KV 100 MVA ICT 1 @ TAMBATI	IntraState	28/09/2022	09:51			PO	attending Red hot spot and faulty Jumper replacement work
220/110 kV 200 MVA ICT 3 @ MUDSHINGI	IntraState	28/09/2022	10:17			PO	HV breaker overhauling in presence of M/S Siemens Engineer & Quarterly Maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Sep/2022

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	28/09/2022	10:48			PO	CTR fire fighting system overhauling
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	28/09/2022	11:25			PO	Relay Testing work. Routine maintenance work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	28/09/2022	10:06			PO	Tree trimming work
KALWA KALYAN	IntraState	28/09/2022	10:27			PO	REPLACEMENT OF O/H VERTICAL JUMPER AT KALYAN END

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage