

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Sep/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	128.136	3436.890	1) Gujrat	12.069	188.064
2) Hydro	11.384	330.641	2) Madhya Pradesh	3.884	121.637
3) Gas	6.784	148.407	3) Chattisgarh	2.700	96.310
Total MSPGCL	146.304	3915.938	4) Maharashtra	165.580	4937.406
B) 1) APLM	56.797	1626.551	5) Goa (Amona)	-1.451	-45.013
2) JSWEL	24.840	688.748	Total	182.782	5298.404
3) VIPL	0.000	0.000	a) Mumbai Schedule	36.482	930.822
4) RPL(AMT)	25.144	662.122	b) Mumbai Drawl	40.699	1035.669
5) SWPGPL	11.507	316.481	c) MSEDCL Bilateral *	66.518	2573.907
6) Other IPP	5.603	167.339	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	36.482	930.758
C) 1) TPCL Thermal	12.098	323.846	Include PX	0.000	0.000
2) TPCL Hydro	4.963	101.001	Standby	0.000	0.064
3) TPCL Gas	2.121	57.689	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.445	251.471	1) MSEDCL	417.789	12472.055
D) STATE			2) Mumbai Discoms	67.326	1769.677
1) Thermal	271.570	7473.448	3) Other Discoms	10.255	275.867
(A1+C1+C4+(B1-B6))			TOTAL STATE	495.370	14517.599
2) Hydro (A2+C2)	16.347	431.642			
3) Gas (A3+B7+C3)	8.905	206.096			
4) Wind	3.052	801.508			
6) SOLAR	12.714	306.500			
TOTAL STATE	312.588	9219.194			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 9 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5614	4750	5534	5573
MSPGCL Hydro	312	607	1543	209
MSPGCL Gas	283	275	282	285
MSPGCL Total Generation	6209	5632	7359	6067
Central Sector Receipt	9280	8454	7596	6312
WIND	121	98	97	176
CPP / IPP Thermal	4971	4362	5978	4793
CPP / IPP Gas	0	0	0	0
SOLAR	802	1469	6	0
Exchange with Mumbai	-1933	-2207	-1607	-1230
MSEDCL DEMAND MET	19004	17342	18966	15764
Load Shedding	0	0	0	0
MSEDCL DEMAND	19004	17342	18966	15764
TPCL GENERATION	591	716	1183	622
AEML GENERATION	304	315	317	300
MUMBAI DEMAND	2828	3238	3107	2152
OTHER DISCOM DEMAND	446	467	463	354
STATE DEMAND MET	22278	21046	22536	18270
STATE DEMAND	22278	21046	22536	18270
Frequency (Hz)	49.99	49.85	49.95	49.94

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 16.03 Hrs	49.73 Hz at 14.56 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Sep/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.56	88.57	170	110
Unit 8	14.13	353.72	650	375
Unit 9	0.00	221.66	0	0
Unit 10	13.53	62.33	634	375
Total	31.23	726.28		
Bhusawal				
Unit 3	2.23	69.64	110	60
Unit 4	8.61	223.30	450	230
Unit 5	8.15	232.32	445	280
Total	18.99	525.27		
Parli				
Unit 6	4.02	119.60	223	148
Unit 7	4.15	108.69	227	140
Unit 8	3.76	106.32	191	145
Total	11.93	334.61		
Chandrapur				
Unit 3	3.09	82.30	142	110
Unit 4	3.46	32.01	155	128
Unit 5	0.00	0.00	0	0
Unit 6	5.20	157.41	260	134
Unit 7	3.38	128.50	247	0
Unit 8	8.64	248.50	410	280
Unit 9	8.94	224.09	444	309
Total	32.71	872.80		
Paras				
Unit 3	4.32	119.82	197	155
Unit 4	4.20	123.10	210	145
Total	8.51	242.92		
Khaparkheda				
Unit 1	2.60	71.22	130	90
Unit 2	1.51	43.76	91	33
Unit 3	3.46	91.57	165	128
Unit 4	3.26	83.14	151	123
Unit 5	9.75	224.76	450	300
Total	20.58	514.46		
Nasik				
Unit 3	0.89	72.76	127	0
Unit 4	0.00	74.64	0	0
Unit 5	3.29	73.15	160	119
Total	4.19	220.55		
Uran				
All Units	6.78	148.41	289	266
Total	6.78	148.41		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.11	23.77	47	46
Total	1.11	23.77		
Koyna				
Stage 1-2	2.10	66.20	325	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	2.00	85.58	808	0
Stage 3	1.17	36.74	240	0
Total	5.27	188.53		
Hydro				
KDPH	0.00	7.03	0	0
VTRNA	0.91	5.40	60	0
TILLARI	0.00	1.19	0	0
BHIRA T.R.	0.41	9.81	80	0
SMLHY_PTN	3.02	88.43	130	121
GHATGHAR	0.67	6.49	125	0
Total	5.01	118.34		
Wind				
Total	3.05	801.51	0	0
Total	3.05	801.51		
CPP				
APML(Mus)	56.80	1626.55	0	0
JSWEL(Mus)	24.84	688.75	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.14	662.12	0	0
SWPGPL-Mus	11.51	316.48	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.26	148.77	252	181
Other(Mus)	0.34	13.05	0	0
JPL	0.00	5.52	0	0
Total	123.89	3461.24		
SOLAR				
Total	12.71	306.50	0	0
Total	12.71	306.50		
Tata				
Trombay 5	7.68	212.55	450	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.16	32.05	91	38
Trombay 7B	0.96	25.64	58	35
TATA Hydro	4.96	101.00	409	58
Trombay 8	4.42	111.30	223	134
Total	19.18	482.54		
AEML				
DTPS U-1&2	7.44	251.47	317	289
Total	7.44	251.47		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	128.14	3436.89	MSPGCL Total	146.30	3915.94
			MSPGCL Thml+Gas	134.92	3585.30	Koyna 1,2 & 4 Total	4.10	151.79
			MSPGCL Hydro	11.38	330.64	State Total	312.59	9219.19

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Sep/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5440	213	285	5938	332	5162	0	0	6641	6081	-1289	15826	0	0	15826	2469	398	18693	50.01
2	5460	209	286	5955	242	4871	0	0	6498	6317	-1271	15735	0	0	15735	2287	379	18401	50.01
3	5573	209	285	6067	176	4793	0	0	6481	6312	-1230	15764	0	0	15764	2152	354	18270	49.94
4	5543	213	286	6042	132	5069	0	0	6360	6151	-1129	15927	0	0	15927	2065	338	18330	50.00
5	5525	213	286	6024	179	5003	0	0	6865	6788	-1155	16483	0	0	16483	2063	356	18902	49.97
6	5564	210	289	6063	169	5302	0	0	7461	7383	-1192	17363	0	0	17363	2160	363	19885	49.93
7	5621	231	283	6135	176	5747	0	52	7970	8070	-1282	18504	0	0	18504	2338	394	21236	49.90
8	5658	288	284	6230	157	5518	0	394	8746	8633	-1515	18984	0	0	18984	2538	433	21955	50.02
9	5614	312	283	6209	121	4971	0	802	9255	9280	-1933	19004	0	0	19004	2828	446	22278	49.99
10	5565	340	284	6189	96	4651	0	1298	9335	9078	-2288	18574	0	0	18574	3124	450	22148	49.94
11	4950	395	282	5627	86	4271	0	1677	9362	9285	-2357	18120	0	0	18120	3356	468	21945	50.00
12	4622	398	283	5303	78	4281	0	1745	9068	9071	-2389	17628	0	0	17628	3426	460	21515	49.96
13	4585	383	277	5245	83	4456	0	1665	8668	8316	-2211	17102	0	0	17102	3377	452	20931	49.91
14	4510	365	276	5151	71	4137	0	1707	8252	8062	-2076	16599	0	0	16599	3223	454	20275	49.97
15	4750	607	275	5632	98	4362	0	1469	8337	8454	-2207	17342	0	0	17342	3238	467	21046	49.85
16	5157	364	281	5802	48	4571	0	1121	8418	8530	-2339	17275	0	0	17275	3270	458	21003	49.95
17	5453	302	281	6036	73	5001	0	589	8011	7857	-2100	17006	0	0	17006	3191	450	20647	50.01
18	5447	552	282	6281	58	5658	0	189	7911	7529	-1878	17404	0	0	17404	3097	432	20934	50.02
19	5534	1543	282	7359	97	5978	0	6	7601	7596	-1607	18966	0	0	18966	3107	463	22536	49.95
20	5560	1447	286	7293	109	6074	0	0	7618	7535	-1502	19052	0	0	19052	3022	457	22531	50.02
21	5595	798	289	6682	106	6073	0	0	7030	7141	-1438	18113	0	0	18113	2914	451	21478	50.03
22	5512	632	286	6430	111	6049	0	0	6804	6757	-1475	17420	0	0	17420	2817	452	20689	50.04
23	5559	849	287	6695	123	6064	0	0	6522	6065	-1413	17077	0	0	17077	2696	457	20230	50.02
24	5339	311	266	5916	131	5830	0	0	6682	6491	-1423	16522	0	0	16522	2568	423	19513	49.95
MUs	128.14	11.38	6.78	146.30	3.05	123.89	0.00	12.71	185.90	182.78	-40.70	417.79	0.00	0.00	417.79	67.33	10.26	495.37	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Sep/2023

Position as on 6.30 Hrs of 28/Sep/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	03/10/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Uran Unit 6	108	02/09/2023	07:16		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	21/09/2023	06:43	27/09/2023	08:00	Boiler Tube Leakage	27/09/2023
IPP	JPL Unit 1	150	21/09/2023	23:11		Continued.	Steam leakage from Turbine	
MSPGCL	Koradi Unit 9	660	22/09/2023	11:39		Continued.	Boiler Tube Leakage and Unit-9 Economizer BTL outage converted to Planned outage for 10 days in view of loadability& reliability improvement.	02/10/2023
MSPGCL	Nasik Unit 4	210	25/09/2023	20:27		Continued.	Poor Coal Stock and ID fan 4B break down.	02/10/2023
MSPGCL	Nasik Unit 3	210	25/09/2023	23:35	27/09/2023	11:17	Emergency Stop Valve leakage	27/09/2023
MSPGCL	Nasik Unit 3	210	27/09/2023	12:27	27/09/2023	16:27	High Pressure Heater (HPH)level High.	
MSPGCL	Uran Unit 8	108	27/09/2023	23:56		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 27/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
400 KV EKTUNI - BABHLESHWAR CKT- 1	IntraState	27/09/2023	10:03	27/09/2023	12:31	EO	To attend Hot spot on 411-89L Y-phase Line-Isolator (Female-arm) near the stud where the IPS is connecting with the wave-trap (Temp-175 degree C).
500 KV LR Outages/Tripping							
POLE-2 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	27/09/2023	00:15	27/09/2023	02:36	EO	Attending Hotspot in Pole-2 Base Filter
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ PADGHE HVDC	IntraState	27/09/2023	03:08	27/09/2023	05:05	EO	For attending Red Hotspots at Z11-Z12 Respective images are also attached.
400 KV TIEBAY Outages/Tripping							
TIE BAY (408) OF RPL CKT-1 AND AKOLA-1 CKT-1 @ AKOLA 2	IntraState	28/09/2023	11:10	28/09/2023	18:42	PO	Annual Maintenance of CB & CT.
400 KV LINE Outages/Tripping							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
CHANDRAPUR - BHADRAVATI CKT - 1	InterState	28/09/2023	10:55	28/09/2023	23:56	T	Tripped on Distance Protection.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of 4Y4 phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	15/09/2023	07:55	27/09/2023	16:03	HT	HT for Load Management
PADGHE - PADGHE HVDC CKT- 2	IntraState	22/09/2023	12:58			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400kV HVDC-1 in service through TBC, Power restriction of 1300MW.
KOLHAPUR (TALANDGE) - ALKUD	IntraState	26/09/2023	18:18	27/09/2023	08:59	T	Tripped on distance protection.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
220 KV JALNA - TAPTITANDA (400 KV) CKT - 2	IntraState	27/09/2023	16:28	27/09/2023	16:38	T	Distance Protection.
BUS COUPLER @ LONIKAND-1	IntraState	27/09/2023	21:16	27/09/2023	23:13	EO	Outage required for attending hotspot on 29B-Y ph PG isolator on 400 kV Bus Coupler At Lonikand-1 S/S
PARLI - KARJAT CKT - 2	IntraState	28/09/2023	12:17	28/09/2023	17:44	T	Tripped on Distance Protection.
KHADKA-AURANGABAD (WALUJ)	IntraState	28/09/2023	18:05		Continued.	HT	H/T For Voltage Management.
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 500 MVA ICT - 3 @ DHULE	IntraState	25/09/2023	10:37	27/09/2023	16:00	PO	Overhauling of own bay CB by OEM ICT-3 HV will shift on 400kV TBC
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	28/09/2023	10:53	28/09/2023	11:10	PO	Shifting of ICT 1 from Bus-1 to Bus-2 for load balancing In view of shifting of ICT-3 on Bus-1 for Hot line work on Bus-2 for jumper removal work ON 29/09/23 for ONGOING OUTAGE ON PARLY - PARLY PG CKT1

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 500 MVA ICT - 3 @ PARLI	IntraState	28/09/2023	11:16	28/09/2023	11:26	PO	Shifting of ICT 3 from Bus-2 to Bus-1 for load balancing In view of shifting of ICT-3 on Bus-1 for Hot line work on Bus-2 for jumper removal work ON 29/09/23 for ONGOING OUTAGE ON PARLY - PARLY PG CKT1
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	28/09/2023	11:37	28/09/2023	12:43	PO	Shifting of ICT 2 from Bus-1 to Bus-2 for load balancing. In view of shifting of ICT-3 on Bus-1 for Hot line work on Bus-2 for jumper removal work ON 29/09/23 for ONGOING OUTAGE ON PARLY - PARLY PG CKT1
400 KV BR Outages/Trippings							
125 MVAR BUS REACTOR @ 400KV KHAPARKHEDA S/S	InterState	27/09/2023	09:20	27/09/2023	17:25	PO	Post Monsoon Maintenance Work
220 KV LINE Outages/Trippings							
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
EKLAHARE (OCR) - PADGHE	IntraState	16/09/2023	18:27			HT	H/T For load management.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/09/2023	19:37		Continued.	HT	Hand tripped from Navsari end for load management
AAREY - MSETCL BORIVALI CKT - 1	IntraState	25/09/2023	09:06			T	Tripped on distance protection.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	26/09/2023	08:43	27/09/2023	18:20	HT	H/T For load management.
ONGC URAN - JNPT	IntraState	26/09/2023	16:42	27/09/2023	17:05	EO	Attending Y Phase CT Oil Leakage.
PEDAMBE-KALAMBANI(TSS)	IntraState	26/09/2023	17:16	27/09/2023	13:40	T	Tripped on distance protection.
MAHINDRA VEHICLE-BRIDGESTONE	IntraState	26/09/2023	20:25	27/09/2023	05:24	T	Tripped on distance protection.
VITTAL SUGAR CO GEN (VSSK) - KARKAMBH	IntraState	26/09/2023	23:52	27/09/2023	17:20	T	Tripped on distance protection Y phase
TEMBHURNI - JEUR	IntraState	26/09/2023	23:52	27/09/2023	00:38	T	Tripped at Temburni end only
LAMBOTI - KARKAMB	IntraState	26/09/2023	23:52	27/09/2023	00:29	T	Tripped on distance protection
GHATGHAR - JINDAL	IntraState	27/09/2023	05:22	27/09/2023	06:27	T	Tripped at Ghatghar end only
BAPGAON - KALWA	IntraState	27/09/2023	05:36	27/09/2023	08:29	EO	Hot spot attending, R ph wave trap bottom pad, Tem-190 deg
CHINCHWAD- PARVATI	IntraState	27/09/2023	08:40	27/09/2023	16:44	PO	Conductor paying out and final Sag Loc 17 to 17A ckt 1 including OPGW
FLAGSHIP-CHINCHWAD	IntraState	27/09/2023	08:40	27/09/2023	16:44	PO	Conductor paying out and final Sag Loc 17 to 17A ckt 1 including OPGW
ACCIL - APTA	IntraState	27/09/2023	09:37	27/09/2023	19:46	PO	Twin jumpering work at cut point locations & replacement of damaged jumper at Loc no. 583A in HIL premises
OSMANABAD - BARSHI	IntraState	27/09/2023	09:45	27/09/2023	16:52	PO	Outage is required for Quarterly bay maintenance work
KARAD - VITA CKT- 1	IntraState	27/09/2023	10:29	27/09/2023	16:04	PO	1.Cold Washing Work 2.Jump Connecting Work at Loc No.50
220KV CHITEGAON -SAWANGI CKT	IntraState	27/09/2023	13:09	27/09/2023	15:27	PO	Routine Maintenance Work.
KALWA - PANCHANAND	IntraState	27/09/2023	14:57	27/09/2023	18:23	T	Tripped on Distance Protection

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 28/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
GHATGHAR - BAPGAON	IntraState	27/09/2023	15:05	27/09/2023	18:02	PO	For attending hot spot at Loc no. 314, 315 and jumper nut bolt tightening work.
VILE BHAGAD - KANDHALGAON	IntraState	27/09/2023	15:33	27/09/2023	17:34	T	Tripped on Distance Protection
KANDALGAON - ONGC PANVEL	IntraState	27/09/2023	15:33	27/09/2023	17:30	T	Tripped on Distance Protection
220 KV CHALISGAON - DHULE CKT	IntraState	27/09/2023	16:24	27/09/2023	18:14	EO	For disc string replacement at tower loc no. 26 R-Ph.
KHARGHAR - BORIVALI CKT - 2	IntraState	27/09/2023	22:42	28/09/2023	06:03	PO	Replacement of old Hardware at Loc no. 48 & 49 (Critical Crossing)
KALWA - SIEMENS	IntraState	27/09/2023	22:56	28/09/2023	04:39	PO	For replacement of hardware at Loc no. 48 & 49 (Critical location)
NERLE - PEDAMBE	IntraState	27/09/2023	23:10	27/09/2023	23:40	T	Bus Section 2 tripped on LBB Protection
ADLABS - PEDAMBE	IntraState	27/09/2023	23:10	27/09/2023	23:45	T	Bus Section 2 tripped on LBB Protection
PEDHAMBE ONI LINE	IntraState	27/09/2023	23:10	28/09/2023	00:25	T	Bus Section 2 tripped on LBB Protection
POPHLI PEDHMBE LINE- 2	IntraState	27/09/2023	23:10	27/09/2023	23:38	T	Bus Section 2 tripped on LBB Protection
BUTIBORI-BUTIBORI 3	IntraState	28/09/2023	09:37	28/09/2023	14:49	PO	For replacement of R Y&B Ph damaged jumper from line isolator to circuit braker and line side ct jumaper of R,Y & B Ph.
BABLESHWAR- ALEPHATA CKT - 1	IntraState	28/09/2023	09:52	28/09/2023	16:32	PO	For attending the damage conductor at various cut point locations found in monkey patrolling of the line. Loc no 172 and loc no 124.
CHAKAN -BRIDGESTONE	IntraState	28/09/2023	13:51	28/09/2023	15:54	T	Tripped on Distance Protection.
APTA - BOMBAY DYEING	IntraState	28/09/2023	13:53	28/09/2023	15:19	T	Tripped on Distance Protection.
URAN - APTA 2	IntraState	28/09/2023	13:58	28/09/2023	15:00	T	Tripped on Distance Protection.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/33 KV 50 MVA PTR 1 @ BOISAR-II	IntraState	13/09/2023	21:38		Continued.	HT	Problem arise during tap changing operation ,Tap was not getting changed ,When tried manually it was found jammed. Hence HT from HV & LV Both .
220/100 KV 200 MVA ICT 1 @ PAL-DOMBIVALI	IntraState	27/09/2023	10:10	27/09/2023	13:22	PO	To attend Hot Spot at R&B phase at Dead end conductor from HV Bushing.
220/132-110 KV 100 MVA ICT 2	IntraState	27/09/2023	11:05	27/09/2023	15:54	PO	Oil Leakage attending Work by Power Seal gasketing technology.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
AUXILIARY BUS @ PADGHE	IntraState	14/09/2023	10:32			PO	For making twin bus conductor arrangements of 220kV Aux. Bus in upper section .
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	22/09/2023	07:10			HT	H/T FOR LOAD MANAGEMENT
MANSAR-PENCH	InterState	27/09/2023	09:07	27/09/2023	16:19	PO	Routine Maintenance work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage