

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Oct/2024 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	135.777	3930.080	1) Gujrat	2.120	193.763
2) Hydro	5.285	225.479	2) Madhya Pradesh	3.696	99.550
3) Gas	6.865	177.438	3) Chattisgarh	5.460	105.510
Total MSPGCL	147.927	4332.997	4) Maharashtra	204.327	5378.260
B) 1) APMIL	54.324	1532.162	5) Goa (Amona)	-2.889	-62.365
2) JSWEL	24.604	669.344	Total	212.714	5714.718
3) VIPL	0.000	0.000	a) Mumbai Schedule	43.502	1322.752
4) RPL(AMT)	25.031	518.391	b) Mumbai Drawl	46.030	1400.044
5) SWPGPL	8.989	241.690	c) MSEDCL Bilateral *	103.148	2441.209
6) Other IPP	9.064	281.384	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	43.502	1318.418
C) 1) TPCL Thermal	3.701	118.112	Include PX	0.000	0.000
2) TPCL Hydro	2.922	103.407	Standby	0.000	4.334
3) TPCL Gas	4.218	113.189	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.648	229.607	1) MSEDCL	454.148	12274.836
D) STATE			2) Mumbai Discoms	64.519	1964.347
1) Thermal	269.138	7520.770	3) Other Discoms	11.743	329.452
(A1+C1+C4+(B1-B6))			TOTAL STATE	530.410	14568.635
2) Hydro (A2+C2)	8.207	328.886			
3) Gas (A3+B7+C3)	11.083	290.627			
4) Wind	7.773	215.134			
6) SOLAR	21.495	498.512			
TOTAL STATE	317.696	8853.929			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5177	5620	6037	5860
MSPGCL Hydro	216	233	208	175
MSPGCL Gas	288	271	280	294
MSPGCL Total Generation	5681	6124	6525	6329
Central Sector Receipt	8877	9381	10274	7824
WIND	263	297	407	271
CPP / IPP Thermal	4515	4838	5820	4948
CPP / IPP Gas	0	0	0	0
SOLAR	2867	1599	4	0
Exchange with Mumbai	-1984	-2138	-1993	-1644
MSEDCL DEMAND MET	19705	19598	20500	17332
Load Shedding	0	0	0	0
MSEDCL DEMAND	19705	19598	20500	17332
TPCL GENERATION	431	460	518	406
AEML GENERATION	312	302	352	304
MUMBAI DEMAND	2727	2900	2863	2354
OTHER DISCOM DEMAND	514	503	537	396
STATE DEMAND MET	22946	23001	23900	20082
STATE DEMAND	22946	23001	23900	20082
Frequency (Hz)	49.99	49.99	49.97	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 06:01 Hrs	49.79 Hz at 16:51 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Oct/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.86	90.02	178	124
Unit 8	0.00	273.06	0	0
Unit 9	11.73	315.52	553	375
Unit 10	11.86	312.17	590	375
Total	27.45	990.76		
Bhusawal				
Unit 3	0.00	67.40	0	0
Unit 4	8.76	206.41	485	285
Unit 5	8.43	227.52	465	285
Total	17.18	501.33		
Parli				
Unit 6	3.70	102.74	215	143
Unit 7	0.00	85.92	0	0
Unit 8	3.68	103.00	175	144
Total	7.38	291.67		
Chandrapur				
Unit 3	3.56	83.78	167	125
Unit 4	3.46	84.79	159	132
Unit 5	7.92	205.78	370	280
Unit 6	7.18	125.59	410	235
Unit 7	7.99	204.31	394	281
Unit 8	9.32	257.68	475	287
Unit 9	0.00	92.36	0	0
Total	39.43	1054.29		
Paras				
Unit 3	4.44	121.16	213	144
Unit 4	4.55	113.87	217	148
Total	8.99	235.03		
Khaparkheda				
Unit 1	4.16	83.06	190	115
Unit 2	4.07	105.70	187	119
Unit 3	3.89	96.22	171	131
Unit 4	4.26	109.43	188	133
Unit 5	11.18	262.43	495	325
Total	27.56	656.83		
Nasik				
Unit 3	3.48	88.41	165	126
Unit 4	3.54	86.58	171	123
Unit 5	0.76	25.18	120	0
Total	7.78	200.17		
Uran				
All Units	6.86	177.44	295	271
Total	6.86	177.44		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	20.08	0	0
Total	0.00	20.08		
Koyna				
Stage 1-2	1.47	49.95	200	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	31.19	0	0
Stage 3	0.42	19.02	160	0
Total	1.89	100.17		
Hydro				
KDPH	0.00	9.31	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	6.95	0	0
BHIRA T.R.	0.34	7.70	40	0
SMLHY_PTN	3.05	93.17	131	105
GHATGHAR	0.00	8.18	0	0
Total	3.39	125.31		
Wind				
Total	7.77	215.13	0	0
Total	7.77	215.13		
CPP				
APML(Mus)	54.32	1532.16	0	0
JSWEL(Mus)	24.60	669.34	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.03	518.39	0	0
SWPGPL-Mus	8.99	241.69	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.33	151.90	259	184
Other(Mus)	0.53	12.10	0	0
JPL	3.20	117.38	136	102
Total	122.01	3242.97		
SOLAR				
Total	21.50	498.51	0	0
Total	21.50	498.51		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.67	71.63	112	111
Trombay 7B	1.55	41.56	65	64
TATA Hydro	2.92	103.41	202	57
Trombay 8	3.70	118.11	169	132
Total	10.84	334.71		
AEML				
DTPS U-1&2	7.65	229.61	455	298
Total	7.65	229.61		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	135.78	3930.08	MSPGCL Total	147.93	4333.00
			MSPGCL Thml+Gas	142.64	4107.52	Koyna 1,2 & 4 Total	1.47	81.14
			MSPGCL Hydro	5.28	225.48	State Total	317.70	8853.93

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 27/Oct/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6018	168	292	6478	195	5332	0	0	8513	8302	-2015	17820	0	0	17820	2842	472	21134	49.95
2	5802	165	294	6261	275	5071	0	0	8371	8185	-1875	17481	0	0	17481	2653	436	20570	50.01
3	5813	180	293	6286	321	4930	0	0	8162	8023	-1752	17400	0	0	17400	2478	408	20286	49.99
4	5860	175	294	6329	271	4948	0	0	8096	7824	-1644	17332	0	0	17332	2354	396	20082	49.98
5	5874	175	294	6343	284	5052	0	0	8217	8267	-1590	17933	0	0	17933	2303	423	20659	49.97
6	6018	175	294	6487	286	5335	0	0	9126	8808	-1616	18846	0	0	18846	2306	454	21606	50.01
7	5793	365	295	6453	415	5077	0	73	9786	9557	-1609	19477	0	0	19477	2296	489	22262	50.01
8	6075	371	295	6741	545	5212	0	665	8896	8513	-1595	19586	0	0	19586	2308	495	22389	49.94
9	5351	376	290	6017	418	4767	0	1601	8419	8577	-1703	19163	0	0	19163	2421	514	22098	49.97
10	5352	226	290	5868	251	4590	0	2323	8225	8502	-1899	19123	0	0	19123	2573	512	22208	50.04
11	5177	216	288	5681	263	4515	0	2867	8565	8877	-1984	19705	0	0	19705	2727	514	22946	49.99
12	4682	178	282	5142	249	4289	0	3134	8947	9101	-2069	19332	0	0	19332	2818	514	22664	49.99
13	4586	239	278	5103	312	4332	0	3124	8882	8954	-2106	19225	0	0	19225	2856	494	22575	50.00
14	4600	168	280	5048	339	4310	0	2803	8975	8891	-2109	18786	0	0	18786	2837	496	22119	50.01
15	4952	223	276	5451	343	4551	0	2406	9044	9103	-2109	19270	0	0	19270	2864	475	22609	49.98
16	5620	233	271	6124	297	4838	0	1599	9272	9381	-2138	19598	0	0	19598	2900	503	23001	49.99
17	5991	208	274	6473	303	5219	0	766	9363	9119	-2047	19293	0	0	19293	2825	540	22658	49.92
18	6101	203	278	6582	318	5902	0	130	9464	8973	-1798	19575	0	0	19575	2766	532	22873	49.97
19	6037	208	280	6525	407	5820	0	4	10657	10274	-1993	20500	0	0	20500	2863	537	23900	49.97
20	6010	255	282	6547	409	5670	0	0	10251	10410	-2076	20419	0	0	20419	2908	541	23868	50.01
21	6149	299	283	6731	368	5787	0	0	9060	9218	-2065	19517	0	0	19517	2889	522	22928	49.98
22	6130	171	284	6585	309	5717	0	0	8708	8649	-2050	18706	0	0	18706	2892	504	22102	49.98
23	6093	148	288	6529	278	5514	0	0	8698	8533	-2074	18289	0	0	18289	2906	491	21686	49.99
24	5693	160	290	6143	317	5234	0	0	8817	8673	-2114	17770	0	0	17770	2934	483	21187	49.98
MUs	135.78	5.28	6.86	147.93	7.77	122.01	0.00	21.50	214.51	212.71	-46.03	454.15	0.00	0.00	454.15	64.52	11.74	530.41	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

Maximum Demand scenario for the date 27/Oct/2024		
State Demand	MSEDC L Non-Coincident Peak Demand	Mumbai Non-Coincident Peak Demand
23900 MW	20500 MW	2934 MW
19 Hrs	19 Hrs	24 Hrs
Includes LS - 0 MW	Includes LS - 0 MW	--

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Oct/2024

Position as on 6.30 Hrs of 28/Oct/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP								
IPP	SWPGPL U-3	135	09/10/2024	01:00		Continued.	Annual Overhaul	29/10/2024
Total Capacity IPP		135						
Total Capacity PLANNED OUTAGE		135						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/10/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/11/2024
MSPGCL	Koradi Unit 8	660	24/10/2024	01:30	28/10/2024	15:14	Boiler Tube Leakage	28/10/2024
MSPGCL	Nasik Unit 5	210	25/10/2024	22:26	27/10/2024	11:55	ID Fan 5A Problem	27/10/2024
MSPGCL	Chandrapur Unit 9	500	26/10/2024	16:00	28/10/2024	23:56	Suspected BTL	28/10/2024
MSPGCL	Nasik Unit 5	210	27/10/2024	21:05		Continued.	ID Fan 5A problem	30/10/2024
Total Capacity MSPGCL		1825						
TPC-G								
TPC-G	Trombay 5	500	22/09/2024	16:14		Continued.	Emergency withdrwan due to fire in cable vault.	
Total Capacity TPC-G		500						
IPP								
IPP	RPL(AMT) U-3	270	23/07/2024	00:47		Continued.	Turbine Vibration High	31/10/2024
IPP	JPL Unit 1	150	20/10/2024	15:11		Continued.	Turbine bearing Vabration high	03/11/2024
IPP	SWPGPL U-1	135	28/10/2024	16:03		Continued.	Due to SSC CHAIN PROBLEM. (Bottom Ash evacuation Problem)	
Total Capacity IPP		555						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3200						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	24/10/2024	20:00	28/10/2024	17:25	No Schedule ..It is taken on Bar as per requirement	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Oct/2024

Position as on 6.30 Hrs of 28/Oct/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	24/10/2024	20:14	28/10/2024	17:39	No schedule .. It is taken on Bar as per requirement.	
MSPGCL	Parli Unit 7	250	26/10/2024	02:36		Continued.	Zero Schedule.	
MSPGCL	Uran Unit 5	108	28/10/2024	20:45		Continued.	No schedule from MSEDCL.	
MSPGCL	Uran Unit 6	108	28/10/2024	20:57		Continued.	No schedule from MSEDCL.	
Total Capacity MSPGCL		682						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		682						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Bhusawal Unit 3	210	25/10/2024	17:00		Continued.	withdrawn under Tolling.	
Total Capacity MSPGCL		210						
Total Capacity UNIT OUT ON TOLLING *		210						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Oct/2024

Statement-VII

Position as on 6.30 Hrs of 28/Oct/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT @ AKOLA 2	IntraState	27/10/2024	10:28	27/10/2024	20:44	PO	Annual Maintenance of ICT at Akola-II SS.
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 412 OF WARDHA PGCIL @ KORADI 2	IntraState	16/10/2024	10:19			PO	Overhauling of CB by Agency
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	04/10/2024	08:31			HT	H/T for load management.
PADGHE - KALWA CKT - 2	IntraState	23/10/2024	03:47			PO	During this outage, Kalwa Padghe Ckt -2 for the work of erection of 1 Nos of QD+9 towers and stringing on newly erected towers in Loc. No 1096 for the work of shifting/height rising of various EHV (400/220kV) Transmission lines infringing in Mumbai-Ahmedabad High Speed Rail Corporation Ltd. (NHSRCL) corridor under ORC
LONIKAND 2 - KARJAT CKT - 2	IntraState	26/10/2024	22:24	27/10/2024	06:29	PO	Insulator string replacement by long rod porcelain insulators
KHADKA-AURANGABAD (WALUJ)	IntraState	27/10/2024	01:16			HT	Overvoltage Control
JEJURI- KOYNA STAGE-IV	IntraState	27/10/2024	08:15	27/10/2024	19:45		scheme PID Faulty insulator string replacement work
KHADKA-AURANGABAD (WALUJ)	IntraState	28/10/2024	10:34	28/10/2024	18:15	PO	1) LA monitoring device installation and integration work by agency. 2) PG Isolator servicing work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400 KV BR Outages/Trippings							
BUS REACTOR (80 MVAR) - 1 @ BABHALESHWAR	IntraState	07/10/2024	09:40			PO	The work of Dismantling of existing 80 MVAR replacement by 125 MVAR bus reactor along with allied requirement at 400KV Bableshwar has been entrusted to M/s RK Electrical vide Zone office order no. 1258 dtd 12.08.2022. Following work are proposed on reactor 1 1) Dismantling of reactor 1 2) Erection of new 125 MVAR reactor 3) Commissioning work 4) Replacement work as per the work order
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Oct/2024

Statement-VII

Position as on 6.30 Hrs of 28/Oct/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
WAGHIVALI (MSETCL) - ULWE GIS CKT - 2	IntraState	25/06/2024	08:05			T	Tripped on differential protection.
GHODBUNDER - GORAI	IntraState	29/07/2024	12:14			PO	Bunching activity on line to form newly reconfigured line as 220kV Ghodbunder-Versova Line-2 for outage of 220kV Gorai EHV Station.
220kV Koradi-2 - Uppalwadi ckt 2	IntraState	28/08/2024	00:14			T	Distance Protection
EKLAHARE (OCR) - PADGHE	IntraState	24/09/2024	07:48			HT	For load mgmt
220KV KORADI II (400KV)- BUTIBORI 3 CKT I	IntraState	01/10/2024	13:10			HT	H/T From Butibori 3 end
220KV KORADI II(400KV) - BUTIBORI 3 CKT II	IntraState	01/10/2024	13:11			HT	H/T From Koradi 2 end
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	07/10/2024	15:10			HT	H/T For load management.
KARAD - DASGAON	IntraState	14/10/2024	15:46			PO	i)Dismantling of Exst. S/C Tower Loc. No. 160 of 220 KV KaradDasgaon (Pedambe) line. ii) Foundation of In-Line M/C Narrow Base Tower (MCN+3). iii) Erection of Tower & stringing of 220 KV Karad - Dasgaon & 220 Karad Koyna line
KALWA - PRINT HOUSE LINE	IntraState	15/10/2024	16:31			HT	Hand tripped at Kalwa end for load management.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 1	IntraState	16/10/2024	16:01			HT	Line Hand tripped for load management on 220kV Ulve - Waghivali ckt no. 1.
WAGHIVALI (MSETCL) - WAGHIVALI (TATA) CKT - 2	IntraState	17/10/2024	06:26			HT	H/T for controlling load of 220kV Ulve-Waghivali ckt-1
KALWA - PANCHANAND	IntraState	17/10/2024	12:10			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
KALWA - PRINT HOUSE LINE	IntraState	17/10/2024	12:23			EO	For providing bunching at Loc. No. 691 by fixing T clamps & jumper connections to provide 2nd source to 220kV Taloja.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	23/10/2024	06:57			HT	Load management .
PANVEL TSS - TIMBER MARKET	IntraState	27/10/2024	08:21	27/10/2024	20:12	PO	220kV Panvel Timber Market - Panvel TSS line for diversion on ERS tower between loc no. 2&3.
KALWA - SALESETTE CKT - 5	IntraState	27/10/2024	10:51	27/10/2024	15:53	EO	Bird nest removal at Kalwa MSETCL premises gantry
MAHALAXMI - BACKBAY	IntraState	27/10/2024	23:46	28/10/2024	03:10	PO	Protection testing.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Oct/2024

Statement-VII

Position as on 6.30 Hrs of 28/Oct/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIWALI - PAWAS LINE	IntraState	28/10/2024	08:54	28/10/2024	18:50	PO	1)For cold washing of insulator strings, replacement of flashover insulator strings, attending hot spot and other line maintenance work by EHV LMSDn New Koyna & Kankavali. 2) Replacement of damaged top & bottom Wave trap jumper of R & Y ph and B ph incoming jumper by new jumpers & routine maintenance of line bay at 220kV Pawas s/s.
220 KV WARORA - CHANDRAPUR (400 KV) CKT	IntraState	28/10/2024	09:58	28/10/2024	17:15	PO	1.RPH LINE SIDE INSULATOR STING REPLACEMENT WORK. 2.RPH CT TO WAVE TRAP JUMPER REPLACEMENT WORK. 3.ROUTINE HARD-WARE TIGHTENING WOK.
DONDAICHA(220)-AMALNER(220)	IntraState	28/10/2024	10:16	28/10/2024	13:01	PO	REPLACEMENT OF FLASHOVER DISC INSULATOR STRING AT TL NO. 67 (R PHASE)
BADNERA-AKOLA II	IntraState	28/10/2024	10:30	28/10/2024	19:47	PO	RETROFITTING OF BACK UP RELAY BY SIEMENS AND BAY MAINTENANCE WORK
WARORA - WARORA RLY TSS 1	IntraState	28/10/2024	10:42	28/10/2024	14:26	PO	ROUTINE MAINTENANCE C AND TAN DELTA MEASUREMENT OF LINE CT CC TAN DELTA, IR, MAINTENANCE OF BAY EQUIPMENTS
KHARGHAR - NET MAGIC GIS	IntraState	28/10/2024	16:40	28/10/2024	19:42	EO	To attend Hot spot on bottom ph. Bushings terminal at Netmagic CTT TL no. 2.
220 KV ICT Outages/Trippings							
220/132 KV 100 MVA ICT 1@ BABHALESHWAR	IntraState	12/07/2024	13:35			PO	Augmentation of 220/132kV 100MVA to 220/132kV 200MVA at Babheshwar.
220/22KV 50MVA PTR 3 @ BHOSARI 2	IntraState	24/07/2024	23:02			T	Tripped due to caught fire.
220/132 KV 100 MVA ICT II @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/132 KV 100 MVA ICT I @ UPPALWADI	IntraState	28/08/2024	12:52			HT	H/T LV for load management.
220/33KV 25MVA PTR 1 @ NIWALI	IntraState	25/10/2024	09:49	27/10/2024	19:03	PO	CB overhauling work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Oct/2024

Statement-VII

Position as on 6.30 Hrs of 28/Oct/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	27/10/2024	09:10	27/10/2024	21:19	PO	for service & maintenance of SERGI Nitrogen Injection Fire Fighting System of 100MVA, 220/100kV ICT-1 by agency, OLTC Overhauling by agency & Diagnostic Testing and Bay Maintenance work.
220/132 KV 200 MVA PTR NO 3 @ PHURSUNGI	IntraState	28/10/2024	09:18	28/10/2024	19:43	PO	Diagnostic testing work, Half yearly maint. , NIFPS CTR cable & sensor replacement replacement by agency.
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	28/10/2024	09:50	28/10/2024	15:54	PO	Diagnostic testing work & quarterly maintenance work
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	28/10/2024	10:01	28/10/2024	18:09	EO	1. Replacement work of Differential Relay. 2. Replacement work of Back up Relay. 3. Routine Maintenance Work.
220/33 kV 50 MVA BBL PTR 2 @ MUDSHINGI	IntraState	28/10/2024	10:17	28/10/2024	16:20	PO	for quarterly maintenance work and to attend hot spot.
132 KV LINE Outages/Trippings							
MANSAR-PENCH	InterState	26/09/2024	14:40			HT	H/T at 132KV Pench end
CHAKAN- CHINCHWAD- BAJAJ AUTO CHAKAN TAP	IntraState	16/10/2024	07:02			HT	For Load Management
110 KV BUSBAR Outages/Trippings							
ZONE 1 (BUS SECTION 1+2+3) @ BHIVPURI	IntraState	27/10/2024	05:47	27/10/2024	12:38	PO	R/M of bus side GODs and PT 1 testing

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage