

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Nov/2022 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	150.758	3847.943	1) Gujrat	-8.240	-225.402
2) Hydro	5.939	236.998	2) Madhya Pradesh	-1.495	-39.259
3) Gas	5.580	74.835	3) Chattisgarh	4.760	165.430
Total MSPGCL	162.277	4159.776	4) Maharashtra	168.555	4546.717
B) 1) APMIL	73.972	1804.829	5) Goa (Amona)	-0.991	-36.963
2) JSWEL	10.898	329.011	Total	162.589	4410.523
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.995	828.656
4) RPL(AMT)	31.225	737.378	b) Mumbai Drawl	33.140	951.981
5) SWPGPL	7.990	201.903	c) MSEDCL Bilateral *	57.521	1840.384
6) Other IPP	41.523	958.876	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.995	828.654
C) 1) TPCL Thermal	10.370	294.262	Include PX	0.000	0.000
2) TPCL Hydro	1.763	94.097	Standby	0.000	0.002
3) TPCL Gas	0.000	13.475	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.364	242.198	1) MSEDCL	462.629	12049.657
D) STATE			2) Mumbai Discoms	54.637	1596.016
1) Thermal	336.100	8416.400	3) Other Discoms	9.382	252.748
(A1+C1+C4+(B1-B6))			TOTAL STATE	526.648	13898.421
2) Hydro	7.702	331.095			
(A2+C2)					
3) Gas	5.580	88.310			
(A3+B7+C3)					
4) Wind	3.216	332.930			
6) SOLAR	11.461	319.160			
TOTAL STATE	364.059	9487.895			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6817	6173	6436	5627
MSPGCL Hydro	427	222	266	153
MSPGCL Gas	232	225	225	232
MSPGCL Total Generation	7476	6620	6927	6012
Central Sector Receipt	8072	7891	7035	5630
WIND	111	94	120	170
CPP / IPP Thermal	6989	7009	7038	6637
CPP / IPP Gas	0	0	0	0
SOLAR	1560	1724	1	0
Exchange with Mumbai	-1447	-1498	-1369	-1464
MSEDCL DEMAND MET	22362	21449	19331	16603
Load Shedding	0	0	0	0
MSEDCL DEMAND	22362	21449	19331	16603
TPCL GENERATION	557	559	681	460
AEML GENERATION	501	500	474	324
MUMBAI DEMAND	2505	2557	2524	2248
OTHER DISCOM DEMAND	399	391	421	382
STATE DEMAND MET	25266	24397	22276	19233
STATE DEMAND	25266	24397	22276	19233
Frequency (Hz)	49.95	49.98	50.05	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 16.03 Hrs	49.76 Hz at 09.05 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.11	122.76	215	210
Unit 7	0.00	0.00	0	0
Unit 8	11.40	345.78	554	410
Unit 9	13.72	346.22	625	472
Unit 10	13.02	202.57	578	445
Total	43.25	1017.32		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	9.51	222.06	465	280
Unit 5	8.86	248.72	445	275
Total	18.37	470.78		
Parli				
Unit 6	3.78	107.56	212	148
Unit 7	0.00	96.70	0	0
Unit 8	3.58	92.52	168	138
Total	7.36	296.78		
Chandrapur				
Unit 3	3.32	85.88	165	122
Unit 4	2.98	78.33	141	117
Unit 5	4.92	172.19	300	80
Unit 6	6.57	147.59	287	250
Unit 7	5.19	193.48	375	0
Unit 8	9.46	255.98	476	276
Unit 9	9.32	204.08	478	279
Total	41.76	1137.52		
Paras				
Unit 3	5.66	135.14	249	198
Unit 4	5.73	80.22	252	228
Total	11.38	215.36		
Khaparkheda				
Unit 1	2.74	72.56	130	105
Unit 2	2.82	72.74	135	80
Unit 3	3.58	88.36	180	128
Unit 4	3.23	83.41	146	122
Unit 5	9.87	233.80	440	270
Total	22.25	550.88		
Nasik				
Unit 3	3.18	23.64	165	110
Unit 4	3.20	76.68	170	115
Unit 5	0.00	58.99	0	0
Total	6.38	159.31		
Uran				
All Units	5.58	74.84	241	218
Total	5.58	74.84		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	12.01	22	0
Total	0.04	12.01		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.65	67.82	445	40
Stage 4	0.00	57.24	0	0
Stage 3	0.49	27.55	80	0
Total	3.14	152.61		
Hydro				
KDPH	0.43	9.81	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.52	7.46	58	0
BHIRA T.R.	0.14	4.71	40	0
SMLHY_PTN	1.66	43.56	72	66
GHATGHAR	0.00	6.84	0	0
Total	2.76	72.39		
Wind				
Total	3.22	332.93	0	0
Total	3.22	332.93		
CPP				
APML(Mus)	73.97	1804.83	0	0
JSWEL(Mus)	10.90	329.01	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.22	737.38	0	0
SWPGPL-Mus	7.99	201.90	0	0
Other(Mus)	41.52	958.88	0	0
Total	165.61	4032.00		
SOLAR				
Total	11.46	319.16	0	0
Total	11.46	319.16		
Tata				
Trombay 5	7.03	199.74	365	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.00	7.77	0	0
Trombay 7B	0.00	5.71	0	0
TATA Hydro	1.76	94.10	283	9
Trombay 8	3.34	94.52	174	130
Total	12.13	401.83		
AEMIL				
DTPS U-1&2	9.36	242.20	502	317
Total	9.36	242.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	150.76	3847.94	MSPGCL Total	162.28	4159.78
			MSPGCL Thml+Gas	156.34	3922.78	Koyna 1,2 & 4 Total	2.65	125.05
			MSPGCL Hydro	5.94	237.00	State Total	364.06	9487.90

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5897	235	239	6371	223	6538	0	0	5927	6018	-1365	17419	0	17419	2223	366	20008	49.93
2	6146	317	240	6703	195	6761	0	0	5652	5749	-1307	17755	0	17755	2090	346	20191	49.99
3	6252	131	239	6622	195	6878	0	0	5796	5863	-1234	18012	0	18012	1973	312	20297	50.00
4	6301	126	240	6667	185	6896	0	0	5791	5821	-1166	18086	0	18086	1896	317	20299	49.94
5	6427	175	240	6842	200	6885	0	0	5965	6033	-1086	18566	0	18566	1875	308	20749	50.00
6	6596	124	241	6961	171	6862	0	0	6467	6656	-1206	19106	0	19106	1936	338	21380	49.99
7	6747	154	239	7140	162	6861	0	15	6701	6788	-1163	19390	0	19390	1999	413	21802	50.00
8	6772	395	240	7407	191	6913	0	236	6467	6627	-1017	19899	0	19899	2102	458	22459	49.99
9	6918	400	238	7556	148	6886	0	761	6549	6795	-1139	20614	0	20614	2230	393	23237	49.96
10	6889	571	238	7698	85	6991	0	1237	6687	7037	-1275	21368	0	21368	2387	405	24160	49.96
11	6817	427	232	7476	111	6989	0	1560	7875	8072	-1447	22362	0	22362	2505	399	25266	49.95
12	6306	269	230	6805	77	6989	0	1720	8303	8356	-1511	22043	0	22043	2569	393	25005	50.00
13	6173	222	225	6620	94	7009	0	1724	7742	7891	-1498	21449	0	21449	2557	391	24397	49.98
14	6289	186	227	6702	87	7034	0	1571	7827	7728	-1657	20994	0	20994	2449	471	23914	50.02
15	6401	221	218	6840	78	7074	0	1333	7825	7759	-1658	20986	0	20986	2392	440	23818	50.00
16	6429	199	223	6851	81	7047	0	895	8125	7654	-1636	20492	0	20492	2380	400	23272	50.01
17	6186	187	226	6599	75	7065	0	364	7737	7469	-1558	19621	0	19621	2352	393	22366	49.99
18	6370	208	228	6806	94	7097	0	44	6644	6710	-1352	18992	0	18992	2396	407	21795	50.00
19	6436	266	225	6927	120	7038	0	1	6935	7035	-1369	19331	0	19331	2524	421	22276	50.05
20	6374	313	228	6915	127	7082	0	0	6613	6325	-1431	18587	0	18587	2475	431	21493	50.02
21	5710	209	230	6149	117	7029	0	0	6128	6045	-1518	17415	0	17415	2409	407	20231	49.97
22	5335	235	230	5800	103	6586	0	0	6083	6333	-1568	16851	0	16851	2364	403	19618	50.00
23	5360	216	232	5808	127	6461	0	0	6043	6195	-1515	16687	0	16687	2306	389	19382	49.99
24	5627	153	232	6012	170	6637	0	0	5958	5630	-1464	16603	0	16603	2248	382	19233	49.99
MUs	150.76	5.94	5.58	162.28	3.22	165.61	0.00	11.46	161.84	162.59	-33.14	462.63	0.00	462.63	54.64	9.38	526.65	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 27/Nov/2022

Position as on 6.30 Hrs of 28/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	23/12/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-2	135	11/11/2022	19:36		Continued.	Submerged Scrapper Conveyor Scrapper bar problem.	29/11/2022
MSPGCL	Nasik Unit 5	210	19/11/2022	23:20		Continued.	Boiler Tube Leakage	29/11/2022
TPC-G	Trombay 7B	60	24/11/2022	04:52		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	24/11/2022	05:13		Continued.	Gas shortage	
MSPGCL	Parli Unit 7	250	26/11/2022	14:52		Continued.	Boiler Tube Leakage	
IPP	IEPL Unit 1	270	26/11/2022	18:42	27/11/2022	07:58	EXCITATION PROBLEM.	
IPP	JSW (J) U4	300	27/11/2022	11:25		Continued.	due to no schedule.	
MSPGCL	Chandrapur Unit 7	500	27/11/2022	15:48	27/11/2022	21:36	Gland Filling Pressure High and axial shaft High.	
MSPGCL	Chandrapur Unit 7	500	27/11/2022	22:41	28/11/2022	07:30	DUE TO GLAND SEALING PRESSURE HIGH AND AXIAL SHIFT HIGH	28/11/2022
MSPGCL	Paras Unit 4	250	28/11/2022	07:03		Continued.	VACCUUM TRIP DEVICE OPERATED	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 27/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 28/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	18/11/2022	00:36	28/11/2022	02:50	PO	For Pole 1 Scheduled Annual Outage and Pole1 Y Phase Converter Transformer replacement work.
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	25/11/2022	23:24	27/11/2022	23:57	PO	annual outage
CHANDRAPUR - PADGHE POLE 1 & 2	IntraState	26/11/2022	10:38	27/11/2022	21:25		to execute overhead stringing of 400kV Babhaleshwar Kudus (under construction) line between locn no G315 & G316.
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (403) OF LINE- 4 @ KORADI 3	IntraState	28/11/2022	09:37			PO	Annual Maintenance of Bay Equipment
400 KV LR Outages/Tripping							
400KV KORADI-BHUSAWAL (Koradi end)	IntraState	28/11/2022	06:58			PO	Replacement of flashover string at Various loc. No. by LMU 400KV Koradi
400 KV LINE Outages/Tripping							
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	08/11/2022	07:32			HT	For Load Management
PADGHE - PADGHE HVDC CKT- 1	IntraState	18/11/2022	00:36	28/11/2022	02:50	PO	1) Bay Maint work 2) Diagnostic Testing work 3) A Bus :- PG Isolator replacement of 400kV HVDC-I Y&B-ph 4) Bhel CB Pole Overhauling work. If pole overhauling not completed within outage period line will be charge on TBC.
LONIKAND I - KOYNA STAGE-IV	IntraState	19/11/2022	18:23			EO	For shifting 400kV Lonikand-Stage IV line on 400kV TBC due to hotspot on 29 B Isolator B phase on hanger rod assembly
BUS - 2 @ NEW KOYNA	IntraState	21/11/2022	12:51			PO	1) 21/11/2022 to 22/11/2022 Bus Insulator replacement work at section TBC & Bus coupler & Spare bay 2) 23/11/2022 Bus Insulator replacement work at section Dabhol 1 & 2 3) 24/11/2022 Bus Insulator replacement work at section ICT I & ICT-II 4) 25/11/2022 Bus Insulator replacement work at section Koyana -I & II and damage conductor replacement work 5) 26/11/2022 Bus Insulator replacement work at section Karad - I & II 6) 27/11/2022 to 28/11/2022 Bus Insulator replacement work at section Jaigad - I & II
BABHALESHWAR - PADGHE CKT - 2	IntraState	24/11/2022	15:10	27/11/2022	06:00	EO	During Yard Inspection a leakage is observed on Bph Grading capacitor of 400 KV Padghe-II and it is requested to give permission for shifting of 400 KV BBLR-Padghe-II on 400 KV TBC to attend the same.
KHADKA-AURANGABAD (WALUJ)	IntraState	26/11/2022	21:29	27/11/2022	06:45	HT	H/T FOR O/V

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 28/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS 'A' @ PADGHE	IntraState	27/11/2022	09:46	27/11/2022	16:58	PO	1)Replacement of Hanger assembly of A bus PG Isolator of 400kV HVDC- 1 Bay by hot line method. 2)All feeders on A Bus in service.
KARAD - TALANDGE CKT - 2	IntraState	28/11/2022	06:31	28/11/2022	09:24	PO	Alignment of repaired R,Y,B ph PG Isolator(i.e. replacement of Cu blades) is carried out.Re connection of IPS tubes between Bus-I PG Isolator & BPI.
NAGOTHANE - DABHOL CKT - 1	IntraState	28/11/2022	09:30			PO	Replacement of Surge Arrestor for all the three poles
220 KV LINE Outages/Trippings							
BOISAR - VERSOVA	IntraState	12/11/2022	07:17			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
DAHANU - VERSOVA	IntraState	12/11/2022	07:40			PO	Bunching of lines at location no.SS 82 to facilitate the following project work:DFCCIL project : Shifting of lines on temporary towers from SS 225 to SS 228. Post bunching the existing lines will be reconfigured as 220 kV Dahanu - Boisar temporary line.
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	19/11/2022	14:33			HT	H/T TO CONTROL BBLR LINE LOADING
KHARGHAR - NERUL	IntraState	22/11/2022	06:38			EO	A bus to B bus shift Via TBC for prevent to further avoid damage of A bus B phase conductor near Nerul bay.
KHARGHAR - SONKHAR	IntraState	22/11/2022	10:45			EO	B bus to A bus shift Via TBC for balancing of Bus loading & Nerul ,Sonkhar line connected to MMR region for saftey purpose both are charged throuh different Bus.
AAREY - MSETCL BORIVALI CKT - 1	IntraState	24/11/2022	17:39			T	Tripped on Differential protection

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 27/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 28/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
PADGHE - NALASOPARA - VASAI (T)	IntraState	26/11/2022	17:05	27/11/2022	19:04	PO	A) Work by Project Dn, Kalyan: Outage on Padghe-Nalasopara tap to vasa line will be taken out on 26.11.2022 16:00 to 18:00 Hrs to remove jumper at loc no.54 and 2nd source to Vasai-Padgha will be established till the start of AEMLs work at 23:00 Hrs 2) At Loc No.54, Jumpers will be removed and then from Loc No.54 to Nalasopara line will be in outage from Dtd 26.11.2022 at 16:00 Hrs to 27.11.2022 at 19:00Hrs. In this case 2nd source to Nalasopara will not be available. B) Outage for safety purpose for DFCCIL during which AEML will carry out stringing of 6 conductors & 1 OPGW for height raising work of AEML's existing 220KV D/C SS-Line section betwn loc no. SS-225 & SS-228 in Vasai for DFCCIL. C) During above outage, PT diagnostic & Bus Section Isolator maintenance including bay maint.
TROMBAY MSETCL TIE - 1	IntraState	27/11/2022	01:19	27/11/2022	07:30	PO	ATTENDING HOT SPOT AT 1. Msetcl end dropper connection to CT for A, B and C phase. 2. Tata end A phase 29B connection.
KALWA - TFIPL	IntraState	27/11/2022	02:48	27/11/2022	05:33	T	Tripped on Distance protection
EKLAHARE (OCR) - PADGHE	IntraState	27/11/2022	10:39	28/11/2022	00:28	HT	For load management
BUS SECTION BREAKER-3 @ TROMBAY	IntraState	27/11/2022	14:54	27/11/2022	15:16	EO	FOR RAISING SF6 GAS PRESSURE
KAMBA - VASAI	IntraState	27/11/2022	23:43	27/11/2022	14:16	PO	Outage is for safety purpose for DFCCIL during which AEML will carry out stringing of 6 conductors & 1 OPGW for height raising work of AEMLs existing 220KV D/C SS-Line section betwn loc no. SS-225 & SS-228 in Vasai for DFCCIL. During above outage, PT diagnostic & Bus Section Isolator maintenance including bay maint. will be done at 220KV Vasai S/strn
EKLAHARE (OCR) - PADGHE	IntraState	28/11/2022	08:35			HT	For load management
GHATGHAR - BAPGAON	IntraState	28/11/2022	09:19	28/11/2022	09:46	T	Tripped at Ghatghar end only AR successful at Bapgaon end
KHARGHAR - TSS PANVEL	IntraState	28/11/2022	10:14			PO	220kv Kharghar panvel TSS line for connecting the second circuit and making the LILO to 220kv New Panvel TSS on dt. 28.11.22 from loc no. 3 Latic Tower to Monopole No. 1
KADEGAON-MIRAJ	IntraState	28/11/2022	10:42			PO	Cold line washing work
TROMBAY MSETCL TIE - 2	IntraState	28/11/2022	11:26			PO	BREAKER REPLACEMENT AT BOTH ENDS
URAN - SEZ JNPT	IntraState	28/11/2022	12:03			PO	Shifting of 220KV Uran SEZ Line on TBC for New Breaker Foundation Work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 28/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/100 KV 100 MVA ICT 2 @ VASAI II	IntraState	26/11/2022	23:50	27/11/2022	14:39		For Diagnostic testing work
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	28/11/2022	09:20			PO	CB Overhauling work
220/33kv 100 MVA TF 1 @ GHODBUNDER	IntraState	28/11/2022	09:59			PO	Annual Maintenance of CB.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage