

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 27/Dec/2021 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.095	3717.580	1) Gujrat	-9.804	-210.343
2) Hydro	8.034	205.501	2) Madhya Pradesh	1.661	37.145
3) Gas	5.748	132.602	3) Chattisgarh	5.290	156.470
Total MSPGCL	151.877	4055.683	4) Maharashtra	149.148	3667.194
B) 1) APML	70.017	1670.086	5) Goa (Amona)	-1.624	-43.056
2) JSWEL	8.135	367.273	Total	144.671	3607.410
3) VIPL	0.000	0.000	a) Mumbai Schedule	22.125	661.041
4) RPL(AMT)	26.919	705.696	b) Mumbai Drawl	24.102	705.755
5) SWPGPL	5.944	203.799	c) MSEDCL Bilateral *	47.093	1326.598
6) Other IPP	38.752	1019.218	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	22.125	661.041
C) 1) TPCL Thermal	6.572	211.314	Include PX	0.000	3.902
2) TPCL Hydro	5.293	117.253	Standby	0.000	0.000
3) TPCL Gas	3.174	79.313	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.114	262.097	1) MSEDCL	422.864	11028.645
D) STATE			2) Mumbai Discoms	48.255	1375.725
1) Thermal	303.548	8157.063	3) Other Discoms	9.823	264.190
(A1+C1+C4+(B1-B6))			TOTAL STATE	480.942	12668.560
2) Hydro	13.327	322.754			
(A2+C2)					
3) Gas	8.922	211.915			
(A3+B7+C3)					
4) Wind	4.021	206.273			
6) SOLAR	6.453	163.152			
TOTAL STATE	336.271	9061.157			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6507	6499	6125	4583
MSPGCL Hydro	840	335	268	237
MSPGCL Gas	237	232	225	253
MSPGCL Total Generation	7584	7066	6618	5073
Central Sector Receipt	7387	7134	6195	5164
WIND	138	74	70	358
CPP / IPP Thermal	6757	6660	6675	5166
CPP / IPP Gas	0	0	0	0
SOLAR	855	1053	4	0
Exchange with Mumbai	-1176	-1345	-1100	-678
MSEDCL DEMAND MET	17088	16407	13770	11930
Load Shedding	0	0	0	0
MSEDCL DEMAND	17088	16407	13770	11930
TPCL GENERATION	805	695	847	382
AEML GENERATION	492	438	478	328
MUMBAI DEMAND	2473	2478	2425	1388
OTHER DISCOM DEMAND	371	353	391	263
STATE DEMAND MET	24018	23120	20887	16471
STATE DEMAND	24018	23120	20887	16471
Frequency (Hz)	49.99	50.02	50.02	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 13:03 Hrs	49.78 Hz at 14:18 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 27/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	96.43	180	115
Unit 7	0.00	0.00	0	0
Unit 8	0.00	336.83	0	0
Unit 9	12.94	237.40	628	228
Unit 10	12.24	352.44	595	375
Total	28.67	1023.11		
Bhusawal				
Unit 3	3.38	59.58	180	115
Unit 4	8.84	234.24	460	280
Unit 5	8.88	235.75	450	280
Total	21.10	529.57		
Parli				
Unit 6	4.56	57.33	250	151
Unit 7	4.43	39.88	227	151
Unit 8	4.23	90.94	215	151
Total	13.22	188.14		
Chandrapur				
Unit 3	3.57	65.01	172	124
Unit 4	3.53	86.34	165	125
Unit 5	8.32	156.08	400	298
Unit 6	9.12	210.82	440	278
Unit 7	8.14	206.86	390	296
Unit 8	0.00	218.66	0	0
Unit 9	10.18	251.03	471	282
Total	42.86	1194.79		
Paras				
Unit 3	4.71	116.64	252	140
Unit 4	4.65	118.15	251	137
Total	9.36	234.79		
Khaparkheda				
Unit 1	0.00	24.87	0	0
Unit 2	0.00	25.46	0	0
Unit 3	3.57	35.32	180	125
Unit 4	3.40	28.48	165	124
Unit 5	9.79	258.19	455	285
Total	16.76	372.33		
Nasik				
Unit 3	2.84	53.64	167	0
Unit 4	0.00	33.17	0	0
Unit 5	3.29	88.03	181	116
Total	6.13	174.85		
Uran				
All Units	5.75	132.60	256	224
Total	5.75	132.60		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	6.68	43	20
Total	0.60	6.68		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.39	60.23	395	35
Stage 4	0.50	22.08	214	0
Stage 3	0.24	18.70	80	0
Total	3.13	101.01		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.46	8.85	58	0
BHIRA T.R.	0.20	6.83	40	0
SMLHY_PTN	4.24	88.75	194	151
GHATGHAR	0.00	0.00	0	0
Total	4.90	104.50		
Wind				
Total	4.02	206.27	0	0
Total	4.02	206.27		
CPP				
APML(Mus)	70.02	1670.09	0	0
JSWEL(Mus)	8.14	367.27	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.92	705.70	0	0
SWPGPL-Mus	5.94	203.80	0	0
Other(Mus)	38.75	1019.22	0	0
Total	149.77	3966.07		
SOLAR				
Total	6.45	163.15	0	0
Total	6.45	163.15		
Tata				
Trombay 5	6.57	189.51	369	253
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.87	46.95	115	53
Trombay 7B	1.30	32.37	66	44
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.29	117.25	404	9
Total	15.04	407.88		
AEMIL				
DTPS U-1&2	9.11	262.10	492	314
Total	9.11	262.10		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.10	3717.58	MSPGCL Total	151.88	4055.68
			MSPGCL Thml+Gas	143.84	3850.18	Koyna 1,2 & 4 Total	2.89	82.31
			MSPGCL Hydro	8.03	205.50	State Total	336.27	9061.16

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 27/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4540	228	250	5018	263	5250	0	0	5536	5214	-772	14686	0	14686	1552	287	16525	50.02
2	4530	234	242	5006	320	5143	0	0	5477	5445	-707	14925	0	14925	1455	282	16662	49.99
3	4583	237	253	5073	358	5166	0	0	5463	5164	-678	14820	0	14820	1388	263	16471	50.00
4	4716	231	242	5189	321	5289	0	0	5461	5332	-648	15226	0	15226	1351	257	16834	50.02
5	5116	223	254	5593	276	5347	0	0	5526	5515	-663	15780	0	15780	1367	288	17435	50.01
6	5366	212	244	5822	252	6127	0	0	5509	5634	-687	16834	0	16834	1451	314	18599	49.99
7	6024	210	256	6490	293	6651	0	0	5413	5178	-667	17592	0	17592	1566	353	19511	50.01
8	6620	210	246	7076	284	6756	0	69	5767	5970	-751	19040	0	19040	1743	364	21147	49.99
9	6660	311	254	7225	151	6779	0	323	6405	6549	-952	19700	0	19700	2034	375	22109	50.00
10	6615	665	242	7522	101	6798	0	607	6802	7057	-1069	20635	0	20635	2318	381	23334	49.97
11	6507	840	237	7584	138	6757	0	855	7334	7387	-1176	21174	0	21174	2473	371	24018	49.99
12	6544	707	245	7496	107	6714	0	962	7442	7347	-1274	20983	0	20983	2522	369	23874	50.06
13	6499	335	232	7066	74	6660	0	1053	7722	7134	-1345	20289	0	20289	2478	353	23120	50.02
14	6134	264	227	6625	85	6562	0	938	7404	7014	-1345	19515	0	19515	2342	364	22221	50.01
15	5988	500	238	6726	59	6621	0	801	7268	7399	-1342	19890	0	19890	2357	374	22621	49.92
16	6351	562	229	7142	65	6672	0	517	6928	6631	-1272	19372	0	19372	2373	383	22128	49.98
17	6343	280	231	6854	63	6678	0	268	6503	6369	-1103	18744	0	18744	2365	385	21494	49.98
18	6291	223	236	6750	52	6695	0	55	6213	5640	-1095	17693	0	17693	2370	404	20467	50.01
19	6125	268	225	6618	70	6675	0	4	6354	6195	-1100	18071	0	18071	2425	391	20887	50.02
20	6305	349	224	6878	88	6696	0	0	5780	5291	-1137	17421	0	17421	2363	395	20179	50.04
21	5511	254	236	6001	67	6595	0	0	5581	5078	-1102	16266	0	16266	2211	373	18850	50.02
22	5045	225	227	5497	185	6014	0	0	5659	5368	-1134	15567	0	15567	2064	363	17994	50.06
23	4977	237	243	5457	148	5507	0	0	5622	5574	-1110	15216	0	15216	1914	360	17490	50.00
24	4705	229	235	5169	201	5615	0	0	5467	5186	-973	14862	0	14862	1773	336	16971	50.01
MUs	138.10	8.03	5.75	151.88	4.02	149.77	0.00	6.45	148.64	144.67	-24.10	424.30	0.00	424.30	48.26	8.38	480.94	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 27/Dec/2021

Position as on 6.30 Hrs of 28/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkheda Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 8	500	25/12/2021	00:01		Continued.	CW DEBRIS FILTER INSPECTION AND MAINTENENCE WORK	
IPP	SWPGL U-2	135	25/12/2021	00:09		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkheda Unit 1	210	09/12/2021	00:56	28/12/2021	09:55	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22	28/12/2021	12:25	withdrawn against case 4 to dhariwal	
MSPGCL	Koradi Unit 8	660	25/12/2021	09:56		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 3	210	27/12/2021	20:30		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	27/12/2021	23:45		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkheda Unit 4	210	28/12/2021	10:00		Continued.	Boiler Tube Leakage	31/12/2021

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 28/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 701 OF 765/400KV 1500MVA ICT-1 @ KORADI 3	IntraState	28/12/2021	09:02	28/12/2021	19:46	PO	Annual Maintenance of Bay Equipments
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	27/12/2021	17:21	27/12/2021	18:24	EO	URGENT attained CT OIL LEAKAGE, as it may lead to tripping of filter.
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	27/12/2021	10:27	28/12/2021	18:03	PO	For TIE CB DCRM Testing & Bay Maintenance work.
400 KV LINE Outages/Trippings							
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
TBC @ KORADI-1	IntraState	24/12/2021	13:40			EO	"Heavy air leakage in ABB make 400 kV CB R pole observed and CB got lockout due to 0 bar air pressure in CB. To attend the heavy air leakage of ABB make 400 kV CB R pole emergency outage is required on 400 kV TBC Bay ."
JAIGAD - KARAD CKT - 1	IntraState	26/12/2021	22:03	27/12/2021	10:00	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	26/12/2021	22:56	27/12/2021	08:56	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 1	IntraState	26/12/2021	23:30	27/12/2021	09:07	HT	HT FOR OVERVOLTAGE
PARLI - KUMBHARGAON(NANDED) CKT - 2	IntraState	27/12/2021	06:20	27/12/2021	15:09	T	Distance Protection
CHANDRAPUR 2 - CHD SWITCHING CKT - 1	IntraState	27/12/2021	11:21	27/12/2021	16:14	PO	Daignostic testing and allied bay maintenance work
KOLHAPUR (TALANDGE) - ALKUD	IntraState	27/12/2021	12:03	27/12/2021	16:33	PO	Quarterly maintenance work
JAIGAD - KARAD CKT - 2	IntraState	27/12/2021	22:06	28/12/2021	10:05	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	27/12/2021	23:28	28/12/2021	08:59	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 1	IntraState	27/12/2021	23:39	28/12/2021	08:41	HT	HT FOR OVERVOLTAGE
400 KV ICT Outages/Trippings							
400/220/33 KV 500MVA ICT - 3 @ NAGOTHANE	IntraState	27/12/2021	12:38	27/12/2021	19:43	EO	To attend LV Bushing (B Ph) Hot Spot
400/220/33 KV 315 MVA ICT - 2 @ KORADI	IntraState	27/12/2021	13:57	27/12/2021	20:30	PO	Retrofitting of Numerical REF Relay under MTAMC project.
220 KV MAINBAY Outages/Trippings							
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22	28/12/2021	21:14	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
220 KV LINE Outages/Trippings							
CHINCHWAD- PARVATI	IntraState	08/12/2021	18:01	27/12/2021	17:23	HT	air leakage in CB

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 28/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54	28/12/2021	18:11	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
BOISAR II - BOISAR (PG) CKT - 2	IntraState	26/12/2021	06:17	27/12/2021	05:51	PO	Replacement of conductor between loc no.3 & 4(Railway Crossing) and 220KV Boisar-II S/stn Gantry to Loc no.4
BABHALESHWAR - UTECH SUGAR	IntraState	26/12/2021	22:30		Continued.	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	NMIA work
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	FOR NMIA WORK
TALANDGE - MUDSHINGI CKT - 2	IntraState	27/12/2021	09:28	27/12/2021	17:00	PO	To attend hot spot observed in Thermovision scanning at tower loc No-2,9,11,21A,LILO 17.Replacement of nut bolt &
BUS SECTION @ KOLSHET	IntraState	27/12/2021	10:30	27/12/2021	20:45	PO	1),Diagnostic test (CT tan delta ,CB CRM and timing. 2) TNC Switch replacement work 3) Bay maintenance , RMW
MAIN BUS SECTION I @ WATHAR	IntraState	27/12/2021	11:10	27/12/2021	17:35	PO	Quarterly maintenance on 220 kV Bus Section-I (220 kV Karad - Wathar line, 220/33 kV 50 MVA IMP T/F, 220/33 kV 50 MVA BHEL T/F).
NEW KOYNA - LOTEPARSHURAM	IntraState	27/12/2021	11:15	27/12/2021	18:03	PO	Replacement of B-ph CT having higher tan delta values at 220kV Lote S/s.
EKLAHARA(OCR)-RAYMOND	IntraState	27/12/2021	13:00	27/12/2021	15:41	EO	220 kv nashik to reymond for flashover long rod replacement at loc.370, B phase from.
NAGAR BELWANDI CKT 1	IntraState	27/12/2021	14:24	27/12/2021	15:30	EO	For attending the sparking on CT clamp of R-Phase
MALHARPETH - KARAD	IntraState	28/12/2021	09:29	28/12/2021	16:26	PO	Replacement of single/double suspension hardware at various locations & restringing of conductor between Loc No.156-157
ALKUD - VITA	IntraState	28/12/2021	10:21	28/12/2021	17:15	PO	Providing and fixing of suspension clamps at various locations
KHARGHAR - TOPWORTH	IntraState	28/12/2021	10:36	28/12/2021	18:52	PO	For providing of earthwire at Loc.No.581-584. OPGW work between Loc.No.640-673

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 27/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 28/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - AIROLI KNOWLEDGE PARK	IntraState	28/12/2021	16:05	28/12/2021	18:55	PO	For B-phase Hot spot attending work at Loc no.405B.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	27/12/2021	09:41		Continued.	PO	1. Retrofitting of REF relay for MTAMC pending work 2. Diagnostic testing work 3. Painting of ICT
220/33 KV 50 MVA PTR 1	IntraState	27/12/2021	10:10	27/12/2021	18:36	PO	For Transformer OLTC overhauling work.
220/132 KV 150 MVA PTR NO 7	IntraState	27/12/2021	10:28	27/12/2021	19:21	PO	For CTR MAKE NIFPS Maintenance, Air Cell Checking and recommissioning, Annual Relay Testing
220/33KV 50MVA PTR 3 @ WATHAR	IntraState	27/12/2021	10:53	27/12/2021	17:51	PO	Quarterly Maintenance work .
220/33kv 100 MVA TF 3 @ AAREY	IntraState	27/12/2021	16:42	27/12/2021	17:35	EO	ATTAINING 220KV CB B-PH SF6 GAS LOW PRESSURE ALARM. NORMAL PRESSURE 6.5BAR ., OBSERVED PRESSURE 5.8BAR
220/33 KV 50 MVA PTR 2	IntraState	28/12/2021	10:52	28/12/2021	16:30	PO	For Transformer OLTC overhauling work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage