

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Jan/2020 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	138.438	3522.512	1) Gujrat	4.839	138.644
2) Hydro	7.504	335.637	2) Madhya Pradesh	13.563	350.830
3) Gas	5.305	150.757	3) Chattisgarh	5.750	188.100
Total MSPGCL	151.247	4008.906	4) Maharashtra	123.475	3291.130
B) 1) APLM	72.971	1991.382	5) Goa (Amona)	-0.726	-14.960
2) JSWEL	24.967	679.853	Total	146.901	3953.744
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.837	610.554
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	26.800	644.248
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	30.092	793.633
6) Other IPP	15.653	429.021	Include PX	6.291	154.346
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.837	609.629
C) 1) TPCL Thermal	13.865	403.760	Include PX	10.574	226.652
2) TPCL Hydro	3.828	92.450	Standby	0.000	0.925
3) TPCL Gas	3.300	59.115	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.097	173.189	1) MSEDCL	414.077	10831.175
D) STATE			2) Mumbai Discoms	52.890	1372.764
1) Thermal	270.991	7199.717	TOTAL STATE	466.967	12203.939
(A1+C1+C4+(B1-B6))					
2) Hydro	11.332	428.087			
(A2+C2)					
3) Gas	8.605	209.872			
(A3+B7+C3)					
4) Wind	22.468	248.002			
6) SOLAR	6.670	164.515			
TOTAL STATE	320.066	8250.193			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	6360	6326	5802	5046
MSPGCL Hydro	361	239	166	116
MSPGCL Gas	284	272	295	153
MSPGCL Total Generation	7005	6837	6263	5315
Central Sector Receipt	7593	7354	5671	4955
WIND	971	1109	794	1011
CPP / IPP Thermal	5074	5036	4920	4191
CPP / IPP Gas	0	0	0	0
SOLAR	1002	991	4	0
Exchange with Mumbai	-1453	-1422	-1307	-725
MSEDCL DEMAND MET	20192	19905	16345	14747
Load Shedding	0	0	0	0
MSEDCL DEMAND	20192	19905	16345	14747
TPCL GENERATION	1080	1037	1043	634
AEML GENERATION	250	237	209	192
MUMBAI DEMAND	2783	2696	2559	1551
STATE DEMAND MET	22975	22601	18904	16298
STATE DEMAND	22975	22601	18904	16298
Frequency (Hz)	50.04	49.95	49.94	49.96

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.16 Hz at 12.01 Hrs	49.8 Hz at 22.09 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 28/Jan/2020

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	6.52	305.76	530	0
Unit 9	10.14	305.84	550	301
Unit 10	11.10	271.68	551	350
Total	27.76	883.27		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Total	0.00	0.00		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	5.26	73.85	250	190
Unit 7	5.20	79.96	248	187
Unit 8	5.31	127.79	251	198
Total	15.77	281.60		
Chandrapur				
Unit 3	4.24	116.96	188	151
Unit 4	0.00	96.53	0	0
Unit 5	7.21	217.93	321	285
Unit 6	10.24	284.60	470	355
Unit 7	9.84	73.20	446	360
Unit 8	10.87	299.65	470	360
Unit 9	10.93	294.52	490	360
Total	53.33	1383.39		
Paras				
Unit 3	5.14	134.19	250	187
Unit 4	5.56	145.05	257	190
Total	10.70	279.23		
Khaparkheda				
Unit 1	4.04	68.86	185	155
Unit 2	4.00	69.48	175	160
Unit 3	4.26	71.64	200	158
Unit 4	4.37	76.98	200	160
Unit 5	10.21	296.62	465	360
Total	26.87	583.58		
Nasik				
Unit 3	4.00	107.14	196	158
Unit 4	0.00	4.30	0	0
Unit 5	0.00	0.00	0	0
Total	4.00	111.44		
Uran				
All Units	5.30	150.76	295	86
Total	5.30	150.76		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.14	4.67	39	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.14	4.67		
Koyna				
Stage 1-2	2.46	94.82	380	40
Stage 4	1.72	126.78	623	0
Stage 3	0.57	47.35	144	0
Total	4.75	268.94		
Hydro				
KDPH	0.89	7.82	37	37
VTRNA	0.00	0.00	0	0
TILLARI	0.54	13.18	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.10	3.92	80	0
RNGR+BHTSA	0.33	9.74	14	13
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.05	0	0
SMLHY_PTN	0.44	9.94	30	15
GHATGHAR	0.45	22.05	125	0
Total	2.76	66.70		
Wind				
Total	22.47	248.00	0	0
Total	22.47	248.00		
CPP				
APML(Mus)	72.97	1991.38	0	0
JSWEL(Mus)	24.97	679.85	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	15.65	429.02	0	0
Total	113.59	3100.26		
SOLAR				
Total	6.67	164.52	0	0
Total	6.67	164.52		
Tata				
Trombay 5	8.91	260.45	470	311
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.96	33.77	84	79
Trombay 7B	1.34	25.35	57	55
Trombay 8	4.96	143.31	245	183
TATA Hydro	3.83	92.45	294	60
Total	20.99	555.32		
AEML				
DTPS U-1&2	5.10	173.19	251	191
Total	5.10	173.19		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	138.44	3522.51	MSPGCL Total	151.25	4008.91
			MSPGCL Thml+Gas	143.74	3673.27	Koyna 1,2 & 4 Total	4.18	221.60
			MSPGCL Hydro	7.50	335.64	State Total	320.07	8250.19

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Jan/2020

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5251	111	293	5655	1132	4266	0	0	5272	5003	-923	15133	0	15133	1746	16879	49.97
2	5070	106	218	5394	1043	4192	0	0	5125	5099	-807	14921	0	14921	1630	16551	49.97
3	5046	116	153	5315	1011	4191	0	0	5059	4955	-725	14747	0	14747	1551	16298	49.96
4	5068	107	184	5359	1026	4212	0	0	5048	4911	-683	14825	0	14825	1505	16330	50.01
5	5354	112	178	5644	1105	4250	0	0	5254	5206	-691	15514	0	15514	1516	17030	50.05
6	5810	117	86	6013	1139	4494	0	0	5709	5920	-765	16801	0	16801	1656	18457	50.00
7	5845	348	104	6297	1090	4852	0	3	6443	6328	-742	17828	0	17828	1883	19711	49.96
8	5889	972	145	7006	1000	5075	0	72	6437	6451	-800	18804	0	18804	2061	20865	49.93
9	6046	1137	187	7370	823	5123	0	341	6371	6342	-999	19000	0	19000	2331	21331	49.99
10	6254	925	199	7378	833	5097	0	647	6766	6838	-1210	19583	0	19583	2575	22158	50.01
11	6363	482	267	7112	906	5035	0	831	7418	7602	-1428	20058	0	20058	2741	22799	50.02
12	6360	361	284	7005	971	5074	0	1002	7876	7593	-1453	20192	0	20192	2783	22975	50.04
13	6326	239	272	6837	1109	5036	0	991	7526	7354	-1422	19905	0	19905	2696	22601	49.95
14	6026	220	281	6527	1251	4843	0	903	7273	7222	-1435	19311	0	19311	2542	21853	50.01
15	6072	222	258	6552	1271	4795	0	771	7227	7132	-1438	19083	0	19083	2557	21640	49.96
16	6224	216	245	6685	1092	4871	0	620	7084	7026	-1482	18812	0	18812	2563	21375	49.96
17	6278	236	280	6794	1027	4864	0	382	6496	6410	-1469	18008	0	18008	2570	20578	49.97
18	5799	446	275	6520	940	4873	0	103	5902	6252	-1412	17276	0	17276	2542	19818	49.99
19	5802	166	295	6263	794	4920	0	4	5847	5671	-1307	16345	0	16345	2559	18904	49.94
20	5783	121	269	6173	758	4929	0	0	5850	5684	-1188	16356	0	16356	2519	18875	50.00
21	5341	111	260	5712	693	4698	0	0	5691	5621	-1242	15482	0	15482	2330	17812	49.97
22	5348	261	261	5870	583	4344	0	0	5431	5574	-1128	15243	0	15243	2172	17415	50.01
23	5486	261	161	5908	482	4642	0	0	5318	5498	-1081	15449	0	15449	1995	17444	49.98
24	5597	111	150	5858	389	4915	0	0	5398	5209	-970	15401	0	15401	1867	17268	50.01
MUs	138.44	7.50	5.31	151.25	22.47	113.59	0.00	6.67	147.82	146.90	-26.80	414.08	0.00	414.08	52.89	466.97	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Jan/2020

Position as on 6.30 Hrs of 29/Jan/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
AEML	AEML Unit 2	250	06/01/2020	18.44		Continued.	Annual Overhaul	
MSPGCL	Koyna STG-IV Unit-3	250	20/01/2020	09.00		Continued.	Maintenance work	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	09/11/2019	03.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-4	270	12/11/2019	00.00		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Uran Unit 8	108	30/11/2019	19.14	28/01/2020	22.21	Over Speed Bolt Trip.	
MSPGCL	Nasik Unit 5	210	12/12/2019	10.25		Continued.	PA Fan Problem (Under Case 4 Bidding From 04.25Hrs DT. 13-12-2019)	
MSPGCL	Bhusawal Unit 5	500	23/12/2019	22.05		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 22.00Hrs DT. 26-12-2019)	
MSPGCL	Uran Unit B0	120	28/12/2019	22:48	28/01/2020	09.52	Gas shortage	
MSPGCL	Uran Unit 7	108	28/12/2019	22:48	28/01/2020	02.10	Gas shortage	
MSPGCL	Bhusawal Unit 4	500	29/12/2019	00.57		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Koyna Unit 9	80	18/01/2020	08.00	28/01/2020	11.15	Transformer shifting work.	
MSPGCL	Nasik Unit 4	210	21/01/2020	10.30		Continued.	Zero schedule	
IPP	RPL(AMT) U-1	270	25/01/2020	0:00		Continued.	Zero Schedule by MSEDCL	
MSPGCL	Chandrapur Unit 4	210	26/01/2020	07.00	29/01/2020	20.52	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Jan/2020

Position as on 6.30 Hrs of 29/Jan/2020

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 6	108	28/01/2020	01.40		Continued.	Routine Operating Hour Equalization Of Units.	
MSPGCL	Uran Unit 5	108	28/01/2020	05.12	28/01/2020	05.38	Turbine Vibration	
MSPGCL	Koradi Unit-8	660	28/01/2020	17.03	28/01/2020	23.29	BFP Tripped	
MSPGCL	Uran Unit A0	120	28/01/2020	22.03		Continued.	Gas shortage	
MSPGCL	Uran Unit 5	108	28/01/2020	22.03		Continued.	Gas shortage	
MSPGCL	Uran Unit 8	108	28/01/2020	22.44	29/01/2020	01.57	Tripped	
MSPGCL	Paras Unit 3	250	29/01/2020	08.47	29/01/2020	18.50	Furnace Pressure High	
MSPGCL	Paras Unit 4	250	29/01/2020	22.25		Continued.	Due To Electircal Board Fault.	
MSPGCL	Khaparkheda Unit 4	210	29/01/2020	23.41		Continued.	Furnace Pressure High	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jan/2020

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
Koradi-III - Akola-II ckt-I	IntraState	29/01/2020	09.39	29/01/2020	15.41	PO	Routine Maintenance Work
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	27/01/2020	19.03	28/01/2020	06.41	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	28/01/2020	17.59	29/01/2020	06.19	HT	Over Voltage
Dhule Sar'Sarovar II	InterState	29/01/2020	19.26		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	27/01/2020	19.00	28/01/2020	06.17	HT	Over Voltage
Deepnagar Waluj 1	IntraState	28/01/2020	09.12	28/01/2020	17.38	PO	Bird Guard Fixing
Khadka-Aurangabad (Waluj)	IntraState	28/01/2020	18.05	29/01/2020	06.23	HT	Over Voltage
Koradi-Khaperkheda I	IntraState	29/01/2020	11.01	29/01/2020	15.46	EO	To Attend Hot Spot On Isolator At Koradi End.
Lonikand 1 - Chakan	IntraState	29/01/2020	12.54	29/01/2020	13.12	HT	For Shifting (B To A)
Khadka-Aurangabad (Waluj)	IntraState	29/01/2020	19.30		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential protection,Declared faulty.
400/220 Kv 315 Mva Ict -2 @New Koyana	IntraState	27/01/2020	08.29	28/01/2020	00.26	PO	Routine Maintenance Work
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	27/01/2020	20.16	28/01/2020	09.25	PO	For Main Bus Outage.
400/220/33 Kv 500 Mva Ict 2 @ CHANDRAPUR 2	IntraState	27/01/2020	20.19	28/01/2020	09.27	PO	For Main Bus Outage.
400/220 Kv 500 MVA ICT-I @Kalwa	IntraState	28/01/2020	00.01	28/01/2020	08.48	PO	Painting Work.
167 Mva Spare Ict @Lamboti	IntraState	28/01/2020	09.49	29/01/2020	16.19	PO	SFRA Testing.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
Borivali - Tarapur	InterState	25/01/2020	08.45		Continued.	PO	Work At Tarapur End.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Kalwa-TIFIL	IntraState	27/12/2019	18.40		Continued.	PO	normalizing the Direct Circuit.
MAHAPE - RELIANCE GIS	IntraState	08/01/2020	10:44		Continued.	HT	At Mahape End For New Configuration.
Talandge-Mudshingi Ckt-I	IntraState	27/01/2020	08.45		Continued.	PO	Construction Work.
Trombay - Kalwa	IntraState	27/01/2020	10.54		Continued.	PO	Stringing Work.
Talandge(400kv)- Ichalkaranji ckt-1	IntraState	28/01/2020	08.21	28/01/2020	18.38	PO	Replacement of Disc Insulator String with Antifogg
Bhira Dharavi 8	IntraState	28/01/2020	09.17	28/01/2020	16.26	PO	Maintenance work
Adlabs - Pedambe	IntraState	28/01/2020	09.17	28/01/2020	19.30	PO	Cold washing of Insulator Strings
Mumewadi -Halkarni ckt-II	IntraState	28/01/2020	09.31	28/01/2020	14.47	PO	CT Tan Delta
Karad - Vita Ckt- II	IntraState	28/01/2020	10.52	28/01/2020	17.27	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita - Ghatnandre	IntraState	28/01/2020	10.52	28/01/2020	17.32	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita-Khanapur(Mahuli Tap)	IntraState	28/01/2020	10.52	28/01/2020	17.29	PO	DC Contactor of 220KV Battery charger replacement and TBC bay Main Bus Isolator Alignment work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jan/2020

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2020

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Vita-Wayphale	IntraState	28/01/2020	10.52	28/01/2020	17.52	PO	DC Contactor of 220KV Battery charger replacement and TBC bay Main Bus Isolator Alignment work
Vita - Mhaishal	IntraState	28/01/2020	10.52	28/01/2020	17.50	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita-Hiwarwadi	IntraState	28/01/2020	10.52	28/01/2020	17.31	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Vita Alkud	IntraState	28/01/2020	10.52	28/01/2020	17.30	PO	DC Contactor of 220KV Battery charger replacement and TBC Bay Main Bus Isolator Alignment work
Karad-Nerle	IntraState	28/01/2020	11.03	28/01/2020	17.43	PO	Testing Work
Kalwa - Mulund 2	IntraState	28/01/2020	17.35	28/01/2020	19.03	EO	To attend Hot Spot
Kalwa - Mulund 1	IntraState	29/01/2020	06.39	29/01/2020	11.52	PO	Safety Purpose.
GIS Bhandup - Borivali	IntraState	29/01/2020	08.47	29/01/2020	12.20	PO	Hot Spot On IPS Tube At Breakerside Attending Work.
Talandge-Hamidwada	IntraState	29/01/2020	09.05	29/01/2020	18.00	PO	Insulator Replacement.
Chandrapur GCR - Sicom I	IntraState	29/01/2020	09.55	29/01/2020	13.36	PO	Isolator of Aux. Bus Isolator Jumper For Dismantling RCC Structure.
Parli New Tps - Beed Ckt 1	IntraState	29/01/2020	10.08	29/01/2020	15.25	PO	To attend The Hot Spot And Diagnostic Testing Work.
512 Khadki- Century Enka	IntraState	29/01/2020	10.35	29/01/2020	19.05	PO	CT & CB Testing.
Bus Coupler @ Kalwa	IntraState	29/01/2020	11.22	29/01/2020	11.53	PO	Control Loading On Kalwa Salsette.
Borivali - Ghodbunder	IntraState	29/01/2020	12.32	29/01/2020	19.45	PO	Replacement Of Line Boxes.
Koradi-Ambazari-I	IntraState	29/01/2020	15.58	29/01/2020	18.05	PO	Diagnostic Testing Work.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	28/01/2020	10.24	28/01/2020	19.09	PO	Overhauling of LV CB
220/132 Kv 200 Mva Vijai Ict 2 @Bale (Solapur 2)	IntraState	28/01/2020	10.52	28/01/2020	13.34	HT	Abnormal sound
220/132 KV 100MVA ICT-II @ Bhokar	IntraState	28/01/2020	11.40	28/01/2020	18.18	PO	Tan Delta and Capacitance Measurement of Bushing
220/100 Kv 100 MVA ICT I @Vasai-II	IntraState	29/01/2020	09.47	29/01/2020	17.55	PO	Attending Oil Leakage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage