

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 28/Jan/2021 THURSDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 160.346        | 4033.459        | 1) Gujrat                      | 2.145          | 21.999           |
| 2) Hydro            | 9.664          | 347.825         | 2) Madhya Pradesh              | 7.703          | 264.454          |
| 3) Gas              | 7.030          | 166.241         | 3) Chattisgarh                 | 5.460          | 174.700          |
| <b>Total MSPGCL</b> | <b>177.040</b> | <b>4547.525</b> | 4) Maharashtra                 | 129.282        | 3883.024         |
| B) 1) APML          | 55.323         | 1091.201        | 5) Goa (Amona)                 | -0.708         | -29.884          |
| 2) JSWEL            | 18.083         | 479.334         | <b>Total</b>                   | <b>143.882</b> | <b>4314.293</b>  |
| 3) VIPL             | 0.000          | 0.000           | a) Mumbai Schedule             | 18.963         | 534.173          |
| 4) RPL(AMT)         | 26.382         | 746.507         | b) Mumbai Drawl                | 20.312         | 549.369          |
| 5) WPCL             | 7.778          | 206.326         | c) MSEDCL Bilateral *          | 30.440         | 1058.136         |
| 6) Other IPP        | 18.073         | 491.856         | Include PX                     | -0.055         | 234.345          |
| 7) PGPL             | 0.000          | 0.000           | d) Mumbai Bilateral *          | 17.034         | 526.939          |
| C) 1) TPCL Thermal  | 8.728          | 302.829         | Include PX                     | 2.165          | 258.832          |
| 2) TPCL Hydro       | 3.038          | 118.781         | Standby                        | 1.929          | 7.234            |
| 3) TPCL Gas         | 3.847          | 74.433          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) AEML Thermal     | 9.718          | 269.291         | 1) MSEDCL                      | 439.559        | 11691.079        |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 45.643         | 1314.703         |
| 1) Thermal          | 304.431        | 7620.803        | <b>TOTAL STATE</b>             | <b>485.202</b> | <b>13005.782</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 12.702         | 466.606         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 10.877         | 240.674         |                                |                |                  |
| (A3+B7+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 6.310          | 191.553         |                                |                |                  |
| 6) SOLAR            | 7.000          | 171.853         |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>341.320</b> | <b>8691.489</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 12 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|---------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 7082                      | 6983                  | 7042                      | 5775                      |
| MSPGCL Hydro             | 874                       | 422                   | 580                       | 100                       |
| MSPGCL Gas               | 281                       | 279                   | 293                       | 305                       |
| MSPGCL Total Generation  | 8236                      | 7684                  | 7916                      | 6180                      |
| Central Sector Receipt   | 7191                      | 7133                  | 4905                      | 5445                      |
| WIND                     | 255                       | 130                   | 165                       | 418                       |
| CPP / IPP Thermal        | 5818                      | 5840                  | 5339                      | 4483                      |
| CPP / IPP Gas            | 0                         | 0                     | 0                         | 0                         |
| SOLAR                    | 1021                      | 1087                  | 0                         | 0                         |
| Exchange with Mumbai     | -1015                     | -1084                 | -1054                     | -567                      |
| <b>MSEDCL DEMAND MET</b> | <b>21507</b>              | <b>20791</b>          | <b>17270</b>              | <b>15958</b>              |
| Load Shedding            | 0                         | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 21507                     | 20791                 | 17270                     | 15958                     |
| TPCL GENERATION          | 875                       | 777                   | 694                       | 475                       |
| AEML GENERATION          | 499                       | 498                   | 495                       | 280                       |
| <b>MUMBAI DEMAND</b>     | <b>2389</b>               | <b>2359</b>           | <b>2243</b>               | <b>1322</b>               |
| STATE DEMAND MET         | 23896                     | 23150                 | 19513                     | 17280                     |
| <b>STATE DEMAND</b>      | <b>23896</b>              | <b>23150</b>          | <b>19513</b>              | <b>17280</b>              |
| Frequency (Hz)           | 50.03                     | 50.00                 | 50.02                     | 50.00                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.18 Hz at 12.02 Hrs | 49.8 Hz at 05.09 Hrs | 50            | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 28/Jan/2021

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 6             | 3.32         | 74.25          | 170      | 130      |
| Unit 7             | 3.04         | 48.91          | 138      | 103      |
| Unit 8             | 11.38        | 327.20         | 555      | 374      |
| Unit 9             | 11.74        | 330.65         | 603      | 390      |
| Unit 10            | 10.24        | 270.91         | 480      | 370      |
| <b>Total</b>       | <b>39.71</b> | <b>1051.92</b> |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 3             | 0.00         | 58.90          | 0        | 0        |
| Unit 4             | 10.65        | 271.16         | 480      | 285      |
| Unit 5             | 10.56        | 200.81         | 480      | 285      |
| <b>Total</b>       | <b>21.21</b> | <b>530.86</b>  |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 5.29         | 141.83         | 250      | 194      |
| Unit 7             | 5.31         | 142.05         | 248      | 187      |
| Unit 8             | 5.47         | 145.82         | 250      | 200      |
| <b>Total</b>       | <b>16.06</b> | <b>429.71</b>  |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 3.28         | 105.21         | 152      | 121      |
| Unit 4             | 3.54         | 80.21          | 160      | 123      |
| Unit 5             | 9.04         | 217.04         | 445      | 275      |
| Unit 6             | 9.39         | 245.44         | 440      | 285      |
| Unit 7             | 8.01         | 218.52         | 375      | 280      |
| Unit 8             | 11.22        | 62.07          | 480      | 450      |
| Unit 9             | 11.21        | 309.77         | 477      | 443      |
| <b>Total</b>       | <b>55.68</b> | <b>1238.26</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 5.02         | 132.10         | 225      | 162      |
| Unit 4             | 4.09         | 142.19         | 250      | 0        |
| <b>Total</b>       | <b>9.11</b>  | <b>274.29</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 3.12         | 89.32          | 160      | 90       |
| Unit 2             | 3.52         | 99.09          | 165      | 115      |
| Unit 3             | 4.26         | 109.83         | 200      | 135      |
| Unit 4             | 4.12         | 108.00         | 202      | 130      |
| Unit 5             | 0.00         | 8.74           | 0        | 0        |
| <b>Total</b>       | <b>15.02</b> | <b>414.97</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 3.54         | 93.45          | 195      | 124      |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>3.54</b>  | <b>93.45</b>   |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 7.03         | 166.24         | 316      | 270      |
| <b>Total</b>       | <b>7.03</b>  | <b>166.24</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>PENCH (MS)</b>  |              |                |          |          |
| Pench (MS)         | 0.46         | 7.39           | 26       | 0        |

| Generating unit | Generation    |                |          |          |
|-----------------|---------------|----------------|----------|----------|
|                 | Daily (Mus)   | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Total</b>    | <b>0.46</b>   | <b>7.39</b>    |          |          |
| <b>Koyna</b>    |               |                |          |          |
| Stage 1-2       | 2.75          | 79.20          | 320      | 40       |
| Stage 4         | 2.34          | 138.91         | 500      | 0        |
| Stage 3         | 1.02          | 46.59          | 80       | 0        |
| <b>Total</b>    | <b>6.11</b>   | <b>264.71</b>  |          |          |
| <b>Hydro</b>    |               |                |          |          |
| KDPH            | 0.44          | 10.14          | 19       | 19       |
| VTRNA           | 0.44          | 4.39           | 60       | 0        |
| TILLARI         | 0.47          | 6.60           | 58       | 0        |
| BHTGR/VEER      | 0.00          | 0.00           | 0        | 0        |
| BHIRA T.R.      | 0.22          | 7.45           | 40       | 0        |
| RNGR+BHTSA      | 0.32          | 9.36           | 14       | 13       |
| BHANDARDRA      | 0.00          | 0.00           | 0        | 0        |
| ELDARY          | 0.00          | 6.85           | 0        | 0        |
| SMLHY_PTN       | 0.41          | 7.56           | 18       | 17       |
| GHATGHAR        | 1.25          | 30.78          | 250      | 0        |
| <b>Total</b>    | <b>3.55</b>   | <b>83.12</b>   |          |          |
| <b>Wind</b>     |               |                |          |          |
| Total           | 6.31          | 191.55         | 0        | 0        |
| <b>Total</b>    | <b>6.31</b>   | <b>191.55</b>  |          |          |
| <b>CPP</b>      |               |                |          |          |
| APML(Mus)       | 55.32         | 1091.20        | 0        | 0        |
| JSWEL(Mus)      | 18.08         | 479.33         | 0        | 0        |
| VIPL(Mus)       | 0.00          | 0.00           | 0        | 0        |
| RPLAMT(Mus)     | 26.38         | 746.51         | 0        | 0        |
| WPCL(Mus)       | 7.78          | 206.33         | 0        | 0        |
| Other(Mus)      | 18.07         | 491.86         | 0        | 0        |
| <b>Total</b>    | <b>125.64</b> | <b>3015.22</b> |          |          |
| <b>SOLAR</b>    |               |                |          |          |
| Total           | 7.00          | 171.85         | 0        | 0        |
| <b>Total</b>    | <b>7.00</b>   | <b>171.85</b>  |          |          |
| <b>Tata</b>     |               |                |          |          |
| Trombay 5       | 8.73          | 195.26         | 448      | 315      |
| Trombay 6       | 0.00          | 0.00           | 0        | 0        |
| Trombay 7A      | 2.40          | 45.43          | 100      | 100      |
| Trombay 7B      | 1.45          | 29.00          | 61       | 59       |
| Trombay 8       | 0.00          | 107.57         | 0        | 0        |
| TATA Hydro      | 3.04          | 118.78         | 270      | 0        |
| <b>Total</b>    | <b>15.61</b>  | <b>496.04</b>  |          |          |
| <b>AEML</b>     |               |                |          |          |
| DTPS U-1&2      | 9.72          | 269.29         | 499      | 280      |
| <b>Total</b>    | <b>9.72</b>   | <b>269.29</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 160.35      | 4033.46       | MSPGCL Total        | 177.04      | 4547.52       |
|                |             |         | MSPGCL Thml+Gas | 167.38      | 4199.70       | Koyna 1,2 & 4 Total | 5.09        | 218.11        |
|                |             |         | MSPGCL Hydro    | 9.66        | 347.82        | State Total         | 341.32      | 8691.49       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 28/Jan/2021

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |      | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 5996        | 100  | 304  | 6400   | 299  | 4498      | 0    | 0     | 5475        | 5512        | -673                 | 16037                 | 0                    | 16037                     | 1479             | 17516           | 50.01         |
| 2                  | 5994        | 90   | 295  | 6378   | 362  | 4494      | 0    | 0     | 5499        | 5434        | -625                 | 16043                 | 0                    | 16043                     | 1388             | 17431           | 50.00         |
| 3                  | 5775        | 100  | 305  | 6180   | 418  | 4483      | 0    | 0     | 5688        | 5445        | -567                 | 15958                 | 0                    | 15958                     | 1322             | 17280           | 50.00         |
| 4                  | 5362        | 90   | 296  | 5748   | 432  | 4481      | 0    | 0     | 5718        | 5870        | -515                 | 16015                 | 0                    | 16015                     | 1272             | 17287           | 49.99         |
| 5                  | 5917        | 154  | 306  | 6378   | 404  | 4482      | 0    | 0     | 5726        | 6155        | -533                 | 16885                 | 0                    | 16885                     | 1288             | 18173           | 50.00         |
| 6                  | 6546        | 196  | 295  | 7038   | 355  | 4862      | 0    | 0     | 5938        | 5649        | -618                 | 17286                 | 0                    | 17286                     | 1372             | 18658           | 49.95         |
| 7                  | 6820        | 184  | 316  | 7320   | 317  | 5524      | 0    | 1     | 6278        | 6293        | -652                 | 18803                 | 0                    | 18803                     | 1493             | 20296           | 49.95         |
| 8                  | 7001        | 630  | 296  | 7928   | 254  | 5836      | 0    | 71    | 6241        | 6143        | -526                 | 19706                 | 0                    | 19706                     | 1680             | 21386           | 49.91         |
| 9                  | 7110        | 1200 | 306  | 8616   | 306  | 5888      | 0    | 317   | 6151        | 6192        | -741                 | 20578                 | 0                    | 20578                     | 1949             | 22526           | 50.02         |
| 10                 | 7097        | 1116 | 294  | 8506   | 362  | 5882      | 0    | 633   | 6511        | 6768        | -941                 | 21210                 | 0                    | 21210                     | 2186             | 23396           | 50.02         |
| 11                 | 7046        | 1004 | 292  | 8342   | 361  | 5818      | 0    | 900   | 7054        | 6891        | -1023                | 21288                 | 0                    | 21288                     | 2329             | 23617           | 50.04         |
| 12                 | 7082        | 874  | 281  | 8236   | 255  | 5818      | 0    | 1021  | 7224        | 7191        | -1015                | 21507                 | 0                    | 21507                     | 2389             | 23896           | 50.03         |
| 13                 | 6983        | 422  | 279  | 7684   | 130  | 5840      | 0    | 1087  | 7112        | 7133        | -1084                | 20791                 | 0                    | 20791                     | 2359             | 23150           | 50.00         |
| 14                 | 6934        | 588  | 278  | 7800   | 125  | 5846      | 0    | 1038  | 6615        | 6477        | -995                 | 20292                 | 0                    | 20292                     | 2227             | 22518           | 50.02         |
| 15                 | 7093        | 296  | 279  | 7668   | 132  | 5834      | 0    | 846   | 6919        | 6881        | -912                 | 20450                 | 0                    | 20450                     | 2234             | 22684           | 50.01         |
| 16                 | 7032        | 412  | 278  | 7722   | 123  | 5802      | 0    | 644   | 6865        | 6847        | -885                 | 20252                 | 0                    | 20252                     | 2228             | 22480           | 49.97         |
| 17                 | 7064        | 398  | 279  | 7742   | 119  | 5834      | 0    | 341   | 6495        | 6179        | -865                 | 19350                 | 0                    | 19350                     | 2225             | 21575           | 49.98         |
| 18                 | 7031        | 172  | 270  | 7472   | 137  | 5688      | 0    | 95    | 6243        | 5750        | -1057                | 18086                 | 0                    | 18086                     | 2205             | 20291           | 50.02         |
| 19                 | 7026        | 556  | 291  | 7872   | 133  | 5092      | 0    | 6     | 5636        | 5161        | -1208                | 17056                 | 0                    | 17056                     | 2228             | 19284           | 49.99         |
| 20                 | 7042        | 580  | 293  | 7916   | 165  | 5339      | 0    | 0     | 5062        | 4905        | -1054                | 17270                 | 0                    | 17270                     | 2243             | 19513           | 50.02         |
| 21                 | 7039        | 152  | 293  | 7484   | 186  | 5032      | 0    | 0     | 4923        | 4385        | -1040                | 16048                 | 0                    | 16048                     | 2132             | 18180           | 50.00         |
| 22                 | 6608        | 158  | 294  | 7060   | 263  | 4450      | 0    | 0     | 5729        | 5591        | -969                 | 16395                 | 0                    | 16395                     | 1976             | 18371           | 50.01         |
| 23                 | 6374        | 98   | 315  | 6788   | 321  | 4384      | 0    | 0     | 5699        | 5591        | -981                 | 16102                 | 0                    | 16102                     | 1800             | 17902           | 50.03         |
| 24                 | 6374        | 94   | 295  | 6762   | 351  | 4431      | 0    | 0     | 5604        | 5439        | -833                 | 16150                 | 0                    | 16150                     | 1639             | 17790           | 50.04         |
| MUs                | 160.35      | 9.66 | 7.03 | 177.04 | 6.31 | 125.64    | 0.00 | 7.00  | 146.40      | 143.88      | -20.31               | 439.56                | 0.00                 | 439.56                    | 45.64            | 485.20          | 50.00         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 28/Jan/2021**

Position as on 6.30 Hrs of 29/Jan/2021

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                       | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|------------|------------|------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |            |            |                                                                        |               |
| MSPGCL                | Koyna STG-IV Unit-2     | 250      | 23/11/2020   | 08.00        |            | Continued. | Capital Overhaul                                                       |               |
| MSPGCL                | Khaparkheda Unit 5      | 500      | 01/01/2021   | 23.13        |            | Continued. | Annual Overhaul                                                        |               |
| IPP                   | JSW (J) U4              | 300      | 28/01/2021   | 01.34        |            | Continued. | Annual Overhaul                                                        |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |            |            |                                                                        |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |            | Continued. | No PPA.                                                                |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                            |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |            | Continued. | No Schedule                                                            |               |
| IPP                   | IEPL Unit 1             | 270      | 28/08/2018   | 21.26        |            | Continued. | No PPA                                                                 |               |
| IPP                   | VIPL U-1                | 300      | 29/12/2018   | 00.30        |            | Continued. | Coal Shortage                                                          |               |
| IPP                   | VIPL U-2                | 300      | 17/01/2019   | 00.15        |            | Continued. | Coal Shortage                                                          |               |
| MSPGCL                | Nasik Unit 5            | 210      | 12/12/2019   | 10.25        |            | Continued. | PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 13-12-2019)     |               |
| MSPGCL                | Uran Unit 8             | 108      | 01/03/2020   | 20.57        |            | Continued. | Gas shortage                                                           |               |
| MSPGCL                | Uran Unit 7             | 108      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                  |               |
| MSPGCL                | Uran Unit B0            | 120      | 25/05/2020   | 12.51        |            | Continued. | Turbine Blade Failure                                                  |               |
| MSPGCL                | Nasik Unit 3            | 210      | 03/12/2020   | 06.45        |            | Continued. | Economizer Tube Leakage. (Zero Schedule from 18:45hrs of 05.12.2020)   |               |
| IPP                   | Adani U-5               | 660      | 18/01/2021   | 21.00        |            | Continued. | zero scheduled                                                         |               |
| MSPGCL                | Koyna Unit 11           | 80       | 19/01/2021   | 10.05        |            | Continued. | Tripped on stator earth fault (will not be available till dt.18.04.21) |               |
| TPC_G                 | Trombay 8               | 250      | 24/01/2021   | 12.20        |            | Continued. | Due to heavy leakage from Deaerator drain valve.                       |               |
| MSPGCL                | Bhusawal Unit 3         | 210      | 26/01/2021   | 00.00        |            | Continued. | Zero schedule.                                                         |               |
| MSPGCL                | Paras Unit 4            | 250      | 26/01/2021   | 08.40        | 28/01/2021 | 06.22      | Clinker Formation                                                      |               |
| MSPGCL                | Koyna Unit 12           | 80       | 28/01/2021   | 09.10        | 28/01/2021 | 17.50      | String insulator washing work by transco new koyna.                    |               |

**State Load Despatch Center,Airoli (MSETCL)**  
**Details of Line outages/Trippings for 28/Jan/2021**

**Statement-VII**

**Position as on 6.30 Hrs of 29/Jan/2021**

| Name of Line                                      | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                        |
|---------------------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|-------------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                         |
| Karad Solapur (PG)                                | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403                                                                |
| Dhule Sar'Sarovar II                              | InterState                | 26/01/2021   | 17.48        | 28/01/2021 | 11.01      | HT          | Over Voltage                                                                                                            |
| Dhule Sar'Sarovar I                               | InterState                | 28/01/2021   | 17.00        |            | Continued. | HT          | Over Voltage                                                                                                            |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 27/01/2021   | 19.57        | 28/01/2021 | 07.23      | HT          | Over Voltage                                                                                                            |
| Dhule- Bableshwar - I                             | IntraState                | 27/01/2021   | 20.00        | 28/01/2021 | 07.31      | HT          | Over Voltage                                                                                                            |
| Khadka- Deepnagar Ckt 2                           | IntraState                | 28/01/2021   | 09.09        | 28/01/2021 | 16.33      | PO          | CT Tan delta testing work.                                                                                              |
| Khadka-Aurangabad (Waluj)                         | IntraState                | 29/01/2021   | 01.44        | 29/01/2021 | 06.44      | HT          | Over Voltage                                                                                                            |
| <b>400 KV ICT Outages/Trippings</b>               |                           |              |              |            |            |             |                                                                                                                         |
| 400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE) | IntraState                | 10/08/2020   | 09.58        |            | Continued. | PO          | Replacement of existing 315 MVA ICT by 3*167 MVA ICT.                                                                   |
| 400/220/33 Kv 315 Mva Ict 2 @Dhule                | IntraState                | 23/09/2020   | 09.12        |            | Continued. | PO          | Augmentation work of 400/220 315MVA ICT-II to 501MVA                                                                    |
| <b>220 KV LINE Outages/Trippings</b>              |                           |              |              |            |            |             |                                                                                                                         |
| Mudshingi Chikodi                                 | InterState                | 24/09/2019   | 17.12        |            | Continued. | PO          | No Schedule(Charge from Mudshingi end only)                                                                             |
| Talandage - Chikodi                               | InterState                | 01/10/2019   | 17.10        |            | Continued. | PO          | No Schedule(Close at Chikodi end only)                                                                                  |
| Parli 3 (Old Gcr)-Girwali Ckt-3                   | IntraState                | 20/08/2020   | 13.05        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                               |
| Parli 3(Old Gcr)- Girwali Ckt 4                   | IntraState                | 20/08/2020   | 13.06        |            | Continued. | PO          | Erection of Tower Due to Railway Crossing                                                                               |
| ALKUD - MENDHEGIRI CKT - 2                        | IntraState                | 12/01/2021   | 11.00        |            | Continued. | PO          | CT,PT,ABT Meter and testing work                                                                                        |
| Chandrapur GCR - Sicom II                         | IntraState                | 24/01/2021   | 10.07        |            | Continued. | PO          | Dismantling of RCC Structure and erection of new structure of CT                                                        |
| Chikhli-Jalna-I                                   | IntraState                | 27/01/2021   | 08.03        | 28/01/2021 | 07.21      | HT          | In The view of Akola ICT Overloading.                                                                                   |
| Chikhli-Jalna-II                                  | IntraState                | 27/01/2021   | 08.16        | 28/01/2021 | 16.45      | HT          | In The view of Akola ICT Overloading.                                                                                   |
| Lonand-Baramati                                   | IntraState                | 27/01/2021   | 11.34        |            | Continued. | PO          | Bus isolator replacement work.                                                                                          |
| Mudshingi-Belewadi                                | IntraState                | 28/01/2021   | 07.29        | 28/01/2021 | 08.29      | EO          | For attending Hot Spot at loc. No.136 R Ph.                                                                             |
| Theur- Magar Patta City                           | IntraState                | 28/01/2021   | 09.00        | 28/01/2021 | 13.41      | PO          | Half yearly maintenance work & Diagnostic testing work.                                                                 |
| Miraj - Mhaishal                                  | IntraState                | 28/01/2021   | 09.12        | 28/01/2021 | 21.13      | PO          | Double jumpering at cut point locations.                                                                                |
| Kolkewade - Pedhambe - Unit 12                    | IntraState                | 28/01/2021   | 09.14        | 28/01/2021 | 17.50      | PO          | For cold washing of insulator strings & emergency tree cutting work.                                                    |
| Talandage - Sawantwadi I                          | IntraState                | 28/01/2021   | 09.14        | 28/01/2021 | 16.37      | PO          | For replacement of faulty insulator found in PID.                                                                       |
| Taloja II - OCIL-I                                | IntraState                | 28/01/2021   | 10.23        | 28/01/2021 | 13.04      | EO          | CT Tan-delta work & hot-spot attending work.                                                                            |
| Koradi-Ambazari-Ii                                | IntraState                | 28/01/2021   | 10.38        | 28/01/2021 | 17.44      | PO          | For Dismantling of CB pole for Replacement of Circuit breaker Pole nozzle.                                              |
| Wathar - Mudshingi 3 Line                         | IntraState                | 28/01/2021   | 12.44        | 28/01/2021 | 18.13      | PO          | Line insulators cleaning by cold line method.                                                                           |
| Goregaon Aarey Line 2                             | IntraState                | 28/01/2021   | 15.30        | 28/01/2021 | 16.08      | T           | DC Extension during Energy Meter Replacement Work Of TF-2.                                                              |
| Goregaon Versova Line 2                           | IntraState                | 28/01/2021   | 15.30        | 28/01/2021 | 16.13      | T           | DC Extension during Energy Meter Replacement Work Of TF-2.                                                              |
| Alkud Miraj                                       | IntraState                | 28/01/2021   | 18.03        | 28/01/2021 | 20.59      | PO          | Double jumpering work at M/C locations of 220kV Miraj-Mhaishal line. Outage taken on 220kV Miraj-Alkud line for safety. |
| Bableshwar Ahamadnagar-Ii                         | IntraState                | 28/01/2021   | 21.08        | 28/01/2021 | 21.19      | T           | Distance Protection                                                                                                     |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 28/Jan/2021**

**Statement-VII**

Position as on 6.30 Hrs of 29/Jan/2021

| Name of Line                                  | Inter State /<br>Intra State | Tripped<br>Date | Tripped<br>Time | Sync. Date | Sync.<br>Time | Outage<br>Type | Reason of Outage                                                              |
|-----------------------------------------------|------------------------------|-----------------|-----------------|------------|---------------|----------------|-------------------------------------------------------------------------------|
| <b>220 KV ICT Outages/Trippings</b>           |                              |                 |                 |            |               |                |                                                                               |
| 220/132 Kv 100 Mva Emco Ict 2<br>@Dondaicha   | IntraState                   | 28/01/2021      | 08.02           | 28/01/2021 | 13.51         | PO             | For replacement Of LV R & Y<br>phase CT & diagnostic Testing<br>work.         |
| 220/100 Kv 125 Mva Hel Ict 2<br>@Jambhul      | IntraState                   | 28/01/2021      | 09.52           | 28/01/2021 | 08.40         | PO             | Replacement of 220 kV HV CT R<br>& Y Phase due to oil leakage and<br>rusting. |
| 220/132 Kv 200 Mva Vijay Ict 1<br>@Chalisgaon | IntraState                   | 28/01/2021      | 10.20           | 28/01/2021 | 13.46         | PO             | Bushings tand & Cap value.                                                    |
| 220/132 Kv 100 Mva Cgl Ict 1<br>@Bhugaon      | IntraState                   | 28/01/2021      | 10.42           |            | Continued.    | PO             | OLTC Overhauling Work.                                                        |
| 220/132 Kv 100 Mva Cgl Ict 1<br>@Dondaicha    | IntraState                   | 28/01/2021      | 14.29           | 28/01/2021 | 17.09         | PO             | For replacement Of LV B PHASE<br>CT & Diagnostic Testing work.                |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage