

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Jan/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.972	4046.005	1) Gujrat	-7.613	-133.022
2) Hydro	6.355	344.111	2) Madhya Pradesh	4.948	86.629
3) Gas	3.386	129.571	3) Chattisgarh	4.930	148.600
Total MSPGCL	156.713	4519.687	4) Maharashtra	176.897	4847.925
B) 1) APML	64.621	1603.744	5) Goa (Amona)	-1.597	-42.132
2) JSWEL	16.510	535.130	Total	177.565	4908.000
3) VIPL	0.000	0.000	a) Mumbai Schedule	29.167	651.377
4) RPL(AMT)	31.223	720.570	b) Mumbai Drawl	33.552	758.019
5) SWPGPL	9.623	245.021	c) MSEDCL Bilateral *	73.531	1938.049
6) Other IPP	42.101	1298.163	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	29.156	650.696
C) 1) TPCL Thermal	3.410	227.501	Include PX	0.000	0.000
2) TPCL Hydro	3.086	106.743	Standby	0.011	0.681
3) TPCL Gas	1.715	62.560	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.429	255.317	1) MSEDCL	485.905	13384.161
D) STATE			2) Mumbai Discoms	50.192	1410.138
1) Thermal	322.889	8931.451	3) Other Discoms	9.537	270.365
(A1+C1+C4+(B1-B6))			TOTAL STATE	545.634	15064.664
2) Hydro	9.441	450.854			
(A2+C2)					
3) Gas	5.101	192.131			
(A3+B7+C3)					
4) Wind	16.422	223.555			
6) SOLAR	14.216	358.675			
TOTAL STATE	368.069	10156.666			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6813	6165	6750	5415
MSPGCL Hydro	245	205	832	145
MSPGCL Gas	137	136	142	142
MSPGCL Total Generation	7195	6506	7724	5702
Central Sector Receipt	8979	8746	6452	6348
WIND	757	628	308	874
CPP / IPP Thermal	7476	6893	7545	5990
CPP / IPP Gas	0	0	0	0
SOLAR	1742	2062	0	0
Exchange with Mumbai	-1826	-1842	-1239	-1178
MSEDCL DEMAND MET	23884	22598	20349	17374
Load Shedding	0	0	0	0
MSEDCL DEMAND	23884	22598	20349	17374
TPCL GENERATION	393	329	720	219
AEML GENERATION	330	351	501	305
MUMBAI DEMAND	2549	2522	2460	1702
OTHER DISCOM DEMAND	439	395	441	362
STATE DEMAND MET	26872	25515	23250	19438
STATE DEMAND	26872	25515	23250	19438
Frequency (Hz)	49.99	49.99	50.02	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 19.58 Hrs	49.66 Hz at 22.22 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.24	120.30	210	110
Unit 7	0.00	0.00	0	0
Unit 8	12.56	370.01	540	478
Unit 9	12.73	264.43	558	492
Unit 10	12.92	360.53	592	488
Total	42.46	1115.27		
Bhusawal				
Unit 3	3.19	65.36	170	115
Unit 4	9.18	272.30	480	275
Unit 5	8.40	222.73	435	275
Total	20.76	560.39		
Parli				
Unit 6	4.18	114.34	229	147
Unit 7	0.00	13.70	0	0
Unit 8	3.97	81.29	213	142
Total	8.16	209.34		
Chandrapur				
Unit 3	3.32	81.73	167	120
Unit 4	2.84	73.33	126	115
Unit 5	6.92	181.76	300	275
Unit 6	7.87	197.85	425	275
Unit 7	0.00	0.00	0	0
Unit 8	10.06	291.67	494	282
Unit 9	10.31	298.13	496	320
Total	41.33	1124.48		
Paras				
Unit 3	0.00	119.69	0	0
Unit 4	5.94	127.46	254	240
Total	5.94	247.15		
Khaparkheda				
Unit 1	2.86	77.84	135	110
Unit 2	2.74	78.08	123	105
Unit 3	3.39	96.55	173	128
Unit 4	3.34	88.25	173	123
Unit 5	9.59	265.27	470	280
Total	21.92	605.99		
Nasik				
Unit 3	3.23	41.80	174	113
Unit 4	3.18	93.60	171	115
Unit 5	0.00	47.98	0	0
Total	6.41	183.39		
Uran				
All Units	3.39	129.57	145	135
Total	3.39	129.57		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	8.36	0	0
Total	0.00	8.36		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.34	96.84	405	35
Stage 4	0.05	102.89	30	0
Stage 3	0.58	43.38	240	0
Total	2.97	243.11		
Hydro				
KDPH	0.00	9.83	0	0
VTRNA	0.48	4.48	61	0
TILLARI	0.00	5.80	0	0
BHIRA T.R.	0.22	6.25	40	0
SMLHY_PTN	2.50	49.73	108	98
GHATGHAR	0.19	16.55	125	0
Total	3.39	92.64		
Wind				
Total	16.42	223.56	0	0
Total	16.42	223.56		
CPP				
APML(Mus)	64.62	1603.74	0	0
JSWEL(Mus)	16.51	535.13	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.22	720.57	0	0
SWPGPL-Mus	9.62	245.02	0	0
Other(Mus)	42.10	1298.16	0	0
Total	164.08	4402.63		
SOLAR				
Total	14.22	358.68	0	0
Total	14.22	358.68		
Tata				
Trombay 5	0.00	128.60	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.90	35.62	42	36
Trombay 7B	0.81	26.94	36	32
TATA Hydro	3.09	106.74	431	1
Trombay 8	3.41	98.90	220	130
Total	8.21	396.80		
AEML				
DTPS U-1&2	8.43	255.32	501	287
Total	8.43	255.32		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.97	4046.00	MSPGCL Total	156.71	4519.69
			MSPGCL Thml+Gas	150.36	4175.58	Koyna 1,2 & 4 Total	2.39	199.73
			MSPGCL Hydro	6.36	344.11	State Total	368.07	10156.67

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 28/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5415	145	142	5702	874	5990	0	0	6530	6348	-1178	17374	0	17374	1702	362	19438	49.95
2	5468	145	142	5755	916	5985	0	0	6385	6301	-1050	17570	0	17570	1571	337	19478	49.99
3	5494	146	144	5784	940	5972	0	0	6475	6455	-974	17858	0	17858	1497	319	19674	49.98
4	5470	149	145	5764	951	5909	0	0	6498	6355	-933	17736	0	17736	1444	310	19490	49.95
5	5334	143	144	5621	1040	5972	0	0	6618	7213	-955	18558	0	18558	1468	333	20359	50.00
6	5998	238	145	6381	1167	6465	0	0	6730	6641	-1067	19227	0	19227	1587	360	21174	50.07
7	6528	145	145	6818	1205	6864	0	2	6981	6729	-1153	20084	0	20084	1723	381	22188	50.02
8	6747	216	145	7108	1063	7277	0	163	7080	7254	-1243	21234	0	21234	1866	388	23488	50.04
9	6671	146	144	6961	859	7380	0	725	7848	8009	-1463	22063	0	22063	2117	408	24588	50.00
10	6770	467	144	7381	839	7359	0	1233	8173	8350	-1571	23168	0	23168	2364	423	25955	49.89
11	6813	245	137	7195	757	7476	0	1742	9061	8979	-1826	23884	0	23884	2549	439	26872	49.99
12	6429	247	135	6811	805	7138	0	1978	9130	8947	-1902	23365	0	23365	2578	412	26355	50.04
13	6165	205	136	6506	628	6893	0	2062	8737	8746	-1842	22598	0	22598	2522	395	25515	49.99
14	5761	198	136	6095	468	6692	0	2049	8652	8717	-1589	22045	0	22045	2355	387	24787	50.01
15	5885	217	137	6239	365	6675	0	1822	8912	9125	-1649	22177	0	22177	2332	400	24909	49.94
16	6075	254	136	6465	260	6815	0	1394	9029	9182	-1635	22055	0	22055	2338	426	24819	49.94
17	6271	209	138	6618	181	7134	0	813	8569	8663	-1627	21351	0	21351	2336	431	24118	49.98
18	6623	310	139	7072	181	7399	0	227	7356	7258	-1576	20110	0	20110	2353	451	22914	50.02
19	6727	741	140	7608	256	7493	0	6	6463	6395	-1254	20047	0	20047	2428	457	22932	49.96
20	6750	832	142	7724	308	7545	0	0	6372	6452	-1239	20349	0	20349	2460	441	23250	50.02
21	6416	246	142	6804	431	7327	0	0	6376	6123	-1352	18891	0	18891	2355	442	21688	50.06
22	5968	167	142	6277	515	6940	0	0	6735	6547	-1578	18264	0	18264	2229	437	20930	50.00
23	5539	366	142	6047	661	6663	0	0	6708	6576	-1515	18020	0	18020	2084	412	20516	49.86
24	5655	178	144	5977	752	6715	0	0	6457	6200	-1381	17877	0	17877	1934	386	20197	50.00
MUs	146.97	6.35	3.39	156.71	16.42	164.08	0.00	14.22	177.88	177.56	-33.55	485.91	0.00	485.91	50.19	9.54	545.63	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Jan/2023

Position as on 6.30 Hrs of 29/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18		Continued.	ID Fan Problem	30/01/2023
MSPGCL	Uran Unit 6	108	25/01/2023	11:17		Continued.	Gas Skid Tripped	
MSPGCL	Paras Unit 3	250	26/01/2023	09:50	29/01/2023	01:17	Boiler Tube Leakage	29/01/2023
IPP	IEPL Unit 1	270	26/01/2023	23:33		Continued.	Air Filter Problem	01/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
MSPGCL	Koyna Unit 7	80	28/01/2023	07:30	29/01/2023	17:10	Preventive Maintenance Work	
IPP	SWPGPL U-4	135	29/01/2023	07:45	29/01/2023	13:56	Oil leakage from TG bearing no. 2	
MSPGCL	Bhusawal Unit 4	500	29/01/2023	12:45		Continued.	Boiler Tube Leakage	01/02/2023
IPP	SWPGPL U-2	135	29/01/2023	21:22		Continued.	Ash Conveying System Problem	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 28/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV TIEBAY Outages/Tripping							
TIE BAY - 702 OF BUS REACTOR AND 765/400kV 1500MVA ICT @ AKOLA 2	IntraState	28/01/2023	10:16	28/01/2023	18:36	PO	OEM Inspection of CB
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
PADGHE - TARAPUR CKT - 1	InterState	27/01/2023	21:22	28/01/2023	13:45	PO	1) 400kV Tarapur -1 shifted on TBC for safety purposed for removing jumper between Gantry of 400kV Trapur I & II by Hot line method. 2) Once work completed line will be charged on own CB & Bus
PADGHE - TARAPUR CKT - 1	InterState	29/01/2023	14:01	29/01/2023	17:19	PO	1) Tarapur -I on TBC for safety purpose for re connection of A bus gantry jumper between Tarapur -I & II by hot line method. 2) after work Tarapur -I will be charge on own CB.
PADGHE - TARAPUR CKT - 2	InterState	29/01/2023	17:41	29/01/2023	19:30	PO	1) Tarapur -II on TBC for re connection of IPS tube between A& B bus PG Isolator. 2) after work Tarapur -II will be charge on own CB.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
BUS 'A' @ PADGHE	IntraState	28/01/2023	10:50	29/01/2023	16:50	PO	A bus Conductor Replacement of Section -1 between 400kV Tarapur II & 500MVA ICT -5. 1) 500MVA ICT-5 & 400kV Tarapur -2 on TBC for 3hrs for removing IPS tube between A & B Bus PG isolator one by one and later on will be charged on B bus for 3 days. 2) 400kV Tarapur I on TBC for removing jumper by Hot line method.
400 KV ICT Outages/Tripping							
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	27/01/2023	22:33		Continued.	PO	Replacement of ICT-3 Rph HV bushing due to high tan delta value.
400/220KV 315 MVA ICT - 1 @ NEW KOYNA	IntraState	28/01/2023	15:57	28/01/2023	18:06	EO	CONTINUOUS OIL LEAKAGES FROM 105 MVA Y PH BUCHHOLZ RELAY
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	29/01/2023	20:24	29/01/2023	22:46	PO	1) ICT-5 HV side on TBC for re connection of IPS to tube between A & B bus PG Isolator. 2) after work ICT -5 will be charge on own CB.
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY - KALWA	IntraState	18/01/2023	13:07	28/01/2023	12:09	EO	For attending SF6 gas leakage in main CB of 220KV Trombay Bay by shifting the 220KV Kalwa-Trombay line on TBC.
EKLAHARE (OCR) - PADGHE	IntraState	27/01/2023	06:15			PO	1. Bunching at Loc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. Of Lattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
GHATGHAR - JINDAL	IntraState	27/01/2023	06:35			PO	1. Bunching at Loc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. Of Lattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
CHIKHALI-JALNA I	IntraState	27/01/2023	06:45	29/01/2023	06:59	HT	Akola ICT O/L
CHIKHALI-JALNA II	IntraState	27/01/2023	06:45	29/01/2023	06:59	HT	Akola ICT O/L
BORIVALI - TARAPUR	IntraState	27/01/2023	10:07			HT	Planned outage for annual maintenance at Tarapur end
JEJURI-PHURSUNGI 2	IntraState	27/01/2023	15:55	28/01/2023	18:59	EO	Replacement of pilot string at loc no. 20 B phase
ALEPHATA-PARGAON(KATHAPUR)	IntraState	27/01/2023	22:19	29/01/2023	23:59	HT	For load management purpose
BADNERA TSS-II	IntraState	27/01/2023	22:33	28/01/2023	20:30	HT	R Phase CT secondary wiring open
TROMBAY SALSETTE LINE-2	IntraState	27/01/2023	23:16	28/01/2023	01:30	PO	Work in vicinity to working on A Ph loop connection at loc. 58 of 110 kV Dharavi Powai line.
COLOURCHEM - TEMGHAR	IntraState	28/01/2023	06:43	28/01/2023	15:55	PO	Stringing of 2 Nos. Of span on newly constructed towers in r/o of shifting/ diversion of line infringing in Bullet train crossing under ORC.
KALWA - MULUND 1	IntraState	28/01/2023	09:20	28/01/2023	10:46	EO	Emergency online shifting of line through 220kv central breaker for replacement of Own CB Compressor (Outage not required)
PANDHARPUR - KHANAPUR	IntraState	28/01/2023	09:25	28/01/2023	17:20	PO	Outage is required for For cleaning disc insulator string from loc No. 261 to 393.
SADAWAGHAPUR KARAD CKT 2	IntraState	28/01/2023	09:30	28/01/2023	17:39	PO	Cleaning of Isulator string,support insulator,post insulator,insulator portion of various bays equipment by using high voltage cleaner.
AURANGABAD (WALUJ)-BHENDA	IntraState	28/01/2023	11:40	28/01/2023	16:30	HT	Outage availed for testing work
TROMBAY CARNAC - 5	IntraState	28/01/2023	11:52	28/01/2023	20:51	PO	Work in vicinity for desilting in aeration basin of Unit 5 FGD
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	28/01/2023	12:28	28/01/2023	18:37	PO	For Annual Relay Testing at MSETCL Borivali End by Testing Division Kalwa
PIRANGUT - HINJAWADI 2	IntraState	28/01/2023	12:46	28/01/2023	18:12	PO	1. Jumper Removal at Tower no 1. 2.String from MCTT to tower no 158. 3.Dismantling of existing Tower near MDN. 4.Destrining from MCTT to Tower no 158 old conductor.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
INFOSYS - HINJAWADI 1	IntraState	28/01/2023	12:47			PO	.Destringing of conductor from Guide tower to MDN tower (Temporary connection of Hinjewadi1 Infosys Line) 2. OPGW stringing from MCTT to MDN Tower 3. Conductor Stringing from MCTT to MDN tower 4.Dismantling of tower 158A near MDN tower 5.Conductor stringing from Guide tower to MDN tower 6. Bunching at MDN to MCTT for MAintaining Pirangut and Hinjewadi 1 Connectivity 7. Jumpering at MCTT to Cable bushing 8. OPGE/OFC splicing at MCTT and Hinjewadi 1 gantry
INFOSYS - PEGASUS	IntraState	28/01/2023	12:47	28/01/2023	19:09	PO	220KV R Phase CT Replacement work and Half year maintenance and testing work
KANDALGAON - KOYNA (POPHALI)	IntraState	28/01/2023	14:15	28/01/2023	19:20	EO	For replacement damaged insulator string due to ball rod rusting at Loc no 4 87A 4DSN middle ph
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	28/01/2023	22:30	29/01/2023	23:14	EO	AT MSETCL BORIVALI YPH CB SPRING NOT CHARGING HENCE CB LOCKOUT ALARM PERSISTING ON LINE
SAHARA-URSE	IntraState	28/01/2023	23:08	29/01/2023	02:27	HT	Load Management.
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	IntraState	28/01/2023	23:27	29/01/2023	02:19	HT	To attend Hotspot at Talegaon PG SS.
TEMGHAR - KALWA	IntraState	29/01/2023	07:24	29/01/2023	17:51	PO	Stringing of 2 Nos. Of span on newly constructed towers in r/o of shifting/ diversion of line infringing in Bullet train crossing under ORC.
MAIN BUS SECTION - 1 @ PEDAMBE	IntraState	29/01/2023	08:00	29/01/2023	19:00	PO	For New Koyna Bay Main bus side defects attending & all bays M.B. Isolators P/M work.
BORIVALI - BOISAR (PG)	IntraState	29/01/2023	08:16	29/01/2023	18:50	EO	Repairing of Damage Conductor at Loc No. 44-45 & 46-47 on 220kv PGCIL Borivali Line.
VILEBHAGAD - INOX	IntraState	29/01/2023	08:28	29/01/2023	20:38	PO	1.CT tan delta test 2. CB CRM & Timing 3. Jumper nut bolt tightening work 4. Isolator maintenance work 5.Relay testing by testing team
TROMBAY CARNAC - 5	IntraState	29/01/2023	09:13	29/01/2023	20:21	PO	Work in vicinity for desilting in aeration basin of Unit 5 FGD
BORIVALI - TARAPUR	IntraState	29/01/2023	09:21	29/01/2023	19:06	EO	Repairing of Damaged Conductor at Loc No.82-83.
NEW KOYNA - PEDAMBE	IntraState	29/01/2023	22:15		Continued.	HT	CT circuit defective indication is operated.
TROMBAY SALSETTE LINE-2	IntraState	29/01/2023	23:48		Continued.	PO	Work in vicinity for working on bottom ckt A Ph cross arm of 110 kV Salsette Vikhroli line at loc. 60.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 29/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	28/01/2023	09:41	28/01/2023	18:26	PO	Work of conversion of single to twin conductor from LV bushing to LV CT
110 KV LINE Outages/Trippings							
SALSETTE VIKHROLI	IntraState	29/01/2023	23:45		Continued.	PO	Formation of three terminal 110 kV Salsette Vikhroli Powai line FOR 220 kv tds PROJECT

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage