

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Feb/2024 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	177.276	4668.955	1) Gujrat	5.141	11.796
2) Hydro	6.770	204.197	2) Madhya Pradesh	7.122	164.104
3) Gas	6.885	190.821	3) Chattisgarh	3.840	106.230
Total MSPGCL	190.931	5063.973	4) Maharashtra	164.769	4795.936
B) 1) APLM	60.926	1797.948	5) Goa (Amona)	-2.074	-49.519
2) JSWEL	28.050	706.850	Total	178.798	5028.547
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.230	810.694
4) RPL(AMT)	31.323	880.494	b) Mumbai Drawl	33.836	918.868
5) SWPGPL	12.308	345.041	c) MSEDCL Bilateral *	84.912	2336.584
6) Other IPP	47.401	1327.336	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.230	810.691
C) 1) TPCL Thermal	11.037	257.368	Include PX	0.000	0.000
2) TPCL Hydro	3.835	91.573	Standby	0.000	0.003
3) TPCL Gas	3.626	93.105	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.003	271.592	1) MSEDCL	527.963	14636.847
D) STATE			2) Mumbai Discoms	62.337	1632.396
1) Thermal	378.324	10255.584	3) Other Discoms	10.812	294.150
(A1+C1+C4+(B1-B6))			TOTAL STATE	601.112	16563.393
2) Hydro (A2+C2)	10.605	295.770			
3) Gas (A3+B7+C3)	10.511	283.926			
4) Wind	7.096	253.299			
6) SOLAR	15.778	446.377			
TOTAL STATE	422.314	11534.956			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7651	7553	8084	6779
MSPGCL Hydro	215	289	552	160
MSPGCL Gas	282	270	285	297
MSPGCL Total Generation	8148	8112	8921	7236
Central Sector Receipt	8964	8699	6941	6286
WIND	242	95	438	498
CPP / IPP Thermal	7296	7415	8171	7328
CPP / IPP Gas	0	0	0	0
SOLAR	2005	1339	0	0
Exchange with Mumbai	-1812	-1751	-1419	-1082
MSEDCL DEMAND MET	24380	23424	22556	19898
Load Shedding	0	0	0	0
MSEDCL DEMAND	24380	23424	22556	19898
TPCL GENERATION	830	871	1031	521
AEML GENERATION	420	464	491	301
MUMBAI DEMAND	3062	3086	2941	1904
OTHER DISCOM DEMAND	463	485	496	368
STATE DEMAND MET	27905	26995	25993	22170
STATE DEMAND	27905	26995	25993	22170
Frequency (Hz)	50.00	49.99	49.98	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 18.02 Hrs	49.82 Hz at 06.26 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Feb/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.18	121.25	190	150
Unit 8	14.49	408.94	654	445
Unit 9	12.04	366.32	527	470
Unit 10	13.15	378.27	605	514
Total	43.86	1274.78		
Bhusawal				
Unit 3	3.43	97.06	180	115
Unit 4	9.69	204.74	480	290
Unit 5	10.02	256.98	495	295
Total	23.14	558.77		
Parli				
Unit 6	3.83	115.04	230	139
Unit 7	3.77	113.38	209	144
Unit 8	3.94	114.47	250	140
Total	11.54	342.89		
Chandrapur				
Unit 3	3.30	92.30	150	123
Unit 4	3.46	87.46	165	119
Unit 5	8.59	235.81	430	275
Unit 6	8.28	112.46	440	280
Unit 7	8.57	212.53	453	290
Unit 8	9.27	266.03	422	284
Unit 9	10.73	302.78	493	295
Total	52.20	1309.37		
Paras				
Unit 3	5.68	153.99	251	221
Unit 4	6.04	161.32	258	235
Total	11.72	315.31		
Khaparkheda				
Unit 1	4.00	109.36	185	140
Unit 2	4.56	62.26	198	176
Unit 3	2.46	98.19	176	0
Unit 4	4.49	106.19	196	177
Unit 5	11.91	312.35	500	490
Total	27.43	688.35		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.94	101.07	187	122
Unit 5	3.44	78.42	158	115
Total	7.38	179.49		
Uran				
All Units	6.88	190.82	298	270
Total	6.88	190.82		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	2.25	22	0
Total	0.04	2.25		
Koyna				
Stage 1-2	1.70	46.84	210	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	17.02	0	0
Stage 3	0.63	14.99	160	0
Total	2.33	78.85		
Hydro				
KDPH	0.86	24.19	36	36
VTRNA	0.59	6.47	61	0
TILLARI	0.31	7.96	64	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.64	71.70	164	84
GHATGHAR	0.00	12.78	0	0
Total	4.40	123.10		
Wind				
Total	7.10	253.30	0	0
Total	7.10	253.30		
CPP				
APML(Mus)	60.93	1797.95	0	0
JSWEL(Mus)	28.05	706.85	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.32	880.49	0	0
SWPGPL-Mus	12.31	345.04	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.56	140.87	267	158
Other(Mus)	38.18	1109.08	0	0
JPL	4.66	77.38	210	185
Total	180.01	5057.67		
SOLAR				
Total	15.78	446.38	0	0
Total	15.78	446.38		
Tata				
Trombay 5	7.38	216.67	376	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.19	56.11	107	60
Trombay 7B	1.43	37.00	65	50
TATA Hydro	3.84	91.57	384	12
Trombay 8	3.65	40.70	196	132
Total	18.50	442.05		
AEML				
DTPS U-1&2	10.00	271.59	496	298
Total	10.00	271.59		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	177.28	4668.96	MSPGCL Total	190.93	5063.97
			MSPGCL Thml+Gas	184.16	4859.78	Koyna 1,2 & 4 Total	1.70	63.86
			MSPGCL Hydro	6.77	204.20	State Total	422.31	11534.96

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Feb/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6750	163	297	7210	521	7322	0	0	6957	6731	-1241	20142	0	0	20142	2140	401	22683	49.96
2	6744	163	297	7204	547	7331	0	0	6845	6632	-1141	20203	0	0	20203	2001	370	22574	49.97
3	6779	160	297	7236	498	7328	0	0	6764	6286	-1082	19898	0	0	19898	1904	368	22170	49.99
4	6637	183	296	7116	447	7248	0	0	6660	6664	-1006	20130	0	0	20130	1829	339	22298	50.02
5	6875	163	296	7334	427	7341	0	0	6752	6670	-996	20413	0	0	20413	1821	363	22597	49.96
6	7513	173	296	7982	357	7514	0	0	6794	7020	-1011	21464	0	0	21464	1932	398	23794	49.95
7	7958	265	298	8521	393	7901	0	3	6970	7053	-1063	22397	0	0	22397	2118	411	24926	49.99
8	8092	412	297	8801	302	8166	0	231	6952	7018	-994	23066	0	0	23066	2325	458	25849	50.07
9	7813	468	288	8569	174	7799	0	843	7842	7869	-1267	23524	0	18	23524	2616	463	26603	50.05
10	7738	448	290	8476	170	7422	0	1465	8531	8216	-1494	23795	0	25	23795	2875	460	27130	50.01
11	7651	215	282	8148	242	7296	0	2005	9280	8964	-1812	24380	0	103	24380	3062	463	27905	50.00
12	7084	308	275	7667	174	7117	0	2286	9110	9058	-1880	23949	0	138	23949	3140	473	27562	49.97
13	6693	423	273	7389	138	7087	0	2370	8739	8779	-1899	23384	0	52	23384	3120	480	26984	49.99
14	6616	320	274	7210	104	6812	0	2194	8695	8741	-1817	22778	0	31	22778	2998	466	26242	50.06
15	7081	279	272	7632	94	7162	0	1908	8655	8866	-1806	23386	0	19	23386	3047	470	26903	50.02
16	7553	289	270	8112	95	7415	0	1339	8838	8699	-1751	23424	0	17	23424	3086	485	26995	49.99
17	7773	244	278	8295	110	7802	0	827	8613	7970	-1700	22785	0	2	22785	3065	519	26369	50.02
18	7927	241	278	8446	197	7817	0	301	7926	7190	-1635	21801	0	0	21801	3012	515	25328	50.03
19	7887	336	282	8505	347	7770	0	6	7351	7002	-1530	21586	0	0	21586	2973	514	25073	49.97
20	8084	552	285	8921	438	8171	0	0	7221	6941	-1419	22556	0	0	22556	2941	496	25993	49.98
21	7420	305	288	8013	416	7658	0	0	7042	6967	-1379	21189	0	0	21189	2776	486	24451	50.00
22	7106	307	292	7705	330	7381	0	0	6906	6892	-1311	20506	0	0	20506	2628	491	23625	50.02
23	7783	177	292	8252	271	7626	0	0	6598	6280	-1307	20649	0	0	20649	2512	473	23634	49.98
24	7719	177	292	8188	304	7522	0	0	6612	6289	-1295	20556	0	0	20556	2416	452	23424	49.99
MUs	177.28	6.77	6.88	190.93	7.10	180.01	0.00	15.78	182.65	178.80	-33.84	527.96	0.00	0.40	527.96	62.34	10.81	601.11	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

- 1) 3phase AG DLS due to overloading of 400kV Chakan-Talegaon line.
- 2) ELR Carried out due to TF overload at 220kV Kopargaon s/s & Due to 132kV BBLR-Rahuri line over load.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Feb/2024

Position as on 6.30 Hrs of 29/Feb/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	28/03/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	08/03/2024
MSPGCL	Nasik Unit 3	210	18/01/2024	16:56		Continued.	Tolling (Converted to Planned outage on dt 02.02.2024 for boiler & allied work.)	13/03/2024
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Uran Unit 6	108	16/01/2024	20:29		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Khaparkheda Unit 3	210	26/02/2024	00:48	28/02/2024	08:27	Suspected Boiler Tube Leakage	28/02/2024
MSPGCL	Ghatghar Unit-1	125	28/02/2024	22:00		Continued.	GM Link Fault	
Total Capacity MSPGCL		563						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		883						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 29/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 418 OF IEPL @ KORADI-2	IntraState	29/09/2023	10:42			PO	1)Diagnostic testing of Circuit breaker 418-Q52. 2) Routine Maintenance work of Bay 418.
400 KV LINE Outages/Trippings							
AKOLA - WARDHA(PG) CKT - 1	InterState	28/02/2024	07:45	28/02/2024	21:57	HT	For emergency line maintenance work.
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
PADGHE - KALWA CKT - 1	IntraState	11/02/2024	00:35			PO	For tapping of 400kV Kalwa- Padgha-1 line (Loc no. 1113) with 400kV Kalwa-Kharghar line Loc no. 167 (Tapping work will be finished by 11.06.2024 @ 06:00 Hrs) using ERS thereby forming temporary 400kV Kalwa-Kharghar -Padgha Tap line and carrying out replacement of existing conductor the HTLS conductor of 400kV Kalwa-Padgha-1 line 1148 (Airoli) to 1114 (Shilphata)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42			HT	H/T for controlling loading of 400kV Talegaon-Chakan
DABHOL - NEW KOYNA CKT - 2	IntraState	28/02/2024	08:49	28/02/2024	23:22	PO	Earthwire replacement Work
BABHALESHWAR - PADGHE CKT - 2	IntraState	28/02/2024	23:40	29/02/2024	02:25	HT	Emergency outage for Hardware tightening work.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	28/02/2024	08:37	28/02/2024	18:41	PO	HV Insulation Coating of IPS Tube & BPI erected for RRS Scheme
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	28/02/2024	08:45	28/02/2024	18:30	PO	HV Insulation Coating of IPS Tube & BPI erected for RRS Scheme
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	28/02/2024	12:12	28/02/2024	16:16	PO	For Diagnostic testing work.
400 KV BR Outages/Trippings							
400KV 125MVAR BUS REACTOR @ KARAD	IntraState	06/01/2024	11:55			PO	Existing 125 MVAR Reactor CB Have mechanical problem and need to replace
220 KV MAINBAY Outages/Trippings							
220KV AMALNER - JPL CKT 1	IntraState	28/02/2024	11:58	28/02/2024	23:57	PO	To carry out the remaining Excavation work for civil foundation.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	01/02/2024	10:07			PO	Outage required for PLCC, CVT & WT Foundation, Erection work at 220kV Navsari SS.
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
AMBAZARI - KARANJA CKT	IntraState	28/02/2024	08:40	28/02/2024	16:42	PO	4 Nature of work to be carried out stringing work.
NERLE- POPHALI	IntraState	28/02/2024	09:16	28/02/2024	17:30	PO	Back up relay commissioning work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 29/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HALKARNI - TILARI LINE	IntraState	28/02/2024	10:00	28/02/2024	10:35	T	Line tripped on distance protection.
TBC @ SOUTH SOLAPUR	IntraState	28/02/2024	10:00	28/02/2024	11:35	PO	Quarterly Maintenance
BHIRA - KARANJADE 8	IntraState	28/02/2024	10:05	28/02/2024	14:56	PO	Closer inspection
PADGHE - WADA	IntraState	28/02/2024	11:11	28/02/2024	20:18	PO	Retrofitting of Distance & Backup protection relay
TATA BORIVLI MSETCL BORIVLI - 4	IntraState	28/02/2024	11:26			PO	220 kV Tata (Borivali) - 4 Circuit Breaker Mechanism overhauling work to be carried by M/s. TATA.
220 KV CHALISGAON - DHULE CKT	IntraState	28/02/2024	11:28	28/02/2024	18:42	HT	CT oil Leakage.
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	28/02/2024	11:50	28/02/2024	19:25	PO	Replacement of damaged conductor & Conductor restringing Work
OSMANABAD - SOLAPUR (BALE)	IntraState	28/02/2024	15:05	28/02/2024	19:15	PO	Work at Bale end.
OSMANABAD - SOLAPUR (BALE)	IntraState	28/02/2024	15:05	28/02/2024	19:15	PO	1. Cold washing of Insulator string from Loc no. 1 to 47. 2. To replace flashover string at Loc no. 20 B ph.
VITA - MIRAJ	IntraState	28/02/2024	16:10	28/02/2024	20:14	PO	Fixing of Turbine Ventilator type Bird Guard
KARAD - DASGAON	IntraState	28/02/2024	18:03			PO	For Erection & Stringing of In-line narrow base multi circuit tower (Loc No.150,151 & 152) of New 220kV Karad-Koyana line
SAHARA-URSE	IntraState	28/02/2024	23:31	29/02/2024	05:14	HT	H/T for outage of 220kV Urse-Talegaon Ambi ckt-2
URSE - TALEGAON (AMBI) CKT 2	IntraState	28/02/2024	23:50	29/02/2024	05:04	PO	Replacement of PID faulty string at Loc no. 20 & 30.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220 / 110 / 33kV 250MVA ICT 2 @ BORIVALI (TATA)	IntraState	28/02/2024	09:52			PO	Project work 33kV Cable Replacement
220/33 KV 100 MVA PTR 2	IntraState	28/02/2024	10:05	28/02/2024	12:00	PO	For measurement of tn delta of HV R-phase CT.
220/132 KV 200MVA ICT 3@ BALE(SOLAPUR)	IntraState	28/02/2024	10:22	28/02/2024	16:23	PO	Quarterly Maintenance
220/132-110/11KV 200MVA VID ICT 1 @ MIRAJ	IntraState	28/02/2024	10:28	28/02/2024	12:24	PO	Chemical Washing of Insulator Strings.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	28/02/2024	11:01	28/02/2024	15:01	PO	Measurment of IR Values of LA
220/33 KV 100 MVA PTR 3	IntraState	28/02/2024	12:24	28/02/2024	15:00	PO	For measurement of tan delta of HV B-phase ct.
220/132 KV 100 MVA ICT 2 @ BELWANDI	IntraState	28/02/2024	15:08	28/02/2024	16:14	PO	Measurement of IR Values of LA
220 KV BUSBAR Outages/Trippings							
220KV BUS 1 @ TARAPUR-220 KV	InterState	23/02/2024	11:41			PO	Preventive Maintenance checks & SF6 gas leak rectification job
220KV BUS 2 @ TARAPUR-220 KV	InterState	23/02/2024	11:41			PO	Preventive Maintenance checks & SF6 gas leak rectification job
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALYAN KALWA SALSETTE 1	IntraState	06/02/2024	19:55			PO	PROJECT WORK-Conductor replacement
TROMBAY PAREL 3 / CARNAC 2	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section
TROMBAY CARNAC 1 / 3	IntraState	17/02/2024	10:35			PO	Project work for replacement of cable section

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Feb/2024

Statement-VII

Position as on 6.30 Hrs of 29/Feb/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KHOPOLI - BHIVPURI CKT - 2	IntraState	29/02/2024	07:39			PO	1. Tower cable section 110 KV porcelain type LA replacement by Polymeric type LA

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage