

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Mar/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	181.701	4509.836	1) Gujrat	-4.357	40.441
2) Hydro	33.015	326.949	2) Madhya Pradesh	10.926	177.755
3) Gas	2.898	102.830	3) Chattisgarh	3.030	124.470
Total MSPGCL	217.614	4939.615	4) Maharashtra	170.828	4626.940
B) 1) APLM	57.974	1885.646	5) Goa (Amona)	-1.205	-42.364
2) JSWEL	20.554	659.101	Total	179.222	4927.242
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.942	866.365
4) RPL(AMT)	26.442	840.329	b) Mumbai Drawl	32.352	1001.512
5) SWPGPL	9.238	274.352	c) MSEDCL Bilateral *	95.465	2424.454
6) Other IPP	26.214	1029.059	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	27.942	866.365
C) 1) TPCL Thermal	12.056	297.776	Include PX	0.000	0.000
2) TPCL Hydro	5.084	96.237	Standby	0.000	0.000
3) TPCL Gas	2.725	73.572	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.364	293.004	1) MSEDCL	520.595	14001.568
D) STATE			2) Mumbai Discoms	63.581	1762.101
1) Thermal	345.543	9789.103	3) Other Discoms	10.303	283.954
(A1+C1+C4+(B1-B6))			TOTAL STATE	594.479	16047.623
2) Hydro	38.099	423.186			
3) Gas	5.623	176.402			
4) Wind	8.769	334.447			
6) SOLAR	17.223	397.243			
TOTAL STATE	415.257	11120.381			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	7554	7500	7331	7926
MSPGCL Hydro	897	522	2202	884
MSPGCL Gas	113	114	201	113
MSPGCL Total Generation	8564	8136	9734	8923
Central Sector Receipt	9465	9430	6732	6383
WIND	76	96	367	578
CPP / IPP Thermal	5694	5691	6075	5743
CPP / IPP Gas	0	0	0	0
SOLAR	2218	2279	0	0
Exchange with Mumbai	-1923	-1834	-1125	-942
MSEDCL DEMAND MET	23626	23335	21335	20335
Load Shedding	0	0	0	0
MSEDCL DEMAND	23626	23335	21335	20335
TPCL GENERATION	851	831	1247	508
AEML GENERATION	485	488	499	498
MUMBAI DEMAND	3259	3153	2871	1948
OTHER DISCOM DEMAND	468	463	448	351
STATE DEMAND MET	27353	26951	24654	22633
STATE DEMAND	27353	26951	24654	22633
Frequency (Hz)	49.87	49.99	49.99	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.32 Hz at 18.02 Hrs	49.72 Hz at 10.46 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Mar/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.73	127.74	205	190
Unit 8	13.10	271.14	554	510
Unit 9	13.71	379.75	615	502
Unit 10	13.50	255.80	598	518
Total	45.04	1034.43		
Bhusawal				
Unit 3	3.76	90.36	170	135
Unit 4	11.26	268.36	495	380
Unit 5	11.50	279.60	495	440
Total	26.51	638.34		
Parli				
Unit 6	5.78	126.86	250	184
Unit 7	4.41	123.21	248	126
Unit 8	4.40	97.80	196	169
Total	14.59	347.86		
Chandrapur				
Unit 3	3.02	95.16	140	100
Unit 4	3.43	89.62	145	138
Unit 5	9.69	137.45	415	390
Unit 6	1.36	233.05	340	0
Unit 7	10.41	234.70	442	424
Unit 8	11.71	299.56	499	479
Unit 9	11.72	268.24	500	475
Total	51.34	1357.79		
Paras				
Unit 3	5.40	131.56	239	211
Unit 4	5.53	146.63	239	194
Total	10.93	278.20		
Khaparkheda				
Unit 1	2.72	74.42	130	105
Unit 2	2.68	82.29	133	88
Unit 3	4.29	101.22	186	174
Unit 4	4.40	108.06	191	174
Unit 5	10.89	292.86	485	400
Total	24.98	658.84		
Nasik				
Unit 3	4.19	24.19	185	158
Unit 4	4.13	93.02	181	152
Unit 5	0.00	77.17	0	0
Total	8.32	194.38		
Uran				
All Units	2.90	102.83	201	110
Total	2.90	102.83		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	3.58	46	0
Total	0.19	3.58		
Koyna				
Stage 1-2	7.72	75.90	560	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	15.61	80.38	1010	83
Stage 3	4.78	33.75	320	0
Total	28.11	190.04		
Hydro				
KDPH	0.86	23.74	36	36
VTRNA	1.18	30.88	60	0
TILLARI	0.46	9.16	58	0
BHIRA T.R.	0.30	4.29	80	0
SMLHY_PTN	1.89	65.26	82	76
GHATGHAR	0.00	0.00	0	0
Total	4.71	133.33		
Wind				
Total	8.77	334.45	0	0
Total	8.77	334.45		
CPP				
APML(Mus)	57.97	1885.65	0	0
JSWEL(Mus)	20.55	659.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	26.44	840.33	0	0
SWPGPL-Mus	9.24	274.35	0	0
Dhariwal	6.14	165.99	279	218
IEPL	5.23	139.41	269	196
Other(Mus)	14.85	723.65	0	0
Total	140.42	4688.49		
SOLAR				
Total	17.22	397.24	0	0
Total	17.22	397.24		
Tata				
Trombay 5	7.79	197.56	452	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.58	42.70	108	44
Trombay 7B	1.15	30.87	65	39
TATA Hydro	5.08	96.24	403	27
Trombay 8	4.26	100.22	223	131
Total	19.86	467.58		
AEML				
DTPS U-1&2	11.36	293.00	499	312
Total	11.36	293.00		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	181.70	4509.84	MSPGCL Total	217.61	4939.62
			MSPGCL Thml+Gas	184.60	4612.67	Koyna 1,2 & 4 Total	23.34	156.28
			MSPGCL Hydro	33.02	326.95	State Total	415.26	11120.38

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Mar/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	7986	600	112	8698	592	5933	0	0	6502	6632	-1109	20357	0	0	20357	2289	388	23035	49.97
2	8016	652	112	8780	561	5784	0	0	6726	6794	-1087	20460	0	0	20460	2135	372	22967	49.98
3	8006	499	111	8616	560	5771	0	0	6821	6841	-1000	20429	0	0	20429	2016	359	22804	49.97
4	7926	884	113	8923	578	5743	0	0	6653	6383	-942	20335	0	0	20335	1948	351	22633	49.93
5	7768	1557	111	9436	554	5821	0	0	6532	6623	-859	21217	0	0	21217	1994	358	23569	49.97
6	7683	1886	112	9681	556	5896	0	0	6506	6644	-833	21558	0	0	21558	2156	386	24100	49.93
7	7660	2151	112	9923	493	5837	0	42	6912	7303	-835	22365	0	0	22365	2232	398	24995	49.95
8	7586	2005	112	9703	343	5915	0	489	7218	7425	-1041	22393	0	0	22393	2364	442	25198	50.03
9	7606	1253	116	8975	237	5755	0	1168	8220	8353	-1457	22563	0	0	22563	2654	468	25685	50.01
10	7567	492	113	8172	175	5730	0	1704	8894	9057	-1713	22644	0	0	22644	2950	481	26075	49.98
11	7476	860	114	8450	82	5749	0	2143	9485	9200	-1791	23363	0	0	23363	3124	469	26957	49.92
12	7554	897	113	8564	76	5694	0	2218	9629	9465	-1923	23626	0	0	23626	3259	468	27353	49.87
13	7500	522	114	8136	96	5691	0	2279	9444	9430	-1834	23335	0	0	23335	3153	463	26951	49.99
14	7478	492	114	8084	150	5682	0	2191	9158	9186	-1981	22863	0	0	22863	3018	449	26330	50.05
15	7454	806	113	8373	190	5638	0	2001	9210	9116	-2055	22814	0	0	22814	3033	450	26296	49.99
16	7423	1458	112	8993	249	5677	0	1586	8857	8573	-2004	22621	0	0	22621	3057	453	26131	49.98
17	7394	1883	112	9389	283	5757	0	995	7958	8140	-1796	22310	0	0	22310	3050	459	25818	49.97
18	7377	2133	114	9624	370	5851	0	386	7200	7213	-1466	21516	0	0	21516	2995	462	24973	50.02
19	7394	1999	134	9527	366	5951	0	21	6336	6274	-1155	20518	0	0	20518	2892	466	23876	50.01
20	7331	2202	201	9734	367	6075	0	0	6252	6732	-1125	21335	0	0	21335	2871	448	24654	49.99
21	7415	2105	196	9716	363	6080	0	0	5815	6118	-1061	20763	0	0	20763	2766	453	23982	49.99
22	7462	1996	115	9573	574	6123	0	0	5837	5687	-1117	20395	0	0	20395	2638	445	23478	49.98
23	7351	1827	110	9288	515	6149	0	0	5819	5860	-1091	20291	0	0	20291	2526	430	23247	49.92
24	7288	1856	112	9256	439	6118	0	0	5846	6173	-1077	20523	0	0	20523	2461	386	23370	49.96
MUs	181.70	33.01	2.90	217.61	8.77	140.42	0.00	17.22	177.83	179.22	-32.35	520.59	0.00	0.00	520.59	63.58	10.30	594.48	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Mar/2023

Position as on 6.30 Hrs of 29/Mar/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U1	300	19/03/2023	17:29		Continued.	Zero Schedule	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/04/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Uran Unit 6	108	18/03/2023	12:44	28/03/2023	18:40	ZERO SCHEDULE.	
IPP	SWPGPL U-3	135	22/03/2023	21:54	29/03/2023	12:12	ESP Backfilter replacement work	
MSPGCL	Nasik Unit 5	210	23/03/2023	03:10	29/03/2023	17:50	Withdrawn due to changer from Unit3 to 5	29/03/2023
IPP	RPL(AMT) U-2	270	26/03/2023	10:34	28/03/2023	18:53	bottom ash evacuation problem	
IPP	Adani U-4	660	26/03/2023	15:59		Continued.	Due to turbine left hand side MS drain bonnet leakage.	31/03/2023
MSPGCL	Chandrapur Unit 6	500	28/03/2023	04:18		Continued.	Boiler Tube Leakage	31/03/2023
MSPGCL	Uran Unit 6	108	28/03/2023	21:03	29/03/2023	04:55	Zero Schedule.	
MSPGCL	Nasik Unit 4	210	29/03/2023	04:36		Continued.	Boiler Tube Leakage	03/04/2023
MSPGCL	Koradi Unit 6	210	29/03/2023	07:35		Continued.	DUE TO FLAHOVER IN SLIP RINGS.	30/03/2023
MSPGCL	Uran Unit 6	108	29/03/2023	08:33		Continued.	Zero Schedule	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 28/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Tripping							
TIRODA - KORADI 3 CKT - 2	IntraState	28/03/2023	17:57	28/03/2023	21:57	EO	For attending hotspot on metering CT of 765kv Tiroda-Koradi-III line-2
500 KV TBC Outages/Tripping							
POLE-1 BASE AC FILTER Z1-Z2(200MVAR) @ CHANDRAPUR HVDC	IntraState	29/03/2023	11:05	29/03/2023	13:35	EO	Pole 1 Z1-Z2 Filter for replacement of capacitor due to persisting Unbalance Protection level 2 Alarm for same .
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	29/03/2023	22:24		Continued.	EO	1) To release the trapped gases of Pole-2 B-ph Converter transformer & Replacement of 1 nos cooling fan system 2) MCB replacement of cooling fan system of converter transformer
400 KV TIEBAY Outages/Tripping							
220 KV TBC	IntraState	29/03/2023	08:11	29/03/2023	17:10	PO	1) TAN DELTA MEASUREMENT OF CT AT BAY 207. 2) CRM,TIMING& IR MEASUREMENT OF CB AT BAY 207 3) ROUTINE BAY MAINTENANCE WORK
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
JAIGAD - NEW KOYNA CKT - 2	IntraState	27/03/2023	10:18		Continued.	PO	Circuit breaker Overhauling work by Shifting on TBC
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	28/03/2023	14:13	28/03/2023	15:56	EO	To attend alignment of 29C Isolator
400 KV ICT Outages/Tripping							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 105 MVA SPARE ICT @ DHULE	IntraState	27/03/2023	10:24	29/03/2023	17:39	PO	For diagnostic testing work and also REF relay replacement work
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	28/03/2023	09:08	28/03/2023	14:56	PO	Tan Delta and Relay testing work
400/132 KV 200 MVA ICT - 1 @ KHADKA	IntraState	28/03/2023	09:08	28/03/2023	14:56	PO	For CT Capacitance and Tan Delta Testing Work and relay testing work.
400/220/33 KV 500MVA ICT - 1 @ KHAPARKHEDA	IntraState	28/03/2023	09:25	28/03/2023	18:58	PO	Application of HV insulation coating on tertiary side equipments by external agency.
400/220 KV 315MVA ICT - 1 @ KARAD	IntraState	28/03/2023	16:07	28/03/2023	19:29	EO	attending hot spot at 400 kv R ph CT Top plate cover nutbolts Temp -569 degree
400 KV BR Outages/Tripping							
BUS REACTOR (125 MVA) @ LAMBOTI	IntraState	28/03/2023	11:20	28/03/2023	14:45	PO	Testing healthiness of CTR Make NIFPS of 400kv Bus Reactor
220 KV MAINBAY Outages/Tripping							
220 KV MAIN BUS - 1 @ NEW KOYNA	IntraState	29/03/2023	10:41		Continued.	EO	Making Bus bar out off service - For attending problem interposing CT & Resistance of Bay No.3 (Lote) As relay engineer came at site on 29.03.2023

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV MAIN BUS - 2 @ NEW KOYNA	IntraState	29/03/2023	10:41		Continued.	EO	Making Bus bar out off service - For attending problem interposing CT & Resistance of Bay No.3 (Lote) As relay engineer came at site on 29.03.2023
220 KV MAIN BUS - I	IntraState	29/03/2023	10:55	29/03/2023	15:05	PO	JUMPERING BETWEEN EXISTING 220 KV MAIN BUS I TO EXTENDED AND NEWLY ERECTED 220KV MAIN BUS I
220 KV MAIN BUS - II	IntraState	29/03/2023	15:35	29/03/2023	19:05	PO	UMPERING BETWEEN EXISTING 220 KV MAIN BUS I TO EXTENDED AND NEWLY ERECTED 220 KV MAIN BUS I
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AEML BORIVALI - TPC BORIVALI LINE	IntraState	20/03/2023	00:14			T	Tripped due to cable joint failure.
GIS BUS SECTION - 1 @ BORIVALI (TATA)	IntraState	27/03/2023	11:20	28/03/2023	17:27	PO	Project related activity:- Docking of new Bus VT-3 with Bus 1
KHAPARKHEDA-AMBAZARI-I	IntraState	28/03/2023	07:02	28/03/2023	17:58	PO	Restraining of Loose Span
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	28/03/2023	09:44	28/03/2023	20:03	HT	Load management
OLD GCR PARLI - GIRWALI CKT - III	IntraState	28/03/2023	10:03	28/03/2023	16:15	PO	CB and CT Testing work
URAN - SEZ JNPT	IntraState	28/03/2023	15:30	28/03/2023	18:00	EO	For own Breaker testing work. B-phase current not showing while on own breaker (line in service thorough TBC)
KANDALGAON - KOYNA (POPHALI)	IntraState	28/03/2023	18:00	28/03/2023	20:10	T	TRIPPED ON DISTANCE PROTECTION
LOTEPARSHURAM- DASTURI LINE	IntraState	28/03/2023	18:01	28/03/2023	19:30	T	TRIPPED ON DISTANCE PROTECTION
220 KV DHULE(400 KV) - AMALNER	IntraState	28/03/2023	18:26	28/03/2023	19:56	EO	To attend Hot Spot
BHUGAON - WARDHA (PG)	IntraState	29/03/2023	05:33	29/03/2023	09:42	HT	H/T TO CONTROL OD 1000MW. H/T AT WARDHA PG END ONLY
BHUGAON - WARDHA (PG)	IntraState	29/03/2023	05:33	29/03/2023	09:42	HT	HT for Overdrawal
MAIN BUS - 1 @ BHIRA	IntraState	29/03/2023	06:41	29/03/2023	14:11	PO	R/M & Protection testing
GIS BUS SECTION -2 @ BORIVALI (TATA)	IntraState	29/03/2023	07:49		Continued.	PO	Docking of new Bus VT-4 with Bus 2B
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	29/03/2023	08:20	29/03/2023	21:08	HT	Load management
AMBAZARI - KARANJA CKT	IntraState	29/03/2023	09:07	29/03/2023	18:21	PO	FOR RESTRINGING OF LOOSE SPAN FROM LOC NO. 03 TO 07.
220KV TULJAPUR-BALE CKT	IntraState	29/03/2023	09:57	29/03/2023	17:50	PO	Outage is required for Testing & Commissioning of 220kV HYBRID PASS
OSMANABAD - SOLAPUR (BALE)	IntraState	29/03/2023	09:58	29/03/2023	17:48	PO	Outage is required for Testing & Commissioning of 220kV HYBRID PASS
LAMBOTI - SOLAPUR 2(BALE) CKT - 1	IntraState	29/03/2023	10:01	29/03/2023	17:26	PO	Outage is required for Testing & Commissioning of 220kV HYBRID PASS

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 28/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI -SOLAPUR 2(BALE) CKT-2	IntraState	29/03/2023	10:02	29/03/2023	17:31	PO	Outage is required for Testing & Commissioning of 220kV HYBRID PASS
MAIN BUS @ BALE (SOLAPUR 2)	IntraState	29/03/2023	10:02	29/03/2023	17:23	PO	Outage is required for Testing & Commissioning of 220kV HYBRID PASS
SAKI (AEML) - SAKI (TATA) CKT - 2	IntraState	29/03/2023	10:11	29/03/2023	16:30	PO	Preventive Maintenance of Bay Equipment.
132KV GEORAI(220KV)-GEORAI(132KV) CKT	IntraState	29/03/2023	10:20	29/03/2023	18:07	PO	132/33 KV, 50MVA, T/F & 2 (BBL) & 132KV, BUS SECTION 2, ALONG WITH 132KV
220 KV PATODA - MANJARSUMBHA	IntraState	29/03/2023	11:41	29/03/2023	15:43	PO	RELAY TESTING, TAN DELTA TESTING AND ROUTING MAINTENANCE
KANHAN-ULTRATECH CEMENT	IntraState	29/03/2023	11:56	29/03/2023	12:55	EO	ATTENDING HOT SPOT
MURUD - TULJAPUR	IntraState	29/03/2023	12:07	29/03/2023	12:39	T	D/P,Z1BPH,3KA,13.6KM
UMRED-KANHAN 2	IntraState	29/03/2023	14:18	29/03/2023	14:51	PO	FOR REMOVING AUXILLARY ISOLATOR YPH BLADE
LAMBOTI - KARKAMB	IntraState	29/03/2023	15:25	29/03/2023	18:17	EO	Outage is required for Attending hotspot on '220 KV Lamboti bay: line to CT jump of Y-ph (line side)' of 88°C by replacement of jump.
TROMBAY - KALWA	IntraState	29/03/2023	19:11	29/03/2023	19:41	EO	For safety purpose to remove old Broken OPGW between Loc. No. 23 to 24.
TROMBAY - MULUND	IntraState	29/03/2023	19:16	29/03/2023	19:42	EO	For safety purpose to remove old Broken OPGW between Loc. No. 23 to 24.
220 KV ICT Outages/Tripping							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/22 KV 25 MVA PTR 2 @ NAGOTHANE	IntraState	27/03/2023	09:40			PO	CB replacement work
220/132KV 100MVA PTR 2 @ KHAREPATAN	IntraState	28/03/2023	09:07	28/03/2023	13:49	PO	For attending oil leakage of Y PH HV side CT of ICT
220/132 KV 100 MVA ICT 3 @ LONAND	IntraState	28/03/2023	09:40	28/03/2023	12:22	PO	Diagnostic Testing Work
220/132 KV 200 MVA ICT 4	IntraState	28/03/2023	10:25	28/03/2023	18:25	PO	Replacement of all three OSR relays due to oil leakage
220/132KV 200MVA ICT 4 @ EKLAHARE (OCR)	IntraState	28/03/2023	13:16	28/03/2023	14:21	EO	Work of attending red hot at LV side bus isolator jaw.
220/132-110 KV 100 MVA ICT 2	IntraState	29/03/2023	10:29	29/03/2023	18:28	PO	Oil leakage attending work by Power seal gasket technology.
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	29/03/2023	12:20	29/03/2023	13:30	PO	Replacement of Y-Ph LA due to High LCM Value. Attending hot spot on Y-Ph LV CT P2 side (160 Degrees)
132 KV LINE Outages/Tripping							
SOLAPUR 2(BALE)-NALDURG	IntraState	29/03/2023	10:28	29/03/2023	10:54	T	BACK PROTECTION OPERATED DUE TO TRIPPING AT BALE END
MAUDA - KANHAN CKT	IntraState	29/03/2023	12:28	29/03/2023	20:20	T	D/P,Y-BPH,6.7KA,6.74KA,6.5KM
132 KV ELICHPUR - HINGOLI CKT	IntraState	29/03/2023	13:31	29/03/2023	16:25	PO	FOR BYPASSING LA
DEULGAON MAHI-DUSARBID	IntraState	29/03/2023	13:55	29/03/2023	16:00	PO	OUTAGE PROPOSED FOR MEASUREMENT OF 132KV PT-C & TAN DELTA AND IR. & ROUTINE MAINTENANCE WORK
110 KV LINE Outages/Tripping							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Mar/2023

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
SALSETTE VIKHROLI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	29/03/2023	18:07	29/03/2023	18:49	EO	Preparatory work at Tower No. 26N2 for Road Xing at Uran Phata by KVTCL

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage