

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Mar/2024 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	180.294	4554.390	1) Gujrat	3.417	114.379
2) Hydro	16.505	252.796	2) Madhya Pradesh	14.216	343.484
3) Gas	6.955	190.501	3) Chattisgarh	4.440	132.220
Total MSPGCL	203.754	4997.687	4) Maharashtra	199.606	5040.930
B) 1) APLM	73.129	1790.196	5) Goa (Amona)	-2.843	-57.308
2) JSWEL	21.064	713.320	Total	218.836	5573.705
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.643	856.659
4) RPL(AMT)	25.720	795.330	b) Mumbai Drawl	36.694	955.576
5) SWPGPL	11.326	331.861	c) MSEDCL Bilateral *	109.470	2776.044
6) Other IPP	31.372	1128.740	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.643	856.659
C) 1) TPCL Thermal	12.782	307.914	Include PX	0.000	0.000
2) TPCL Hydro	6.076	121.511	Standby	0.000	0.000
3) TPCL Gas	4.131	101.600	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.767	258.879	1) MSEDCL	561.667	14924.536
D) STATE			2) Mumbai Discoms	71.450	1745.475
1) Thermal	367.454	9880.630	3) Other Discoms	10.736	302.057
(A1+C1+C4+(B1-B6))			TOTAL STATE	643.853	16972.068
2) Hydro	22.581	374.307			
3) Gas	11.086	292.101			
4) Wind	8.125	356.400			
6) SOLAR	15.771	477.727			
TOTAL STATE	425.017	11381.165			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	7225	7666	7421	7980
MSPGCL Hydro	723	380	1298	367
MSPGCL Gas	283	278	290	295
MSPGCL Total Generation	8231	8324	9009	8642
Central Sector Receipt	9995	10282	8921	8212
WIND	286	270	478	336
CPP / IPP Thermal	6505	6807	7033	6830
CPP / IPP Gas	0	0	0	0
SOLAR	2219	1334	0	0
Exchange with Mumbai	-2051	-2085	-1499	-1058
MSEDCL DEMAND MET	24695	24463	23455	22608
Load Shedding	0	0	0	0
MSEDCL DEMAND	24695	24463	23455	22608
TPCL GENERATION	997	921	1215	800
AEML GENERATION	502	502	488	488
MUMBAI DEMAND	3550	3508	3202	2346
OTHER DISCOM DEMAND	490	469	487	354
STATE DEMAND MET	28735	28440	27144	25308
STATE DEMAND	28735	28440	27144	25308
Frequency (Hz)	49.94	50.01	49.93	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.26 Hz at 18:03 Hrs	49.59 Hz at 22:23 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.40	109.46	200	150
Unit 8	14.68	380.21	650	570
Unit 9	14.03	293.10	627	540
Unit 10	13.22	241.44	600	490
Total	46.32	1024.22		
Bhusawal				
Unit 3	3.78	97.02	180	125
Unit 4	8.38	237.82	495	0
Unit 5	11.12	197.10	500	365
Total	23.28	531.93		
Parli				
Unit 6	4.37	114.48	218	145
Unit 7	0.00	105.17	0	0
Unit 8	4.88	96.37	250	146
Total	9.24	316.02		
Chandrapur				
Unit 3	3.46	92.21	157	125
Unit 4	3.86	86.67	173	125
Unit 5	9.35	234.12	430	290
Unit 6	9.19	234.32	450	275
Unit 7	9.53	233.47	452	292
Unit 8	10.04	267.52	425	395
Unit 9	11.45	288.54	491	417
Total	56.90	1436.85		
Paras				
Unit 3	5.35	153.26	242	191
Unit 4	5.82	158.39	252	212
Total	11.18	311.65		
Khaparkheda				
Unit 1	3.88	104.56	170	135
Unit 2	4.55	114.24	202	165
Unit 3	4.13	108.53	178	168
Unit 4	4.53	114.43	196	177
Unit 5	11.48	299.67	480	456
Total	28.56	741.42		
Nasik				
Unit 3	0.82	36.28	174	0
Unit 4	3.99	100.40	179	138
Unit 5	0.00	55.61	0	0
Total	4.82	192.29		
Uran				
All Units	6.96	190.50	297	278
Total	6.96	190.50		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.29	3.13	54	0
Total	0.29	3.13		
Koyna				
Stage 1-2	3.83	54.80	505	45

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.03	41.25	748	0
Stage 3	1.84	21.73	240	0
Total	10.71	117.79		
Hydro				
KDPH	0.86	24.19	36	36
VTRNA	0.79	19.07	60	0
TILLARI	0.50	13.98	65	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.78	72.03	120	111
GHATGHAR	0.85	5.74	125	0
Total	5.80	135.01		
Wind				
Total	8.12	356.40	0	0
Total	8.12	356.40		
CPP				
APML(Mus)	73.13	1790.20	0	0
JSWEL(Mus)	21.06	713.32	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.72	795.33	0	0
SWPGPL-Mus	11.33	331.86	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.21	157.19	267	248
Other(Mus)	20.81	879.98	0	0
JPL	4.35	91.57	215	85
Total	162.61	4759.45		
SOLAR				
Total	15.77	477.73	0	0
Total	15.77	477.73		
Tata				
Trombay 5	8.12	202.71	432	264
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	62.14	108	107
Trombay 7B	1.54	39.46	65	64
TATA Hydro	6.08	121.51	428	116
Trombay 8	4.66	105.21	233	132
Total	22.99	531.02		
AEML				
DTPS U-1&2	11.77	258.88	502	458
Total	11.77	258.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	180.29	4554.39	MSPGCL Total	203.75	4997.69
			MSPGCL Thml+Gas	187.25	4744.89	Koyna 1,2 & 4 Total	8.86	96.05
			MSPGCL Hydro	16.50	252.80	State Total	425.02	11381.16

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7912	327	295	8534	557	6953	0	0	8707	8211	-1381	22472	0	0	22472	2713	402	25587	49.94
2	7964	383	295	8642	453	6889	0	0	8636	8418	-1170	22846	0	0	22846	2516	386	25748	49.99
3	7980	367	295	8642	336	6830	0	0	8623	8212	-1058	22608	0	0	22608	2346	354	25308	49.99
4	7749	350	296	8395	263	6833	0	0	8693	8665	-1047	22769	0	0	22769	2232	340	25341	49.98
5	7915	216	296	8427	247	6846	0	0	8771	8673	-954	22881	0	0	22881	2219	358	25458	50.00
6	7809	392	297	8498	313	6972	0	0	8982	8989	-920	23475	0	0	23475	2311	377	26163	49.98
7	7869	425	297	8591	341	6946	0	24	9399	9106	-964	23633	0	13	23633	2425	411	26469	49.99
8	7719	418	292	8429	277	6853	0	585	9281	9016	-1241	23475	0	59	23475	2574	444	26493	50.07
9	7072	722	295	8089	162	6465	0	966	9410	9271	-1623	22856	0	101	22856	2896	474	26226	50.02
10	7006	1343	290	8639	228	6346	0	1486	9807	9392	-1884	23727	0	161	23727	3212	480	27419	49.99
11	6969	836	289	8094	235	6282	0	1990	10455	10215	-1999	24317	0	228	24317	3443	500	28260	49.96
12	7225	723	283	8231	286	6505	0	2219	10207	9995	-2051	24695	0	33	24695	3550	490	28735	49.94
13	7136	334	278	7748	318	6509	0	2237	10222	9643	-2033	23935	0	8	23935	3538	487	27960	49.96
14	6939	265	279	7483	299	6199	0	2123	10255	10211	-1977	23849	0	6	23849	3434	489	27772	50.00
15	7297	410	284	7991	293	6368	0	1745	10504	10403	-2149	24182	0	50	24182	3472	469	28123	49.96
16	7666	380	278	8324	270	6807	0	1334	10490	10282	-2085	24463	0	95	24463	3508	469	28440	50.01
17	7553	538	284	8375	259	6863	0	742	10474	10506	-1927	24345	0	18	24345	3448	473	28266	49.99
18	7733	452	287	8472	290	6941	0	303	10046	9865	-1864	23521	0	0	23521	3348	486	27355	50.02
19	7791	553	288	8632	341	6966	0	17	9247	8818	-1769	22501	0	7	22501	3315	504	26320	50.03
20	7421	1298	290	9009	478	7033	0	0	9115	8921	-1499	23455	0	0	23455	3202	487	27144	49.93
21	7334	1110	292	8736	473	7029	0	0	8450	8423	-1350	22841	0	0	22841	3066	470	26377	49.98
22	7360	1332	288	8980	466	7053	0	0	7994	8093	-1251	22862	0	0	22862	2947	479	26288	49.93
23	7424	1653	293	9370	458	7057	0	0	8103	7729	-1245	22913	0	0	22913	2878	456	26247	49.78
24	7451	1678	294	9423	482	7066	0	0	8164	7779	-1253	23048	0	0	23048	2857	449	26354	49.94
MUs	180.29	16.51	6.95	203.75	8.13	162.61	0.00	15.77	224.03	218.84	-36.69	561.67	0.00	0.78	561.67	71.45	10.74	643.85	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132 kV BBLR -Rahuri Line Over Load. 2)Due to overloading of 400 kV Chakan-Talegaon line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Mar/2024

Position as on 6.30 Hrs of 29/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/04/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 5	210	19/03/2024	17:40		Continued.	Withdrawn On Tolling.	
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	01/04/2024
MSPGCL	Uran Unit 6	108	12/03/2024	20:15		Continued.	For open cycle No schedule from MSEDCL.	
MSPGCL	Parli Unit 7	250	27/03/2024	05:38		Continued.	Boiler Tube Leakage	30/03/2024
MSPGCL	Nasik Unit 3	210	28/03/2024	05:31		Continued.	Boiler Tube Leakage	31/03/2024
MSPGCL	Bhusawal Unit 4	500	28/03/2024	19:14	29/03/2024	02:32	Station Transformer Tripped.	
Total Capacity MSPGCL		1313						
IPP								
IPP	JSW (J) U1	300	24/03/2024	00:06		Continued.	CW duct leakage.	29/03/2024
IPP	RPL(AMT) U-2	270	27/03/2024	13:35		Continued.	Bottom Ash Evacuation Problem.	30/03/2024
IPP	JPL Unit 1	150	28/03/2024	12:00	28/03/2024	13:38	High Turbine Vibration	
Total Capacity IPP		720						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2353						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Mar/2024

Position as on 6.30 Hrs of 29/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	26/03/2024	10:41			PO	Overhauling of Circuit breaker
400 KV LR Outages/Trippings							
AURANGABAD (WALUJ) - PUNE GIS CKT - 2 L/R @ WALUJ	IntraState	28/03/2024	10:32	28/03/2024	21:22	PO	For LR AMP
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 2	InterState	19/03/2024	12:23	28/03/2024	18:55	PO	Major maintenance of GIS bay no.18
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/02/2024	06:42	28/03/2024	10:23	HT	H/T for controlling loading of 400kV Talegaon-Chakan
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	27/03/2024	19:17	28/03/2024	01:59	PO	flash over disc replacement work at loc 549, broken disc at loc 555
PARLI - KARJAT CKT - 2	IntraState	28/03/2024	08:47	28/03/2024	09:40	T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	28/03/2024	10:32	28/03/2024	21:22	PO	For Taking LR Out & In service
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	28/03/2024	23:52			HT	For load management of Talegaon Chakan line
DEEPNAGAR - THAPTI TANDA	IntraState	29/03/2024	07:11			PO	To carry out maintenance work and attending the defects observed in monkey patrolling
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26			PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/220/33 KV 500MVA ICT - 1 @ LONIKAND 2	IntraState	28/03/2024	06:23	28/03/2024	09:28	PO	For RRS testing trial work
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	28/03/2024	06:26	28/03/2024	10:20	PO	For RRS testing trial work
400/220/33 KV 500 MVA ICT - 1 @ NANDED	IntraState	28/03/2024	12:18	28/03/2024	16:24	PO	Annual bay maintenance & relay testing work
400/220KV 167MVA SPARE ICT @ NANDED (KUMBHARGAON)	IntraState	28/03/2024	12:20	28/03/2024	16:33	PO	Oil leakage problem attending the work
400/220/33 KV 315 MVA ICT - 1 @ PARLI	IntraState	28/03/2024	12:47	28/03/2024	18:09	EO	Charging /Commissioning of new IV side 220kV CGL make CB., 29 D Isolator alignment work.
400/220kv SPARE ICT @ JEJURI	IntraState	28/03/2024	14:46	28/03/2024	16:24	PO	To Attend Remote Closing Issue & for remaining RRS related protection trials.
220 KV MAINBAY Outages/Trippings							
220 KV BUS SECTION - II	IntraState	28/03/2024	09:07	28/03/2024	18:13	PO	Replacement of jumpers of R,Y,B ph and quarterly maintenance work.
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400kV KHARGHAR s/s.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KARAD - WATHAR	IntraState	25/03/2024	11:11			PO	For foundation work of 220kV Narrow base multi ckt tower loc no. 200A of New 220kV Karad-Koyana line
VARKUTI- HIWARWADI	IntraState	25/03/2024	15:07			PO	Old Insulator replacement work by long rod at Loc No 166 to 230
220KV PANDHARKAWDA - WANI CKT I	IntraState	27/03/2024	09:13			HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
220KV PANDHARKAWDA - WANI CKT ii	IntraState	27/03/2024	09:29	29/03/2024	21:10	HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
220KV PANDHARKAWDA - WANI CKT I	IntraState	27/03/2024	21:56	28/03/2024	09:36	HT	W.END--RY IF-2.8 KA IY-2.899 KA ZCOM 48.90 KM.
BORIVALI - CTRLS CKT	IntraState	27/03/2024	22:50	28/03/2024	07:55	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KHARGHAR - BORIVALI CKT - 2	IntraState	27/03/2024	22:54	28/03/2024	07:50	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
KALWA - BORIVALI	IntraState	27/03/2024	22:57	28/03/2024	07:52	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
GIS BHANDUP - BORIVALI	IntraState	27/03/2024	23:02	28/03/2024	07:57	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
CHIKHALI-JALNA II	IntraState	28/03/2024	08:27	28/03/2024	19:01	PO	Stringing between span loc no.8 to 9 for Proposed Lilo on 220kV Jalna-Chikhali to 220kV Nagewadi line.
CHIKHALI-JALNA I	IntraState	28/03/2024	08:27	28/03/2024	19:02	PO	Stringing between span loc no.8 to 9 for Proposed Lilo on 220kV Jalna-Chikhali to 220kV Nagewadi line.
MALEGAON (ZODGA) - BALAPUR CKT 1	IntraState	28/03/2024	08:28	28/03/2024	11:11	PO	Isolator maintenance work by outside agency at 220kV Balapur Ss.
BOISAR II - VIRAJ	IntraState	28/03/2024	09:28	28/03/2024	18:09	PO	1. Replacement of Midspan Joint between span BTL 15-16 (Y ı Phase). 2. Positioning of OPGW conductor
NANDED 2 (WAGHALA) - PARBHANI	IntraState	28/03/2024	10:11	28/03/2024	17:20	PO	Line maintenance work.
GADCHANDUR - VIRUR-I	IntraState	28/03/2024	12:06	28/03/2024	13:31	EO	Attending of Hotspot on Rph CT clamp.
NIGADE- PETH LINE	IntraState	28/03/2024	13:27	28/03/2024	19:32	PO	Replacement of O/C E/F back up relay
LAMBOTI - TULJAPUR CKT - 2	IntraState	28/03/2024	13:27	28/03/2024	17:25	EO	Replacement of Y-ph pilot string bottom flashover DI & Suspension clamp at loc no.114.
PHURSUNGI-PARVATI	IntraState	28/03/2024	13:40	28/03/2024	14:55	T	Line tripped on distance protection.
BHIGWAN-BARAMATI AGRO	IntraState	28/03/2024	14:20	28/03/2024	17:00	PO	CT Tan delta and R ph CT Oil leakage(through sec bushing) attending work.
MHAISAL - ALKUD	IntraState	28/03/2024	18:44	29/03/2024	03:06	PO	Polymer insulator replacement Work
PADGHE - NALASOPARA - VASAI (T)	IntraState	29/03/2024	05:14			PO	Faulty Insulator replacement work identified in PID.
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 29/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/33 KV 50MVA PTR 2	IntraState	27/03/2024	10:27			HT	Overhauling of hv gis hybrid pass (abb make) .
220 KV BUSBAR Outages/Trippings							
BUS BAR PROTECTION @ MALEGAON-220 KV	IntraState	28/03/2024	12:00	28/03/2024	17:45	PO	220kV Busbar scheme testing work by testing team.
BUS SECTION-2 @ MAHAPE	IntraState	29/03/2024	06:42			PO	(Outage is required on BUS SECTION-3 @ MAHAPE but same not available in OMS. Hence Bus section-2 selected) for Maintenance work.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	27/03/2024	23:23	28/03/2024	03:30	PO	Normalization of 110 kV Parel Mankhurd line and waghivali Chembur line
110 KV BUSBAR Outages/Trippings							
BUS-1 @ KHOPOLI	IntraState	29/03/2024	23:45	29/03/2024	04:47	PO	110 KV DT 5 Bkr Main bus side jumper reconnection post completion of breaker O/H

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage