

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/May/2022 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	166.858	4667.313	1) Gujrat	-8.230	-163.905
2) Hydro	33.683	632.772	2) Madhya Pradesh	5.385	146.424
3) Gas	6.367	159.144	3) Chattisgarh	2.700	96.000
Total MSPGCL	206.908	5459.229	4) Maharashtra	157.844	5090.119
B) 1) APLM	58.168	1803.617	5) Goa (Amona)	-1.322	-37.641
2) JSWEL	14.930	501.866	Total	156.377	5130.997
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.169	994.987
4) RPL(AMT)	19.191	669.475	b) Mumbai Drawl	34.936	1066.201
5) SWPGPL	9.371	238.020	c) MSEDCL Bilateral *	81.729	2144.376
6) Other IPP	15.630	544.949	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.169	994.831
C) 1) TPCL Thermal	15.415	406.913	Include PX	0.000	0.000
2) TPCL Hydro	4.819	117.093	Standby	0.000	0.156
3) TPCL Gas	1.951	62.458	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.942	314.512	1) MSEDCL	491.309	14186.238
D) STATE			2) Mumbai Discoms	69.066	1967.164
1) Thermal	311.505	9146.665	3) Other Discoms	8.738	261.163
(A1+C1+C4+(B1-B6))			TOTAL STATE	569.113	16414.565
2) Hydro	38.502	749.865			
(A2+C2)					
3) Gas	8.318	221.602			
(A3+B7+C3)					
4) Wind	43.743	906.190			
6) SOLAR	10.665	259.259			
TOTAL STATE	412.733	11283.581			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6938	7010	6329	7406
MSPGCL Hydro	1140	1552	2066	1160
MSPGCL Gas	257	246	267	270
MSPGCL Total Generation	8336	8808	8662	8836
Central Sector Receipt	7947	7408	6166	5420
WIND	1348	1528	2072	2257
CPP / IPP Thermal	4327	4949	5022	4975
CPP / IPP Gas	0	0	0	0
SOLAR	1431	897	0	0
Exchange with Mumbai	-1899	-1927	-1315	-968
MSEDCL DEMAND MET	21086	21280	20237	20228
Load Shedding	0	0	0	0
MSEDCL DEMAND	21086	21280	20237	20228
TPCL GENERATION	765	824	1154	1085
AEML GENERATION	491	494	501	500
MUMBAI DEMAND	3155	3245	2970	2553
OTHER DISCOM DEMAND	404	382	370	292
STATE DEMAND MET	24645	24907	23578	23073
STATE DEMAND	24645	24907	23578	23073
Frequency (Hz)	50.00	49.94	49.86	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.16 Hz at 1802 Hrs	49.66 Hz at 2309 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/May/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	101.84	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.64	372.84	582	0
Unit 9	12.71	346.13	569	498
Unit 10	13.26	358.79	580	511
Total	36.61	1179.60		
Bhusawal				
Unit 3	0.00	74.35	0	0
Unit 4	11.12	228.44	480	330
Unit 5	9.24	249.65	460	295
Total	20.36	552.44		
Parli				
Unit 6	5.04	85.20	240	151
Unit 7	5.09	116.99	241	144
Unit 8	3.10	76.52	136	124
Total	13.23	278.71		
Chandrapur				
Unit 3	3.58	104.13	160	130
Unit 4	3.21	96.13	140	120
Unit 5	8.79	208.30	375	300
Unit 6	9.00	229.22	388	295
Unit 7	4.71	247.68	419	0
Unit 8	10.39	281.31	461	380
Unit 9	10.39	282.70	438	425
Total	50.07	1449.47		
Paras				
Unit 3	5.02	119.42	229	140
Unit 4	4.86	122.70	223	138
Total	9.88	242.13		
Khaparkheda				
Unit 1	3.18	83.23	150	105
Unit 2	3.63	98.38	155	140
Unit 3	4.22	101.92	185	133
Unit 4	3.34	89.34	150	132
Unit 5	10.88	306.98	475	440
Total	25.26	679.84		
Nasik				
Unit 3	4.25	89.86	191	125
Unit 4	3.55	96.95	167	131
Unit 5	3.64	98.32	166	117
Total	11.44	285.12		
Uran				
All Units	6.37	159.14	280	246
Total	6.37	159.14		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	3.06	23	0
Total	0.04	3.06		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	8.21	134.04	515	45
Stage 4	14.99	217.49	1024	0
Stage 3	5.00	77.93	320	58
Total	28.20	429.46		
Hydro				
KDPH	0.59	15.11	25	25
VTRNA	0.00	17.34	0	0
TILLARI	0.00	8.24	0	0
BHIRA T.R.	0.21	5.34	77	0
SMLHY_PTN	4.65	144.95	201	179
GHATGHAR	0.00	9.26	0	0
Total	5.44	200.25		
Wind				
Total	43.74	906.19	0	0
Total	43.74	906.19		
CPP				
APML(Mus)	58.17	1803.62	0	0
JSWEL(Mus)	14.93	501.87	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	19.19	669.48	0	0
SWPGPL-Mus	9.37	238.02	0	0
Other(Mus)	15.63	544.95	0	0
Total	117.29	3757.93		
SOLAR				
Total	10.66	259.26	0	0
Total	10.66	259.26		
Tata				
Trombay 5	9.99	265.15	459	282
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.06	38.59	47	42
Trombay 7B	0.90	23.87	39	36
TATA Hydro	4.82	117.09	441	19
Trombay 8	5.42	141.77	230	197
Total	22.18	586.46		
AEML				
DTPS U-1&2	11.94	314.51	502	489
Total	11.94	314.51		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	166.86	4667.31	MSPGCL Total	206.91	5459.23
			MSPGCL Thml+Gas	173.22	4826.46	Koyna 1,2 & 4 Total	23.20	351.53
			MSPGCL Hydro	33.68	632.77	State Total	412.73	11283.58

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 28/May/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	7428	1716	280	9424	2576	5246	0	0	5210	5128	-1451	20572	0	20572	3002	351	23925	49.86
2	7455	1716	270	9440	2438	5029	0	0	5540	5350	-1415	20509	0	20509	2839	333	23681	49.98
3	7405	1390	271	9066	2352	4994	0	0	5935	5578	-1290	20393	0	20393	2674	307	23374	49.95
4	7406	1160	270	8836	2257	4975	0	0	5589	5420	-968	20228	0	20228	2553	292	23073	50.00
5	7361	942	270	8574	2201	4964	0	0	5619	5920	-779	20574	0	20574	2473	306	23352	50.03
6	7324	1394	271	8988	1840	4960	0	0	5945	5906	-801	20547	0	20547	2479	347	23372	50.01
7	7404	1974	280	9658	1547	4983	0	96	5965	6098	-1195	20822	0	20822	2389	365	23576	50.00
8	7436	1292	270	8998	1500	4960	0	356	6167	6284	-1318	20395	0	20395	2423	385	23203	50.04
9	7107	462	270	7838	1781	4704	0	743	6547	6561	-1280	19949	0	19949	2580	399	22928	50.05
10	6887	568	260	7714	1586	4271	0	1039	7190	7294	-1584	19904	0	19904	2820	416	23140	50.03
11	6527	926	268	7722	1435	4203	0	1280	7682	7698	-1868	20067	0	20067	3052	403	23522	50.01
12	6938	1140	257	8336	1348	4327	0	1431	7902	7947	-1899	21086	0	21086	3155	404	24645	50.00
13	6866	370	258	7494	1360	4816	0	1423	8035	8144	-1883	20991	0	20991	3168	364	24523	49.97
14	6877	318	257	7452	1352	4941	0	1327	8068	7889	-1836	20759	0	20759	3116	366	24241	50.00
15	7027	894	257	8178	1451	4935	0	1150	7756	7460	-1905	20893	0	20893	3213	377	24482	49.92
16	7010	1552	246	8808	1528	4949	0	897	7379	7408	-1927	21280	0	21280	3245	382	24907	49.94
17	6972	1754	266	8992	1585	4923	0	613	6916	6751	-1859	20620	0	20620	3198	385	24202	50.01
18	6636	1964	246	8846	1865	4925	0	260	6465	6467	-1608	20368	0	20368	3084	386	23839	50.03
19	6345	2020	256	8620	2018	4982	0	50	6069	6121	-1421	19995	0	19995	2959	376	23330	50.02
20	6329	2066	267	8662	2072	5022	0	0	6073	6166	-1315	20237	0	20237	2970	370	23578	49.86
21	6463	1932	267	8662	1973	5026	0	0	6117	6086	-1296	20083	0	20083	2937	368	23388	49.99
22	6510	2000	266	8776	1799	5053	0	0	5878	5993	-1270	20001	0	20001	2887	350	23238	49.86
23	6542	2072	267	8880	1921	5030	0	0	6050	6218	-1311	20392	0	20392	2881	346	23619	49.88
24	6603	2064	277	8944	1958	5072	0	0	6171	6490	-1457	20646	0	20646	2966	361	23972	49.92
MUs	166.86	33.68	6.37	206.91	43.74	117.29	0.00	10.66	156.27	156.38	-34.94	491.31	0.00	491.31	69.06	8.74	569.11	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/May/2022

Position as on 6.30 Hrs of 29/May/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	JSW (J) U3	300	28/05/2022	02:09	29/05/2022	18:45	no schedule	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/06/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-1	270	11/05/2022	21:00		Continued.	Coal Shortage	
MSPGCL	Uran Unit 8	108	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
MSPGCL	Uran Unit B0	120	13/05/2022	01:34		Continued.	excitation fault (unit out due to gas shortage from 02:30hrs of dt.13.05.2022)	
IPP	RPL(AMT) U-3	270	24/05/2022	02:23		Continued.	Flame Failure	31/05/2022
MSPGCL	Bhusawal Unit 3	210	24/05/2022	17:31	29/05/2022	16:55	CVSM Control Valve Problem	30/05/2022
MSPGCL	Koradi Unit 6	210	27/05/2022	06:05	29/05/2022	06:27	Boiler Tube Leakage	29/05/2022
IPP	Adani U-3	660	27/05/2022	16:13		Continued.	APH-A HOT PA BELOW LEAKAGE.	31/05/2022
MSPGCL	Chandrapur Unit 7	500	28/05/2022	12:18	29/05/2022	01:14	Air heater problem	29/05/2022
MSPGCL	Koradi Unit 8	660	28/05/2022	17:27	28/05/2022	19:54	Flame Failure	
MSPGCL	Uran Unit 6	108	29/05/2022	00:32		Continued.	Gas shortage	
TPC-G	Trombay 7B	60	29/05/2022	04:57		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	29/05/2022	05:26		Continued.	Gas shortage	
MSPGCL	Nasik Unit 3	210	29/05/2022	19:00		Continued.	Boiler Tube Leakage	31/05/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/May/2022

Statement-VII

Position as on 6.30 Hrs of 29/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
DEEPNAGAR - AURANGABAD (WALUJ)	IntraState	28/05/2022	06:14	28/05/2022	17:47	PO	For replacement of Dead end & Mid span joint & Faulty insulator strings detected in PID.
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 1 @ DHULE	IntraState	28/05/2022	09:54			PO	Work of Overhauling of OLTC of 315 MVA ICT-1
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	29/05/2022	17:25		Continued.	PO	For pre-monsoon maintenance activities and diagnostic testing, cleaning of tertiary to avoid tripping of ICT on NDR.
400/220/33 KV 500MVA ICT - 2 @ LONIKAND 2	IntraState	29/05/2022	17:48	29/05/2022	23:15	PO	For pre-monsoon maintenance activities and diagnostic testing, cleaning of tertiary to avoid tripping of ICT on NDR.
220 KV LINE Outages/Trippings							
MULUND - GIS BHANDUP	IntraState	29/01/2022	15:44			T	cABLE FAULT
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kV GCR-BBLR-2 line on 220kV TBC bay.
KHARGHAR - NERUL	IntraState	27/05/2022	22:37	28/05/2022	00:51	EO	To attend hotspot on B ph CB pole to D isolator jumper by replacing twin Jumper
BOISAR II - BOISAR (PG) CKT - 2	IntraState	28/05/2022	03:27	28/05/2022	05:46	EO	Hot spot attending work Yph CT to D-Isolator jumper crimping at D-Isolator end. (102.9 OC, Image.IR00549)
BOISAR II - BOISAR (PG) CKT - 2	IntraState	28/05/2022	05:46	28/05/2022	06:30	EO	Hot spot attending work 1. Bph T-Jumper crimping at A-Isolator end. (128.8 OC, Image.IR00550) 2.Yph T-Jumper crimping at A-Isolator end.(113 OC, Img.IR00551)
PEDHAMBE ONI LINE	IntraState	28/05/2022	09:30	28/05/2022	17:05	EO	Outage for attending Hot spot at Loc. no. 141 Pedhambe side Y phase
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	28/05/2022	11:58	28/05/2022	19:34	EO	For attending low line clearance at loc 5 6
CHAKAN-BHOSARI 1	IntraState	28/05/2022	13:19	28/05/2022	19:08	PO	Double Jumpering Work
PANDHARPUR - MALINAGAR	IntraState	28/05/2022	16:20	28/05/2022	21:26	PO	Outage is required for For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.
BOISAR II - BOISAR (PG) CKT - 2	IntraState	29/05/2022	01:07	29/05/2022	01:52	EO	Hot spot attending work- 220kV A Bus Isolatorçs. @ Jaw towards B Bus.
DASTURI-KANDALGAON LINE	IntraState	29/05/2022	05:55	29/05/2022	14:52	PO	Outage tree cutting work at various location and other line maintenance work.
PANDHARPUR - MALINAGAR	IntraState	29/05/2022	16:22	29/05/2022	21:22	PO	Outage is required for For changing / replacement of faulty string at loc no. Main line - 1,4,7,15,16,19,22,69.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work
220/132KV 100MVA ICT 1 @ SATARA MIDC	IntraState	25/05/2022	10:38			PO	Transformer painting work

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/May/2022

Statement-VII

Position as on 6.30 Hrs of 29/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33 KV 50 MVA PTR 2 @ BHENDA	IntraState	28/05/2022	08:00	28/05/2022	12:30	PO	Quarterly maintenance work / pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.
220 / 110 / 23kv 250 MVA ICT 3 @ SALSETTE	IntraState	28/05/2022	08:07	28/05/2022	12:01	PO	Attending Oil leakage from conservator flange
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	28/05/2022	08:16	28/05/2022	14:53	PO	For Half yearly maintenance and diagnostic testing work.
220/132 KV 200 MVA ICT 3 @ AHMEDNAGAR	IntraState	28/05/2022	08:36	28/05/2022	10:50	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon
220/22 KV 50 MVA PTR 1 @ AIROLI KNOWLEDGE PARK	IntraState	28/05/2022	08:36	28/05/2022	11:12	PO	Pre monsoon maintenance & Hotspot attending work
220/33 KV 50MVA PTR @ KALWAN	IntraState	28/05/2022	09:03	28/05/2022	11:50	PO	for premonsoon maintenance work
220/132 KV 200 MVA ICT 1 @ EKLHARE(GCR)	IntraState	28/05/2022	09:25	28/05/2022	17:15	PO	Diagnosis of testing work and pre-monsoon maintenance work
220/22KV 50MVA PTR - 1 @ PALAVA	IntraState	28/05/2022	09:38	28/05/2022	12:19	PO	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	28/05/2022	09:45	28/05/2022	18:55	PO	PREMONSOON MAINTENANCE AND 2. BAY MAINTENANCE WORK
220/33 KV 50 MVA TF - 1@BELWANDI	IntraState	28/05/2022	10:15	28/05/2022	11:35	PO	Pre-Monsoon Maintenance Work
220/132 KV 200 MVA ICT 2 @ AHMEDNAGAR	IntraState	28/05/2022	11:15	28/05/2022	13:05	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
220/22KV 50MVA PTR - 2 @ PALAVA	IntraState	28/05/2022	12:31	28/05/2022	15:25	PO	Pre-monsoon maintenance work and neutral earth pit resistance measurement work.
220/132KV 100MVA ICT-1 @ WALCHANDNAGAR	IntraState	28/05/2022	13:10	28/05/2022	16:51	PO	PRE MONSOON MAINTENANCE WORK
220/132 KV 100 MVA ICT - 1 @KALWAN	IntraState	28/05/2022	13:21	28/05/2022	16:05	PO	For Premonsoon maintenance work.
220/33 KV 50 MVA PTR 1 @ BHENDA	IntraState	28/05/2022	13:50	28/05/2022	15:45	PO	Quarterly maintenance work / Pre Monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2 from top side.
220/22 KV 50 MVA PTR 1 @ KALWA	IntraState	28/05/2022	14:25	28/05/2022	16:57	PO	For replacement of 22kv main bus isolator & RM Work at MSEDCL END.
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	28/05/2022	14:35	28/05/2022	14:35	PO	ATTENDING RED HOT SPOTS 2. BALANCE PREMONSOON MAINTENANCE WORK
220/132 KV 200 MVA ICT 1 @ AHMEDNAGAR	IntraState	28/05/2022	14:47	28/05/2022	16:01	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
220/33 KV 50 MVA PTR 3 @ BHENDA	IntraState	28/05/2022	16:01	28/05/2022	17:51	PO	Quarterly maintenace work/ pre monsoon maintenance work and oil leakage attend of PTR-1 & PTR-2
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	IntraState	28/05/2022	16:22	28/05/2022	17:19	PO	Pre monsoon work, i.e. cleaning of bushings, tightening of N&B ,& various related work before monsoon.
220/22 KV 50 MVA PTR 3 @ NALASOPARA	IntraState	29/05/2022	07:30	29/05/2022	15:15	PO	1. 80 MVA 220/22-22 kv PTR-3 for attending PTR LV Bushing oil leakage (minor) attending work. 2. Pre monsoon maintenance work. 3. OLTC overhauling of PTR.
220 / 110 / 33kv 250MVA ICT 8 @ DHARAVI	IntraState	29/05/2022	09:50	29/05/2022	14:52	PO	Routine Maintenance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/May/2022

Statement-VII

Position as on 6.30 Hrs of 29/May/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22 KV 50 MVA PTR 2 @ VASAI	IntraState	29/05/2022	14:50	29/05/2022	19:34	PO	Hot spot attending by replacement of 22kV Bph bushing of 50MVA, 220/22kV PTR-2 by Agency & Pre monsoon maintenance work & Diagnostic testing.
220/132KV 100MVA ICT 1 @ CHAKAN PHASE II	IntraState	29/05/2022	20:49	29/05/2022	20:49	PO	Half yearly maintenance and pre monsoon maintenance.
132 KV LINE Outages/Trippings							
NAGAR - SUPA	IntraState	28/05/2022	15:41	28/05/2022	19:05	PO	Outage Proposal of 132kV Ahmednagar- supa line for Removing of bunching arrangement between Loc 70-71
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	28/05/2022	13:49	28/05/2022	18:47	PO	For attending to hot-spot at loc-14

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage