

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Jun/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.497	4256.236	1) Gujrat	-5.117	-30.792
2) Hydro	5.674	231.642	2) Madhya Pradesh	-2.175	2.944
3) Gas	5.158	189.856	3) Chattisgarh	1.110	49.730
Total MSPGCL	157.329	4677.734	4) Maharashtra	160.550	5088.386
B) 1) APLM	54.782	1594.569	5) Goa (Amona)	-2.714	-57.807
2) JSWEL	21.544	631.304	Total	151.654	5052.461
3) VIPL	0.000	0.000	a) Mumbai Schedule	39.079	1175.557
4) RPL(AMT)	30.813	843.918	b) Mumbai Drawl	41.833	1244.170
5) SWPGPL	12.026	338.902	c) MSEDCL Bilateral *	90.359	2327.224
6) Other IPP	13.626	391.163	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	39.079	1175.504
C) 1) TPCL Thermal	11.383	354.103	Include PX	0.000	0.000
2) TPCL Hydro	4.531	147.894	Standby	0.000	0.053
3) TPCL Gas	3.377	113.771	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.923	248.917	1) MSEDCL	446.843	13118.060
D) STATE			2) Mumbai Discoms	71.047	2108.854
1) Thermal	300.594	8659.112	3) Other Discoms	11.224	322.765
(A1+C1+C4+(B1-B6))			TOTAL STATE	529.114	15549.679
2) Hydro	10.205	379.536			
(A2+C2)					
3) Gas	8.535	303.627			
(A3+B7+C3)					
4) Wind	47.496	728.830			
6) SOLAR	10.630	426.114			
TOTAL STATE	377.460	10497.219			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	6173	5817	6757	6310
MSPGCL Hydro	294	247	315	195
MSPGCL Gas	274	130	111	272
MSPGCL Total Generation	6741	6194	7183	6777
Central Sector Receipt	6853	7425	6630	5137
WIND	2067	2464	2133	1831
CPP / IPP Thermal	5462	4982	6008	5767
CPP / IPP Gas	0	0	0	0
SOLAR	1025	286	0	0
Exchange with Mumbai	-1982	-1915	-1902	-1264
MSEDCL DEMAND MET	19655	18926	19548	17879
Load Shedding	0	0	0	0
MSEDCL DEMAND	19655	18926	19548	17879
TPCL GENERATION	802	957	928	628
AEML GENERATION	489	440	399	359
MUMBAI DEMAND	3273	3312	3229	2251
OTHER DISCOM DEMAND	511	510	504	369
STATE DEMAND MET	23439	22748	23281	20499
STATE DEMAND	23439	22748	23281	20499
Frequency (Hz)	49.98	50.02	50.02	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.22 Hz at 18.03 Hrs	49.83 Hz at 15.19 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.14	117.02	188	130
Unit 8	13.67	380.10	614	395
Unit 9	12.38	342.16	613	382
Unit 10	0.21	337.89	212	0
Total	30.39	1177.16		
Bhusawal				
Unit 3	3.14	57.04	160	120
Unit 4	0.00	151.03	0	0
Unit 5	9.99	274.06	490	300
Total	13.12	482.14		
Parli				
Unit 6	3.74	52.90	240	142
Unit 7	3.69	68.18	216	140
Unit 8	3.66	59.04	192	144
Total	11.08	180.13		
Chandrapur				
Unit 3	3.37	89.52	160	129
Unit 4	3.39	98.64	164	131
Unit 5	7.64	208.11	405	275
Unit 6	7.34	176.66	380	274
Unit 7	8.04	249.78	453	276
Unit 8	8.53	230.65	395	277
Unit 9	9.77	259.19	484	290
Total	48.09	1312.55		
Paras				
Unit 3	4.81	129.15	222	148
Unit 4	5.24	45.38	254	149
Total	10.04	174.54		
Khaparkheda				
Unit 1	3.68	95.65	170	110
Unit 2	4.14	111.49	194	118
Unit 3	3.95	94.50	175	130
Unit 4	4.08	112.67	189	129
Unit 5	11.18	302.94	490	290
Total	27.02	717.26		
Nasik				
Unit 3	0.00	64.85	0	0
Unit 4	3.54	53.29	185	126
Unit 5	3.20	94.32	153	113
Total	6.74	212.46		
Uran				
All Units	5.16	189.86	275	111
Total	5.16	189.86		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.47	0	0
Total	0.00	1.47		
Koyna				
Stage 1-2	1.57	71.21	140	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	45.27	0	0
Stage 3	0.76	30.84	160	0
Total	2.33	147.32		
Hydro				
KDPH	0.00	2.96	0	0
VTRNA	0.80	20.30	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.40	4.85	40	0
SMLHY_PTN	2.14	50.00	93	81
GHATGHAR	0.00	6.22	0	0
Total	3.34	84.32		
Wind				
Total	47.50	728.83	0	0
Total	47.50	728.83		
CPP				
APML(Mus)	54.78	1594.57	0	0
JSWEL(Mus)	21.54	631.30	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.81	843.92	0	0
SWPGPL-Mus	12.03	338.90	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.81	156.84	267	193
Other(Mus)	1.84	83.03	0	0
JPL	5.98	151.30	273	232
Total	132.79	3799.86		
SOLAR				
Total	10.63	426.11	0	0
Total	10.63	426.11		
Tata				
Trombay 5	7.42	233.91	361	256
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.16	71.36	109	0
Trombay 7B	1.22	42.41	64	0
TATA Hydro	4.53	147.89	387	38
Trombay 8	3.96	120.20	222	130
Total	19.29	615.77		
AEML				
DTPS U-1&2	9.92	248.92	490	340
Total	9.92	248.92		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.50	4256.24	MSPGCL Total	157.33	4677.73
			MSPGCL Thml+Gas	151.66	4446.09	Koyna 1,2 & 4 Total	1.57	116.48
			MSPGCL Hydro	5.67	231.64	State Total	377.46	10497.22

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6461	189	274	6924	2122	5811	0	0	5941	5552	-1468	18509	0	0	18509	2699	432	21640	49.98
2	6211	189	274	6674	1908	5795	0	0	5848	5763	-1480	18270	0	0	18270	2506	390	21166	49.99
3	6248	189	273	6710	1858	5772	0	0	5747	5132	-1292	17803	0	0	17803	2354	377	20534	50.00
4	6310	195	272	6777	1831	5767	0	0	5719	5137	-1264	17879	0	0	17879	2251	369	20499	50.03
5	6278	195	273	6746	1677	5656	0	0	5966	5603	-1267	18036	0	0	18036	2216	379	20631	50.00
6	6496	190	273	6959	1580	5681	0	0	6349	6315	-1345	18748	0	0	18748	2303	442	21493	49.96
7	6754	189	267	7210	1527	6214	0	97	6445	6265	-1443	19402	0	0	19402	2412	468	22282	49.93
8	6479	229	270	6978	1401	5968	0	344	6478	6485	-1546	19151	0	0	19151	2616	479	22246	50.00
9	6211	310	269	6790	1780	5627	0	667	6858	6450	-1836	18963	0	0	18963	2958	515	22436	50.01
10	6173	294	274	6741	2067	5462	0	1025	7059	6853	-1982	19655	0	0	19655	3273	511	23439	49.98
11	5840	337	275	6452	2213	5017	0	1261	7472	7008	-2178	19266	0	0	19266	3485	507	23258	50.01
12	5418	183	272	5873	2225	4959	0	1405	7526	7167	-2239	18894	0	0	18894	3546	496	22936	50.06
13	4973	142	272	5387	2308	4671	0	1378	7474	7000	-2194	18064	0	0	18064	3497	486	22047	50.00
14	4777	146	270	5193	2289	4258	0	1380	7541	7364	-2060	17947	0	0	17947	3291	477	21715	50.00
15	5002	191	208	5401	2406	4751	0	1205	7232	7216	-2088	18431	0	0	18431	3263	460	22154	49.95
16	5570	230	130	5930	2257	4962	0	900	6821	6576	-2071	18074	0	0	18074	3331	480	21885	49.94
17	6177	188	131	6496	2453	5069	0	638	6558	5801	-2026	17934	0	0	17934	3327	497	21758	49.99
18	5817	247	130	6194	2464	4982	0	286	6915	7425	-1915	18926	0	0	18926	3312	510	22748	50.02
19	6146	283	131	6560	2414	5145	0	44	6995	7004	-1896	18758	0	0	18758	3248	513	22519	50.04
20	6757	315	111	7183	2133	6008	0	0	6725	6630	-1902	19548	0	0	19548	3229	504	23281	50.02
21	6803	309	115	7227	1814	6632	0	0	6305	5938	-1764	19342	0	0	19342	3132	505	22979	50.04
22	6626	310	132	7068	1568	6448	0	0	6054	5580	-1558	18616	0	0	18616	3015	490	22121	49.98
23	6618	313	132	7063	1639	6200	0	0	6208	5604	-1518	18507	0	0	18507	2914	481	21902	49.96
24	6352	311	130	6793	1562	5936	0	0	6368	5786	-1501	18120	0	0	18120	2869	456	21445	50.03
MUs	146.50	5.67	5.16	157.33	47.50	132.79	0.00	10.63	158.60	151.65	-41.83	446.84	0.00	0.00	446.84	71.05	11.22	529.11	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 28/Jun/2024

Position as on 6.30 Hrs of 29/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Koyna Unit 2	70	15/06/2024	07:10		Continued.	Govrner renovation	10/07/2024
MSPGCL	Bhusawal Unit 4	500	16/06/2024	00:00		Continued.	Annual Overhaul	06/07/2024
MSPGCL	Koyna Unit 10	80	20/06/2024	18:00		Continued.	For laying of Optical fiber cable from powerhouse to switchyard on overhead 220 KV EHV line	30/06/2024
MSPGCL	Koyna Unit 9	80	20/06/2024	18:00		Continued.	For laying of Optical fiber cable from powerhouse to switchyard on overhead 220 KV EHV line	30/06/2024
Total Capacity MSPGCL		730						
Total Capacity PLANNED OUTAGE		730						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Koradi Unit-10	660	28/06/2024	00:54		Continued.	Boiler Tube Leakage	30/06/2024
MSPGCL	Uran Unit 8	108	28/06/2024	14:36	29/06/2024	04:23	Comp surge Protection	
Total Capacity MSPGCL		1013						
TPC-G								
TPC-G	Trombay 7A	120	28/06/2024	19:26	28/06/2024	22:30	Gas shortage	
TPC-G	Trombay 7B	60	28/06/2024	19:31	29/06/2024	00:02	Gas shortage	
Total Capacity TPC-G		180						
IPP								
IPP	SWPGPL U-4	135	29/06/2024	07:10		Continued.	Due to turbine Problem.	
Total Capacity IPP		135						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	30/12/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/11/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		1648						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Jun/2024

Position as on 6.30 Hrs of 29/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	17/06/2024	21:44		Continued.	Zero Schedule given by MSEDCL	
MSPGCL	Uran Unit 6	108	26/06/2024	22:30		Continued.	No Schedule from MSEDCL.	
Total Capacity MSPGCL		216						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		216						
UNIT OUT ON TOLLING *								
MSPGCL								
MSPGCL	Nasik Unit 3	210	19/06/2024	17:30		Continued.	Case IV Tolling	
Total Capacity MSPGCL		210						
Total Capacity UNIT OUT ON TOLLING *		210						
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 29/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY (712) OF AKOLA CKT - 2 @ KORADI 3	IntraState	29/06/2024	09:34			PO	Annual Maintenance of CB & CT at Koradi-III SS.
400 KV LINE Outages/Trippings							
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVar bus reactor by new 125 MVar bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	23/06/2024	19:11			HT	H/T For load Management.
JEJURI- KOYNA STAGE-IV	IntraState	28/06/2024	07:36	28/06/2024	09:03	PO	Important Work for making preparation of retrofitting of Distance Protection Relay.
220 KV CHANDRAPUR GCR (400 KV) - GRACE CKT	IntraState	28/06/2024	09:53	28/06/2024	13:25	HT	1. repalcemnt of burnt ioslator jaw pf 29d 2. replacement of burnt isolator rod of 29d.
BUS COUPLER @ KALWA	IntraState	28/06/2024	23:04			EO	To attend the Heavy sparking observed on R & B-ph Bus Isolator.
KARAD - TALANDGE CKT - 1	IntraState	29/06/2024	08:02	29/06/2024	09:40	EO	Hot spot of 212degree cel. at IPS clamp towards 29C isolator
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/132 KV 200 MVA ICT - 2 @ KHADKA	IntraState	03/06/2024	23:26			T	Differential protection
400/11kv STN-4A @ DEEPNAGAR	IntraState	26/06/2024	11:13			PO	For E/M for checking, cleaning and oil filtration work at MSPGCL End.
400/220/33 KV 315 MVA ICT - 3 @ PADGHE	IntraState	28/06/2024	14:56	29/06/2024	00:17	PO	1) Replacement of Differential Realy 2) Bay Maint work 3) MTAMC work 4) Bph IV Bushing Tand rechecking work if weather is clear 5.replacement of 29C bus PG isolator replacement work
400/220/33 KV 315MVA ICT - 3 @ KHADKA	IntraState	29/06/2024	08:18			PO	For replacement of OTI and WTI meter of R , Y and B phase Unit and routine maintenance works.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
BALE - SOLAPUR (PG)	InterState	19/06/2024	08:56			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 29/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NTT - KALWA	IntraState	05/06/2024	00:20			PO	For carrying out the cable end termination work at Gigaplex for work of GIS s/stn of M/s Gigaplex s/stn (PGD) and opportunity outage for cable cutting work for work of 220kV GIS S/tn M/s NTT Global DC NAV2 Pvt Ltd.
TOPWORTH - KHANDESHWAR	IntraState	15/06/2024	14:24			PO	Making LILO of 220kV Khandeshwar - Topwarth line & 220kV Khandeshwar Panvel TSS line and commissioning of 220/33kV Timber Market GIS, Panvel
PANVEL TSS - KHANDESHWAR	IntraState	15/06/2024	14:30			PO	Making LILO of 220kV Khandeahwar Topwarth line & 220kV Khandeshwar - Panvel TSS line and commissioing of 220/33kV Timber Market GIS, Panvel
OSMANABAD - SOLAPUR (BALE)	IntraState	19/06/2024	09:15			PO	1) Outage is required for Project work for Balance foundation, erection & stringing work of 220 kV Bale-PGCIL M/C portion (From Loc No 17A-37 A) 2) 220 kV Bale-PGCIL arrangement will be changed from 220 kV PG-Dharashiv (Osmanabad). (Bunching arrangement at Loc. No. 37)
MIDC CHANDRAPUR-GADCHANDUR	IntraState	26/06/2024	20:00			T	B PH WT JUMPER OPENED
SALSETTE - VIKHROLI (GIS) CKT - 3	IntraState	27/06/2024	18:04	28/06/2024	04:32	T	Tripped on distance protection
URAN - SEZ JNPT	IntraState	28/06/2024	04:30	28/06/2024	09:00	T	Distance Protection
KARAD - VITA CKT- 2	IntraState	28/06/2024	08:55	28/06/2024	18:17	PO	Insulator string replacement at various locations under scheme
VITA - KHANAPUR LINE	IntraState	28/06/2024	08:55	28/06/2024	18:17	PO	Insulator string replacement at various locations under scheme
PARLI NEW TPS - BEED CKT 2	IntraState	28/06/2024	10:15	28/06/2024	13:47	T	Replacement of flashed disc insulator string at loc. 173r & 197y.
TALANDGE - BIDRI	IntraState	28/06/2024	10:46	29/06/2024	00:02	PO	Retrofitting of Backup OC & EF Relay.
220 KV UMRED - TOPWORTH CKT	IntraState	28/06/2024	11:53	28/06/2024	14:13	HT	Outage is required for aux iso maint. work with allied maint. work at 220kv umred ss end.
URAN - SEZ JNPT	IntraState	28/06/2024	11:57	28/06/2024	17:08	T	Y ph fault ,13.01 kA , 3.62 km from Uran end
MAIN BUS SECTION - 2 @ PEDAMBE	IntraState	28/06/2024	12:08	28/06/2024	18:00	PO	Pedhambe- Adlab Line main bus to main bus isolator damaged jumper, clamp and isolator arm replacement work.
ONGC URAN - JNPT	IntraState	28/06/2024	18:00	28/06/2024	23:17	T	Line tripped on distance protection
URAN - SEZ JNPT	IntraState	28/06/2024	18:00	28/06/2024	19:30	T	Transient Fault
TROMBAY - VIKHROLI (GIS) CKT - 1 / CARNAC 7	IntraState	29/06/2024	00:06	29/06/2024	05:58	PO	METRO-4 WORK IN VICINITY
TROMBAY - VIKHROLI (GIS) CKT - 2	IntraState	29/06/2024	00:29	29/06/2024	05:54	PO	METRO-4 WORK IN VICINITY
GHATGHAR - JINDAL	IntraState	29/06/2024	04:13	29/06/2024	06:33	T	Distance Protection
PADGHE - JINDAL	IntraState	29/06/2024	04:13	29/06/2024	06:07	T	Distance Protection
PIRANGUT - HINJAWADI 2	IntraState	29/06/2024	07:25			PO	Work of stringing of conductor from New Monopole Loc. No. 154 to loc 153(Old tower)
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 29/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT-2 @ WALCHANDNAGAR	IntraState	21/06/2024	12:50			PO	Augmentation of 100 MVA ICT-02 with 200 MVA ICT
220/132 KV 100 MVA ICT-1	IntraState	28/06/2024	06:46	28/06/2024	11:48	T	Tripped on PRV and OSR.
BUS PT BAY @ PAL-DOMBIVALI	IntraState	28/06/2024	11:01	28/06/2024	18:45	PO	For replacing of 220 kV Bus PT set (All 3 phase) of 220 kV Side.
220/22kV 50MVA TF-1 @ JAMBHUL	IntraState	28/06/2024	11:16	28/06/2024	13:21	PO	The 22kV LV Incomer HT cable at 22kV LV take Off Structure needs to be buried deep in ground and back filling work.
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	28/06/2024	15:43	28/06/2024	19:50	T	ICT tripped on transformer internal fault indication.
110 KV LINE Outages/Trippings							
KALYAN KALWA SALSETTE 2	IntraState	28/06/2024	17:55	28/06/2024	18:26	EO	Hanging object and bird nest removal at loc. 74 Hanging object and bird nest removal at loc. 74

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage