

**State Load Despatch Center, Airoli (MSETCL) Statement I**  
**Daily system Report for 28/Jul/2017 FRIDAY**

| I GENERATION (MUs)  |                |                 | II EXCHANGES (MUs)             |                |                  |
|---------------------|----------------|-----------------|--------------------------------|----------------|------------------|
| A) MSPGCL           | Daily          | Monthly         | E) InterState Exchanges        | Daily          | Monthly          |
| 1) Thermal          | 97.730         | 2772.266        | 1) Gujrat                      | 4.687          | 30.206           |
| 2) Hydro            | 6.478          | 180.929         | 2) Madhya Pradesh              | 20.206         | 474.553          |
| 3) Gas              | 9.779          | 243.127         | 3) Chattisgarh                 | 7.290          | 219.180          |
| <b>Total MSPGCL</b> | <b>113.987</b> | <b>3196.322</b> | 4) Maharashtra Net             | 81.565         | 2410.853         |
| B) 1) APML          | 53.938         | 1564.561        | 5) Goa (Amona)                 | -0.528         | -13.002          |
| 2) JSWEL            | 14.749         | 366.746         | <b>Total</b>                   | <b>113.220</b> | <b>3121.790</b>  |
| 3) VIPL             | 5.731          | 164.832         | a) Mumbai Schedule             | 22.232         | 595.466          |
| 4) RPL(AMT)         | 0.000          | 0.000           | b) Mumbai Drawl                | 31.529         | 791.520          |
| 5) WPCL             | 2.560          | 84.588          | c) MSEDCL Bilateral *          | 13.745         | 494.779          |
| 6) PGPL             | 0.000          | 0.000           | Include PX                     | -2.403         | 12.655           |
| 7) Other IPP        | 3.262          | 86.406          | d) Mumbai Bilateral *          | 22.232         | 595.466          |
| C) 1) TPCL Thermal  | 13.482         | 373.241         | Include PX                     | 6.688          | 182.951          |
| 2) TPCL Hydro       | 5.572          | 137.003         | Include Standby                | 0.000          | 0.000            |
| 3) TPCL Gas         | 1.178          | 80.297          | <b>H) ENERGY CATERED (MUs)</b> |                |                  |
| 4) R-INFRA Thermal  | 9.335          | 279.304         | 1) MSEDCL                      | 321.028        | 9176.966         |
| <b>D) STATE</b>     |                |                 | 2) Mumbai Discoms              | 61.096         | 1661.355         |
| 1) Thermal          | 200.787        | 5691.944        | <b>TOTAL STATE</b>             | <b>382.124</b> | <b>10838.321</b> |
| (A1+C1+C4+(B1-B6))  |                |                 |                                |                |                  |
| 2) Hydro            | 12.050         | 317.932         |                                |                |                  |
| (A2+C2)             |                |                 |                                |                |                  |
| 3) Gas              | 10.957         | 323.424         |                                |                |                  |
| (A3+B6+C3)          |                |                 |                                |                |                  |
| 4) Wind             | 43.941         | 1337.813        |                                |                |                  |
| 6) SOLAR            | 1.169          | 45.428          |                                |                |                  |
| <b>TOTAL STATE</b>  | <b>268.904</b> | <b>7716.541</b> |                                |                |                  |

\* Displayed for information, not added in total.

**DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II**

| PARTICULARS              | A. Morning Peak at 9 Hrs | B. Day Peak at 13 Hrs | C. Evening Peak at 20 Hrs | D. Night Minimum at 3 Hrs |
|--------------------------|--------------------------|-----------------------|---------------------------|---------------------------|
| MSPGCL Thermal           | 4391                     | 3804                  | 4281                      | 3842                      |
| MSPGCL Hydro             | 397                      | 419                   | 388                       | 88                        |
| MSPGCL Gas               | 405                      | 395                   | 411                       | 405                       |
| MSPGCL Total Generation  | 5193                     | 4618                  | 5080                      | 4335                      |
| Central Sector Receipt   | 5499                     | 5501                  | 4932                      | 3800                      |
| WIND                     | 1717                     | 1956                  | 1666                      | 1909                      |
| CPP / IPP Thermal        | 3708                     | 3139                  | 3585                      | 3109                      |
| CPP / IPP Gas            | 0                        | 0                     | 0                         | 0                         |
| SOLAR                    | 70                       | 127                   | 0                         | 0                         |
| Exchange with Mumbai     | -1262                    | -1822                 | -1427                     | -881                      |
| <b>MSEDCL DEMAND MET</b> | <b>14925</b>             | <b>13519</b>          | <b>13836</b>              | <b>12272</b>              |
| Load Shedding            | 0                        | 0                     | 0                         | 0                         |
| MSEDCL DEMAND            | 14925                    | 13519                 | 13836                     | 12272                     |
| TPCL GENERATION          | 934                      | 924                   | 1002                      | 589                       |
| R-INFRA GENERATION       | 498                      | 374                   | 374                       | 373                       |
| <b>MUMBAI DEMAND</b>     | <b>2694</b>              | <b>3120</b>           | <b>2803</b>               | <b>1843</b>               |
| STATE DEMAND MET         | 17619                    | 16639                 | 16639                     | 14115                     |
| <b>STATE DEMAND</b>      | <b>17619</b>             | <b>16639</b>          | <b>16639</b>              | <b>14115</b>              |
| Frequency (Hz)           | 50.00                    | 50.04                 | 49.96                     | 49.96                     |

**FREQUENCY PARTICULARS**

| MAXIMUM FREQ.         | MINIMUM FREQ.        | AVERAGE FREQ. | FREQ. BELOW 49.2 Hz |
|-----------------------|----------------------|---------------|---------------------|
| 50.16 Hz at 16.04 Hrs | 49.8 Hz at 04.44 Hrs | 49.98         | 0 % of Time(min)    |

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

## Daily and Progressive Generation,Maximum,Minimum for 28/Jul/2017

| Generating unit    | Generation   |                |          |          |
|--------------------|--------------|----------------|----------|----------|
|                    | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>Koradi</b>      |              |                |          |          |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 11.24        | 249.04         | 505      | 435      |
| Unit 9             | 9.74         | 241.50         | 502      | 326      |
| Unit 10            | 11.59        | 268.60         | 550      | 460      |
| <b>Total</b>       | <b>32.57</b> | <b>759.15</b>  |          |          |
| <b>Bhusawal</b>    |              |                |          |          |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| Unit 3             | 0.00         | 0.00           | 0        | 0        |
| Unit 4             | 0.00         | 52.33          | 0        | 0        |
| Unit 5             | 0.00         | 22.97          | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>75.29</b>   |          |          |
| <b>Parli</b>       |              |                |          |          |
| Unit 4             | 0.00         | 0.00           | 0        | 0        |
| Unit 5             | 0.00         | 0.00           | 0        | 0        |
| Unit 6             | 0.00         | 0.00           | 0        | 0        |
| Unit 7             | 0.00         | 0.00           | 0        | 0        |
| Unit 8             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |
| <b>Chandrapur</b>  |              |                |          |          |
| Unit 3             | 4.38         | 16.10          | 206      | 164      |
| Unit 4             | 0.00         | 107.27         | 0        | 0        |
| Unit 5             | 9.32         | 215.22         | 425      | 360      |
| Unit 6             | 8.92         | 261.25         | 392      | 345      |
| Unit 7             | 9.22         | 266.71         | 416      | 359      |
| Unit 8             | 9.58         | 250.58         | 470      | 330      |
| Unit 9             | 9.64         | 260.40         | 479      | 341      |
| <b>Total</b>       | <b>51.06</b> | <b>1377.53</b> |          |          |
| <b>Paras</b>       |              |                |          |          |
| Unit 3             | 5.02         | 141.23         | 250      | 190      |
| Unit 4             | 5.08         | 52.93          | 250      | 188      |
| <b>Total</b>       | <b>10.10</b> | <b>194.16</b>  |          |          |
| <b>Khaparkheda</b> |              |                |          |          |
| Unit 1             | 0.00         | 13.54          | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| Unit 3             | 0.00         | 16.68          | 0        | 0        |
| Unit 4             | 0.00         | 21.01          | 0        | 0        |
| Unit 5             | 0.00         | 140.20         | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>191.44</b>  |          |          |
| <b>Nasik</b>       |              |                |          |          |
| Unit 3             | 3.99         | 74.19          | 190      | 160      |
| Unit 4             | 0.00         | 41.20          | 0        | 0        |
| Unit 5             | 0.00         | 59.31          | 0        | 0        |
| <b>Total</b>       | <b>3.99</b>  | <b>174.69</b>  |          |          |
| <b>Uran</b>        |              |                |          |          |
| All Units          | 9.78         | 243.13         | 425      | 395      |
| <b>Total</b>       | <b>9.78</b>  | <b>243.13</b>  |          |          |
| <b>PGPL</b>        |              |                |          |          |
| Unit 1             | 0.00         | 0.00           | 0        | 0        |
| Unit 2             | 0.00         | 0.00           | 0        | 0        |
| <b>Total</b>       | <b>0.00</b>  | <b>0.00</b>    |          |          |

| Generating unit   | Generation   |                |          |          |
|-------------------|--------------|----------------|----------|----------|
|                   | Daily (Mus)  | Monthly (Mus)  | Max (MW) | Min (MW) |
| <b>PENCH (MS)</b> |              |                |          |          |
| Pench (MS)        | 0.02         | 3.40           | 9        | 0        |
| <b>Total</b>      | <b>0.02</b>  | <b>3.40</b>    |          |          |
| <b>Koyna</b>      |              |                |          |          |
| Stage 1-2         | 2.97         | 71.94          | 555      | 40       |
| Stage 4           | 0.00         | 21.01          | 0        | 0        |
| Stage 3           | 1.14         | 40.87          | 160      | 0        |
| <b>Total</b>      | <b>4.11</b>  | <b>133.82</b>  |          |          |
| <b>Hydro</b>      |              |                |          |          |
| KDPH              | 0.00         | 0.00           | 0        | 0        |
| VTRNA             | 0.76         | 5.18           | 60       | 0        |
| TILLARI           | 0.00         | 6.69           | 0        | 0        |
| BHTGR/VEER        | 0.00         | 0.00           | 0        | 0        |
| BHIRA T.R.        | 0.50         | 11.90          | 80       | 0        |
| RNGR+BHTSA        | 0.42         | 2.35           | 18       | 16       |
| BHANDARDRA        | 0.34         | 11.66          | 15       | 14       |
| ELDARY            | 0.00         | 0.00           | 0        | 0        |
| SMLHY_PTN         | 0.35         | 3.88           | 15       | 14       |
| GHATGHAR          | 0.00         | 5.44           | 0        | 0        |
| <b>Total</b>      | <b>2.37</b>  | <b>47.10</b>   |          |          |
| <b>Wind</b>       |              |                |          |          |
| Total             | 43.94        | 1337.81        | 0        | 0        |
| <b>Total</b>      | <b>43.94</b> | <b>1337.81</b> |          |          |
| <b>CPP</b>        |              |                |          |          |
| APML(Mus)         | 53.94        | 1564.56        | 0        | 0        |
| JSWEL(Mus)        | 14.75        | 366.75         | 0        | 0        |
| VIPL(Mus)         | 5.73         | 164.83         | 0        | 0        |
| RPLAMT(Mus)       | 0.00         | 0.00           | 0        | 0        |
| WPCL(Mus)         | 2.56         | 84.59          | 0        | 0        |
| Other(Mus)        | 3.26         | 86.41          | 0        | 0        |
| <b>Total</b>      | <b>80.24</b> | <b>2267.13</b> |          |          |
| <b>SOLAR</b>      |              |                |          |          |
| Total             | 1.17         | 45.43          | 0        | 0        |
| <b>Total</b>      | <b>1.17</b>  | <b>45.43</b>   |          |          |
| <b>Tata</b>       |              |                |          |          |
| Trombay 5         | 8.51         | 238.79         | 490      | 311      |
| Trombay 6         | 0.00         | 0.00           | 0        | 0        |
| Trombay 7A        | 1.12         | 50.85          | 109      | 0        |
| Trombay 7B        | 0.06         | 29.45          | 39       | 0        |
| Trombay 8         | 4.97         | 134.45         | 242      | 199      |
| TATA Hydro        | 5.57         | 137.00         | 400      | 75       |
| <b>Total</b>      | <b>20.23</b> | <b>590.54</b>  |          |          |
| <b>R-INFRA</b>    |              |                |          |          |
| DTPS U-1&2        | 9.34         | 279.30         | 498      | 371      |
| <b>Total</b>      | <b>9.34</b>  | <b>279.30</b>  |          |          |

| * Infirm Power |             |         | Summary         |             |               | Summary             |             |               |
|----------------|-------------|---------|-----------------|-------------|---------------|---------------------|-------------|---------------|
| Particulars    | Daily (Mus) | Monthly | Particulars     | Daily (Mus) | Monthly (Mus) | Particulars         | Daily (Mus) | Monthly (Mus) |
|                |             |         | MSPGCL Thermal  | 97.73       | 2772.27       | MSPGCL Total        | 113.99      | 3196.32       |
|                |             |         | MSPGCL Thml+Gas | 107.51      | 3015.39       | Koyna 1,2 & 4 Total | 2.97        | 92.95         |
|                |             |         | MSPGCL Hydro    | 6.48        | 180.93        | State Total         | 268.90      | 7716.54       |

# State Load Despatch Center,Airoli (MSETCL)

## Annexure-2

Hourly Load Data As on 28/Jul/2017

| TIME<br>SR.<br>NO. | MSPGCL GEN. |      |      | TOTAL  | WIND  | CPP / IPP |      | SOLAR | CS<br>SHARE | CS<br>RECPT | Mum.<br>NET<br>EXCH. | MSEDCL<br>DEM.<br>MET | LOAD<br>SHEDDI<br>NG | MSEDCL<br>DEM.<br>WITH LS | MUMBAI<br>DEMAND | STATE<br>DEMAND | FREQ.<br>(Hz) |
|--------------------|-------------|------|------|--------|-------|-----------|------|-------|-------------|-------------|----------------------|-----------------------|----------------------|---------------------------|------------------|-----------------|---------------|
|                    | THM         | HY   | GAS  |        |       | THM       | GAS  |       |             |             |                      |                       |                      |                           |                  |                 |               |
| 1                  | 4380        | 98   | 407  | 4885   | 1782  | 3552      | 0    | 0     | 4024        | 3778        | -1069                | 12928                 | 0                    | 12928                     | 2136             | 15064           | 49.98         |
| 2                  | 3900        | 93   | 407  | 4400   | 1870  | 3198      | 0    | 0     | 4144        | 4038        | -994                 | 12512                 | 0                    | 12512                     | 1956             | 14468           | 50.00         |
| 3                  | 3842        | 88   | 405  | 4335   | 1909  | 3109      | 0    | 0     | 3814        | 3800        | -881                 | 12272                 | 0                    | 12272                     | 1843             | 14115           | 49.96         |
| 4                  | 3856        | 98   | 407  | 4361   | 1949  | 3105      | 0    | 0     | 3809        | 3888        | -828                 | 12475                 | 0                    | 12475                     | 1786             | 14261           | 49.95         |
| 5                  | 3818        | 188  | 405  | 4411   | 1847  | 3097      | 0    | 0     | 3946        | 4268        | -821                 | 12802                 | 0                    | 12802                     | 1778             | 14580           | 49.89         |
| 6                  | 4242        | 297  | 404  | 4943   | 1537  | 3279      | 0    | 0     | 4334        | 4539        | -932                 | 13366                 | 0                    | 13366                     | 1899             | 15265           | 49.95         |
| 7                  | 4437        | 713  | 397  | 5547   | 1634  | 3649      | 0    | 4     | 4657        | 4744        | -863                 | 14715                 | 0                    | 14715                     | 2071             | 16786           | 49.98         |
| 8                  | 4372        | 678  | 407  | 5457   | 1713  | 3697      | 0    | 33    | 4782        | 5172        | -919                 | 15153                 | 0                    | 15153                     | 2272             | 17425           | 50.04         |
| 9                  | 4391        | 397  | 405  | 5193   | 1717  | 3708      | 0    | 70    | 4996        | 5499        | -1262                | 14925                 | 0                    | 14925                     | 2694             | 17619           | 50.00         |
| 10                 | 4363        | 384  | 405  | 5152   | 1861  | 3715      | 0    | 120   | 5178        | 5315        | -1640                | 14523                 | 0                    | 14523                     | 2919             | 17442           | 49.99         |
| 11                 | 4365        | 332  | 406  | 5103   | 2071  | 3751      | 0    | 131   | 5157        | 4840        | -1805                | 14091                 | 0                    | 14091                     | 3140             | 17231           | 50.00         |
| 12                 | 3829        | 276  | 405  | 4510   | 1967  | 3511      | 0    | 158   | 5248        | 5401        | -1920                | 13627                 | 0                    | 13627                     | 3189             | 16816           | 49.98         |
| 13                 | 3804        | 419  | 395  | 4618   | 1956  | 3139      | 0    | 127   | 5053        | 5501        | -1822                | 13519                 | 0                    | 13519                     | 3120             | 16639           | 50.04         |
| 14                 | 3805        | 211  | 404  | 4420   | 1971  | 3092      | 0    | 141   | 4939        | 5239        | -1671                | 13192                 | 0                    | 13192                     | 2992             | 16184           | 50.01         |
| 15                 | 3816        | 171  | 408  | 4395   | 2217  | 3095      | 0    | 139   | 4923        | 4974        | -1683                | 13137                 | 0                    | 13137                     | 2984             | 16121           | 50.00         |
| 16                 | 3792        | 153  | 410  | 4355   | 2246  | 2968      | 0    | 126   | 4913        | 4861        | -1643                | 12913                 | 0                    | 12913                     | 2943             | 15856           | 50.02         |
| 17                 | 3864        | 91   | 425  | 4380   | 2215  | 2805      | 0    | 83    | 4526        | 4898        | -1632                | 12749                 | 0                    | 12749                     | 2908             | 15657           | 50.04         |
| 18                 | 3876        | 334  | 413  | 4623   | 1945  | 2851      | 0    | 32    | 4248        | 4579        | -1504                | 12526                 | 0                    | 12526                     | 2859             | 15385           | 50.02         |
| 19                 | 3980        | 305  | 412  | 4697   | 1849  | 3047      | 0    | 5     | 4671        | 4855        | -1418                | 13035                 | 0                    | 13035                     | 2807             | 15842           | 49.95         |
| 20                 | 4281        | 388  | 411  | 5080   | 1666  | 3585      | 0    | 0     | 4802        | 4932        | -1427                | 13836                 | 0                    | 13836                     | 2803             | 16639           | 49.96         |
| 21                 | 4348        | 192  | 400  | 4940   | 1637  | 3732      | 0    | 0     | 4763        | 4644        | -1263                | 13690                 | 0                    | 13690                     | 2691             | 16381           | 49.94         |
| 22                 | 4146        | 155  | 409  | 4710   | 1644  | 3681      | 0    | 0     | 4619        | 4513        | -1187                | 13361                 | 0                    | 13361                     | 2566             | 15927           | 49.94         |
| 23                 | 4156        | 173  | 410  | 4739   | 1438  | 3606      | 0    | 0     | 4300        | 4448        | -1172                | 13059                 | 0                    | 13059                     | 2408             | 15467           | 49.97         |
| 24                 | 4067        | 244  | 422  | 4733   | 1300  | 3266      | 0    | 0     | 4165        | 4494        | -1173                | 12620                 | 0                    | 12620                     | 2332             | 14952           | 49.99         |
| MUs                | 97.73       | 6.48 | 9.78 | 113.99 | 43.94 | 80.24     | 0.00 | 1.17  | 110.01      | 113.22      | -31.53               | 321.03                | 0.00                 | 321.03                    | 61.10            | 382.12          | 49.98         |

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 28/Jul/2017**

**Position as on 6.30 Hrs of 29/Jul/2017**

| Generating Company    | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date | Sync. Time | Reason of Outage                                                                                                                                                 | Expected Date |
|-----------------------|-------------------------|----------|--------------|--------------|-----------|------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|---------------|
| <b>PLANNED OUTAGE</b> |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| TPC-G                 | Trombay 6               | 500      | 15/07/2015   | 17.08        |           | Continued. | Economic shutdown.                                                                                                                                               |               |
| CENT.SECTOR           | TARAPUR 4               | 540      | 23/04/2017   | 19:55        |           | Continued. | Annual Maintenance                                                                                                                                               |               |
| CENT.SECTOR           | Tarapur 1               | 160      | 04/06/2017   | 19.09        |           | Continued. | 3 months outage for refuelling.                                                                                                                                  |               |
| MSPGCL                | Khaparkheda Unit 2      | 210      | 14/06/2017   | 23.16        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| MSPGCL                | Koradi Unit 7           | 210      | 21/06/2017   | 01.24        |           | Continued. | COH.                                                                                                                                                             |               |
| IPP                   | JSW (J) U4              | 300      | 04/07/2017   | 20.41        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| CENT.SECTOR           | TARAPUR-3               | 540      | 11/07/2017   | 16.30        |           | Continued. | Reactor Inspection Work                                                                                                                                          |               |
| IPP                   | Adani U-3               | 660      | 14/07/2017   | 23.48        |           | Continued. | Annual Overhaul                                                                                                                                                  |               |
| MSPGCL                | Bhusawal Unit 5         | 500      | 15/07/2017   | 05.59        |           | Continued. | Zero Schedule By MSEDCL (Converted to AOH from 00:00Hrs of 20.07.2017)                                                                                           |               |
| <b>FORCED OUTAGE</b>  |                         |          |              |              |           |            |                                                                                                                                                                  |               |
| RGPL                  | Dabhol 1B               | 230      | 28/05/2013   | 22:02        |           | Continued. | Gas Shortage.                                                                                                                                                    |               |
| RGPL                  | Dabhol 1X               | 290      | 27/06/2013   | 21.46        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| RGPL                  | Dabhol 1A               | 230      | 27/06/2013   | 21.47        |           | Continued. | Gas Shortage                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 6           | 210      | 09/07/2015   | 00.00        |           | Continued. | EE R&M LE Work                                                                                                                                                   |               |
| IPP                   | SWPGL U-1               | 135      | 16/02/2016   | 17.09        |           | Continued. | No PPA.                                                                                                                                                          |               |
| IPP                   | SWPGL U-2               | 135      | 29/02/2016   | 21.46        |           | Continued. | No PPA                                                                                                                                                           |               |
| MSPGCL                | Parli Unit 4            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Parli Unit 5            | 210      | 01/04/2016   | 00.00        |           | Continued. | Economic shutdown                                                                                                                                                |               |
| MSPGCL                | Bhusawal Unit 2         | 210      | 14/06/2016   | 19.35        |           | Continued. | Boiler Tube Leakage(Converted to Zero Shedule By MSEDCL. from 00.00Hrs dt.19-6-16)                                                                               |               |
| MSPGCL                | Uran Unit 8             | 108      | 14/08/2016   | 07.56        |           | Continued. | Maintenance work                                                                                                                                                 |               |
| RGPL                  | Dabhol 2A               | 230      | 24/08/2016   | 13.31        |           | Continued. | Change Over.                                                                                                                                                     |               |
| MSPGCL                | Koradi Unit 5           | 200      | 05/09/2016   | 00.21        |           | Continued. | ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work |               |
| PGPL                  | PGPL U1                 | 262      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                                      |               |
| PGPL                  | PGPL U2                 | 126      | 07/02/2017   | 17.30        |           | Continued. | No Schedule                                                                                                                                                      |               |
| IPP                   | RPL(AMT) U-1            | 270      | 24/05/2017   | 03.27        |           | Continued. | Flame Failure(converted to Zero Schedule from 00.00Hrs DT.13th Jun 17)                                                                                           |               |
| IPP                   | JSW (J) U2              | 300      | 31/05/2017   | 23.58        |           | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| IPP                   | Dhariwal                | 300      | 01/06/2017   | 00.01        |           | Continued. | NO SCHEDULE.                                                                                                                                                     |               |
| IPP                   | RPL(AMT) U-3            | 270      | 05/06/2017   | 14.31        |           | Continued. | swapping with unit-5(converted to Zero Schedule from 00.00Hrs DT.15th Jun 17)                                                                                    |               |

**State Load Despatch Center,Airoli (MSETCL)      Statement-VI**  
**Details of Generating Unit Outages/Trippings for 28/Jul/2017**

**Position as on 6.30 Hrs of 29/Jul/2017**

| Generating Company | Name of Generating Unit | Capacity | Tripped Date | Tripped Time | Sync.Date  | Sync. Time | Reason of Outage                                                     | Expected Date |
|--------------------|-------------------------|----------|--------------|--------------|------------|------------|----------------------------------------------------------------------|---------------|
| IPP                | RPL(AMT) U-4            | 270      | 09/06/2017   | 00.20        |            | Continued. | Zero Schedule by MSEDCL                                              |               |
| IPP                | RPL(AMT) U-5            | 270      | 09/06/2017   | 01.39        |            | Continued. | Zero Schedule by MSEDCL                                              |               |
| IPP                | RPL(AMT) U-2            | 270      | 09/06/2017   | 04.24        |            | Continued. | Zero Schedule by MSEDCL                                              |               |
| MSPGCL             | Parli Unit 7            | 250      | 13/06/2017   | 00.04        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Bhusawal Unit 3         | 210      | 13/06/2017   | 06.01        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| IPP                | VIPL U-1                | 300      | 13/06/2017   | 08.30        |            | Continued. | GT WORK                                                              |               |
| MSPGCL             | Parli Unit 6            | 250      | 14/06/2017   | 00.02        |            | Continued. | Zero schedule by MSEDCL.                                             |               |
| MSPGCL             | Parli Unit 8            | 250      | 17/06/2017   | 00.08        |            | Continued. | Zero Schedule by MSEDCL                                              |               |
| MSPGCL             | Nasik Unit 4            | 210      | 10/07/2017   | 14.28        |            | Continued. | Boiler validity extention.on date 12/07/2017 converted zero schedule |               |
| MSPGCL             | Khaparkheda Unit 1      | 210      | 11/07/2017   | 23.53        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Khaparkheda Unit 3      | 210      | 12/07/2017   | 08.40        |            | Continued. | Boiler Tube Leakage. on date 13.07.2017 converted to zero schedule.  |               |
| MSPGCL             | Khaparkheda Unit 4      | 210      | 13/07/2017   | 03.36        |            | Continued. | Drum level low. on Dated 14.07.2017 converted to zero schedule.      |               |
| MSPGCL             | Nasik Unit 5            | 210      | 16/07/2017   | 00.00        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Bhusawal Unit 4         | 500      | 17/07/2017   | 23.46        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| TPC-G              | Trombay 7B              | 60       | 21/07/2017   | 23.20        | 28/07/2017 | 22.09      | Gas Path Inspection and CW Tunnel repairs (For 8 Days)               |               |
| TPC-G              | Trombay 7A              | 120      | 22/07/2017   | 02.51        | 28/07/2017 | 12.27      | Gas Path Inspection and CW Tunnel repairs (For 8 Days)               |               |
| MSPGCL             | Khaparkheda Unit 5      | 500      | 25/07/2017   | 00.00        |            | Continued. | Zero Schedule By MSEDCL                                              |               |
| MSPGCL             | Chandrapur Unit 4       | 210      | 26/07/2017   | 13.36        | 28/07/2017 | 23.49      | Boiler Tube Leakage                                                  |               |
| CPP                | SWPGL U-3               | 135      | 27/07/2017   | 13.00        |            | Continued. | ID Fan Problem                                                       |               |
| MSPGCL             | Ghatghar Unit-1         | 125      | 28/07/2017   | 00.00        |            | Continued. | rbtv leakage attending work.                                         |               |
| MSPGCL             | Ghatghar Unit-2         | 125      | 28/07/2017   | 00.00        |            | Continued. | due to common pressure shaft with unit 1.                            |               |

**State Load Despatch Center, Airoli (MSETCL)**  
**Details of Line outages/Trippings for 28/Jul/2017**

**Statement-VII**

Position as on 6.30 Hrs of 29/Jul/2017

| Name of Line                         | Inter State / Intra State | Tripped Date | Tripped Time | Sync. Date | Sync. Time | Outage Type | Reason of Outage                                                                                                    |
|--------------------------------------|---------------------------|--------------|--------------|------------|------------|-------------|---------------------------------------------------------------------------------------------------------------------|
| <b>400 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Karad Solapur (PG)                   | InterState                | 03/05/2017   | 11:49        |            | Continued. | PO          | Line converted as 220 kV Solapur (PG)- Jeur from LOC 403                                                            |
| Parli(MS)-Parli (PG) I               | InterState                | 26/07/2017   | 12.50        |            | Continued. | PO          | online installation of abt meter.                                                                                   |
| Dhule Sar'Sarovar II                 | InterState                | 27/07/2017   | 13.13        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Khadka-Aurangabad (Waluj)            | IntraState                | 12/07/2017   | 18.11        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Ektuni-Bableshwar ckt II             | IntraState                | 16/07/2017   | 16.05        |            | Continued. | HT          | To control load                                                                                                     |
| karad -kolhapur-I                    | IntraState                | 20/07/2017   | 09.38        |            | Continued. | HT          | Over Voltage                                                                                                        |
| Jaigad-Karad Ckt-I                   | IntraState                | 27/07/2017   | 17.46        | 28/07/2017 | 06.42      | HT          | Over Voltage                                                                                                        |
| Jaigad-New Koyna Ckt-II              | IntraState                | 28/07/2017   | 06.02        | 28/07/2017 | 10.02      | T           | Distance Protection                                                                                                 |
| Karad-Jaigad - I                     | IntraState                | 28/07/2017   | 17.00        |            | Continued. | HT          | Over Voltage                                                                                                        |
| <b>400 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 400/220 Kv 500 Mva Ict 1 @Lamboti    | IntraState                | 27/07/2017   | 16.43        | 28/07/2017 | 00.01      | PO          | outage for ctr commissioning.                                                                                       |
| 400/220kv, 500 MVA ICT-II @Deepnagar | IntraState                | 28/07/2017   | 09.00        | 28/07/2017 | 18.28      | PO          | Testing Work                                                                                                        |
| <b>220 KV LINE Outages/Trippings</b> |                           |              |              |            |            |             |                                                                                                                     |
| Talandage - Chikodi                  | InterState                | 01/06/2017   | 00.01        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Mudshingi - Chikodi                  | InterState                | 01/06/2017   | 00.06        |            | Continued. | PO          | NO SCHEDULE.                                                                                                        |
| Chandrapur GCR - Warora - I          | IntraState                | 05/04/2015   | 09.13        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Chandrapur GCR - Wani                | IntraState                | 05/04/2015   | 09.15        |            | Continued. | PO          | Bunching of conductor Loc no 86 Disconnecting of jumer at Loc no 86 & 107 and de-energising the line bet.86 to 107. |
| Kharghar-Borivali ckt II             | IntraState                | 07/06/2017   | 12.23        |            | Continued. | T           | Distance Protection                                                                                                 |
| Vita - Mhaishal                      | IntraState                | 01/07/2017   | 14.19        |            | Continued. | PO          | Bunching Work                                                                                                       |
| Vita - Miraj                         | IntraState                | 01/07/2017   | 14.53        |            | Continued. | PO          | bunching work.                                                                                                      |
| Karad - Sadawagpur I                 | IntraState                | 21/07/2017   | 11.07        |            | Continued. | T           | Distance Protection                                                                                                 |
| Pedambe-Nerle                        | IntraState                | 27/07/2017   | 16.16        | 28/07/2017 | 14.06      | T           | Distance Protection                                                                                                 |
| Versova Aarey Line 1                 | IntraState                | 28/07/2017   | 09.43        | 28/07/2017 | 19.33      | PO          | Isolator Maintenance work.                                                                                          |
| Mahape - TIFIL                       | IntraState                | 28/07/2017   | 11.00        | 28/07/2017 | 16.50      | PO          | Attending Hot Spot                                                                                                  |
| Jejuri-Phursungi 2                   | IntraState                | 28/07/2017   | 12.41        | 28/07/2017 | 13.35      | PO          | shifted on TBC at phursungi end                                                                                     |
| Jambhul - Pal                        | IntraState                | 28/07/2017   | 14.48        | 28/07/2017 | 17.37      | PO          | Attending Hot Spot                                                                                                  |
| Pedambe-Nerle                        | IntraState                | 28/07/2017   | 15.00        |            | Continued. | T           | Distance Protection                                                                                                 |
| <b>220 KV ICT Outages/Trippings</b>  |                           |              |              |            |            |             |                                                                                                                     |
| 220/100 Kv 200 MVA ICT III @Borivali | IntraState                | 21/09/2014   | 09.16        |            | Continued. | T           | Failed on internal Fault(Now repaired and ready for commissioning)                                                  |

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage