

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Aug/2023 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.808	3645.502	1) Gujrat	14.826	361.599
2) Hydro	13.981	449.480	2) Madhya Pradesh	7.625	226.227
3) Gas	4.538	53.323	3) Chattisgarh	1.730	49.140
Total MSPGCL	162.327	4148.305	4) Maharashtra	177.866	4648.402
B) 1) APML	52.752	1538.369	5) Goa (Amona)	-1.579	-44.126
2) JSWEL	19.954	472.756	Total	200.468	5241.242
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.135	880.066
4) RPL(AMT)	25.638	752.429	b) Mumbai Drawl	35.514	981.579
5) SWPGPL	12.099	280.452	c) MSEDCL Bilateral *	96.832	2605.746
6) Other IPP	6.620	174.090	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.135	880.056
C) 1) TPCL Thermal	11.524	340.884	Include PX	0.000	0.000
2) TPCL Hydro	6.050	163.044	Standby	0.000	0.011
3) TPCL Gas	3.428	74.060	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.899	258.767	1) MSEDCL	484.602	12805.828
D) STATE			2) Mumbai Discoms	66.415	1818.330
1) Thermal	282.294	7463.249	3) Other Discoms	10.621	281.666
(A1+C1+C4+(B1-B6))			TOTAL STATE	561.638	14905.824
2) Hydro	20.031	612.524			
(A2+C2)					
3) Gas	7.966	127.383			
(A3+B7+C3)					
4) Wind	35.613	1138.071			
6) SOLAR	15.266	323.359			
TOTAL STATE	361.170	9664.586			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 2 Hrs
MSPGCL Thermal	5799	5958	5950	6290
MSPGCL Hydro	485	266	1295	239
MSPGCL Gas	142	229	234	188
MSPGCL Total Generation	6426	6453	7479	6717
Central Sector Receipt	10213	9756	8189	6493
WIND	1616	1936	1349	1416
CPP / IPP Thermal	4508	4465	5291	5097
CPP / IPP Gas	0	0	0	0
SOLAR	1814	1383	0	0
Exchange with Mumbai	-2187	-2012	-1255	-1066
MSEDCL DEMAND MET	21925	21509	20561	18290
Load Shedding	0	0	0	0
MSEDCL DEMAND	21925	21509	20561	18290
TPCL GENERATION	690	777	1275	753
AEML GENERATION	499	467	501	320
MUMBAI DEMAND	3376	3256	3031	2139
OTHER DISCOM DEMAND	465	472	492	367
STATE DEMAND MET	25766	25237	24084	20796
STATE DEMAND	25766	25237	24084	20796
Frequency (Hz)	49.98	50.02	50.03	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.27 Hz at 09.58 Hrs	49.81 Hz at 11.53 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	88.32	160	105
Unit 8	12.35	274.15	574	380
Unit 9	11.85	341.30	533	429
Unit 10	0.00	0.00	0	0
Total	27.59	703.77		
Bhusawal				
Unit 3	3.02	85.56	140	110
Unit 4	10.08	233.00	455	370
Unit 5	9.83	259.12	445	360
Total	22.94	577.67		
Parli				
Unit 6	4.69	97.26	240	150
Unit 7	4.84	97.64	238	144
Unit 8	3.95	89.70	201	150
Total	13.47	284.60		
Chandrapur				
Unit 3	3.63	83.74	163	123
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.79	167.87	390	265
Unit 7	6.84	197.08	305	260
Unit 8	9.81	283.47	435	370
Unit 9	10.58	284.33	468	418
Total	38.67	1016.48		
Paras				
Unit 3	4.77	116.73	220	151
Unit 4	5.11	129.64	230	153
Total	9.88	246.36		
Khaparkheda				
Unit 1	3.42	63.50	165	115
Unit 2	2.74	75.47	123	100
Unit 3	3.78	99.08	179	133
Unit 4	4.02	110.47	177	154
Unit 5	9.89	272.46	440	370
Total	23.84	620.98		
Nasik				
Unit 3	0.00	46.24	0	0
Unit 4	3.74	85.98	173	118
Unit 5	3.68	63.40	165	127
Total	7.43	195.63		
Uran				
All Units	4.54	53.32	240	114
Total	4.54	53.32		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.64	21.29	49	0
Total	0.64	21.29		
Koyna				
Stage 1-2	2.12	82.65	280	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	4.36	147.03	752	0
Stage 3	1.66	55.31	240	0
Total	8.14	284.99		
Hydro				
KDPH	0.86	8.87	36	36
VTRNA	0.00	0.73	0	0
TILLARI	0.00	2.10	0	0
BHIRA T.R.	0.46	12.58	80	0
SMLHY_PTN	3.55	110.59	150	143
GHATGHAR	0.33	8.32	125	0
Total	5.20	143.19		
Wind				
Total	35.61	1138.07	0	0
Total	35.61	1138.07		
CPP				
APML(Mus)	52.75	1538.37	0	0
JSWEL(Mus)	19.95	472.76	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.64	752.43	0	0
SWPGPL-Mus	12.10	280.45	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.92	146.19	254	205
Other(Mus)	0.70	27.90	0	0
Total	117.06	3218.10		
SOLAR				
Total	15.27	323.36	0	0
Total	15.27	323.36		
Tata				
Trombay 5	7.65	225.30	451	263
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.09	44.17	108	39
Trombay 7B	1.34	29.89	65	35
TATA Hydro	6.05	163.04	432	135
Trombay 8	3.87	115.59	222	129
Total	21.00	577.99		
AEML				
DTPS U-1&2	9.90	258.77	502	299
Total	9.90	258.77		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.81	3645.50	MSPGCL Total	162.33	4148.30
			MSPGCL Thml+Gas	148.35	3698.82	Koyna 1,2 & 4 Total	6.49	229.68
			MSPGCL Hydro	13.98	449.48	State Total	361.17	9664.59

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6316	256	188	6760	1334	5133	0	0	6645	6408	-1062	18193	0	0	18193	2300	380	20873	50.01
2	6290	239	188	6717	1416	5097	0	0	6791	6493	-1066	18290	0	0	18290	2139	367	20796	49.99
3	6216	264	188	6668	1438	4821	0	0	6987	6895	-1012	18458	0	0	18458	2022	352	20832	49.96
4	6190	249	188	6627	1450	4910	0	0	7041	7057	-948	18743	0	0	18743	1957	353	21053	50.01
5	6204	238	188	6630	1198	5165	0	0	7608	7286	-946	18983	0	0	18983	1954	350	21287	50.02
6	6141	291	160	6592	1274	5368	0	0	8407	7990	-954	19889	0	0	19889	2082	381	22352	49.99
7	6114	1089	114	7317	1243	5365	0	113	8759	8427	-1040	21009	0	0	21009	2272	416	23697	49.98
8	6148	643	115	6906	1139	5291	0	532	9423	9098	-1351	21167	0	0	21167	2492	448	24107	50.03
9	6030	304	121	6455	1340	4957	0	1109	9607	9483	-1896	20985	0	0	20985	2844	463	24292	50.08
10	6073	265	145	6483	1664	5030	0	1604	9433	9486	-2196	21594	0	0	21594	3142	477	25213	50.09
11	5917	273	136	6326	1707	4689	0	1716	10080	10188	-2265	21875	0	0	21875	3339	486	25700	50.00
12	5799	485	142	6426	1616	4508	0	1814	10223	10213	-2187	21925	0	0	21925	3376	465	25766	49.98
13	5780	213	155	6148	1788	4403	0	1998	10145	9547	-2154	21262	0	0	21262	3317	468	25047	49.97
14	5486	235	185	5906	1831	3901	0	1990	10084	9832	-2046	20955	0	0	20955	3196	459	24610	49.98
15	5713	348	228	6289	1815	3913	0	1677	9919	10148	-2098	21291	0	0	21291	3222	453	24966	49.97
16	5958	266	229	6453	1936	4465	0	1383	9760	9756	-2012	21509	0	0	21509	3256	472	25237	50.02
17	5921	282	231	6434	2002	4939	0	929	8953	8947	-1838	20915	0	0	20915	3207	498	24620	50.01
18	5961	315	225	6501	1624	5092	0	365	8809	8680	-1696	20057	0	0	20057	3157	509	23723	50.04
19	5959	444	240	6643	1453	5290	0	36	8689	8218	-1365	19783	0	0	19783	3058	492	23333	50.06
20	5950	1295	234	7479	1349	5291	0	0	8496	8189	-1255	20561	0	0	20561	3031	492	24084	50.03
21	5917	1588	237	7742	1229	5226	0	0	7277	7402	-1152	19959	0	0	19959	2919	488	23366	50.04
22	5915	1587	230	7732	1237	4800	0	0	7199	7094	-1052	19331	0	0	19331	2795	480	22606	50.02
23	5917	1508	235	7660	1254	4696	0	0	7125	6946	-986	19126	0	0	19126	2703	444	22273	50.00
24	5893	1302	236	7431	1276	4713	0	0	6976	6687	-937	18740	0	0	18740	2635	430	21805	50.03
MUs	143.81	13.98	4.54	162.33	35.61	117.06	0.00	15.27	204.44	200.47	-35.51	484.60	0.00	0.00	484.60	66.41	10.62	561.64	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Aug/2023

Position as on 6.30 Hrs of 29/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	07/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	31/08/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	30/08/2023
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	02/09/2023
MSPGCL	Nasik Unit 3	210	13/08/2023	16:00		Continued.	Boiler Tube Leakage (Tolling from 15:00 hrs on Dt 14.08.2023.)	
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Uran Unit B0	120	26/08/2023	22:00		Continued.	GOVERNOR ISSUE	
MSPGCL	Uran Unit 7	108	26/08/2023	23:13		Continued.	Load Hunting problem	
IPP	Adani U-1	660	28/08/2023	21:21		Continued.	Due to APH A Hot SA heavy bellow leakage.	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 29/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
DHULE - KHANDWA CKT - 1	InterState	28/08/2023	10:14	28/08/2023	19:57	HT	Planned outage by powergrid
PADGHE - TARAPUR CKT - 1	InterState	28/08/2023	12:09	28/08/2023	14:00	T	Tripped on Distance protection.
PADGHE - TARAPUR CKT - 1	InterState	28/08/2023	14:26	28/08/2023	18:07	T	Tripped on distance protection
DHULE - KHANDWA CKT - 2	InterState	29/08/2023	09:23			PO	For Reactor AMP works KHANDWA-2 L/R@ DHULE-MS � as per OCC Sr. 937
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of ȳȳ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	24/08/2023	06:20			HT	H/T to control loading
KHADKA-AURANGABAD (WALUJ)	IntraState	27/08/2023	19:41	28/08/2023	07:14	HT	H/T FOR O/V
PARLI-SOLAPUR (LAMBOTI)	IntraState	28/08/2023	05:05	28/08/2023	07:04	T	Tripped only at parli end
KORADI II - KORADI III CKT - 1	IntraState	28/08/2023	09:34	28/08/2023	21:45	PO	Annual Maintenance of Line equipment at Koradi III SS
KHADKA-AURANGABAD (WALUJ)	IntraState	28/08/2023	20:12	29/08/2023	06:56	HT	H/T on overvoltage
DABHOL - NEW KOYNA CKT - 1	IntraState	29/08/2023	09:15			PO	PID Faulty String insulators replacement
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
95 MVA STN TF - II @KORADI 2	IntraState	28/08/2023	09:18	28/08/2023	21:48	PO	1) Removal/dismantling of of Rph , Yph & Bph metering CT from Station Transformer-II Bay 407. 2) Routine Bay maintenance work.
400/220 KV 167 MVA ICT @ PARLI	IntraState	28/08/2023	10:09	28/08/2023	18:12	PO	(1) Winding Resistance testing work. (2) Bay maintenance work.
220 KV MAINBAY Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	28/08/2023	10:40	28/08/2023	15:04	PO	CT Tan D
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
APTA - KALWA	IntraState	27/08/2023	16:19	28/08/2023	03:37	T	TRIPPED ON DISTANCE PROTECTION
ACCIL - APTA	IntraState	27/08/2023	18:51	28/08/2023	08:15	T	TRIPPED ON DISTANCE PROTECTION
TROMBAY SALSETTE LINE-2	IntraState	27/08/2023	23:35	28/08/2023	04:56	PO	Project work- for Stringing of OPGW in span 92-93 of Trombay Dharavi Salsette line corridor Pulling back OPGW to tower no. 59 (from 58) at Vikhroli RSS

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 29/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HINJAWADI I- CHINCHWAD	IntraState	28/08/2023	07:21	28/08/2023	21:27	PO	On. 24.08.23 Thursday a) Conductor paying out & Final sag (Location 160 to 161) & Top Ckt b) Installation of Missing parts & final checking of Monopole (160 & 161) On. 25.08.23 Friday a) Conductor paying out & Final Sag (Location 161 a to 162) & Top Ckt b) Installation of Missing parts & final checking of Monopole (161A&162) On. 26.08.23 Saturday Conductor paying out & Final sag(Location 161 to 161 A) & Circuit I & Top circuit On. 27.08.23 Sunday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Top Circuit On. 28.08.23 Monday Conductor paying out & Final sag (Location 161 to 161 A) & Circuit I & Bottom Circuit On. 29.08.23 Tuesday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Bottom Circuit
ONI KHAREPATAN LINE	IntraState	28/08/2023	09:04	28/08/2023	13:25	PO	Diagnostic testing of bay equipments at Kharepatan end.
220 KV CHALISGAON - KHADKA CKT -1	IntraState	28/08/2023	09:43	28/08/2023	13:15	PO	For Disc Replacement.
TALANDGE - ICHALKARANJI 2	IntraState	28/08/2023	09:50	28/08/2023	15:46	PO	1) 220kV Talandge- Tilwani ckt-1 will be in service. 2)For load management on 220 kV Talandage -Tilawani CKT I , 220 kV Miraj -Tilawani line will be kept off at 220 kV Tilawani end .
220 KV PARAS - MALKAPUR CKT	IntraState	28/08/2023	10:15	28/08/2023	15:43	PO	For Replacement Of Flashover Insulator String.
BOMBAY DYEING - SAHARA	IntraState	28/08/2023	11:43	28/08/2023	19:46	PO	For OPGW installation work on T. No .99 & T. No .105. The existing earth wire is missing in this section.
KHAREPATAN -PAWAS LINE	IntraState	28/08/2023	14:09	28/08/2023	16:21	PO	Diagnostic testing of bay equipments at Kharepatan end
ADLABS - PEDAMBE	IntraState	28/08/2023	16:53	28/08/2023	22:48	T	Tripped on distance protection

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 29/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HINJAWADI I- CHINCHWAD	IntraState	29/08/2023	07:05			PO	On. 24.08.23 Thursday a) Conductor paying out & Final sag (Location 160 to 161) & Top Ckt b) Installation of Missing parts & final checking of Monopole (160 & 161) On. 25.08.23 Friday a) Conductor paying out & Final Sag (Location 161 a to 162) & Top Ckt b) Installation of Missing parts & final checking of Monopole (161A&162) On. 26.08.23 Saturday Conductor paying out & Final sag(Location 161 to 161 A) & Circuit I & Top circuit On. 27.08.23 Sunday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Top Circuit On. 28.08.23 Monday Conductor paying out & Final sag (Location 161 to 161 A) & Circuit I & Bottom Circuit On. 29.08.23 Tuesday Conductor paying out & Final sag (Location 161 to 161 A) & circuit & II & Bottom Circuit
GHATGHAR - JINDAL	IntraState	29/08/2023	08:40			PO	220kv Ghat-jindal line. For flashover disc Insulator replacement work at loc no 49,50. (B ph) 220KV Ghatghar-Washala line Required outage for safety to work on Jindal-Ghatghar line due to M/C tower.
WASHALA - GHATGHAR	IntraState	29/08/2023	08:44			PO	220kv Ghat-jindal line. For flashover disc Insulator replacement work at loc no 49,50. (B ph) 220KV Ghatghar-Washala line Required outage for safety to work on Jindal-Ghatghar line due to M/C tower.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132 KV 200 MVA ICT 4	IntraState	28/08/2023	10:16	28/08/2023	17:57	PO	Routine Maintenance Work.
220/132 KV 150 MVA ICT 2 @ EKLAHRE (GCR)	IntraState	28/08/2023	10:45	28/08/2023	15:46	PO	For CTR Maintenance Works & Trials
220/132 KV 200 MVA ICT 1	IntraState	28/08/2023	11:23	28/08/2023	14:51	PO	Backup And Differential Relay Testing Work.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage