

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Sep/2017 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	106.403	2931.697	1) Gujrat	1.368	26.528
2) Hydro	9.507	394.594	2) Madhya Pradesh	13.772	393.096
3) Gas	6.337	204.663	3) Chattisgarh	6.310	170.620
Total MSPGCL	122.247	3530.954	4) Maharashtra Net	105.115	2650.555
B) 1) APML	61.931	1362.438	5) Goa (Amona)	0.000	-2.860
2) JSWEL	27.610	587.953	Total	126.565	3237.939
3) VIPL	7.486	198.480	a) Mumbai Schedule	29.777	641.695
4) RPL(AMT)	20.233	618.407	b) Mumbai Drawl	33.317	776.576
5) WPCL	3.164	67.526	c) MSEDCL Bilateral *	19.971	503.751
6) PGPL	0.000	0.000	Include PX	1.142	42.200
7) Other IPP	4.122	77.785	d) Mumbai Bilateral *	29.337	637.545
C) 1) TPCL Thermal	17.344	445.656	Include PX	7.762	123.560
2) TPCL Hydro	6.129	121.850	Include Standby	0.440	4.150
3) TPCL Gas	3.244	74.558	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	5.910	269.119	1) MSEDCL	349.334	9279.746
D) STATE			2) Mumbai Discoms	65.944	1687.765
1) Thermal	254.203	6559.061	TOTAL STATE	415.278	10967.511
(A1+C1+C4+(B1-B6))					
2) Hydro	15.636	516.444			
(A2+C2)					
3) Gas	9.581	279.221			
(A3+B6+C3)					
4) Wind	7.100	318.909			
6) SOLAR	2.193	55.931			
TOTAL STATE	288.713	7729.566			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	4354	4395	4858	4429
MSPGCL Hydro	1036	908	468	91
MSPGCL Gas	254	252	259	262
MSPGCL Total Generation	5644	5555	5585	4782
Central Sector Receipt	5781	5920	5325	4443
WIND	108	258	431	251
CPP / IPP Thermal	5205	5187	5221	5131
CPP / IPP Gas	0	0	0	0
SOLAR	310	181	0	0
Exchange with Mumbai	-1783	-1674	-1525	-964
MSEDCL DEMAND MET	15265	15428	15037	13643
Load Shedding	780	407	330	0
MSEDCL DEMAND	16045	15835	15367	13643
TPCL GENERATION	1261	1325	1335	790
R-INFRA GENERATION	248	250	251	222
MUMBAI DEMAND	3292	3249	3111	1976
STATE DEMAND MET	18557	18677	18148	15619
STATE DEMAND	19337	19084	18478	15619
Frequency (Hz)	49.98	49.91	49.98	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.12 Hz at 17.01 Hrs	49.75 Hz at 00.05 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 28/Sep/2017

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	34.12	0	0
Unit 8	10.83	304.98	476	385
Unit 9	0.00	69.47	0	0
Unit 10	9.32	233.30	502	303
Total	20.16	641.87		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	7.60	202.30	365	300
Unit 5	7.64	225.71	360	300
Total	15.25	428.02		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	4.17	124.11	182	167
Unit 7	2.65	120.17	176	0
Unit 8	2.75	2.75	188	0
Total	9.58	247.04		
Chandrapur				
Unit 3	0.00	44.56	0	0
Unit 4	0.00	0.00	0	0
Unit 5	7.91	205.97	400	0
Unit 6	0.00	66.75	0	0
Unit 7	9.48	186.54	410	351
Unit 8	9.33	285.51	500	330
Unit 9	9.23	202.06	442	333
Total	35.95	991.38		
Paras				
Unit 3	4.09	113.10	183	165
Unit 4	4.00	111.27	177	156
Total	8.08	224.37		
Khaparkheda				
Unit 1	0.00	24.14	0	0
Unit 2	0.00	79.84	0	0
Unit 3	0.00	36.38	0	0
Unit 4	0.00	0.00	0	0
Unit 5	9.56	54.49	500	360
Total	9.56	194.85		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.90	113.29	168	157
Unit 5	3.92	90.89	170	160
Total	7.83	204.18		
Uran				
All Units	6.34	204.66	280	252
Total	6.34	204.66		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
PENCH (MS)				
Pench (MS)	0.03	1.11	17	0
Total	0.03	1.11		
Koyna				
Stage 1-2	2.94	108.32	385	30
Stage 4	2.93	168.75	495	0
Stage 3	1.58	67.77	160	0
Total	7.46	344.83		
Hydro				
KDPH	0.76	7.98	32	31
VTRNA	0.43	10.58	61	0
TILLARI	0.00	1.63	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.41	9.27	80	0
RNGR+BHTSA	0.32	6.82	14	13
BHANDARDRA	0.03	4.54	14	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.11	8.95	5	4
GHATGHAR	0.00	0.00	0	0
Total	2.05	49.76		
Wind				
Total	7.10	318.91	0	0
Total	7.10	318.91		
CPP				
APML(Mus)	61.93	1362.44	0	0
JSWEL(Mus)	27.61	587.95	0	0
VIPL(Mus)	7.49	198.48	0	0
RPLAMT(Mus)	20.23	618.41	0	0
WPCL(Mus)	3.16	67.53	0	0
Other(Mus)	4.12	77.78	0	0
Total	124.55	2912.59		
SOLAR				
Total	2.19	55.93	0	0
Total	2.19	55.93		
Tata				
Trombay 5	11.51	292.06	490	409
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.90	42.76	102	64
Trombay 7B	1.34	31.80	63	51
Trombay 8	5.83	153.60	249	200
TATA Hydro	6.13	121.85	459	0
Total	26.72	642.06		
R-INFRA				
DTPS U-1&2	5.91	269.12	251	197
Total	5.91	269.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	106.40	2931.70	MSPGCL Total	122.25	3530.95
			MSPGCL Thml+Gas	112.74	3136.36	Koyna 1,2 & 4 Total	5.87	277.06
			MSPGCL Hydro	9.51	394.59	State Total	288.71	7729.57

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 28/Sep/2017

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4219	194	259	4672	470	5145	0	0	4651	4806	-1399	13694	0	13694	2518	16212	49.92
2	4336	192	272	4800	366	5164	0	0	4449	4440	-1137	13633	0	13633	2214	15847	49.97
3	4369	116	271	4756	289	5182	0	0	4360	4517	-1130	13614	0	13614	2051	15665	49.94
4	4429	91	262	4782	251	5131	0	0	4417	4443	-964	13643	0	13643	1976	15619	50.00
5	4522	91	273	4886	211	5168	0	0	4683	4644	-873	14037	0	14037	1963	16000	49.98
6	4476	131	262	4869	301	5221	0	0	4975	5179	-948	14622	84	14706	2038	16744	49.92
7	4400	126	273	4799	287	5163	0	7	5536	5860	-1064	15052	469	15521	2165	17686	49.92
8	4338	111	264	4713	287	5103	0	63	5854	5898	-1140	14923	489	15412	2324	17736	49.97
9	4306	251	261	4818	170	5079	0	151	5405	5576	-1400	14394	382	14776	2745	17521	49.94
10	4271	547	267	5085	170	5140	0	226	5710	5634	-1444	14811	426	15237	2931	18168	49.94
11	4368	411	254	5033	146	5196	0	283	5839	6023	-1698	14983	546	15529	3227	18756	49.98
12	4354	1036	254	5644	108	5205	0	310	5864	5781	-1783	15265	780	16045	3292	19337	49.98
13	4339	592	262	5193	83	5203	0	326	5825	5688	-1723	14770	927	15697	3281	18978	49.97
14	4378	437	253	5068	128	5199	0	273	5678	5641	-1608	14701	866	15567	3156	18723	50.00
15	4410	818	252	5480	200	5200	0	236	5612	5817	-1676	15257	556	15813	3241	19054	49.96
16	4395	908	252	5555	258	5187	0	181	5714	5920	-1674	15428	407	15835	3249	19084	49.91
17	4453	531	265	5249	287	5207	0	108	5422	5559	-1659	14752	540	15292	3217	18509	49.99
18	4491	130	257	4878	380	5253	0	29	5372	5199	-1646	14093	660	14753	3153	17906	49.99
19	4858	468	259	5585	431	5221	0	0	5345	5325	-1525	15037	330	15367	3111	18478	49.98
20	4739	810	269	5818	453	5234	0	0	5400	5295	-1513	15287	0	15287	3066	18353	49.98
21	4734	475	261	5470	443	5253	0	0	4988	5197	-1437	14927	0	14927	2962	17889	49.95
22	4483	444	276	5203	465	5252	0	0	4690	4880	-1267	14532	0	14532	2745	17277	50.00
23	4418	424	280	5122	437	5232	0	0	4610	4784	-1307	14268	0	14268	2686	16954	50.00
24	4317	173	279	4769	479	5206	0	0	4688	4459	-1302	13611	0	13611	2633	16244	49.96
MUs	106.40	9.51	6.34	122.25	7.10	124.55	0.00	2.19	125.09	126.56	-33.32	349.33	7.46	356.80	65.94	422.74	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Sep/2017

Position as on 6.30 Hrs of 29/Sep/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17.08		Continued.	Economic shutdown.	
CENT.SECTOR	TARAPUR 4	540	23/04/2017	19:55		Continued.	Annual Maintenance	
CENT.SECTOR	Tarapur 1	160	04/06/2017	19.09		Continued.	3 months outage for refuelling.	
CENT.SECTOR	TARAPUR-3	540	11/07/2017	16.30		Continued.	Reactor Inspection Work	
MSPGCL	Khaparkheda Unit 4	210	13/07/2017	03.36		Continued.	Drum level low. on Dated 14.07.2017 converted to zero schedule. Converted into COH from 00:00Hrs of 02.08.2017	
MSPGCL	Nasik Unit 3	210	10/08/2017	00.00		Continued.	Withdrawn for maintenance work.Converted to COH from 15.08.2017.	
MSPGCL	Chandrapur Unit 4	210	22/08/2017	23.56		Continued.	Annual Overhaul	
FORCED OUTAGE								
RGPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
MSPGCL	Koradi Unit 6	210	09/07/2015	00.00		Continued.	EE R&M LE Work	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Bhusawal Unit 2	210	14/06/2016	19.35		Continued.	Shutdown	
MSPGCL	Uran Unit 8	108	14/08/2016	07.56		Continued.	Maintenance work	
RGPL	Dabhol 2A	230	24/08/2016	13.31		Continued.	Change Over.	
MSPGCL	Koradi Unit 5	200	05/09/2016	00.21		Continued.	ID Fan problem, Converted to Zero Schedule By MSEDCL from 00.00hrs/22-9-16. Shutdown taken on 18.10.2016 at 00:00Hrs for Turbine inspection and maintenance work	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	Dhariwal	300	01/06/2017	00.01		Continued.	NO SCHEDULE.	
IPP	VIPL U-1	300	13/06/2017	08.30		Continued.	GT WORK(Coal Shortage From 11-09-2017)	
MSPGCL	Parli Unit 8	250	17/06/2017	00.08	28/09/2017	02.30	Zero Schedule by MSEDCL, scheduled issued on 08.08.2017 but synchronization delayed.	
MSPGCL	Ghatghar Unit-1	125	28/07/2017	00.00		Continued.	RBDV leakage attending work.	
MSPGCL	Ghatghar Unit-2	125	28/07/2017	00.00		Continued.	due to common pressure shaft with unit 1.	
CPP	SWPGL U-3	135	26/08/2017	17.40		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Sep/2017

Position as on 6.30 Hrs of 29/Sep/2017

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Bhusawal Unit 3	210	27/08/2017	07.43		Continued.	Coal Shortage From 29.08.2017.	
IPP	Adani U-4	660	06/09/2017	21.47		Continued.	Changeover from U-4 to U1	
MSPGCL	Koradi Unit 9	660	07/09/2017	00.38		Continued.	Coal shortage form 12.09.2017.	
MSPGCL	Khaparkheda Unit 1	210	08/09/2017	12.23		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 6	500	09/09/2017	04.40		Continued.	Coal Shortage form 12.09.2017.	
MSPGCL	Chandrapur Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 3	210	12/09/2017	00.00		Continued.	Coal Shortage	
MSPGCL	Koradi Unit 7	210	12/09/2017	00.12		Continued.	Coal Shortage	
IPP	RPL(AMT) U-3	270	17/09/2017	00.02		Continued.	Coal Shortage	
IPP	RPL(AMT) U-5	270	17/09/2017	02.01		Continued.	Coal Shortage	
MSPGCL	Uran Unit 5	108	19/09/2017	22.52		Continued.	Boiler protection Operated	
RINFRA-G	REL Unit 2	250	22/09/2017	00.11		Continued.	Coal Shortage	
MSPGCL	Khaparkheda Unit 2	210	25/09/2017	06.50		Continued.	Coal Shortage	
MSPGCL	Chandrapur Unit 5	500	27/09/2017	12.22	28/09/2017	01.29	Generator Protection operated	
MSPGCL	Parli Unit 7	250	28/09/2017	21.12		Continued.	Coal Shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Sep/2017

Statement-VII

Position as on 6.30 Hrs of 29/Sep/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar I	InterState	27/09/2017	17.59	28/09/2017	07.24	T	Over Voltage
Dhule Sar'Sarovar I	InterState	28/09/2017	17.00		Continued.	T	Over Voltage
Ektuni-Bableshwar ckt I	IntraState	15/09/2017	19.16		Continued.	HT	Attending Hot Spot
karad -kolhapur-I	IntraState	19/09/2017	20.43	28/09/2017	11.49	HT	Over Voltage
Deepnagar - Aurangabad	IntraState	27/09/2017	15.39	28/09/2017	07.05	T	Distance Protection
Karad - Jaigad - II	IntraState	27/09/2017	20.43		Continued.	HT	Over Voltage
Nagothane - Dabhol-II	IntraState	28/09/2017	14.01	28/09/2017	17.27	EO	To attend Hot Spot
Bhusawal-Aurangabad	IntraState	28/09/2017	19.55		Continued.	HT	Over Voltage
karad -kolhapur-II	IntraState	28/09/2017	21.37		Continued.	HT	Over Voltage
Padghe - Kalwa-II	IntraState	28/09/2017	23.25	29/09/2017	06.03	PO	Tower Erection Work
Dhule- Bableshwar - I	IntraState	29/09/2017	01.16	29/09/2017	02.00	HT	Emergency Hand Tripped For Isolation Of Bus 02
Babhaleshwar - Padghe-I	IntraState	29/09/2017	01.16	29/09/2017	01.55	HT	Emergency Hand Tripped For Isolation Of Bus 02
Babhaleshwar - Bhusawal II	IntraState	29/09/2017	01.17	29/09/2017	01.50	HT	Emergency Hand Tripped For Isolation Of Bus 02
Babhaleshwar - RIPL(Nashik)	IntraState	29/09/2017	01.18	29/09/2017	01.57	HT	Emergency Hand Tripped For Isolation Of Bus 02
400 KV ICT Outages/Trippings							
400/220 Kv 500 MVA ICT II @Jejuri	IntraState	28/09/2017	09.56	28/09/2017	19.34	PO	Dismantilin G Of Faulty ICT-2 pH Unit
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	28/09/2017	13.23	28/09/2017	18.23	PO	Backup Relay Retrofitting Work
400/220/33 Kv 315 MVA ICT I @Babhaleshwar	IntraState	29/09/2017	01.18	29/09/2017	01.47	HT	Emergency Hand Tripped For Isolation Of Bus 02
400/220 KV 500MVA ICT-IV @ Babhaleshwar	IntraState	29/09/2017	01.19	29/09/2017	01.42	HT	Emergency Hand Tripped For Isolation Of Bus 02
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	NO SCHEDULE.
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	NO SCHEDULE.
Mudshingi Chikodi	InterState	28/09/2017	12.42	28/09/2017	16.48	T	To attend Hot Spot
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Pusad - Hingoli	IntraState	11/09/2017	20.06		Continued.	HT	Distance Relay Faulty at pusad end
Pedambe-Nerle	IntraState	23/09/2017	00.50		Continued.	T	B Phase CT Burst at Pedambe End
Trombay Salsette 1 Backbay	IntraState	28/09/2017	05.22		Continued.	PO	Tree Cutting Work
Sonkhar - Trombay	IntraState	28/09/2017	07.07	28/09/2017	09.21	PO	Ct To Isolator Jumper Replacement Work
Dondaicha(220)-Amalner(220)	IntraState	28/09/2017	08.26	28/09/2017	12.23	PO	Tan Delta Measurment of CTs
Lonand-Bothe	IntraState	28/09/2017	09.35	28/09/2017	12.23	PO	Quarterly Maintanance Work
Badnera-Akola li	IntraState	28/09/2017	09.51	28/09/2017	20.32	PO	Routine Maintenance Work Measurement Of Tan Delta CT Measurement Of CB Timing And CRM
Miraj - Mhaishal	IntraState	28/09/2017	09.53	28/09/2017	14.07	PO	Electromech IINE Backup Relay By Numerical
Mahad-Kandalgaon	IntraState	28/09/2017	10.10	28/09/2017	17.15	PO	Nut Bolt Tightning Work

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Sep/2017

Statement-VII

Position as on 6.30 Hrs of 29/Sep/2017

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Nagar-Babhaleshwar Ckt II	IntraState	28/09/2017	10.22	28/09/2017	18.36	PO	Bay Maintenance Relay
Sahara-Urse	IntraState	28/09/2017	10.22	28/09/2017	13.14	PO	Timing Test Of CB Isolator Maintenance
Bus Section II @ Pophali	IntraState	28/09/2017	12.00	28/09/2017	18.30	PO	Replacement Of Conductor
Pophali - Pedambe II	IntraState	28/09/2017	12.40	28/09/2017	18.30	PO	Replacement Of Conductor
Pophali - New Koyna	IntraState	28/09/2017	12.45	28/09/2017	18.45	PO	Replacement Of Conductor
Dhule - Dondaicha Ckt	IntraState	28/09/2017	12.45	28/09/2017	17.31	PO	Tan Delta Measurment of CTs
Gadchandur - Grace	IntraState	28/09/2017	13.00	28/09/2017	13.35	T	Distance Protection
Pedambe-Pophali	IntraState	28/09/2017	13.00	28/09/2017	22.05	HT	Hand Trip Due To B ph Conductor Snapping
Virur - Gadchiroli	IntraState	28/09/2017	14.00	28/09/2017	15.20	T	Distance Protection
Pophali - Nerale	IntraState	28/09/2017	14.25	28/09/2017	19.00	PO	Replacement Of Conductor
Bombay Dyeing - Sahara	IntraState	28/09/2017	14.50	28/09/2017	17.40	PO	Routine Maintenance Work
Ghatghar - Bapgaon	IntraState	28/09/2017	17.22		Continued.	HT	Distance Protection
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Failed on internal Fault(Now repaired and ready for commissioning)
220/110kv 100MVA ICT-II @Miraj	IntraState	18/09/2017	11.27		Continued.	PO	Replacement Of Ict-2.
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	28/09/2017	08.21	28/09/2017	14.04	HT	In View Of Bus 220 kv Sectionliser Outage
220/132 Kv 100 Mva Vijai Ict 2 @Virur	IntraState	28/09/2017	14.00	28/09/2017	15.05	T	Problem On CB, LV CB Stuck Up Master Trip
220/132 Kv Ict 1 200 Mva @Parbhani	IntraState	28/09/2017	15.48	28/09/2017	17.58	PO	Attending Oil Leakages of ICT
220/132 KV ICT II @ Kopergaon	IntraState	28/09/2017	17.40	28/09/2017	18.55	PO	Routine Bay Maintenance
100 KV LINE Outages/Trippings							
Kandalgaon - Roha II	IntraState	26/09/2017	13.00		Continued.	PO	Relay Testing Work.
Kandalgaon- Roha I	IntraState	26/09/2017	16.50		Continued.	T	Distance Protection

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage