

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Sep/2018 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	117.097	3040.465	1) Gujrat	2.330	29.679
2) Hydro	20.031	428.444	2) Madhya Pradesh	25.791	474.155
3) Gas	7.217	139.154	3) Chattisgarh	2.750	144.680
Total MSPGCL	144.345	3608.063	4) Maharashtra Net	151.077	3556.940
B) 1) APML	54.050	1537.441	5) Goa (Amona)	-0.242	-8.206
2) JSWEL	21.417	616.203	Total	181.706	4197.248
3) VIPL	9.989	390.692	a) Mumbai Schedule	24.459	626.989
4) RPL(AMT)	6.509	660.107	b) Mumbai Drawl	27.274	662.383
5) WPCL	5.667	118.492	c) MSEDCL Bilateral *	87.205	1586.828
6) PGPL	0.000	0.000	Include PX	56.401	810.460
7) Other IPP	7.962	200.242	d) Mumbai Bilateral *	24.459	626.989
C) 1) TPCL Thermal	16.640	442.210	Include PX	8.074	60.252
2) TPCL Hydro	5.827	122.388	Include Standby	0.000	0.000
3) TPCL Gas	4.388	121.584	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	12.000	315.238	1) MSEDCL	415.396	11320.195
D) STATE			2) Mumbai Discoms	66.126	1663.798
1) Thermal	251.331	7321.090	TOTAL STATE	481.522	12983.993
(A1+C1+C4+(B1-B6))					
2) Hydro	25.858	550.832			
(A2+C2)					
3) Gas	11.605	260.738			
(A3+B6+C3)					
4) Wind	5.046	512.708			
6) SOLAR	5.979	141.382			
TOTAL STATE	299.819	8786.750			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	5048	5035	4925	5135
MSPGCL Hydro	591	560	1325	844
MSPGCL Gas	297	285	308	310
MSPGCL Total Generation	5936	5880	6558	6289
Central Sector Receipt	8706	8611	6756	5951
WIND	198	379	171	258
CPP / IPP Thermal	4429	4425	4409	4404
CPP / IPP Gas	0	0	0	0
SOLAR	789	837	0	0
Exchange with Mumbai	-1489	-1378	-1279	-1067
MSEDCL DEMAND MET	18569	18754	16615	15835
Load Shedding	0	0	0	0
MSEDCL DEMAND	18569	18754	16615	15835
TPCL GENERATION	1317	1338	1291	1014
R-INFRA GENERATION	500	500	501	497
MUMBAI DEMAND	3306	3216	3071	2578
STATE DEMAND MET	21875	21970	19686	18413
STATE DEMAND	21875	21970	19686	18413
Frequency (Hz)	50.01	49.97	49.88	49.89

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.11 Hz at 13.01 Hrs	49.63 Hz at 18.41 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 28/Sep/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.15	0	0
Unit 7	0.00	0.00	0	0
Unit 8	7.63	196.91	400	223
Unit 9	1.60	40.40	300	0
Unit 10	6.72	166.15	352	228
Total	15.95	403.61		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	7.69	113.57	360	305
Unit 5	7.59	257.01	360	300
Total	15.28	370.58		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	14.31	0	0
Unit 7	4.61	145.45	205	180
Unit 8	4.88	133.78	230	171
Total	9.49	293.54		
Chandrapur				
Unit 3	4.01	105.56	188	144
Unit 4	3.75	109.76	182	102
Unit 5	9.42	193.87	431	360
Unit 6	9.43	133.00	445	355
Unit 7	9.48	171.81	450	356
Unit 8	0.00	188.46	0	0
Unit 9	10.19	246.76	456	386
Total	46.27	1149.22		
Paras				
Unit 3	0.00	59.46	0	0
Unit 4	5.36	134.20	235	215
Total	5.36	193.67		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	27.37	0	0
Unit 3	3.05	101.58	150	0
Unit 4	3.39	66.92	150	131
Unit 5	10.77	250.67	470	400
Total	17.21	446.54		
Nasik				
Unit 3	3.75	112.26	163	147
Unit 4	3.78	64.92	165	142
Unit 5	0.00	6.13	0	0
Total	7.53	183.31		
Uran				
All Units	7.22	139.15	312	284
Total	7.22	139.15		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.62	3.86	43	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.62	3.86		
Koyna				
Stage 1-2	5.40	114.18	505	40
Stage 4	9.78	186.84	969	0
Stage 3	3.51	67.43	320	0
Total	18.68	368.45		
Hydro				
KDPH	0.20	16.02	19	0
VTRNA	0.00	5.30	0	0
TILLARI	0.00	5.98	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.32	8.74	80	0
RNGR+BHTSA	0.36	7.59	15	14
BHANDARDRA	0.00	2.87	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.47	9.46	20	19
GHATGHAR	0.00	4.03	0	0
Total	1.35	60.00		
Wind				
Total	5.05	512.71	0	0
Total	5.05	512.71		
CPP				
APML(Mus)	54.05	1537.44	0	0
JSWEL(Mus)	21.42	616.20	0	0
VIPL(Mus)	9.99	390.69	0	0
RPLAMT(Mus)	6.51	660.11	0	0
WPCL(Mus)	5.67	118.49	0	0
Other(Mus)	7.96	200.24	0	0
Total	105.59	3523.18		
SOLAR				
Total	5.98	141.38	0	0
Total	5.98	141.38		
Tata				
Trombay 5	11.08	292.68	479	438
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.78	76.78	118	114
Trombay 7B	1.61	44.80	68	66
Trombay 8	5.56	149.53	239	217
TATA Hydro	5.83	122.39	459	0
Total	26.86	686.18		
R-INFRA				
DTPS U-1&2	12.00	315.24	501	497
Total	12.00	315.24		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	117.10	3040.46	MSPGCL Total	144.34	3608.06
			MSPGCL Thml+Gas	124.31	3179.62	Koyna 1,2 & 4 Total	15.17	301.02
			MSPGCL Hydro	20.03	428.44	State Total	299.82	8786.75

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Sep/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	4810	1343	308	6461	139	4406	0	0	6878	6862	-1062	16806	0	16806	2446	19252	49.93
2	4794	729	307	5830	118	4367	0	0	6995	6995	-857	16453	0	16453	2246	18699	49.93
3	4754	443	297	5494	118	4364	0	0	6927	7180	-777	16379	0	16379	2125	18504	49.95
4	4569	727	307	5603	132	4369	0	0	6906	7022	-704	16422	0	16422	2061	18483	49.96
5	4578	837	308	5723	123	4361	0	0	7087	7140	-675	16672	0	16672	2050	18722	49.96
6	4634	917	307	5858	128	4372	0	0	7810	8123	-752	17729	0	17729	2136	19865	49.96
7	4741	1704	298	6743	157	4375	0	32	7955	8057	-850	18514	0	18514	2275	20789	49.93
8	4814	1614	307	6735	97	4359	0	191	8001	8295	-999	18678	0	18678	2436	21114	50.03
9	4850	899	307	6056	108	4373	0	426	7993	8138	-1137	17964	0	17964	2724	20688	49.97
10	5022	773	302	6097	128	4400	0	650	8004	8273	-1337	18211	0	18211	3063	21274	49.94
11	4997	576	289	5862	164	4423	0	777	8306	8484	-1495	18215	0	18215	3268	21483	50.00
12	5048	591	297	5936	198	4429	0	789	8523	8706	-1489	18569	0	18569	3306	21875	50.01
13	5035	560	285	5880	379	4425	0	837	8505	8611	-1378	18754	0	18754	3216	21970	49.97
14	4968	416	295	5679	368	4449	0	754	8459	8569	-1353	18466	0	18466	3169	21635	49.99
15	4896	352	284	5532	350	4408	0	681	8365	8645	-1373	18243	0	18243	3195	21438	49.95
16	4857	866	296	6019	351	4399	0	486	8314	8323	-1436	18142	0	18142	3278	21420	49.91
17	4875	610	287	5772	191	4405	0	280	8231	8404	-1334	17718	0	17718	3173	20891	49.90
18	4801	613	296	5710	187	4438	0	74	7711	7685	-1289	16805	0	16805	3098	19903	49.94
19	4835	1036	289	6160	157	4450	0	2	6778	6809	-1346	16232	0	16232	3163	19395	49.82
20	4925	1325	308	6558	171	4409	0	0	6633	6756	-1279	16615	0	16615	3071	19686	49.88
21	4975	826	312	6113	327	4407	0	0	6062	6247	-1131	15963	0	15963	2839	18802	49.97
22	5082	591	310	5983	471	4368	0	0	5912	5994	-1070	15746	0	15746	2680	18426	49.95
23	5135	844	310	6289	258	4404	0	0	5953	5951	-1067	15835	0	15835	2578	18413	49.89
24	5102	839	311	6252	226	4432	0	0	5953	6437	-1084	16263	0	16263	2533	18796	49.99
MUs	117.10	20.03	7.22	144.35	5.05	105.59	0.00	5.98	178.26	181.71	-27.27	415.40	0.00	415.40	66.13	481.52	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Sep/2018

Position as on 6.30 Hrs of 29/Sep/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-3	660	03/09/2018	05.02		Continued.	Capital overhaul	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
IPP	SWPGL U-2	135	29/02/2016	21.46		Continued.	No PPA	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Bhusawal Unit 3	210	21/05/2018	18.46		Continued.	Coal Swapping IEPL	
MSPGCL	Ghatghar Unit-2	125	29/06/2018	01:12		Continued.	Stator Earth Fault	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
MSPGCL	Koradi Unit 7	210	03/08/2018	15.54		Continued.	Poor Coal Receipt.	
MSPGCL	Khaparkheda Unit 1	210	11/08/2018	23.57		Continued.	Poor coal Receipt	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Koradi Unit 9	660	04/09/2018	12.48	28/09/2018	16.03	Poor Coal Receipt	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Koradi Unit 6	210	09/09/2018	05.52		Continued.	Inspection of Boiler Tubes by R & M Team.	
MSPGCL	Khaparkheda Unit 2	210	10/09/2018	02.35	29/09/2018	23.43	Poor Coal Receipt.	
MSPGCL	Nasik Unit 5	210	11/09/2018	18.45		Continued.	Coal Swapping with DIL	
MSPGCL	Parli Unit 6	250	12/09/2018	06.57		Continued.	Poor Coal receipt	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-5	270	21/09/2018	00.05		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-1	270	22/09/2018	00.00		Continued.	Poor Coal Receipt	
IPP	RPL(AMT) U-3	270	25/09/2018	0.00		Continued.	Poor Coal Receipt	
MSPGCL	Chandrapur Unit-8	500	27/09/2018	00.58		Continued.	Boiler Tube Leakage	
IPP	JSW (J) U2	300	27/09/2018	05.05	29/09/2018	09.29	C.W.Duct Leakage	
MSPGCL	Khaparkheda Unit 3	210	28/09/2018	17.00	28/09/2018	18.55	Furnace Pressure High	
MSPGCL	Koradi Unit 10	660	29/09/2018	12.42		Continued.	Poor Coal Receipt	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 29/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765/400kV 1500MVA ICT-I@Koradi-III	IntraState	29/09/2018	10.38	29/09/2018	16.17	PO	Replacement of 400 KV CVT
500 KV LINE Outages/Trippings							
Chandrapur - Padghe Hvdc Pole 2	IntraState	28/09/2018	17.56	28/09/2018	20.38	EO	Attend Sparking.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Padgha Tarapur II	InterState	27/09/2018	10.18	28/09/2018	22.18	PO	Annual Maintenance Work
Dhule Sar'Sarovar I	InterState	27/09/2018	20.11	28/09/2018	06.25	HT	Over Voltage
Chandrapur-II - Warora - I	InterState	28/09/2018	09.20	28/09/2018	17.26	PO	Quarterly Maintenance Work
Koradi Bhilai	InterState	28/09/2018	10.20	29/09/2018	02.16	PO	Routine Maintenance Work
Dhule Sar'Sarovar II	InterState	28/09/2018	18.15	29/09/2018	05.16	HT	Over Voltage
Dhule Sar'Sarovar I	InterState	29/09/2018	19.10		Continued.	HT	Over Voltage
Dhule- Bableswhar - I	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Dhule - Bableswhar - li	IntraState	01/06/2018	16.42		Continued.	T	Distance Protection Y-PH (Tower Collapsed)
Khadka-Aurangabad (Waluj)	IntraState	27/09/2018	18.18	28/09/2018	06.32	HT	Over Voltage
Kala Kudus Ckt-I	IntraState	28/09/2018	12.53	28/09/2018	21.57	PO	Insulator Replacement Work
Pune(GIS)-Talegaon(PG) Ckt 4	IntraState	28/09/2018	13.36	28/09/2018	19.22	EO	Conductor Unwinding At Wavetrap.
Khadka-Aurangabad (Waluj)	IntraState	28/09/2018	18..42	29/09/2018	06.03	HT	Over Voltage
Deepnagar Taptitanda	IntraState	29/09/2018	06.58	29/09/2018	13.00	PO	Replacement of Dead end and Mid Span Joint
Koradi-Khaperkheda li	IntraState	29/09/2018	10.24	29/09/2018	16.58	PO	To attend Discrepancies observed newly erected Towers
Padghe - Nagothane - II	IntraState	29/09/2018	12.08	29/09/2018	19.32	T	DISTANCE PROTECTION B-PHASE EARTH FAULT DIS. 6.1 KM.
Bhusawal-Aurangabad	IntraState	29/09/2018	19.09		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220KV 500MVA ICT 2@koradi 2	IntraState	18/09/2018	09.47		Continued.	HT	Emergency Hand Tripped due to R Phase Buchholz alarm Indication on ICT
400/220 Kv 315 Mva Ict -2 @New Koyana	IntraState	28/09/2018	11.19	28/09/2018	16.45	EO	Attending Hot Spot
400/220/33kv, 500 MVA ICT-I @Khaparkheda	IntraState	28/09/2018	12.06	28/09/2018	14.42	EO	Attending Hot Spot
400/220/33 Kv 315 MVA ICT -I @Nagothane	IntraState	28/09/2018	20.23	28/09/2018	20.50	T	B/C E/F While Charging Of Wadkhal Ckt 1.
400/220 kV 500MVA ICT-I @ Alkud	IntraState	29/09/2018	15.10	29/09/2018	17.21	PO	Testing Work
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Mahalakshmi Amona	InterState	28/09/2018	15.37	28/09/2018	16.09	T	Distance Protection
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no 86 & 107 and de-energising the line bet.86 to 107.
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa 52B Interconnector CB	IntraState	19/08/2018	18.25	28/09/2018	19.40	HT	Taken In Service To Control Load Of Temghar Ckt At Kalwa 1 S/5 In

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 29/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
							Lieu Of 220kv Bus Outage At Padgha.
Nerul-Trombay	IntraState	31/08/2018	22.04		Continued.	PO	Conductor Replacement
Bhugaon- Wardha	IntraState	27/09/2018	18.40	28/09/2018	00.28	HT	At Deoli end for power regulation.
Kandalgaon - Sona Alloys	IntraState	28/09/2018	03.32	28/09/2018	08.42	T	Distance Protection
Dhule-Chalisagaon	IntraState	28/09/2018	05.51	28/09/2018	09.21	T	Control ICT O/L At Dhule End.
Mahad - Pedambe	IntraState	28/09/2018	09.13	28/09/2018	17.06	PO	Line Maintenance work
Balapur-Akola li	IntraState	28/09/2018	10.20	28/09/2018	16.54	PO	Routine Maintenance Work
Jambhul - Pal	IntraState	28/09/2018	10.20	28/09/2018	17.35	PO	Routine Maintenance Work
Colourchem - Temghar	IntraState	28/09/2018	10.35	28/09/2018	16.36	PO	Bus Isolator Maintenance Work, Colourchem, TF-1 & 3 Will Kept Off.
Dhule-Chalisagaon	IntraState	28/09/2018	11.41	28/09/2018	19.17	HT	Controlling ICT O/L.
Trombay - Mulund	IntraState	28/09/2018	11.51	28/09/2018	13.14	T	Distance Protection, B-E 4.43km, Z-1, IB-17.99 KAMP.
Trombay - Kalwa	IntraState	28/09/2018	12.06	28/09/2018	14.24	T	Distance Protection, B-E 18.30km, Z-1, IB-6.7KAMP.
Loteparshuram- Dasturi Line	IntraState	28/09/2018	14.25	29/09/2018	12.40	T	Distance Protection, Z-1, B PH, 2.17km, 7.5ka.
Ghatghar - Jindal	IntraState	28/09/2018	15.15	28/09/2018	20.23	T	Distance Protection, Pilot String Replaced.
Talandge-Mudshingi Ckt-I	IntraState	28/09/2018	16.08	28/09/2018	16.35	T	Distance Protection, Z-1, B PH, 9.58ka.
Bus A at Padgha	IntraState	28/09/2018	18.37		Continued.	PO	Erection Of Hybrid Bus.
Dhule - Malegaon	IntraState	28/09/2018	18.54	28/09/2018	19.10	HT	In View Of Hot Line Work On ICT 3 At Dhule.
Nagothane-Wadkhal-I	IntraState	28/09/2018	18.56	28/09/2018	12.58	T	Distance Protection, Z-1, R PH, 31km, 5.3ka.
Padgha - Temghar I	IntraState	28/09/2018	19.48		Continued.	HT	220KV A Bus outage at Padgha
Padgha-Temghar-II	IntraState	28/09/2018	19.48		Continued.	HT	220KV A Bus outage at Padgha
Pophali - Nerale	IntraState	29/09/2018	00.45	29/09/2018	09.45	T	Distance Protection
Pophali - Kdph	IntraState	29/09/2018	01.00	29/09/2018	09.15	T	Distance Protection
Pandarpur-Khanapur	IntraState	29/09/2018	09.15	29/09/2018	17.30	PO	Cold washing of Insulator
ALEPHATA UTECH SUGAR	IntraState	29/09/2018	10.04	29/09/2018	18.09	PO	Replacement of Flashover Insulator
Shirsuphal-Bhigwan	IntraState	29/09/2018	10.07	29/09/2018	18.40	PO	jumper Tightening for Cut point locations
Chinchwad-Hinjewadi I	IntraState	29/09/2018	10.17	29/09/2018	14.40	PO	Retrofitting of Distance Relay
Bableshtar - Ahamadnagar-I	IntraState	29/09/2018	10.42	29/09/2018	21.18	PO	Replacement of High Tan Delta CT
Kandalgaon - Sona Alloys	IntraState	29/09/2018	15.40	29/09/2018	20.30	PO	Line Maintenance work
Talandge-Mudshingi Ckt-I	IntraState	29/09/2018	15.45	29/09/2018	16.40	T	Distance Protection
Sonkhar - Trombay	IntraState	29/09/2018	16.09		Continued.	PO	Replacement of Conductor at Loc.No.736&738
220 KV ICT Outages/Trippings							
220/132 Kv Ict 1 200 Mva @Parbhani	IntraState	25/09/2018	11.52	29/09/2018	22.44	PO	Repairing / Servicing Of Intank OLTC.
220/132 Kv 200mva Ptr No 1 @Theur	IntraState	28/09/2018	09.29		Continued.	PO	Control & Relay Panel Replacement Work.
220/132 Kv 200 Mva ICT-I @Girwali	IntraState	28/09/2018	10.11	28/09/2018	16.11	EO	Measurement Of CB Timing And CRM. Hot Spot Attending Work.
220/132 kV 200 Mva ICT-II @Boisar -li	IntraState	28/09/2018	15.10	28/09/2018	19.22	PO	To Check CTR.
220/132 kV 200 Mva ICT-II @Boisar -li	IntraState	28/09/2018	19.41	29/09/2018	12.34	T	Differential protection, B PH,LV-CT Faulty.
220/110 Kv 200 Mva Vel Ptr 2 @Kolhapur-li (Mudshingi)	IntraState	29/09/2018	10.20	29/09/2018	17.40	PO	Testing Work
132 KV LINE Outages/Trippings							
Chikhali-Khamgaon	IntraState	28/09/2018	04.53	28/09/2018	05.08	T	Distance Protection, Zone-1.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Sep/2018

Statement-VII

Position as on 6.30 Hrs of 29/Sep/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kardha-Asgaon	IntraState	28/09/2018	09.20	28/09/2018	16.52	T	Outage On Asgaon 132kv Bus Section 2