

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Oct/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	108.028	3191.652	1) Gujrat	0.891	225.901
2) Hydro	8.079	228.164	2) Madhya Pradesh	0.451	131.166
3) Gas	2.244	61.994	3) Chattisgarh	5.920	145.820
Total MSPGCL	118.351	3481.810	4) Maharashtra	139.538	4313.401
B) 1) APLM	62.370	1533.790	5) Goa (Amona)	-1.886	-40.033
2) JSWEL	13.340	420.576	Total	144.914	4776.255
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.077	934.056
4) RPL(AMT)	25.169	657.462	b) Mumbai Drawl	35.220	1027.661
5) SWPGPL	5.150	183.440	c) MSEDCL Bilateral *	67.430	1848.295
6) Other IPP	17.073	266.242	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.077	934.044
C) 1) TPCL Thermal	10.240	282.430	Include PX	0.000	0.000
2) TPCL Hydro	3.350	106.167	Standby	0.000	0.012
3) TPCL Gas	2.479	67.097	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.176	251.993	1) MSEDCL	364.649	10604.900
D) STATE			2) Mumbai Discoms	59.465	1735.326
1) Thermal	249.546	6787.585	3) Other Discoms	9.277	256.264
(A1+C1+C4+(B1-B6))			TOTAL STATE	433.391	12596.490
2) Hydro (A2+C2)	11.429	334.331			
3) Gas (A3+B7+C3)	4.723	129.091			
4) Wind	9.654	279.263			
6) SOLAR	13.125	289.987			
TOTAL STATE	288.477	7820.257			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	4128	5061	5083	4180
MSPGCL Hydro	456	669	1333	176
MSPGCL Gas	91	89	92	97
MSPGCL Total Generation	4675	5819	6508	4453
Central Sector Receipt	6858	5738	5910	5224
WIND	355	216	338	287
CPP / IPP Thermal	4933	5942	5954	4876
CPP / IPP Gas	0	0	0	0
SOLAR	1719	83	1	0
Exchange with Mumbai	-1716	-1583	-1370	-1137
MSEDCL DEMAND MET	16385	15784	16916	13392
Load Shedding	0	0	0	0
MSEDCL DEMAND	16385	15784	16916	13392
TPCL GENERATION	762	826	1030	528
AEML GENERATION	461	376	430	282
MUMBAI DEMAND	2939	2785	2830	1947
OTHER DISCOM DEMAND	439	431	425	311
STATE DEMAND MET	19763	19000	20171	15650
STATE DEMAND	19763	19000	20171	15650
Frequency (Hz)	49.96	49.88	49.98	49.90

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.18 Hz at 06.02 Hrs	49.67 Hz at 12.17 Hrs	49.96	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Oct/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.16	68.63	210	110
Unit 7	0.00	0.00	0	0
Unit 8	11.56	242.94	516	390
Unit 9	0.00	59.24	0	0
Unit 10	9.46	264.92	397	375
Total	25.18	635.72		
Bhusawal				
Unit 3	0.00	32.53	0	0
Unit 4	8.94	225.04	460	285
Unit 5	9.56	201.64	470	250
Total	18.50	459.20		
Parli				
Unit 6	0.19	89.72	84	0
Unit 7	0.46	77.70	115	0
Unit 8	0.06	64.95	39	0
Total	0.72	232.37		
Chandrapur				
Unit 3	0.62	56.21	107	0
Unit 4	0.43	66.62	105	0
Unit 5	7.04	167.57	320	275
Unit 6	2.12	171.31	195	0
Unit 7	7.34	199.69	341	270
Unit 8	4.33	112.66	419	0
Unit 9	8.94	236.97	435	299
Total	30.82	1011.01		
Paras				
Unit 3	5.07	120.35	239	15
Unit 4	0.00	0.16	0	0
Total	5.07	120.51		
Khaparkheda				
Unit 1	2.73	74.59	125	100
Unit 2	2.99	80.51	145	105
Unit 3	3.49	95.47	176	126
Unit 4	3.45	88.66	165	125
Unit 5	8.94	228.78	435	275
Total	21.59	568.02		
Nasik				
Unit 3	0.00	25.32	0	0
Unit 4	3.17	85.78	170	110
Unit 5	2.98	53.72	163	90
Total	6.15	164.82		
Uran				
All Units	2.24	61.99	97	88
Total	2.24	61.99		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.60	16.54	25	25
Total	0.60	16.54		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.57	58.97	320	40
Stage 4	1.54	45.32	532	0
Stage 3	0.98	25.13	240	0
Total	5.09	129.43		
Hydro				
KDPH	0.00	6.26	0	0
VTRNA	0.00	4.54	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.16	7.34	40	0
SMLHY_PTN	1.92	58.31	88	70
GHATGHAR	0.31	5.74	125	0
Total	2.39	82.20		
Wind				
Total	9.65	279.26	0	0
Total	9.65	279.26		
CPP				
APML(Mus)	62.37	1533.79	0	0
JSWEL(Mus)	13.34	420.58	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.17	657.46	0	0
SWPGPL-Mus	5.15	183.44	0	0
Other(Mus)	17.07	266.24	0	0
Total	123.10	3061.51		
SOLAR				
Total	13.12	289.99	0	0
Total	13.12	289.99		
Tata				
Trombay 5	6.97	181.86	411	261
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.38	37.47	107	48
Trombay 7B	1.10	29.63	64	42
TATA Hydro	3.35	106.17	313	18
Trombay 8	3.27	100.57	171	129
Total	16.07	455.69		
AEMIL				
DTPS U-1&2	8.18	251.99	482	282
Total	8.18	251.99		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	108.03	3191.65	MSPGCL Total	118.35	3481.81
			MSPGCL Thml+Gas	110.27	3253.65	Koyna 1,2 & 4 Total	4.12	104.30
			MSPGCL Hydro	8.08	228.16	State Total	288.48	7820.26

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 28/Oct/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4108	295	96	4499	314	4887	0	0	4995	5112	-1333	13111	0	13111	2215	368	15694	49.98
2	4149	161	97	4407	335	4881	0	0	5183	5234	-1207	13312	0	13312	2064	338	15714	49.89
3	4180	176	97	4453	287	4876	0	0	5211	5224	-1137	13392	0	13392	1947	311	15650	49.90
4	4389	136	97	4622	293	4934	0	0	5139	5088	-1079	13560	0	13560	1875	298	15733	50.01
5	4598	136	97	4831	334	5270	0	0	5109	5165	-1029	14264	0	14264	1851	307	16422	49.96
6	4684	136	97	4917	424	5604	0	0	5431	5471	-1086	14997	0	14997	1923	333	17253	49.99
7	4655	550	97	5302	484	5648	0	64	5978	5959	-1089	16008	0	16008	1983	360	18351	49.88
8	4663	313	97	5073	490	5678	0	462	6159	6372	-1276	16409	0	16409	2145	390	18944	50.00
9	4590	183	97	4870	293	5570	0	997	6192	6399	-1592	16125	0	16125	2440	412	18977	50.00
10	4139	463	94	4696	336	5104	0	1408	6686	6957	-1779	16299	0	16299	2744	423	19466	49.96
11	4128	456	91	4675	355	4933	0	1719	7009	6858	-1716	16385	0	16385	2939	439	19763	49.96
12	4073	225	89	4387	247	4700	0	1809	7219	7066	-1746	16037	0	16037	2992	426	19455	49.86
13	4047	238	88	4373	227	4405	0	1844	7444	7068	-1951	15573	0	15573	2958	393	18924	49.88
14	3955	227	89	4271	211	4261	0	1713	7132	6980	-1888	15141	0	15141	2810	407	18358	50.01
15	4147	160	88	4395	200	4527	0	1463	7078	7122	-1865	15448	0	15448	2809	394	18651	49.99
16	4505	146	88	4739	190	4780	0	1039	6787	6942	-1824	15461	0	15461	2821	405	18687	49.91
17	4835	302	89	5226	194	5218	0	523	6323	6362	-1817	15287	0	15287	2825	419	18531	49.90
18	5061	669	89	5819	216	5942	0	83	5996	5738	-1583	15784	0	15784	2785	431	19000	49.88
19	5083	1333	92	6508	338	5954	0	1	5708	5910	-1370	16916	0	16916	2830	425	20171	49.98
20	5106	1030	93	6229	519	6057	0	0	5593	5647	-1300	16733	0	16733	2763	419	19915	50.04
21	4853	276	95	5224	574	5400	0	0	6357	6113	-1332	15567	0	15567	2622	412	18601	50.01
22	4996	153	95	5244	729	5102	0	0	5755	5614	-1412	14874	0	14874	2479	403	17756	50.02
23	4681	152	96	4929	965	4924	0	0	5520	5112	-1400	14142	0	14142	2357	388	16887	50.00
24	4403	168	96	4667	1099	4447	0	0	5323	5396	-1409	13825	0	13825	2288	375	16488	49.95
MUs	108.03	8.08	2.24	118.35	9.65	123.10	0.00	13.13	145.33	144.91	-35.22	364.65	0.00	364.65	59.47	9.28	433.39	49.96

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 28/Oct/2022

Position as on 6.30 Hrs of 29/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
MSPGCL	Parli Unit 6	250	23/10/2022	00:00	28/10/2022	20:54	Zero Schedule. Now Synchronised	
MSPGCL	Parli Unit 7	250	23/10/2022	00:30	28/10/2022	17:15	Zero schedule. Now Synchronised	
MSPGCL	Parli Unit 8	250	23/10/2022	13:20	28/10/2022	21:33	Zero schedule	
MSPGCL	Chandrapur Unit 4	210	24/10/2022	09:13	28/10/2022	17:07	Zero schedule by MSEDCL. Now Synchronised	
MSPGCL	Chandrapur Unit 3	210	24/10/2022	09:27	28/10/2022	14:03	Zero schedule by MSEDCL	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
MSPGCL	Uran Unit 5	108	27/09/2022	17:11	29/10/2022	11:40	Gas shortage	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	31/10/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	31/10/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	31/10/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
MSPGCL	Koradi Unit 9	660	18/10/2022	17:15		Continued.	Boiler Tube Leakage	30/10/2022
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Oct/2022

Position as on 6.30 Hrs of 29/Oct/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Paras Unit 4	250	22/10/2022	16:51		Continued.	Turbine Vibration	05/11/2022
IPP	SWPGPL U-1	135	23/10/2022	20:29		Continued.	PA Fan Vibration Problem	01/11/2022
MSPGCL	Chandrapur Unit 8	500	27/10/2022	13:14	28/10/2022	11:01	Electrical Protection Operated.	
MSPGCL	Paras Unit 3	250	27/10/2022	21:40	28/10/2022	00:47	Furnace Pressure High	
MSPGCL	Chandrapur Unit 6	500	28/10/2022	11:12	29/10/2022	07:08	SCANNER FAN DISCHARGE TO FURNACE DP(DIFFERENTIAL PRESSURE) LOW.	29/10/2022
MSPGCL	Parli Unit 8	250	28/10/2022	23:14	29/10/2022	02:00	Furnace Pressure High	
MSPGCL	Uran Unit 6	108	29/10/2022	11:59		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 29/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF ICT - 1 & LINE - 4 @ KORADI 3	IntraState	28/10/2022	09:21	28/10/2022	15:55	PO	Annual maintenance of Bay Equipments.
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
Main Bay 412 of Chadrapur II ckt 2 @ C'pur Sw.	IntraState	28/10/2022	11:10	28/10/2022	15:21	PO	Diagnostic testing & allied bay maintenance work
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	29/10/2022	18:24		Continued.	HT	TO CONTROL LINE LOADING ON 400KV SSNNL-ASOJ LINE
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/10/2022	10:27			HT	For Load management
KHADKA-AURANGABAD (WALUJ)	IntraState	27/10/2022	20:35	28/10/2022	10:03	HT	H/T FOR O/V
JAIGAD - KARAD CKT - 2	IntraState	27/10/2022	22:03	28/10/2022	10:15	HT	To control Over Voltage
PADGHE - NAGOTHANE CKT - 1	IntraState	28/10/2022	00:26	28/10/2022	08:40	HT	To control Over Voltage
PARLI - KUMBHARGAON (NANDED) CKT - 1	IntraState	28/10/2022	05:57	28/10/2022	12:20	T	Tripped on Dist Protection
PADGHE - PADGHE HVDC CKT- 1	IntraState	28/10/2022	12:52	28/10/2022	19:15	EO	Emergency shifting of 400kV HVDC - I on TBC at 400kV Padghe for the work of :- 1) Replacement of Resistance of motor control ckt as N2 pressure to be built up manually 3 to 4 times per day of Bph CB of HVDC-1 2) Attending Hot spot on B ph A bus PG isoaltor . Temp 80deg .
KHADKA-AURANGABAD (WALUJ)	IntraState	28/10/2022	20:56	29/10/2022	06:49	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 1	IntraState	28/10/2022	22:05	29/10/2022	07:02	HT	H/T FOR O/V
PADGHE - NAGOTHANE CKT - 2	IntraState	29/10/2022	00:36	29/10/2022	07:06	HT	H/T DUE TO O/V
CHANDRAPUR 2 - WARORA CKT-1	IntraState	29/10/2022	09:16	29/10/2022	18:18	PO	For diagnostic testing and allied maintenance work .
KHADKA-AURANGABAD (WALUJ)	IntraState	29/10/2022	21:30		Continued.	HT	For voltage mgmt
400 KV ICT Outages/Trippings							
60 MVA 400/6.6 KV STN TF - 1	IntraState	28/10/2022	09:20		Continued.	PO	For carrying out transformer and it's bay equipments routine maintenance and electrical testing
400/220/20 KV 500MVA ICT - 1 @ KALWA	IntraState	29/10/2022	06:04	29/10/2022	14:34	PO	All diagnostic testing work, Bay maintenance work
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	29/10/2022	14:47		Continued.	PO	1) Oil leakage attending work from Yph IV bushing 2) OLTC Overhauling work 3) Bay maint work 4) MTAMC work 5) Diagnostic testing work
220 KV LINE Outages/Trippings							
AAREY - MSETCL BORIVALI CKT - 2	IntraState	24/10/2022	22:53			T	R-ph Differential Protection

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 29/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BIDRI - SAWANTWADI	IntraState	27/10/2022	22:03	28/10/2022	08:54	HT	To control Over Voltage
NERLE- POPHALI	IntraState	28/10/2022	08:52	28/10/2022	18:45	PO	Outage for replacement of damaged conductor at loc no. 46B R phase Pophali side , Y phase Pophali side
NAGOTHANE - ACCIL	IntraState	28/10/2022	09:34	28/10/2022	17:21	PO	DIAGNOSTIC TESTING AND MAINTENANCE WORK.
TALEGAON (AMBI)-GENERAL MOTORS	IntraState	28/10/2022	10:14	28/10/2022	18:29	PO	Half yearly maintenance, Diagnostic Testing
TEMBHURNI - JEUR	IntraState	28/10/2022	11:25	28/10/2022	15:38	PO	Outage is required for Jumper replacement work of R & Y - phase Wave trap (WT)
BIDRI - SAWANTWADI	IntraState	28/10/2022	23:46	29/10/2022	09:07	HT	H/T DUE TO O/V
NAGOTHANE - IPCL	IntraState	29/10/2022	09:02	29/10/2022	18:20	PO	DIAGNOSTIC TESTING AND MAINTENANCE WORK
RAYMOND - WASHALA	IntraState	29/10/2022	09:09	29/10/2022	19:32	PO	To attend red hot on R ph- Wave Trap, Bus isolator and Quarterly Maint. Work.
NIWALI - PAWAS LINE	IntraState	29/10/2022	10:02	29/10/2022	18:53		Diagnostic testing of CT,CB and routine bay maintenance work at 220kV Niwali S/s.
TALANDGE - BIDRI	IntraState	29/10/2022	10:06	29/10/2022	12:55	PO	Conversion of SSN to DSN at location No. 68
KANDALGAON - SONA ALLOYS	IntraState	29/10/2022	10:43	29/10/2022	18:25	PO	Damaged conductor to be attended by applying midspan joint at Loc.No.47 & 48 and other line maintenance work.
BOISAR II - BOISAR (PG) CKT - 2	IntraState	29/10/2022	14:55	29/10/2022	21:50	PO	Bay Maintenance works.
CHAKAN (400KV) - VOLKSWAGEN	IntraState	29/10/2022	18:59	29/10/2022	20:04	T	suspected tripping due to DC leakage in BCU
CHAKAN - CHINCHWAD 2	IntraState	29/10/2022	19:02	29/10/2022	20:02	T	suspected tripping due to DC leakage in BCU
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/100 KV 100MVA NO 4 @ CHINCHWAD	IntraState	27/10/2022	22:57	28/10/2022	12:22	EO	HV CB Lockout problem attending work
220/33kV 100 MVA TF 1 @ GHODBUNDER	IntraState	28/10/2022	09:27	28/10/2022	13:52	PO	1. Oil top up in OLTC & Main conservator tank of 100MVA TR-1. 2. Checking of NGT Oil Low alarm.
220/132-110KV 100MVA PTR 2 @ WATHAR	IntraState	28/10/2022	10:10	28/10/2022	17:39	PO	Diagonstic testing work & Quarterly maint. Works
220/110 kV 200 MVA ICT 1 @ MUDSHINGI	IntraState	28/10/2022	15:42	28/10/2022	17:54	EO	To check the Fire detector circuit it is requested to please approve an emergency outage on 200MVA,220/110kV ICT 1 at 220kV Mudshingi substation.
220 KV BUSBAR Outages/Trippings							
BUS SECTION - 3 (7M3) @ CHINCHWAD	IntraState	27/10/2022	23:05	28/10/2022	05:17		Earth wire replacement on 220KV Bus and 220KV Bus isolator maintenance work
BUS SECTION - 1 (7M1) @ CHINCHWAD	IntraState	27/10/2022	23:05	28/10/2022	05:17		Earth wire replacement on 220KV Bus and 220KV Bus isolator maintenance work
BUS SECTION - 2 (7M2) @ CHINCHWAD	IntraState	27/10/2022	23:05	28/10/2022	05:17		Earth wire replacement on 220KV Bus and 220KV Bus isolator maintenance work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Oct/2022

Statement-VII

Position as on 6.30 Hrs of 29/Oct/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS @ PAWAS	IntraState	29/10/2022	10:02	29/10/2022	18:53	PO	For shifting of 220kV PT on new equipment structure & PT Isolator maintenance & routine maintenance of bus isolator work at 220kV Pawas S/s
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage