

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Dec/2018 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	140.069	3777.894	1) Gujrat	-1.466	37.289
2) Hydro	3.817	148.809	2) Madhya Pradesh	5.189	233.299
3) Gas	7.257	195.712	3) Chattisgarh	4.910	154.730
Total MSPGCL	151.143	4122.415	4) Maharashtra Net	77.669	2587.815
B) 1) APML	61.680	1912.940	5) Goa (Amona)	-0.220	-8.778
2) JSWEL	21.233	518.092	Total	86.082	3004.355
3) VIPL	9.345	263.527	a) Mumbai Schedule	18.503	519.677
4) RPL(AMT)	3.851	270.357	b) Mumbai Drawl	21.440	616.459
5) WPCL	0.000	27.408	c) MSEDCL Bilateral *	16.691	552.399
6) PGPL	0.000	0.000	Include PX	-7.454	-159.611
7) Other IPP	15.523	427.716	d) Mumbai Bilateral *	18.503	513.262
C) 1) TPCL Thermal	10.325	357.067	Include PX	0.403	33.069
2) TPCL Hydro	5.072	97.796	Include Standby	0.000	6.415
3) TPCL Gas	4.415	118.300	H) ENERGY CATERED (MUs)		
4) R-INFRA Thermal	4.565	216.881	1) MSEDCL	347.494	10342.096
D) STATE			2) Mumbai Discoms	45.816	1406.493
1) Thermal	266.591	7771.882	TOTAL STATE	393.310	11748.589
(A1+C1+C4+(B1-B6))					
2) Hydro	8.889	246.605			
(A2+C2)					
3) Gas	11.672	314.012			
(A3+B6+C3)					
4) Wind	13.839	266.762			
6) SOLAR	6.238	144.983			
TOTAL STATE	307.229	8744.244			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6146	5970	5743	5466
MSPGCL Hydro	299	264	98	122
MSPGCL Gas	297	289	306	305
MSPGCL Total Generation	6742	6523	6147	5893
Central Sector Receipt	4796	4837	4374	1830
WIND	807	402	186	487
CPP / IPP Thermal	5474	4942	4915	4079
CPP / IPP Gas	0	0	0	0
SOLAR	874	912	0	0
Exchange with Mumbai	-1259	-1218	-1103	-709
MSEDCL DEMAND MET	17434	16398	14519	11580
Load Shedding	0	0	0	0
MSEDCL DEMAND	17434	16398	14519	11580
TPCL GENERATION	928	958	1060	701
R-INFRA GENERATION	190	190	190	190
MUMBAI DEMAND	2377	2366	2353	1600
STATE DEMAND MET	19811	18764	16872	13180
STATE DEMAND	19811	18764	16872	13180
Frequency (Hz)	49.95	49.91	49.97	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.14 Hz at 17.01 Hrs	49.75 Hz at 12.19 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 28/Dec/2018

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	20.06	0	0
Unit 7	3.47	32.86	155	120
Unit 8	7.88	213.27	404	266
Unit 9	8.59	109.29	416	256
Unit 10	7.95	210.81	401	300
Total	27.90	586.29		
Bhusawal				
Unit 3	0.00	10.78	0	0
Unit 4	8.42	215.50	355	350
Unit 5	8.50	269.46	360	350
Total	16.92	495.75		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	11.08	0	0
Unit 7	0.00	37.54	0	0
Unit 8	4.73	135.60	215	152
Total	4.73	184.22		
Chandrapur				
Unit 3	4.12	117.57	190	163
Unit 4	4.03	116.61	182	160
Unit 5	8.90	258.52	405	350
Unit 6	9.22	233.64	435	364
Unit 7	9.07	253.44	420	360
Unit 8	9.20	280.39	470	363
Unit 9	9.31	280.00	470	360
Total	53.85	1540.16		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	4.82	147.87	206	199
Total	4.82	147.87		
Khaparkheda				
Unit 1	3.75	40.48	160	130
Unit 2	3.84	110.42	165	145
Unit 3	3.80	111.12	162	155
Unit 4	3.71	106.03	160	150
Unit 5	9.15	251.58	390	361
Total	24.24	619.62		
Nasik				
Unit 3	3.62	108.96	170	0
Unit 4	3.99	95.03	169	163
Unit 5	0.00	0.00	0	0
Total	7.61	204.00		
Uran				
All Units	7.26	195.71	321	275
Total	7.26	195.71		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	2.00	24	0

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.04	2.00		
Koyna				
Stage 1-2	1.34	42.26	135	40
Stage 4	0.00	12.50	0	0
Stage 3	0.16	12.11	80	0
Total	1.50	66.87		
Hydro				
KDPH	0.00	11.72	0	0
VTRNA	0.51	9.73	60	0
TILLARI	0.00	6.24	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.10	4.65	66	0
RNGR+BHTSA	0.24	8.98	14	0
BHANDARDRA	0.00	0.01	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.36	12.80	23	12
GHATGHAR	1.10	27.80	125	0
Total	2.31	81.94		
Wind				
Total	13.84	266.76	0	0
Total	13.84	266.76		
CPP				
APML(Mus)	61.68	1912.94	0	0
JSWEL(Mus)	21.23	518.09	0	0
VIPL(Mus)	9.34	263.53	0	0
RPLAMT(Mus)	3.85	270.36	0	0
WPCL(Mus)	0.00	27.41	0	0
Other(Mus)	15.52	427.72	0	0
Total	111.63	3420.04		
SOLAR				
Total	6.24	144.98	0	0
Total	6.24	144.98		
Tata				
Trombay 5	7.34	219.96	312	279
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.80	74.74	118	115
Trombay 7B	1.61	43.56	68	66
Trombay 8	2.99	137.11	149	120
TATA Hydro	5.07	97.80	441	6
Total	19.81	573.16		
R-INFRA				
DTPS U-1&2	4.56	216.88	192	190
Total	4.56	216.88		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	140.07	3777.89	MSPGCL Total	151.14	4122.42
			MSPGCL Thml+Gas	147.33	3973.61	Koyna 1,2 & 4 Total	1.34	54.76
			MSPGCL Hydro	3.82	148.81	State Total	307.23	8744.24

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 28/Dec/2018

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5638	66	314	6018	836	4289	0	0	1439	1530	-603	12070	0	12070	1448	13518	49.96
2	5689	66	316	6071	816	4274	0	0	2016	1718	-510	12369	0	12369	1325	13694	50.00
3	5730	71	306	6107	811	4296	0	0	2101	1738	-469	12483	0	12483	1266	13749	49.99
4	5741	71	318	6130	812	4298	0	0	2345	1740	-455	12525	0	12525	1233	13758	50.01
5	5759	76	316	6151	838	4280	0	0	2206	2459	-481	13247	0	13247	1259	14506	49.95
6	5776	133	306	6215	856	4272	0	0	2899	3199	-560	13982	0	13982	1360	15342	49.94
7	5776	146	321	6243	926	4388	0	4	4357	4090	-693	14958	0	14958	1502	16460	49.98
8	6000	228	318	6546	929	4717	0	85	4863	4918	-796	16399	0	16399	1692	18091	49.87
9	6090	228	317	6635	836	5109	0	329	4737	4753	-928	16734	0	16734	1976	18710	49.93
10	6059	267	301	6627	837	5311	0	669	4941	4630	-1137	16937	0	16937	2237	19174	49.92
11	6146	299	297	6742	807	5474	0	874	5028	4796	-1259	17434	0	17434	2377	19811	49.95
12	6168	338	291	6797	747	5273	0	875	4969	4680	-1262	17110	0	17110	2403	19513	49.94
13	5970	264	289	6523	402	4942	0	912	5122	4837	-1218	16398	0	16398	2366	18764	49.91
14	5953	218	278	6449	372	4762	0	873	4909	4847	-1082	16221	0	16221	2219	18440	50.05
15	5960	192	286	6438	270	4737	0	750	4769	4618	-1065	15748	0	15748	2218	17966	50.03
16	5994	192	285	6471	230	4767	0	561	4430	4325	-1073	15281	0	15281	2246	17527	49.93
17	5975	111	275	6361	170	4822	0	273	4289	4129	-1088	14667	0	14667	2260	16927	49.95
18	5913	56	289	6258	131	4916	0	33	3986	4340	-1053	14625	0	14625	2260	16885	49.99
19	5743	98	306	6147	186	4915	0	0	4157	4374	-1103	14519	0	14519	2353	16872	49.97
20	5705	139	296	6140	323	4751	0	0	4169	4061	-1092	14183	0	14183	2296	16479	49.99
21	5689	112	311	6112	381	4564	0	0	3482	3669	-1013	13713	0	13713	2129	15842	49.99
22	5667	122	302	6091	378	4304	0	0	3057	2557	-940	12390	0	12390	1978	14368	50.02
23	5462	202	314	5978	458	4092	0	0	2006	2244	-851	11921	0	11921	1814	13735	50.00
24	5466	122	305	5893	487	4079	0	0	1838	1830	-709	11580	0	11580	1600	13180	50.01
MUs	140.07	3.82	7.26	151.14	13.84	111.63	0.00	6.24	88.11	86.08	-21.44	347.49	0.00	347.49	45.82	393.31	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 28/Dec/2018

Position as on 6.30 Hrs of 29/Dec/2018

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Nasik Unit 5	210	22/11/2018	03.50		Continued.	Boiler Tube Leakage work completed on 24/11/2018. Available against case 4 from 25/11/2018. Converted to COH from 00:00 Hrs of 05/12/2018 (for 40 Days)	
RINFRA-G	REL Unit 1	250	23/12/2018	06.06		Continued.	For COH.	
FORCED OUTAGE								
TPC-G	Trombay 6	500	15/07/2015	17:08		Continued.	Economic shutdown	
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
MSPGCL	Uran Unit 7	108	20/07/2018	12.53		Continued.	Compressor & Turbine Blade Failure.	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	Poor Coal Receipt	
MSPGCL	Uran Unit 8	108	08/09/2018	22.08		Continued.	Withdrawn due to B0 & U-7	
MSPGCL	Paras Unit 3	250	15/09/2018	00.55		Continued.	Stator Earth Fault	
IPP	RPL(AMT) U-4	270	20/09/2018	00.01		Continued.	Zero Schedule.	
MSPGCL	Koyana Unit 4	70	03/11/2018	09.02	29/12/2018	21:25	Stator Earth Fault	
MSPGCL	Koyana Unit 1	70	26/11/2018	00.00		Continued.	Oil Cooler Leakage.	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
MSPGCL	Parli Unit 6	250	12/12/2018	00.00		Continued.	ZERO SCHEDULE.	
MSPGCL	Parli Unit 7	250	12/12/2018	00.00		Continued.	ZERO SCHEDULE.	
MSPGCL	Bhusawal Unit 3	210	14/12/2018	03.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-1	270	14/12/2018	16.00		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-3	270	14/12/2018	16.30		Continued.	Zero Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
MSPGCL	Koradi Unit 6	210	22/12/2018	01.18		Continued.	Bearing Temperature high	
IPP	RPL(AMT) U-2	270	27/12/2018	19.30		Continued.	Zero Schedule.	
IPP	RPL(AMT) U-5	270	28/12/2018	19.30		Continued.	Zero Schedule.	
MSPGCL	Nasik Unit 3	210	28/12/2018	22.05		Continued.	Zero Schedule.	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
MSPGCL	Uran Unit 6	108	29/12/2018	09.40	29/12/2018	13.58	For Air Intake Filter Replacement Work.	
MSPGCL	Koradi Unit-8	660	29/12/2018	23.01		Continued.	FOR BOILER VALIDITY EXTENSION PCR.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2018

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
400 KV Main Bus I @ Ektuni	IntraState	29/12/2018	11.04	29/12/2018	15.40	PO	Replacement Of Faulty Bus Bar Peripheral Unit Of 705(Tie-2) Bay.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line converted as 220 kV Solapur (PG)- Jeur from LOC 403
Dhule Sar'Sarovar II	InterState	24/12/2018	18.09		Continued.	HT	Over Voltage
Padgha Tarapur II	InterState	28/12/2018	04.48		Continued.	T	Y Phase CT Burst. 30/12/2018 (RFC 12.50).
Chandrapur-II - Nanded ckt I	IntraState	26/12/2018	10.44	28/12/2018	07.20	PO	Replacement of Polymer String Insulator.
Karad-Jaigad - I	IntraState	26/12/2018	18.30	28/12/2018	09.45	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	27/12/2018	17.52	28/12/2018	07.52	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	27/12/2018	21.55	28/12/2018	08.53	HT	Over Voltage
Padghe - Kalwa-II	IntraState	28/12/2018	04.48	28/12/2018	05.51	T	Bus Bar Prot.Operated at Padghe due to Y Phase CT Burst of Tarapur-II Line
400KV Main Bus-I @400KV Padgha	IntraState	28/12/2018	04.48	28/12/2018	05.15	T	Bus Bar Protection Operated
Padghe(HVDC)- Padghe(HVAC)-I	IntraState	28/12/2018	04.48	28/12/2018	06.07	T	Bus Bar Prot.Operated at Padghe due to Y Phase CT Burst of Tarapur-II Line
Bus Coupler @ Padgha	IntraState	28/12/2018	04.48	28/12/2018	05.15	T	Bus Bar Operated.
Padghe - Nagothane - I	IntraState	28/12/2018	04.48	28/12/2018	15.45	T	Bus Bar Prot.Operated at Padghe due to Y Phase CT Burst of Tarapur-II Line
Babhaleshwar - Padghe-II	IntraState	28/12/2018	04.48	28/12/2018	05.31	T	Bus Bar Prot.Operated at Padghe due to Y Phase CT Burst of Tarapur-II Line
Chandrapur-II - Nanded ckt II	IntraState	28/12/2018	08.37	28/12/2018	18.18	PO	DCRM Measurement.
Main Bus II @ Akola 2	IntraState	28/12/2018	09.20	28/12/2018	18.00	PO	Bus Bar Equipment Maintenance Activity.
Khadka-Aurangabad (Waluj)	IntraState	28/12/2018	18.22	29/12/2018	09.41	HT	Over Voltage
Karad - Jaigad - II	IntraState	28/12/2018	20.00	29/12/2018	09.44	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	28/12/2018	21.38	29/12/2018	07.50	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt-II	IntraState	29/12/2018	09.26	29/12/2018	14.54	PO	Testing And Maintenance Of Bay Equipment's.
Karad-Jaigad - I	IntraState	29/12/2018	17.31		Continued.	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	29/12/2018	18.06		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	29/12/2018	21.08		Continued.	HT	Over Voltage
Koradi-RattanIndia	IntraState	29/12/2018	21.40		Continued.	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential protection, Declared Faulty.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	25/11/2018	00.54		Continued.	T	NDR ALARM CHANGED ON HUMMING AT (30-12-2018 AT 18.21.)
400/220kv 315MVA ICT-I@Parly	IntraState	24/12/2018	15.40		Continued.	PO	Replacement Of B-PH Unit By Re paired One.
400/220/33kv 500MVA ICT 5 @ Padghe	IntraState	27/12/2018	19.06	29/12/2018	20.50	HT	Due To NDR Alram.
400/220/33 Kv 315 Mva ICT 2 @Padghe	IntraState	28/12/2018	04.48	28/12/2018	06.21	T	Bus Bar Prot.Operated at Padghe due to Y Phase CT Burst of Tarapur-II Line
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/06/2017	00.01		Continued.	PO	No Schedule
Mudshingi - Chikodi	InterState	01/06/2017	00.06		Continued.	PO	No Schedule.
Chandrapur GCR - Warora - I	IntraState	05/04/2015	09.13		Continued.	PO	Bunching of conductor Loc no 86 Disconnecting of jumper at Loc no

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2018

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Chandrapur GCR - Wani	IntraState	05/04/2015	09.15		Continued.	PO	86 & 107 and de-energising the line bet.86 to 107. For Bunching Of Conductor at Loc No.86 Disconnecting Of jumper at Loc No.86 to 107 And Deenergising The Line Between Loc No.86 To 107.
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To control line loading.
Kalwa-TIFIL	IntraState	27/11/2018	06.06		Continued.	EO	Tapping Of Tifil Substation On 220KV Kharghar-Borivali Line
Kalwa - Siemens	IntraState	27/11/2018	13.13	28/12/2018	13.13	HT	To Shift Load On Kharghar ICT
Padgha - Temghar I	IntraState	03/12/2018	08.15		Continued.	EO	To control load on Padgha ICTs.
Padgha-Temghar-II	IntraState	03/12/2018	08.15		Continued.	EO	To control load on Padgha ICTs.
Taloja li - OCIL-II	IntraState	18/12/2018	12.43	28/12/2018	18.46	PO	REPLACEMENT OF METERING CTs & PTs AT OCIL END.
Trombay - Kalwa	IntraState	24/12/2018	14.50		Continued.	PO	For Replacement Of Rusted Tower.
Trombay - Mulund	IntraState	24/12/2018	15.14		Continued.	PO	For Replacement Of Rusted Tower.
Wpcl-Warora 1	IntraState	27/12/2018	10.16	29/12/2018	15.55	PO	Routine Maintenance Work
Goregaon Aarey Line 2	IntraState	28/12/2018	07.30	28/12/2018	18.32	PO	Diversion Line.
Dahanu-Viraj	IntraState	28/12/2018	08.06	28/12/2018	19.16	PO	Routine Maintenance Work
Karad(400kv) -Mudshingi Ckt 2-Tak	IntraState	28/12/2018	08.22	28/12/2018	16.36	PO	Testing & Maintenance Work.
Pophali - Kdph	IntraState	28/12/2018	08.40	28/12/2018	17.45	PO	Insulator Washing.
Kharghar-Borivali ckt I	IntraState	28/12/2018	08.47	28/12/2018	19.02	PO	OPGW Work.
Khaparkhedha-Ambazari-I	IntraState	28/12/2018	09.02	28/12/2018	16.47	PO	Scada Integration Work.
Waluj-Padegaon I	IntraState	28/12/2018	09.09	28/12/2018	17.49	PO	Conversion Of Single Jumper To Twin Jumper.
Oni Kharepatan Line	IntraState	28/12/2018	09.14	28/12/2018	18.00	PO	Insulator Cleaning Work.
Tata Borivli MSETCL Borivli 5	IntraState	28/12/2018	09.45	28/12/2018	18.15	PO	Replacement of R-PH LA At Borivali End.
Kanhan - Suryalaxmi	IntraState	28/12/2018	09.56	28/12/2018	21.10	EO	Attending Hot Spot And Diagnostic Testing Work.
Main Bus I @ Parli Ext.	IntraState	28/12/2018	10.45	28/12/2018	12.05	T	Bus Bar Protection Operated
Malegaon-Sayne	IntraState	28/12/2018	11.25	28/12/2018	15.00	PO	Diagnostic Testing Work.
Kharghar-Borivali ckt II	IntraState	28/12/2018	13.22	28/12/2018	14.23	HT	Safety Work For OPGW Work.
Kharghar-Sonkhar	IntraState	28/12/2018	13.29	28/12/2018	14.11	HT	Safety Work For OPGW Work.
Shivajinagar - Malegaon	IntraState	28/12/2018	15.15	28/12/2018	17.33	PO	Work At Malegaon End.
Goregaon Aarey Line 2	IntraState	29/12/2018	08.08	29/12/2018	20.13	PO	Diversion Of Line On Mono pole 26B.
Dahanu Ghodbunder Line 2	IntraState	29/12/2018	08.12	29/12/2018	20.41	PO	Preventive Maintenance Work At ADTPS.
Oni Kharepatan Line	IntraState	29/12/2018	08.36	29/12/2018	17.05	PO	Insulator Washing.
Talandage - Sawantwadi I	IntraState	29/12/2018	09.01	29/12/2018	12.54	PO	R-Ph Flash over String Replaced At loc no 182.
Urse - Talegaon (Ambi) Ckt 1	IntraState	29/12/2018	09.18	29/12/2018	18.31	PO	Stn-Dtn Conversion & Double Jumpering Work.
Pophali - Kdph	IntraState	29/12/2018	10.23	29/12/2018	18.30	PO	Washing Insulator.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT I @Kolshet	IntraState	29/12/2018	08.48	29/12/2018	08.15	HT	Due To Main Bucholz Alarm, load Affected-Nil other Ict Taken load.
220/132kv 100mva Vijai Ptr No 1 @Baramati	IntraState	29/12/2018	10.15	29/12/2018	13.05	PO	Replacement Of Gear Box Of OLTC And Relay Testing Work.
132 KV LINE Outages/Trippings							
Hingoli 2- Akhada Balapur	IntraState	28/12/2018	01.13	28/12/2018	03.05	T	Half Bus Section Of Busbar Operated.
Hingoli-II - Hingoli-I Ckt 1	IntraState	28/12/2018	01.13	28/12/2018	03.04	T	Half Bus Section Of Busbar

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2018

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2018

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Elichpur - Hingoli	IntraState	28/12/2018	01.22	28/12/2018	03.04	T	Operated.
							Distance Protection Operated, Zone 1, B-E, 1.6KA.