

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 28/Dec/2021 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.932	3840.512	1) Gujrat	-6.827	-217.170
2) Hydro	12.922	218.423	2) Madhya Pradesh	4.289	41.434
3) Gas	5.701	138.303	3) Chattisgarh	5.880	162.350
Total MSPGCL	141.555	4197.238	4) Maharashtra	148.864	3816.058
B) 1) APLM	71.399	1741.485	5) Goa (Amona)	-1.765	-44.821
2) JSWEL	10.125	377.398	Total	150.441	3757.851
3) VIPL	0.000	0.000	a) Mumbai Schedule	23.074	684.115
4) RPL(AMT)	28.180	733.876	b) Mumbai Drawl	25.142	730.897
5) SWPGPL	6.036	209.835	c) MSEDCL Bilateral *	54.248	1380.846
6) Other IPP	38.049	1057.267	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	23.074	684.115
C) 1) TPCL Thermal	6.398	217.712	Include PX	0.000	3.902
2) TPCL Hydro	5.211	122.464	Standby	0.000	0.000
3) TPCL Gas	3.284	82.597	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.108	271.205	1) MSEDCL	424.476	11453.120
D) STATE			2) Mumbai Discoms	49.143	1424.868
1) Thermal	292.227	8449.290	3) Other Discoms	10.120	274.311
(A1+C1+C4+(B1-B6))			TOTAL STATE	483.739	13152.299
2) Hydro (A2+C2)	18.133	340.887			
3) Gas (A3+B7+C3)	8.985	220.900			
4) Wind	8.202	214.475			
6) SOLAR	5.751	168.903			
TOTAL STATE	333.298	9394.455			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	5569	5577	5485	4176
MSPGCL Hydro	1268	847	520	293
MSPGCL Gas	231	241	238	246
MSPGCL Total Generation	7068	6665	6243	4715
Central Sector Receipt	8146	7639	5916	5332
WIND	217	219	216	391
CPP / IPP Thermal	6828	6807	6700	4940
CPP / IPP Gas	0	0	0	0
SOLAR	898	915	0	0
Exchange with Mumbai	-1311	-1344	-1167	-961
MSEDCL DEMAND MET	17567	16701	13610	10765
Load Shedding	0	0	0	0
MSEDCL DEMAND	17567	16701	13610	10765
TPCL GENERATION	814	744	879	463
AEML GENERATION	449	417	390	329
MUMBAI DEMAND	2574	2505	2436	1753
OTHER DISCOM DEMAND	389	382	391	332
STATE DEMAND MET	24420	23406	20344	16170
STATE DEMAND	24420	23406	20344	16170
Frequency (Hz)	49.99	49.94	50.03	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 17:02 Hrs	49.84 Hz at 06:11 Hrs	50	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 28/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.56	99.98	170	120
Unit 7	0.00	0.00	0	0
Unit 8	0.00	336.83	0	0
Unit 9	0.00	237.40	0	0
Unit 10	12.86	365.30	575	407
Total	16.41	1039.52		
Bhusawal				
Unit 3	3.44	63.02	180	115
Unit 4	8.88	243.13	430	280
Unit 5	8.88	244.62	440	280
Total	21.20	550.78		
Parli				
Unit 6	4.47	61.79	240	155
Unit 7	3.92	43.80	202	133
Unit 8	4.32	95.26	211	148
Total	12.71	200.85		
Chandrapur				
Unit 3	3.33	68.34	177	115
Unit 4	3.18	89.52	155	120
Unit 5	8.31	164.39	390	300
Unit 6	9.19	220.01	450	260
Unit 7	7.62	214.47	350	285
Unit 8	0.00	218.66	0	0
Unit 9	10.28	261.31	461	294
Total	41.92	1236.71		
Paras				
Unit 3	4.61	121.25	242	132
Unit 4	4.50	122.65	230	142
Total	9.11	243.90		
Khaparkheda				
Unit 1	1.41	26.28	140	0
Unit 2	0.00	25.46	0	0
Unit 3	3.85	39.17	194	118
Unit 4	1.27	29.76	147	0
Unit 5	10.36	268.56	460	285
Total	16.90	389.22		
Nasik				
Unit 3	0.00	53.64	0	0
Unit 4	1.36	34.53	158	0
Unit 5	3.32	91.36	184	114
Total	4.68	179.53		
Uran				
All Units	5.70	138.30	250	225
Total	5.70	138.30		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.54	7.23	31	5
Total	0.54	7.23		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.78	63.00	395	35
Stage 4	3.22	25.30	750	0
Stage 3	1.55	20.25	240	0
Total	7.55	108.56		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.06	0	0
TILLARI	0.52	9.37	58	0
BHIRA T.R.	0.36	7.19	40	0
SMLHY_PTN	4.49	93.24	198	173
GHATGHAR	0.00	0.00	0	0
Total	5.37	109.87		
Wind				
Total	8.20	214.48	0	0
Total	8.20	214.48		
CPP				
APML(Mus)	71.40	1741.48	0	0
JSWEL(Mus)	10.12	377.40	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	28.18	733.88	0	0
SWPGPL-Mus	6.04	209.84	0	0
Other(Mus)	38.05	1057.27	0	0
Total	153.79	4119.86		
SOLAR				
Total	5.75	168.90	0	0
Total	5.75	168.90		
Tata				
Trombay 5	6.40	195.91	302	257
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.95	48.89	114	54
Trombay 7B	1.34	33.70	67	44
Trombay 8	0.00	21.80	0	0
TATA Hydro	5.21	122.46	439	0
Total	14.89	422.77		
AEMIL				
DTPS U-1&2	9.11	271.20	459	323
Total	9.11	271.20		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	122.93	3840.51	MSPGCL Total	141.56	4197.24
			MSPGCL Thml+Gas	128.63	3978.82	Koyna 1,2 & 4 Total	6.00	88.30
			MSPGCL Hydro	12.92	218.42	State Total	333.30	9394.46

State Load Despatch Center,Airoli (MSETCL)
Hourly Load Data As on 28/Dec/2021

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4522	247	246	5015	267	5855	0	0	5696	5321	-912	15244	0	15244	1637	302	17183	50.00
2	4510	233	237	4980	301	5749	0	0	5731	5475	-837	15363	0	15363	1545	305	17213	49.98
3	4488	240	237	4965	277	5965	0	0	5560	5114	-762	15288	0	15288	1464	271	17023	49.97
4	4491	232	249	4972	300	6115	0	0	5534	5298	-727	15683	0	15683	1424	275	17382	49.97
5	4586	246	239	5071	372	6430	0	0	5641	5363	-742	16209	0	16209	1434	285	17928	50.01
6	5263	288	250	5801	431	6672	0	0	5637	5433	-794	17226	0	17226	1520	317	19063	49.99
7	5570	334	241	6145	526	6755	0	2	5878	5858	-651	18300	0	18300	1636	335	20271	49.96
8	5545	1032	250	6827	560	6759	0	66	6133	6148	-764	19253	0	19253	1811	343	21407	49.98
9	5564	1440	239	7243	343	6775	0	292	6471	6669	-938	19993	0	19993	2110	391	22494	49.97
10	5567	1339	235	7141	256	6786	0	582	7533	7799	-1138	21036	0	21036	2366	390	23792	49.94
11	5505	1607	245	7357	213	6819	0	796	7901	7862	-1273	21386	0	21386	2538	388	24312	49.97
12	5569	1268	231	7068	217	6828	0	898	7908	8146	-1311	21457	0	21457	2574	389	24420	49.99
13	5577	847	241	6665	219	6807	0	915	8010	7639	-1344	20519	0	20519	2505	382	23406	49.94
14	5487	438	225	6150	416	6764	0	764	7786	7800	-1354	20167	0	20167	2361	373	22901	50.01
15	5507	367	226	6100	403	6765	0	709	7964	7659	-1385	19877	0	19877	2360	374	22611	50.02
16	5542	296	235	6073	401	6766	0	439	7778	7094	-1312	19094	0	19094	2354	367	21815	50.02
17	5439	279	226	5944	368	6697	0	236	6958	6706	-1162	18416	0	18416	2363	373	21152	50.03
18	5473	305	226	6004	219	6688	0	52	5912	5773	-1074	17276	0	17276	2371	386	20033	50.03
19	5485	520	238	6243	216	6700	0	0	5964	5916	-1167	17517	0	17517	2436	391	20344	50.03
20	5542	410	232	6184	272	6775	0	0	5780	5390	-1160	17085	0	17085	2387	376	19848	50.04
21	4880	227	229	5336	324	6521	0	0	5792	5253	-1131	15942	0	15942	2235	361	18538	50.03
22	4397	216	241	4854	464	5621	0	0	5925	5830	-1187	15217	0	15217	2064	365	17646	50.04
23	4247	218	237	4702	446	5237	0	0	5662	5563	-1056	14536	0	14536	1895	356	16787	49.99
24	4176	293	246	4715	391	4940	0	0	5374	5332	-961	14085	0	14085	1753	332	16170	50.01
MUs	122.93	12.92	5.70	141.56	8.20	153.79	0.00	5.75	154.53	150.44	-25.14	426.17	0.00	426.17	49.14	8.43	483.74	50.00

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 28/Dec/2021

Position as on 6.30 Hrs of 29/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09:55		Continued.	Annual Overhaul	
TPC_G	Trombay 8	250	06/12/2021	00:00		Continued.	Annual Overhaul	02/01/2022
MSPGCL	Khaparkhedha Unit 2	210	09/12/2021	01:49		Continued.	CHP coal feeding problem(Converted to Annual Overhaul 00:00Hrs Dt. 18.12.2021)	
MSPGCL	Koyna Unit 5	80	20/12/2021	08:40		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 8	500	25/12/2021	00:01	29/12/2021	18:11	CW DEBRIS FILTER INSPECTION AND MAINTENENCE WORK	
IPP	SWPGL U-2	135	25/12/2021	00:09		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Khaparkhedha Unit 1	210	09/12/2021	00:56	28/12/2021	09:55	CHP coal feeding problem	
MSPGCL	Nasik Unit 4	210	11/12/2021	21:22	28/12/2021	12:25	withdrawn against case 4 to dhariwal	
MSPGCL	Koradi Unit 8	660	25/12/2021	09:56		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 3	210	27/12/2021	20:30		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	27/12/2021	23:45		Continued.	Boiler Tube Leakage	
MSPGCL	Khaparkhedha Unit 4	210	28/12/2021	10:00		Continued.	Boiler Tube Leakage	31/12/2021
MSPGCL	Uran Unit 8	108	29/12/2021	00:27		Continued.	Withdrawn	
MSPGCL	Koyna STG-IV Unit-1	250	29/12/2021	01:07	29/12/2021	10:50	on speed disscrepancy measurement fault	
MSPGCL	Chandrapur Unit 8	500	29/12/2021	18:24	29/12/2021	20:16	GENERATOR DAVR,ULR OPERATED FIELD BREAKER OPEN DUE TO JERK ON BUS I & II	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Trippings							
MAIN BAY - 701 OF 765/400KV 1500MVA ICT-1 @ KORADI 3	IntraState	28/12/2021	09:02	28/12/2021	19:46	PO	Annual Maintenance of Bay Equipments
400 KV TIEBAY Outages/Trippings							
TIE BAY (403) OF KHADKA CKT - 2 @ DEEPNAGAR	IntraState	27/12/2021	10:27	28/12/2021	18:03	PO	For TIE CB DCRM Testing & Bay Maintenance work.
TIE BAY - 402 OF BUS REACTOR @ ALKUD	IntraState	29/12/2021	10:25	29/12/2021	17:43	PO	QM & DIAGNOSTIC TESTING WORK
400 KV MAINBAY Outages/Trippings							
MAIN BAY - 401 OF BUS REACTOR @ ALKUD	IntraState	29/12/2021	10:25	29/12/2021	17:53	PO	QM & DIAGNOSTIC TESTING WORK
MAIN BAY (404) OF KALA CKT 1 @ KUDUS	IntraState	29/12/2021	10:42	29/12/2021	15:35	PO	AMP OF 404 Main Bay of 400 KV Padghe Kudus Line 2 at Kudus MSETCL SS.
400 KV LINE Outages/Trippings							
TBC 2 @ CHANDRAPUR	IntraState	20/12/2021	08:58			PO	1) For replacement of 400KV old overaged PG Isolators (Bus-1 & Aux. Bus Isolators.) 2) Servicing and overhauling of 400KV BHEL make quadruple CB. 3) Measurement of Timing, DCRM and CRM of CB.
TBC @ KORADI-1	IntraState	24/12/2021	13:40			EO	"Heavy air leakage in ABB make 400 kV CB R pole observed and CB got lockout due to 0 bar air pressure in CB. To attend the heavy air leakage of ABB make 400 kV CB R pole emergency outage is required on 400 kV TBC Bay ."
JAIGAD - KARAD CKT - 2	IntraState	27/12/2021	22:06	28/12/2021	10:05	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	27/12/2021	23:28	28/12/2021	08:59	HT	HT FOR OVERVOLTAGE
PADGHE - NAGOTHANE CKT - 1	IntraState	27/12/2021	23:39	28/12/2021	08:41	HT	HT FOR OVERVOLTAGE
NEW KOYNA - DABHOL CKT - 1	IntraState	29/12/2021	03:00	29/12/2021	16:23	T	TRIPPED ON OVER VOLTAGE
125 MVAr BUS REACTOR @ ALKUD	IntraState	29/12/2021	09:40	29/12/2021	17:43	PO	QM & Diagnostic testing work
PADGHE - NAGOTHANE CKT - 1	IntraState	29/12/2021	10:03		Continued.	PO	1) For replacement /repair of C-Bus B-Ph PG Isolator as rotary insulator of isolator is damaged 2) Bay maintenance work
PADGHE - NAGOTHANE CKT - 2	IntraState	29/12/2021	12:58	29/12/2021	13:24	T	tripped while testing
220 KV MAINBAY Outages/Trippings							
MAIN BAY(208) OF 220KV-SOLAPUR-FUTURE 1 @SOLAPUR (PG)-220 KV	InterState	20/12/2021	17:22	28/12/2021	21:14	PO	reorientation work along with the disconnection of 220KV Bale-Tuljapur line at Loc.NO. 37 and establishment of link between Solapur PG to 220KV Bale substation will be carried out by utilizing D/C portion of Solapur PG -Bale line and jumpering work at substation end.
220 KV LINE Outages/Trippings							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BORIVALI - BOISAR (PG)	IntraState	19/12/2021	09:18			PO	1) 220kV PGCIL (Boisar)- Borivali line tapping will be done to 220kV Kamba-Vasai line at loc no. 204. After that 220KV PGCIL-Vasai Line will be charged at 18:00 Hrs on 19.12.2021 & it will be in service till 30.01.2022 for 43 days. 2) This work is required for DFCCIL work of Temporary shifting of existing of 100kV D/C padgha -Vasai Line between loc no. 85-93 on existing line corridor of D/C 220kV PadghaNalasopara-Vasai Tap line and 220kV Kamba Vasai Line between location no 8 to 14.
SOLAPUR(BALE) - TULJAPUR	IntraState	20/12/2021	10:54	28/12/2021	18:11	PO	Outage is required 1. Testing & communication work of line and bay at both substation (Bale & PGCIL) 2. Jumpering work at loc 37 on 220kV PGCIL Bale Line 3. Shifting of WT, CC & LMU (in existing Tuljapur bay) at 220kV Bale Substaion.
BABHALESHWAR - UTECH SUGAR	IntraState	26/12/2021	22:30	29/12/2021	19:43	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit, Nasik
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	NMIA work
WAGHIVALI - DHARAVI 7	IntraState	27/12/2021	08:16		Continued.	PO	FOR NMIA WORK
MALHARPETH - KARAD	IntraState	28/12/2021	09:29	28/12/2021	16:26	PO	Replacement of single/double suspension hardware at various locations & restringing of conductor between Loc No.156-157
ALKUD - VITA	IntraState	28/12/2021	10:21	28/12/2021	17:15	PO	Providing and fixing of suspension clamps at various locations
KHARGHAR - TOPWORTH	IntraState	28/12/2021	10:36	28/12/2021	18:52	PO	For providing of earthwire at Loc.No.581-584. OPGW work between Loc.No.640-673
KALWA - AIROLI KNOWLEDGE PARK	IntraState	28/12/2021	16:05	28/12/2021	18:55	PO	For B-phase Hot spot attending work at Loc no.405B.
COLOURCHEM - TEMGHAR	IntraState	29/12/2021	08:18		Continued.	PO	To carry out erection of Monopole Structure at Loc no.18 and stringing work in between loc no.17 & 19 at M/s Lodha Paradise thane.
TALOJA II - OCIL 2	IntraState	29/12/2021	08:20	29/12/2021	19:55	PO	Bay maintenance work and testing of 220kV CT/PTs
ALKUD - VITA	IntraState	29/12/2021	09:10	29/12/2021	17:53	PO	Providing and fixing of suspension clamps at various locations
MAIN BUS - 1 @ VERSOVA	IntraState	29/12/2021	09:10	29/12/2021	20:28	PO	1) Annual maintenance of 220kV Main Bus-1 side isolators and equipments. 2) Checking of alignment and maintenance of isolator 489A of Versova Ghodbunder Line i.e. Bay -4. 3) Checking of alignment and maintenance of isolator 1289A of Versova Goregaon Line-1i.e. Bay-12
LAMBOTI - PANDHARPUR	IntraState	29/12/2021	10:15	29/12/2021	18:06	PO	Outages is required for Quarterly Maintenance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 28/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 29/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS COUPLER @ VERSOVA	IntraState	29/12/2021	10:30	29/12/2021	20:28	PO	1)Facilitating outage of 220kV Main Bus 1. 2) Annual maintenance of Bus 1 connected isolator of Buscoupler bay.
ANANDNAGAR - PALAVA	IntraState	29/12/2021	10:30	29/12/2021	13:16	EO	Attending Hotspot at Wavetrap R phase bottom side
NAGOTHANE - ACCIL	IntraState	29/12/2021	11:11	29/12/2021	17:43	PO	Routine maintenance work and emergency tree cutting work
PANDHARPUR - MALINAGAR	IntraState	29/12/2021	12:13	29/12/2021	15:01	PO	Outages is required for Quarterly Maintenance
KANDALGAON - PIRANGUT	IntraState	29/12/2021	13:00	29/12/2021	17:50	PO	Replacement of faulty LMU, Diagnostic testing work, Bay maintenance work
MUMEWADI -HALKARNI 1 LINE	IntraState	29/12/2021	16:29	29/12/2021	16:56	T	Tripped on Distance protection
BABLESHWAR-BABLESHWAR(400KV)-I	IntraState	29/12/2021	23:32		Continued.	PO	29A, 29B isolator servicing and alignment and mechanism box replacement . Jump opening and reconnection for Main bus I and Main bus II by Hot line Unit,Nasik
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantailing said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 4 @ PADGHE	IntraState	27/12/2021	09:41	29/12/2021	19:05	PO	1. Retrofitting of REF relay for MTAMC pending work 2. Diagnostic testing work 3. Painting of ICT
220/33 KV 50 MVA PTR 2	IntraState	28/12/2021	10:52	28/12/2021	16:30	PO	For Transformer OLTC overhauling work.
250 MVA ICT-4 @ TROMBAY	IntraState	29/12/2021	09:04	29/12/2021	22:10	PO	ATTENDIN HOT SPOT ON LINE SIDE GOD
220/132 KV 100MVA ICT - 1 @ MANMAD	IntraState	29/12/2021	10:00	29/12/2021	14:10	PO	Measurement of C & Tan Delta Values, SFRA & misc maintenance work.
220/100 KV 100MVA NO 4 @ CHINCHWAD	IntraState	29/12/2021	11:45	29/12/2021	17:30	PO	For CTR MAKE NIFPS Maintenance
220/22 KV 50 MVA PTR 1 @ WADKHAL (GIS)	IntraState	29/12/2021	11:54	29/12/2021	17:33	PO	For cold welding work for attending oil leakages
220/132 KV 100MVA ICT - 2 @ MANMAD	IntraState	29/12/2021	14:30	29/12/2021	17:30	PO	Measurement of C & Tan Delta Values, SFRA & misc maintenance work.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage