

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Jan/2023 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	148.283	4194.288	1) Gujrat	-7.702	-140.724
2) Hydro	5.844	349.955	2) Madhya Pradesh	5.565	92.194
3) Gas	3.409	132.980	3) Chattisgarh	4.800	153.400
Total MSPGCL	157.536	4677.223	4) Maharashtra	169.771	5017.696
B) 1) APML	67.834	1671.578	5) Goa (Amona)	-0.896	-43.028
2) JSWEL	16.152	551.282	Total	171.538	5079.538
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.879	678.256
4) RPL(AMT)	31.180	751.750	b) Mumbai Drawl	30.653	788.672
5) SWPGPL	8.446	253.467	c) MSEDCL Bilateral *	69.588	2007.638
6) Other IPP	41.535	1339.698	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.879	677.575
C) 1) TPCL Thermal	3.192	230.693	Include PX	0.000	0.000
2) TPCL Hydro	2.299	109.042	Standby	0.000	0.681
3) TPCL Gas	2.414	64.974	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.328	263.645	1) MSEDCL	484.110	13868.270
D) STATE			2) Mumbai Discoms	46.886	1457.024
1) Thermal	324.950	9256.401	3) Other Discoms	9.402	279.768
(A1+C1+C4+(B1-B6))			TOTAL STATE	540.398	15605.062
2) Hydro	8.143	458.997			
(A2+C2)					
3) Gas	5.823	197.954			
(A3+B7+C3)					
4) Wind	15.777	239.332			
6) SOLAR	14.167	372.842			
TOTAL STATE	368.860	10525.526			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	7011	6404	6608	5554
MSPGCL Hydro	322	560	151	151
MSPGCL Gas	141	141	142	144
MSPGCL Total Generation	7474	7105	6901	5849
Central Sector Receipt	8681	8061	6458	5988
WIND	920	614	513	758
CPP / IPP Thermal	7221	7005	7452	6507
CPP / IPP Gas	0	0	0	0
SOLAR	1806	2067	0	0
Exchange with Mumbai	-1552	-1579	-1224	-1301
MSEDCL DEMAND MET	24142	22873	19670	17412
Load Shedding	0	0	0	0
MSEDCL DEMAND	24142	22873	19670	17412
TPCL GENERATION	338	329	507	233
AEML GENERATION	395	380	436	307
MUMBAI DEMAND	2285	2288	2167	1841
OTHER DISCOM DEMAND	408	400	430	389
STATE DEMAND MET	26835	25561	22267	19642
STATE DEMAND	26835	25561	22267	19642
Frequency (Hz)	49.90	50.07	50.01	49.99

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.42 Hz at 18.03 Hrs	49.73 Hz at 04.10 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Jan/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	5.00	125.30	215	200
Unit 7	0.00	0.00	0	0
Unit 8	12.98	383.00	552	532
Unit 9	12.82	277.25	654	495
Unit 10	12.73	373.26	555	500
Total	43.54	1158.81		
Bhusawal				
Unit 3	3.05	68.42	160	110
Unit 4	4.76	277.06	475	0
Unit 5	9.06	231.79	455	275
Total	16.87	577.26		
Parli				
Unit 6	4.24	118.58	224	149
Unit 7	0.00	13.70	0	0
Unit 8	3.84	85.13	213	143
Total	8.08	217.41		
Chandrapur				
Unit 3	3.27	85.01	168	120
Unit 4	2.82	76.15	127	104
Unit 5	7.07	188.83	320	273
Unit 6	7.80	205.66	415	273
Unit 7	0.00	0.00	0	0
Unit 8	10.18	301.85	493	275
Unit 9	10.31	308.44	496	311
Total	41.46	1165.93		
Paras				
Unit 3	4.49	124.17	230	0
Unit 4	5.78	133.24	252	222
Total	10.26	257.41		
Khaparkheda				
Unit 1	2.65	80.48	120	90
Unit 2	2.89	80.97	136	111
Unit 3	3.27	99.82	148	126
Unit 4	3.42	91.67	170	124
Unit 5	9.53	274.80	490	275
Total	21.76	627.76		
Nasik				
Unit 3	3.18	44.98	174	114
Unit 4	3.14	96.74	159	118
Unit 5	0.00	47.98	0	0
Total	6.32	189.70		
Uran				
All Units	3.41	132.98	147	136
Total	3.41	132.98		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.05	8.41	21	0
Total	0.05	8.41		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.16	99.00	320	40
Stage 4	0.08	102.97	40	0
Stage 3	0.43	43.80	80	0
Total	2.66	245.77		
Hydro				
KDPH	0.00	9.83	0	0
VTRNA	0.46	4.94	61	0
TILLARI	0.00	5.80	0	0
BHIRA T.R.	0.13	6.38	40	0
SMLHY_PTN	2.54	52.28	111	99
GHATGHAR	0.00	16.55	0	0
Total	3.13	95.77		
Wind				
Total	15.78	239.33	0	0
Total	15.78	239.33		
CPP				
APML(Mus)	67.83	1671.58	0	0
JSWEL(Mus)	16.15	551.28	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.18	751.75	0	0
SWPGPL-Mus	8.45	253.47	0	0
Other(Mus)	41.54	1339.70	0	0
Total	165.15	4567.78		
SOLAR				
Total	14.17	372.84	0	0
Total	14.17	372.84		
Tata				
Trombay 5	0.00	128.60	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.37	37.00	110	36
Trombay 7B	1.04	27.98	66	32
TATA Hydro	2.30	109.04	224	4
Trombay 8	3.19	102.09	136	132
Total	7.90	404.71		
AEML				
DTPS U-1&2	8.33	263.64	444	298
Total	8.33	263.64		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	148.28	4194.29	MSPGCL Total	157.54	4677.22
			MSPGCL Thml+Gas	151.69	4327.27	Koyna 1,2 & 4 Total	2.24	201.97
			MSPGCL Hydro	5.84	349.96	State Total	368.86	10525.53

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 29/Jan/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5773	154	143	6070	539	6689	0	0	6562	6481	-1239	18183	0	18183	1795	357	20335	49.91
2	5466	153	145	5764	619	6397	0	0	6683	6787	-1110	18117	0	18117	1664	340	20121	49.92
3	5487	314	144	5945	723	6093	0	0	6615	6746	-1044	18153	0	18153	1589	310	20052	49.91
4	5569	153	144	5866	751	6299	0	0	6569	6594	-997	18211	0	18211	1534	302	20047	49.90
5	5681	148	145	5974	814	6537	0	0	6748	6542	-1007	18531	0	18531	1548	329	20408	49.93
6	6037	153	147	6337	905	6676	0	0	6953	6782	-1101	19249	0	19249	1633	350	21232	50.00
7	6660	158	144	6962	905	6792	0	1	6938	6867	-1128	20032	0	20032	1720	367	22119	50.11
8	6815	183	143	7141	895	7076	0	160	7038	7015	-1113	20791	0	20791	1819	383	22993	50.05
9	6945	378	143	7466	787	7142	0	715	7323	7249	-1128	21834	0	21834	1971	397	24202	49.93
10	7008	419	143	7570	871	7145	0	1296	8188	8069	-1263	23284	0	23284	2134	404	25822	49.86
11	7011	322	141	7474	920	7221	0	1806	8683	8681	-1552	24142	0	24142	2285	408	26835	49.90
12	6847	469	140	7456	730	7165	0	2015	8158	8151	-1606	23499	0	23499	2328	412	26239	49.90
13	6404	560	141	7105	614	7005	0	2067	8018	8061	-1579	22873	0	22873	2288	400	25561	50.07
14	6062	339	136	6537	476	6977	0	2057	8035	8184	-1469	22337	0	22337	2172	425	24934	50.19
15	6164	216	137	6517	379	7094	0	1737	8086	8034	-1448	21893	0	21893	2089	420	24402	50.07
16	6226	206	139	6571	384	7192	0	1348	8266	7999	-1318	21746	0	21746	2029	430	24205	49.95
17	6183	190	140	6513	333	7244	0	735	7851	7665	-1272	20778	0	20778	1995	440	23213	50.00
18	6189	146	139	6474	339	7216	0	230	6919	7100	-1247	19665	0	19665	1995	447	22107	50.01
19	6387	190	140	6717	346	7417	0	0	6744	6848	-1276	19622	0	19622	2110	430	22162	50.09
20	6608	151	142	6901	513	7452	0	0	6624	6458	-1224	19670	0	19670	2167	430	22267	50.01
21	6087	160	143	6390	697	7059	0	0	6463	6228	-1363	18593	0	18593	2133	418	21144	50.03
22	5581	177	142	5900	748	6474	0	0	6476	6598	-1430	17876	0	17876	2077	414	20367	50.02
23	5539	354	144	6037	731	6278	0	0	6293	6411	-1438	17616	0	17616	1970	403	19989	49.99
24	5554	151	144	5849	758	6507	0	0	6160	5988	-1301	17412	0	17412	1841	389	19642	49.99
MUs	148.28	5.84	3.41	157.54	15.78	165.15	0.00	14.17	172.39	171.54	-30.65	484.11	0.00	484.11	46.89	9.40	540.40	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 29/Jan/2023

Position as on 6.30 Hrs of 30/Jan/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18		Continued.	ID Fan Problem	30/01/2023
MSPGCL	Uran Unit 6	108	25/01/2023	11:17		Continued.	Gas Skid Tripped	
MSPGCL	Paras Unit 3	250	26/01/2023	09:50	29/01/2023	01:17	Boiler Tube Leakage	29/01/2023
IPP	IEPL Unit 1	270	26/01/2023	23:33		Continued.	Air Filter Problem	01/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
MSPGCL	Koyna Unit 7	80	28/01/2023	07:30	29/01/2023	17:10	Preventive Maintenance Work	
IPP	SWPGPL U-4	135	29/01/2023	07:45	29/01/2023	13:56	Oil leakage from TG bearing no. 2	
MSPGCL	Bhusawal Unit 4	500	29/01/2023	12:45		Continued.	Boiler Tube Leakage	01/02/2023
IPP	SWPGPL U-2	135	29/01/2023	21:22		Continued.	Ash Conveying System Problem	
MSPGCL	Koyna Unit 1	70	30/01/2023	07:30		Continued.	Preventive Maintenance Work	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Tripping for 29/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 30/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Tripping							
MAIN BAY - 701 OF 765/400KV 1500MVA ICT @ AKOLA 2	IntraState	30/01/2023	10:18			PO	OEM Inspection of CB
400 KV MAINBAY Outages/Tripping							
MAIN BAY (416) OF STATION TF 4A @ DEEPNAGAR	IntraState	30/01/2023	09:44			PO	For servicing & overhauling of 400KV AREVA make STN-4A Main C.B. Mechanism
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
PADGHE - TARAPUR CKT - 1	InterState	29/01/2023	14:01	29/01/2023	17:19	PO	1) Tarapur -I on TBC for safety purpose for re connection of A bus gantry jumper between Tarapur -I & II by hot line method. 2) after work Tarapur -I will be charge on own CB.
PADGHE - TARAPUR CKT - 2	InterState	29/01/2023	17:41	29/01/2023	19:30	PO	1) Tarapur -II on TBC for re connection of IPS tube between A& B bus PG Isolator. 2) after work Tarapur -II will be charge on own CB.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
BUS 'A' @ PADGHE	IntraState	28/01/2023	10:50	29/01/2023	16:50	PO	A bus Conductor Replacement of Section -1 between 400KV Tarapur II & 500MVA ICT -5. 1) 500MVA ICT-5 & 400KV Tarapur -2 on TBC for 3hrs for removing IPS tube between A & B Bus PG isolator one by one and later on will be charged on B bus for 3 days. 2) 400KV Tarapur I on TBC for removing jumper by Hot line method.
KORADI - KHAPERKHEDA CKT - 2	IntraState	30/01/2023	09:03			PO	Proposal for shifting of 400KV Khaperkheda Ckt-2 on 400KV TBC bay for attending rotary broken problem of BUS-2 PG isolators and overhauling & servicing of mechanism box of PG isolators by shifting 400KV Khaperkheda Ckt-2 on 400KV TBC bay .
KORADI - KHAPERKHEDA CKT - 2	IntraState	30/01/2023	09:03			PO	For attending rotary broken problem of BUS-2 PG isolators ,overhauling & servicing of mechanism box of PG isolators by agency.
KHADKA- DEEPNAGAR CKT 2	IntraState	30/01/2023	09:12			PO	For attending red hot on Y pH aux.iso clamp CT end temp>88 degree C
MAIN BUS - 2 @ KORADI	IntraState	30/01/2023	09:35			PO	For attending rotary broken problem of BUS-2 PG isolators ,overhauling & servcing of mechanism box of PG isolators by agency.During outage period BUS reactor to be kept OFF.
400 KV ICT Outages/Tripping							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 30/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	27/01/2023	22:33	30/01/2023	23:20	PO	Replacement of ICT-3 Rph HV bushing due to high tan delta value.
400/220 KV 500 MVA ICT - 5 @ PADGHE	IntraState	29/01/2023	20:24	29/01/2023	22:46	PO	1) ICT-5 HV side on TBC for re connection of IPS to tube between A & B bus PG Isolator. 2) after work ICT -5 will be charge on own CB.
400/220/20 KV 100 MVA SPARE BHEL ICT @ KORADI	IntraState	30/01/2023	08:49			PO	For attending rotary broken problem of 400KV Khaperkheda Ckt-2 BUS-2 PG isolators ,overhauling & servicing of mechanism box of PG isolators by agency. BUS-2 outage proposed on Dt.30.01.2023.Presently,spare ICT bay on BUS-2. Spare ICT couldnot be shifted on BUS-1 hence,400kv SPARE ICT needs to handtrip for attending rotary broken problem of 400KV Khaperkheda Ckt-2 BUS-2 PG isolators
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILO line.
EKLAHARE (OCR) - PADGHE	IntraState	27/01/2023	06:15			PO	1. Bunching at Loc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. Of Lattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
GHATGHAR - JINDAL	IntraState	27/01/2023	06:35			PO	1. Bunching at Loc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. Of Lattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
CHIKHALI-JALNA I	IntraState	27/01/2023	06:45	29/01/2023	06:59	HT	Akola ICT O/L
CHIKHALI-JALNA II	IntraState	27/01/2023	06:45	29/01/2023	06:59	HT	Akola ICT O/L
BORIVALI - TARAPUR	IntraState	27/01/2023	10:07			HT	Planned outage for annual maintenance at Tarapur end
ALEPHATA-PARGAON(KATHAPUR)	IntraState	27/01/2023	22:19	29/01/2023	23:59	HT	For load management purpose
INFOSYS - HINJAWADI 1	IntraState	28/01/2023	12:47			PO	.Destringing of conductor from Guide tower to MDN tower (Temporary connection of Hinjewadi1 Infosys Line) 2. OPGW stringing from MCTT to MDN Tower 3. Conductor Stringing from MCTT to MDN tower 4.Dismantling of tower 158A near MDN tower 5.Conductor stringing from Guide tower to MDN tower 6. Bunching at MDN to MCTT for MAintaining Pirangut and Hinjewadi 1 Connectivity 7. Jumpering at MCTT to Cable bushing 8. OPGE/OFC splicing at MCTT and Hinjewadi 1 gantry

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 30/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
AEML BORIVALI -MSETCL BORIVALI CKT -2	IntraState	28/01/2023	22:30	29/01/2023	23:14	EO	AT MSETCL BORIVALI YPH CB SPRING NOT CHARGING HENCE CB LOCKOUT ALARM PERSISTING ON LINE
SAHARA-URSE	IntraState	28/01/2023	23:08	29/01/2023	02:27	HT	Load Management.
TALEGAON (AMBI)-TALEGAON (PG) CKT 2	IntraState	28/01/2023	23:27	29/01/2023	02:19	HT	To attend Hotspot at Talegaon PG SS.
TEMGHAR - KALWA	IntraState	29/01/2023	07:24	29/01/2023	17:51	PO	Stringing of 2 Nos. Of span on newly constructed towers in r/o of shifting/ diversion of line infringing in Bullet train crossing under ORC.
MAIN BUS SECTION - 1 @ PEDAMBE	IntraState	29/01/2023	08:00	29/01/2023	19:00	PO	For New Koyna Bay Main bus side defects attending & all bays M.B. Isolators P/M work.
BORIVALI - BOISAR (PG)	IntraState	29/01/2023	08:16	29/01/2023	18:50	EO	Repairing of Damage Conductor at Loc No. 44-45 & 46-47 on 220kV PGCIL Borivali Line.
VILEBHAGAD - INOX	IntraState	29/01/2023	08:28	29/01/2023	20:38	PO	1.CT tan delta test 2. CB CRM & Timing 3. Jumper nut bolt tightening work 4. Isolator maintenance work 5.Relay testing by testing team
TROMBAY CARNAC - 5	IntraState	29/01/2023	09:13	29/01/2023	20:21	PO	Work in vicinity for desilting in aeration basin of Unit 5 FGD
BORIVALI - TARAPUR	IntraState	29/01/2023	09:21	29/01/2023	19:06	EO	Repairing of Damaged Conductor at Loc No.82-83.
NEW KOYNA - PEDAMBE	IntraState	29/01/2023	22:15	30/01/2023	22:45	HT	CT circuit defective indication is operated.
TROMBAY SALSETTE LINE-2	IntraState	29/01/2023	23:48	30/01/2023	02:44	PO	Work in vicinity for working on bottom ckt A Ph cross arm of 110 kV Salsette Vikhroli line at loc. 60.
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	30/01/2023	03:32	30/01/2023	03:56	T	Tripped on Distance Protection.
ADLABS - PEDAMBE	IntraState	30/01/2023	05:10	30/01/2023	06:07	T	Tripped On Distance Protection.
PEDAMBE-KALAMBANI(TSS)	IntraState	30/01/2023	05:10			T	Tripped On Distance Protection.
KANDALGAON - KOYNA (POPHALI)	IntraState	30/01/2023	05:43	30/01/2023	06:05	T	Tripped On Distance Protection.
VITA - MIRAJ	IntraState	30/01/2023	05:57	30/01/2023	08:00	T	Tripped On Distance Protection.
MHAISAL - ALKUD	IntraState	30/01/2023	06:06	30/01/2023	08:47	T	Tripped On Distance Protection.
BABLESHWAR -BHENDA	IntraState	30/01/2023	06:30			T	Tripped On Distance Protection.
MALEGAON-SATANA	IntraState	30/01/2023	06:49			HT	H/T For Load Management.
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	30/01/2023	07:07			T	Tripped On Distance Protection.
JEJURI - BARAMATI	IntraState	30/01/2023	07:22			T	Tipped on Distance Protection.
TROMBAY CARNAC - 5	IntraState	30/01/2023	09:13			PO	Work in vicinity for desilting in aeration basin of Unit 5 FGD
PANDHARPUR - BHALVANI	IntraState	30/01/2023	10:02			PO	Outage is required for cleaning disc insulator string from loc No. 331 to 393.
MAIN BUS - 1 @ AAREY	IntraState	30/01/2023	10:47			PO	Annual Maintenance of Main Bus-1 and Bus Side Isolators
BUS COUPLER @ AAREY	IntraState	30/01/2023	10:53			PO	Annual Maintenance of Bus Coupler .facilitating outage of 220kV Main Bus 1
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Jan/2023

Statement-VII

Position as on 6.30 Hrs of 30/Jan/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/110 KV 200 MVA ICT - 1 @ ICHALKARANJI - II	IntraState	30/01/2023	09:45			PO	1) Quaterly bay maintenance work.
110 KV LINE Outages/Trippings							
SALSETTE VIKHROLI	IntraState	29/01/2023	23:45	30/01/2023	04:50	PO	Formation of three terminal 110 kV Salsette Vikhroli Powai line FOR 220 kv tds PROJECT
SALSETTE POWAI	IntraState	30/01/2023	00:07	30/01/2023	04:50	PO	Formation of three terminal 110 kV Salsette Vikhroli Powai line FOR 220 kv tds PROJECT
KALWA KALYAN	IntraState	30/01/2023	00:21	30/01/2023	04:32	PO	110 kv BUS OUTAGE AT KALYAN
KALYAN KALWA SALSETTE 1	IntraState	30/01/2023	00:22	30/01/2023	04:05	PO	110 KV BUS OUTAGE AT KLAYAN

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage