

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Mar/2024 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	177.907	4732.297	1) Gujrat	5.218	119.597
2) Hydro	14.006	266.802	2) Madhya Pradesh	13.886	357.370
3) Gas	7.002	197.503	3) Chattisgarh	4.090	136.310
Total MSPGCL	198.915	5196.602	4) Maharashtra	199.749	5240.679
B) 1) APLM	71.626	1861.822	5) Goa (Amona)	-2.829	-60.137
2) JSWEL	21.488	734.808	Total	220.114	5793.819
3) VIPL	0.000	0.000	a) Mumbai Schedule	32.673	889.332
4) RPL(AMT)	25.642	820.972	b) Mumbai Drawl	36.836	992.412
5) SWPGPL	11.384	343.245	c) MSEDCL Bilateral *	110.341	2886.385
6) Other IPP	31.209	1159.949	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	32.673	889.332
C) 1) TPCL Thermal	11.911	319.825	Include PX	0.000	0.000
2) TPCL Hydro	4.844	126.355	Standby	0.000	0.000
3) TPCL Gas	4.137	105.737	H) ENERGY CATERED (MUs)		
4) AEML Thermal	10.873	269.752	1) MSEDCL	555.221	15480.425
D) STATE			2) Mumbai Discoms	68.601	1814.076
1) Thermal	362.040	10242.670	3) Other Discoms	10.712	312.769
(A1+C1+C4+(B1-B6))			TOTAL STATE	634.534	17607.270
2) Hydro	18.850	393.157			
(A2+C2)					
3) Gas	11.139	303.240			
(A3+B7+C3)					
4) Wind	8.702	365.102			
6) SOLAR	13.689	491.416			
TOTAL STATE	414.420	11795.585			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	7170	7202	7879	7730
MSPGCL Hydro	989	1088	670	318
MSPGCL Gas	285	282	347	293
MSPGCL Total Generation	8444	8572	8896	8341
Central Sector Receipt	9883	10539	8218	7930
WIND	166	240	514	627
CPP / IPP Thermal	6350	6251	6945	6955
CPP / IPP Gas	0	0	0	0
SOLAR	2081	1075	0	0
Exchange with Mumbai	-2086	-2159	-1370	-1327
MSEDCL DEMAND MET	24354	24027	22713	22077
Load Shedding	0	0	0	0
MSEDCL DEMAND	24354	24027	22713	22077
TPCL GENERATION	821	644	1244	1053
AEML GENERATION	434	503	467	487
MUMBAI DEMAND	3341	3306	3081	2867
OTHER DISCOM DEMAND	484	491	490	449
STATE DEMAND MET	28179	27824	26284	25393
STATE DEMAND	28179	27824	26284	25393
Frequency (Hz)	50.01	49.95	49.99	49.93

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.05 Hrs	49.76 Hz at 09.08 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Mar/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.22	113.68	195	130
Unit 8	14.79	395.00	654	536
Unit 9	14.46	307.56	628	530
Unit 10	13.36	254.80	610	515
Total	46.82	1071.04		
Bhusawal				
Unit 3	3.59	100.60	180	120
Unit 4	8.68	246.50	495	0
Unit 5	10.78	207.88	495	330
Total	23.05	554.98		
Parli				
Unit 6	4.07	118.55	215	144
Unit 7	0.00	105.17	0	0
Unit 8	4.54	100.91	250	145
Total	8.60	324.63		
Chandrapur				
Unit 3	3.38	95.59	157	114
Unit 4	3.63	90.30	172	123
Unit 5	8.32	242.44	425	275
Unit 6	8.39	242.70	455	270
Unit 7	8.87	242.34	443	282
Unit 8	10.02	277.54	425	410
Unit 9	11.14	299.67	490	366
Total	53.75	1490.60		
Paras				
Unit 3	5.51	158.78	245	190
Unit 4	5.84	164.23	254	190
Total	11.36	323.01		
Khaparkheda				
Unit 1	4.05	108.60	175	145
Unit 2	4.48	118.71	204	118
Unit 3	4.16	112.69	177	169
Unit 4	4.61	119.05	197	182
Unit 5	11.50	311.17	480	470
Total	28.80	770.22		
Nasik				
Unit 3	1.71	37.99	170	0
Unit 4	3.82	104.22	177	125
Unit 5	0.00	55.61	0	0
Total	5.54	197.83		
Uran				
All Units	7.00	197.50	347	280
Total	7.00	197.50		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.19	3.32	33	0
Total	0.19	3.32		
Koyna				
Stage 1-2	2.02	56.82	260	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.16	46.42	746	0
Stage 3	1.47	23.21	240	0
Total	8.66	126.44		
Hydro				
KDPH	0.86	25.06	36	36
VTRNA	0.77	19.84	60	0
TILLARI	0.50	14.48	65	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	2.87	74.90	127	112
GHATGHAR	0.34	6.08	125	0
Total	5.35	140.36		
Wind				
Total	8.70	365.10	0	0
Total	8.70	365.10		
CPP				
APML(Mus)	71.63	1861.82	0	0
JSWEL(Mus)	21.49	734.81	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.64	820.97	0	0
SWPGPL-Mus	11.38	343.24	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.72	162.91	266	195
Other(Mus)	20.93	900.90	0	0
JPL	4.57	96.14	239	162
Total	161.35	4920.80		
SOLAR				
Total	13.69	491.42	0	0
Total	13.69	491.42		
Tata				
Trombay 5	7.69	210.40	439	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	64.73	108	107
Trombay 7B	1.55	41.01	65	64
TATA Hydro	4.84	126.36	439	68
Trombay 8	4.22	109.43	234	131
Total	20.89	551.92		
AEML				
DTPS U-1&2	10.87	269.75	503	342
Total	10.87	269.75		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	177.91	4732.30	MSPGCL Total	198.92	5196.60
			MSPGCL Thml+Gas	184.91	4929.80	Koyna 1,2 & 4 Total	7.18	103.24
			MSPGCL Hydro	14.01	266.80	State Total	414.42	11795.58

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 29/Mar/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7372	1059	292	8723	546	7086	0	0	8337	8372	-1088	23250	0	0	23250	2726	389	26365	49.99
2	7465	625	292	8382	455	7096	0	0	8510	8553	-968	23148	0	0	23148	2524	371	26042	50.01
3	7486	204	292	7982	394	7050	0	0	9044	8878	-1035	22909	0	0	22909	2367	360	25636	49.99
4	7567	193	293	8053	353	7028	0	0	9108	8924	-1052	22969	0	0	22969	2251	337	25557	50.01
5	7644	198	293	8135	355	7037	0	0	9344	9073	-1014	23229	0	0	23229	2215	358	25801	50.00
6	7780	194	294	8268	364	7014	0	0	9293	9203	-985	23477	0	0	23477	2296	387	26160	50.01
7	7795	259	296	8350	300	7012	0	34	9639	9289	-1039	23512	0	11	23512	2356	434	26302	50.04
8	7609	463	294	8366	248	6908	0	335	9282	8902	-1255	23061	0	12	23061	2437	443	25940	50.03
9	7055	572	290	7917	176	6588	0	892	9493	9370	-1586	22894	0	41	22894	2663	464	26020	49.99
10	7005	774	286	8065	190	6343	0	1408	9572	9839	-1847	23516	0	61	23516	2957	483	26955	49.93
11	7190	875	283	8348	195	6597	0	1799	10045	9956	-2061	24361	0	197	24361	3209	473	28043	49.93
12	7170	989	285	8444	166	6350	0	2081	10399	9883	-2086	24354	0	237	24354	3341	484	28179	50.01
13	7092	863	280	8235	205	6097	0	2003	10319	10047	-2116	23989	0	225	23989	3346	482	27817	50.04
14	6759	753	281	7793	321	6045	0	1710	10346	10313	-2096	23621	0	76	23621	3196	465	27282	50.03
15	7083	846	283	8212	284	6124	0	1418	10798	10470	-2171	23864	0	59	23864	3267	472	27604	49.95
16	7202	1088	282	8572	240	6251	0	1075	10760	10539	-2159	24027	0	138	24027	3306	491	27824	49.95
17	7458	765	284	8507	367	6568	0	668	10369	10169	-2015	23773	0	131	23773	3252	491	27516	50.01
18	7434	649	285	8368	394	6633	0	254	9981	9316	-1859	22622	0	42	22622	3146	484	26252	50.04
19	7408	554	291	8253	444	6862	0	12	8865	8426	-1574	21926	0	0	21926	3047	497	25470	50.02
20	7879	670	347	8896	514	6945	0	0	8429	8218	-1370	22713	0	0	22713	3081	490	26284	49.99
21	7672	373	301	8346	598	6881	0	0	8512	7959	-1401	21900	0	0	21900	3005	483	25388	49.96
22	7379	262	291	7932	490	6922	0	0	8422	8216	-1463	21621	0	0	21621	2908	476	25005	49.98
23	7730	318	293	8341	627	6955	0	0	8085	7930	-1327	22077	0	0	22077	2867	449	25393	49.93
24	7673	460	294	8427	476	6957	0	0	8192	8269	-1269	22410	0	0	22410	2838	450	25698	49.96
MUs	177.91	14.01	7.00	198.92	8.70	161.35	0.00	13.69	225.14	220.11	-36.84	555.22	0.00	1.23	555.22	68.60	10.71	634.53	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)132 kV BBLR -Rahuri Line Over Load. 2)Due to overloading of 400 kV Chakan-Talegaon line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Mar/2024

Position as on 6.30 Hrs of 30/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/04/2024
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	Capital Overhaul	10/04/2024
MSPGCL	Nasik Unit 5	210	19/03/2024	17:40		Continued.	Withdrawn On Tolling.	
Total Capacity MSPGCL		398						
Total Capacity PLANNED OUTAGE		398						
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-1	125	11/03/2024	18:40		Continued.	GM Link Fault	01/04/2024
MSPGCL	Parli Unit 7	250	27/03/2024	05:38		Continued.	Boiler Tube Leakage	30/03/2024
MSPGCL	Nasik Unit 3	210	28/03/2024	05:31	29/03/2024	11:09	Boiler Tube Leakage	31/03/2024
MSPGCL	Bhusawal Unit 4	500	28/03/2024	19:14	29/03/2024	02:32	Station Transformer Tripped.	
Total Capacity MSPGCL		1205						
IPP								
IPP	JSW (J) U1	300	24/03/2024	00:06		Continued.	CW duct leakage.	29/03/2024
IPP	RPL(AMT) U-2	270	27/03/2024	13:35	30/03/2024	04:19	Bottom Ash Evacuation Problem.	30/03/2024
Total Capacity IPP		570						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		2095						
FORCED OUTAGE DUE TO NO PPA								
MSPGCL								
MSPGCL	Uran Unit 6	108	12/03/2024	20:15	29/03/2024	18:33	For open cycle No schedule from MSEDCL.	
MSPGCL	Uran Unit 6	108	29/03/2024	20:16		Continued.	For open cycle No schedule from MSEDCL.	
Total Capacity MSPGCL		216						
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Mar/2024

Position as on 6.30 Hrs of 30/Mar/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		1204						

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 30/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 1	IntraState	29/03/2024	13:42	29/03/2024	19:24	EO	Y-phase L/R heavy leakage.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	26/03/2024	10:41			PO	Overhauling of Circuit breaker
400 KV LR Outages/Trippings							
400KV CHANDRAPUR 1-CHANDRAUR 2 CKT 1(CHPR1 END)	IntraState	29/03/2024	12:37	29/03/2024	19:40	PO	To replace faulty M2 numerical line differential protection relay.
400 KV LINE Outages/Trippings							
PADGHE - TARAPUR CKT - 1	InterState	30/03/2024	02:07			T	Distance Protection
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	28/03/2024	23:52			HT	For load management of Talegaon Chakan line
DEEPNAGAR - THAPTI TANDA	IntraState	29/03/2024	07:11	29/03/2024	18:46	PO	To carry out maintenance work and attending the defects observed in monkey patrolling
220 KV JALKOT - KUMBHARGAON (400 KV) CKT - 1	IntraState	29/03/2024	13:15	29/03/2024	14:35	PO	Emergency tree cutting.
NAGOTHANE - DABHOL CKT - 1	IntraState	29/03/2024	13:40	29/03/2024	14:16	T	Tripped on distance protection from Dabhol end only.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	10/02/2024	15:19			HT	H/T For LV side only
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	10/02/2024	18:31			HT	H/T For LV only.
400/220/33 KV 315MVA ICT - 2 @ AKOLA	IntraState	04/03/2024	11:26	29/03/2024	16:29	PO	Internal inspection of 315 MVA ICT 02 by agency M/s Mahati Electrical.
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	29/03/2024	10:05			PO	For Rapid Restoration scheme Work, DFRA, Quarterly Bay Maintenance Work
400/220/33 KV 315 MVA ICT - 2 @ PARLI	IntraState	30/03/2024	07:06			PO	Bushing & wdg. tan delta measurement of Units.
220 KV MAINBAY Outages/Trippings							
220KV SHIVAJINAGAR-GANGAPUR CKT	IntraState	29/03/2024	15:35	29/03/2024	17:47	PO	Diagnostic testing work.
220KV SHIVAJINAGAR - MALEGAON	IntraState	29/03/2024	17:50	29/03/2024	17:46	PO	Diagnostic testing work.
220KV SHIVAJINAGAR - MALEGAON	IntraState	29/03/2024	17:56	29/03/2024	18:59	PO	Diagnostic testing work and bay maintenance work
220 KV LINE Outages/Trippings							
URAN - KHARGHAR 2	IntraState	14/02/2024	08:41			PO	For making LILO of 220kV cable at 220kV Ulwe GIS &Waghiwali & Retrofitting of "DIFF" relay at 400KV KHARGHAR s/s.
ALEPHATA-PARGAON(KATHAPUR)	IntraState	16/03/2024	01:34			HT	Hand Tripped
KARAD - WATHAR	IntraState	25/03/2024	11:11	29/03/2024	22:12	PO	For foundation work of 220kV Narrow base multi ckt tower loc no. 200A of New 220kV Karad-Koyana line
VARKUTI- HIWARWADI	IntraState	25/03/2024	15:07			PO	Old Insulator replacement work by long rod at Loc No 166 to 230

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 30/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220KV PANDHARKAWDA - WANI CKT I	IntraState	27/03/2024	09:13			HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
220KV PANDHARKAWDA - WANI CKT li	IntraState	27/03/2024	09:29	29/03/2024	21:10	HT	1) for connecting jumpers at loc no. 14/0 pertaining to 220 kv wani � pandharkawada ckt-1&2, in view of proposed charging of 220 kv wani-pandharkawada line (ph-ii).
MHAISAL - ALKUD	IntraState	28/03/2024	18:44	29/03/2024	03:06	PO	Polymer insulator replacement Work
PADGHE - NALASOPARA - VASAI (T)	IntraState	29/03/2024	05:14	29/03/2024	09:05	PO	Faulty Insulator replacement work identified in PID.
ICL - OLD GCR PARLI	IntraState	29/03/2024	05:31	29/03/2024	07:50	T	Bus bar protection operated R-phase ct of consumer feeder burst.
ICL -HARANGUL CKT	IntraState	29/03/2024	05:31	29/03/2024	08:00	T	Bus bar protection operated R-phase ct of consumer feeder burst.
220 KV CHANDRAPUR GCR (400 KV) - WANI CKT	IntraState	29/03/2024	07:54	29/03/2024	17:05	PO	For fixing of bird diverter on conductor .
VITA WAIPHALE	IntraState	29/03/2024	08:15	29/03/2024	16:25	PO	Replacement of Backup Relay
220 KV BALAPUR - MALKAPUR LINE	IntraState	29/03/2024	08:28	29/03/2024	11:39	PO	Line isolator maintenance work.
KALWA - SALESETTE CKT - 5	IntraState	29/03/2024	09:45	29/03/2024	20:33	PO	Conductor replacement of 110kV Kalyan-Kalwa-Salsette 2 line in section Kalwa to Salsette in span between 15-19
220KV GEORAI(220KV)-TAPTITHANDA(400KV)CKT	IntraState	29/03/2024	11:18	29/03/2024	13:27	PO	Diagnostic testing work.
MALEGAON (ZODGA) - BALAPUR CKT 2	IntraState	29/03/2024	13:15	29/03/2024	17:08	PO	Line isolator maintenance work.
EKLAHARE (GCR) - GHATGHAR	IntraState	29/03/2024	13:30	29/03/2024	15:45	PO	Outage required for attending the red-hot at loc.no.14 B-phase Ghatghar side (temp-100¿C)
EKLAHARE (GCR) - GHATGHAR	IntraState	29/03/2024	13:30	29/03/2024	15:45		Outage required for attending the red-hot at loc.no.14 B-phase Ghatghar side (temp-100¿C)
220KV WALUJ(400KV) CKT	IntraState	29/03/2024	13:38	29/03/2024	15:15	PO	Diagnostic testing work.
ADLABS - PEDAMBE	IntraState	29/03/2024	15:43	29/03/2024	20:13	PO	Flashover string replacement at Loc No.356 & Other line maintenance work
MHAISAL - ALKUD	IntraState	29/03/2024	17:33	30/03/2024	01:30	PO	Polymer insulator replacement Work
WAGHIVALI - DHARAVI 8	IntraState	29/03/2024	22:09			PO	Work in vicinity for connection with new bus
KALWA - BORIVALI	IntraState	29/03/2024	22:12	30/03/2024	06:28	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
KHARGHAR - BORIVALI CKT - 2	IntraState	29/03/2024	22:14	30/03/2024	06:35	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work.
GIS BHANDUP - BORIVALI	IntraState	29/03/2024	22:17	30/03/2024	06:20	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
BORIVALI - CTRLS CKT	IntraState	29/03/2024	22:19	30/03/2024	06:33	PO	For Erection of Twin Monopole at Loc. No. 22-23 for MMRDA Metro work..
KARAD - OGALEWADI CKT 2	IntraState	29/03/2024	23:23	30/03/2024	03:05	T	R-PH Coupling Capacitor burst at Karad end
220 KV ICT Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Mar/2024

Statement-VII

Position as on 6.30 Hrs of 30/Mar/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/132KV 100MVA ICT 3 @ PANDHARPUR	IntraState	21/02/2024	10:23			PO	AUGUMENTATION OF ICT 3 FROM 100MVA ICT TO NEW 200MVA ICT
220/33 KV 50MVA PTR 2	IntraState	27/03/2024	10:27			HT	Overhauling of hv gis hybrid pass (abb make) .
220/132 KV 100 MVA ICT 1 @ SOUTH SOLAPUR	IntraState	29/03/2024	10:55	29/03/2024	13:20	PO	Annual Testing work to be done by TCC unit Pune.
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	29/03/2024	11:14	29/03/2024	14:43	T	Tripped on Relay differential protection
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	29/03/2024	13:42	29/03/2024	15:20	PO	Annual Testing work to be done by TCC unit Pune.
220 KV BUSBAR Outages/Trippings							
BUS SECTION-2 @ MAHAPE	IntraState	29/03/2024	06:42	29/03/2024	10:55	PO	(Outage is required on BUS SECTION-3 @ MAHAPE but same not available in OMS. Hence Bus section-2 selected) for Maintenance work.
BUS BAR PROTECTION @ URAN	IntraState	29/03/2024	10:00	29/03/2024	16:29	PO	For 220 kV Busbar relay testing
GIS BUS - 1 @ WAGHIVALI	IntraState	29/03/2024	22:22			PO	Connection of existing bus with new bus section
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
110 KV BUSBAR Outages/Trippings							
BUS-1 @ KHOPOLI	IntraState	29/03/2024	23:45	29/03/2024	04:47	PO	110 KV DT 5 Bkr Main bus side jumper reconnection post completion of breaker O/H

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage