

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 29/Apr/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.854	4736.358	1) Gujrat	-4.572	-99.645
2) Hydro	15.693	545.089	2) Madhya Pradesh	12.769	270.556
3) Gas	6.308	93.936	3) Chattisgarh	6.740	139.680
Total MSPGCL	168.855	5375.383	4) Maharashtra	190.400	5355.276
B) 1) APLM	36.345	1990.888	5) Goa (Amona)	-1.306	-42.423
2) JSWEL	24.988	734.936	Total	204.031	5623.444
3) VIPL	0.000	0.000	a) Mumbai Schedule	37.710	1028.071
4) RPL(AMT)	30.577	869.368	b) Mumbai Drawl	41.283	1135.161
5) SWPGPL	10.823	337.116	c) MSEDCL Bilateral *	89.612	2862.201
6) Other IPP	16.574	582.580	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	37.710	1028.071
C) 1) TPCL Thermal	10.363	339.101	Include PX	0.000	0.000
2) TPCL Hydro	2.174	142.797	Standby	0.000	0.000
3) TPCL Gas	2.736	94.235	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.784	274.576	1) MSEDCL	458.447	14867.675
D) STATE			2) Mumbai Discoms	66.340	1985.873
1) Thermal	286.308	9864.923	3) Other Discoms	10.056	297.678
(A1+C1+C4+(B1-B6))			TOTAL STATE	534.843	17151.226
2) Hydro	17.867	687.886			
3) Gas	9.044	188.171			
4) Wind	5.472	350.036			
6) SOLAR	12.121	436.763			
TOTAL STATE	330.812	11527.779			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	6005	6017	5625	6484
MSPGCL Hydro	438	536	2085	245
MSPGCL Gas	256	227	259	278
MSPGCL Total Generation	6699	6780	7969	7007
Central Sector Receipt	9267	9190	8189	7946
WIND	184	507	315	123
CPP / IPP Thermal	4514	4717	5413	4793
CPP / IPP Gas	0	0	0	0
SOLAR	1549	872	0	0
Exchange with Mumbai	-1918	-2008	-1678	-1441
MSEDCL DEMAND MET	19840	19599	19759	18070
Load Shedding	0	0	0	0
MSEDCL DEMAND	19840	19599	19759	18070
TPCL GENERATION	676	699	766	494
AEML GENERATION	485	447	467	323
MUMBAI DEMAND	3079	3154	2911	2258
OTHER DISCOM DEMAND	454	459	449	358
STATE DEMAND MET	23374	23212	23119	20686
STATE DEMAND	23374	23212	23119	20686
Frequency (Hz)	49.98	49.98	50.02	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.28 Hz at 22:02 Hrs	49.74 Hz at 14:11 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 29/Apr/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.54	112.91	200	175
Unit 8	0.00	330.30	0	0
Unit 9	12.82	170.59	560	520
Unit 10	0.00	354.86	0	0
Total	17.36	968.66		
Bhusawal				
Unit 3	3.54	98.44	160	120
Unit 4	6.86	270.58	460	0
Unit 5	11.00	310.49	485	415
Total	21.40	679.50		
Parli				
Unit 6	4.80	150.49	250	145
Unit 7	4.64	140.06	245	140
Unit 8	4.52	113.18	228	145
Total	13.95	403.73		
Chandrapur				
Unit 3	3.89	111.30	170	130
Unit 4	3.97	87.66	173	132
Unit 5	9.40	269.96	420	315
Unit 6	8.80	236.86	415	165
Unit 7	10.00	249.21	442	328
Unit 8	11.27	326.87	485	443
Unit 9	10.77	224.24	491	403
Total	58.10	1506.10		
Paras				
Unit 3	4.74	135.31	216	161
Unit 4	4.84	138.94	216	188
Total	9.58	274.25		
Khaparkheda				
Unit 1	3.10	80.88	140	115
Unit 2	3.12	75.86	144	78
Unit 3	4.26	113.35	186	138
Unit 4	4.22	123.48	187	139
Unit 5	3.70	282.49	450	0
Total	18.41	676.06		
Nasik				
Unit 3	0.00	67.03	0	0
Unit 4	4.12	86.44	180	150
Unit 5	3.93	74.58	173	147
Total	8.05	228.05		
Uran				
All Units	6.31	93.94	282	227
Total	6.31	93.94		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	1.80	0	0
Total	0.00	1.80		
Koyna				
Stage 1-2	3.58	129.94	535	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	5.55	212.87	1006	0
Stage 3	2.03	74.37	320	0
Total	11.16	417.18		
Hydro				
KDPH	0.77	23.57	32	32
VTRNA	1.16	34.28	61	0
TILLARI	0.46	5.05	58	0
BHIRA T.R.	0.13	8.22	40	0
SMLHY_PTN	2.01	54.99	87	79
GHATGHAR	0.00	0.00	0	0
Total	4.53	126.12		
Wind				
Total	5.47	350.04	0	0
Total	5.47	350.04		
CPP				
APML(Mus)	36.34	1990.89	0	0
JSWEL(Mus)	24.99	734.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.58	869.37	0	0
SWPGPL-Mus	10.82	337.12	0	0
Dhariwal	5.82	174.37	271	210
IEPL	4.74	151.27	199	196
Other(Mus)	6.01	256.94	0	0
Total	119.31	4514.89		
SOLAR				
Total	12.12	436.76	0	0
Total	12.12	436.76		
Tata				
Trombay 5	6.82	220.80	344	268
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.59	56.59	107	42
Trombay 7B	1.15	37.65	64	38
TATA Hydro	2.17	142.80	193	10
Trombay 8	3.54	118.30	184	131
Total	15.27	576.13		
AEML				
DTPS U-1&2	9.78	274.58	488	319
Total	9.78	274.58		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	146.85	4736.36	MSPGCL Total	168.86	5375.38
			MSPGCL Thml+Gas	153.16	4830.29	Koyna 1,2 & 4 Total	9.13	342.81
			MSPGCL Hydro	15.69	545.09	State Total	330.81	11527.78

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 29/Apr/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	Transmission Constraint					
1	6737	216	272	7225	169	5370	0	0	7755	8012	-1694	18695	0	26	18695	2760	387	21842	49.90
2	6796	217	275	7288	118	5344	0	0	7793	7651	-1572	18461	0	22	18461	2583	368	21412	49.98
3	6645	217	275	7137	77	4970	0	0	7889	7923	-1511	18262	0	19	18262	2421	334	21017	50.00
4	6492	216	276	6984	73	4907	0	0	7981	7930	-1466	18105	0	7	18105	2295	324	20723	50.00
5	6484	245	278	7007	123	4793	0	0	8473	7946	-1441	18070	0	1	18070	2258	358	20686	49.97
6	6430	420	278	7128	134	4870	0	0	8305	8542	-1426	18886	0	0	18886	2275	362	21523	49.93
7	6558	497	281	7336	133	5113	0	118	8243	8516	-1397	19421	0	0	19421	2286	398	22105	50.03
8	6552	421	282	7255	99	4938	0	509	8117	8395	-1548	19213	0	0	19213	2381	435	22029	50.03
9	6430	494	281	7205	132	4619	0	1036	8169	8463	-1637	19374	0	11	19374	2578	443	22396	50.00
10	6260	354	258	6872	187	4882	0	1320	8695	8717	-1744	19796	0	0	19796	2845	439	23079	50.01
11	6005	438	256	6699	184	4514	0	1549	9438	9267	-1918	19840	0	34	19840	3079	454	23374	49.98
12	5988	466	252	6706	128	4441	0	1745	9447	9129	-1982	19726	0	56	19726	3167	441	23334	49.98
13	5906	271	243	6420	198	4468	0	1702	9575	9274	-2015	19611	0	27	19611	3152	436	23199	49.99
14	5601	157	237	5995	311	4424	0	1447	9779	9548	-1936	19367	0	0	19367	3052	422	22841	50.02
15	5775	235	236	6246	326	4498	0	1120	9643	9568	-1929	19401	0	0	19401	3096	428	22925	49.89
16	6017	536	227	6780	507	4717	0	872	9100	9190	-2008	19599	0	0	19599	3154	459	23212	49.98
17	5968	1094	235	7297	512	4775	0	491	8824	8898	-2111	19385	0	0	19385	3090	477	22952	49.97
18	5913	1290	240	7443	388	5274	0	196	8526	8157	-2035	18959	0	0	18959	2998	465	22421	50.00
19	5680	1422	258	7360	353	5417	0	16	8000	8107	-1808	18975	0	0	18975	2906	470	22351	50.03
20	5625	2085	259	7969	315	5413	0	0	7727	8189	-1678	19759	0	0	19759	2911	449	23119	50.02
21	5664	1694	275	7633	271	5408	0	0	8059	7974	-1640	19206	0	0	19206	2828	439	22474	50.01
22	5711	1046	276	7033	250	5397	0	0	8184	7930	-1565	18610	0	0	18610	2752	435	21797	50.08
23	5778	963	282	7023	208	5381	0	0	8117	8294	-1555	18936	0	2	18936	2720	416	22071	50.05
24	5839	699	276	6814	276	5374	0	0	8888	8411	-1667	18790	0	0	18790	2753	418	21961	49.97
MUs	146.85	15.69	6.31	168.86	5.47	119.31	0.00	12.12	204.73	204.03	-41.28	458.45	0.00	0.20	458.45	66.34	10.06	534.84	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

1)Due to overloading of 220kV Jejuri-Lonand line.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 29/Apr/2023

Position as on 6.30 Hrs of 30/Apr/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-3	660	27/04/2023	22:35		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Ghatghar Unit-2	125	08/02/2023	07:02		Continued.	Stator Earth Fault	01/06/2023
MSPGCL	Nasik Unit 3	210	17/04/2023	21:27		Continued.	Boiler Tube Leakage	20/05/2023
MSPGCL	Uran Unit 6	108	20/04/2023	19:15		Continued.	No Schedule.	
MSPGCL	Koradi Unit 8	660	28/04/2023	01:51		Continued.	Boiler Tube Leakage	03/05/2023
MSPGCL	Koradi Unit-10	660	28/04/2023	17:02		Continued.	Boiler Tube Leakage	03/05/2023
IPP	Adani U-2	660	29/04/2023	08:21		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 5	500	29/04/2023	08:48		Continued.	Boiler Tube Leakage	02/05/2023
MSPGCL	Bhusawal Unit 4	500	29/04/2023	18:22		Continued.	Boiler Tube Leakage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 29/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 30/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	29/04/2023	22:58	30/04/2023	06:49	EO	1] At 500kV HVDC Padghe SS :- For attending Level -1 Alarm(>1 Thyristor) & replacement of 2 nos of faulty thyristors @P-1 B-ph valve -3 Quadruple Valve, if needed. 2] On line by TL O&M Dn.,Rajgurunagar A)HVDC TL O&M Sub-Division, Padghe :- 1. Replacement of flashover discs of Pole # 1 suspension strings at location no 1870 & 1850. 2. Cleaning of dust/bird-shit contaminated insulator string of at location no. 1845 to 1855 & 1867 to 1878. B] HVDC TL O&M Sub-Division, Junnar :- 1. Cleaning of dust/bird-shit contaminated insulator string at location no.1599 to 1603 & 1619, from loc 1790 to 1802. C] HVDC TL O&M Sub-Division, Babhaleshwar :- 1. Cleaning of dust/bird-shit contaminated insulator string at location no. 1406 to 1409, 1438,1488, from loc 1370 to 1373.
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KUDUS - KALA CKT - 2	InterState	30/04/2023	09:38	30/04/2023	15:13	PO	Replacement of Broken Glass Insulator with Long Rod Polymer Insulator at Loc no 30 (Multicircuit)
KALWA - TALEGAON (PG)	InterState	30/04/2023	23:52		Continued.	EO	1.To replace PID detected strings at loc no. 139 R and B phase. 2. Cold line washing of insulator strings in the highly polluted area, in the view of past history, line tripping observed due high degree of partial discharge over insulator strings in D/C portion due to duct deposition and salty sea air present from April to May.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	03/04/2023	11:30			HT	H/T TO CONTROL LINE LOADING OF PUNE PG
THAPTI TANDA - AURANGABAD (WALUJ)	IntraState	28/04/2023	13:15	29/04/2023	09:05	T	LA R phase blast at TT end
CHANDRAPUR GCR - CHANDRAPUR 2 CKT 1	IntraState	29/04/2023	07:50	29/04/2023	18:54	EO	1) R & B-ph PG-1 (Bus-1) Isolator of 400KV GCR CHD-CHD-2 CKT-1.
MAIN BUS - 1 @ CHANDRAPUR	IntraState	29/04/2023	08:12	29/04/2023	16:40	EO	Permission to work on 400kV Main Bus-1 by hot line technique at 400kV S/st. GCR-1 Chandrapur on dt. 29.04.2023 from 05:00 to 17:00Hrs.
NEW KOYNA-KARAD CKT - 2	IntraState	29/04/2023	08:34	29/04/2023	16:13	PO	Cold line washing work
KORADI II - IEPL	IntraState	29/04/2023	23:02	30/04/2023	13:45	T	Distance Protection
PARLI - KARJAT CKT - 2	IntraState	30/04/2023	15:14	30/04/2023	20:13	PO	Quarterly Maintenance

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 30/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500MVA ICT 3 @ AKOLA	IntraState	25/04/2023	10:41			PO	For termination of power cable
400220kv 167MVA SPARE ICT @ DEEPNAGAR	IntraState	29/04/2023	09:43		Continued.	PO	For Pre-monsoon maint. work in all aspect, Tan delta testing of Bushings, Windings, SFRA & Winding Resistance measurement testing work. Also HV Bay maintenance work & oil filtration work by external agency due to high C2H2 & increase trend in water content is to be carried out.
400/220/20 KV 300 MVA ICT - 1 @ KORADI	IntraState	30/04/2023	03:56	30/04/2023	09:48	T	Bucholz Protection
400/220/33 KV 500MVA ICT - 1 @ DEEPNAGAR	IntraState	30/04/2023	14:55	30/04/2023	18:30	T	Tripped on NDR Protection.
220 KV MAINBAY Outages/Trippings							
MAIN BUS @ VARKUTI	IntraState	29/04/2023	14:30	29/04/2023	17:16	PO	220 KV Varkute bus stability test (During outage busbar protection will be-kept bypass for testing and integratron purpose)
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - MSETCL BORIVALI CKT - 2	IntraState	28/04/2023	21:05	30/04/2023	04:53	PO	Interconnection of existing OLD GIS Bus - 2 with New GIS Bus 2. Work to be executed under MERC approved 220kV AIS to GIS conversion scheme @ Aarey EHV Station.
AAREY - AEML SAKI CKT - 2	IntraState	28/04/2023	21:07	30/04/2023	04:47	PO	Interconnection of existing OLD GIS Bus 2 with NEW GIS Bus 2 work to be executed under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
PIRANGUT - HINJAWADI 2	IntraState	28/04/2023	23:24	29/04/2023	06:15	HT	HT for Load Management
WAGHIVALI - DHARAVI 7	IntraState	29/04/2023	02:16	29/04/2023	04:51	PO	Project work-Installation of Split core CT at chunabhathi.
KALWA - MULUND 1	IntraState	29/04/2023	08:20	29/04/2023	20:03	PO	1) Wave Trap Replacement Work. 2) 29A, 29C, 29F isolator alignment work.
PEDAMBE-KALAMBANI(TSS)	IntraState	29/04/2023	11:40	29/04/2023	16:58	PO	Replacement of Rusted Nut-Bolts of Equipment Support structures at 220KV Kalambani TSS.
TALANDGE - MUDSHINGI CKT - 2	IntraState	29/04/2023	16:11	29/04/2023	20:17	EO	To attend hot spot observed in thermsscanning at loc no. 314, B ph, 114 deg. & at loc no. MC-1, Y ph, 116 deg.
BABLESHWAR - BHENDA	IntraState	29/04/2023	16:32	29/04/2023	16:28	EO	Replacement of flashover string at loc no 85 B ph because of the heavy rains and plastic being wrapped around the B ph crossarm and live conductor pic attach
KANDALGAON - SONA ALLOYS	IntraState	29/04/2023	19:30	29/04/2023	22:01	EO	B-Ph, 220kV CT oil leakage attaining works to be carried out.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 29/Apr/2023

Statement-VII

Position as on 6.30 Hrs of 30/Apr/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS - 2 @ AAREY	IntraState	29/04/2023	21:46	30/04/2023	10:25	PO	Charging of New GIS Bus 2 through 220kV Aarey Goregaon Line 2 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
BUS COUPLER @ AAREY	IntraState	29/04/2023	21:46	30/04/2023	10:25	PO	Charging of New GIS Bus 2 through 220kV Aarey-Goregaon Line 2 and commissioning of New Bus Coupler CB 2552.
PIRANGUT - HINJAWADI 2	IntraState	29/04/2023	22:05	30/04/2023	06:25	HT	HT for Load Management
TROMBAY DHARAVI - 6	IntraState	30/04/2023	00:10	30/04/2023	06:55		Conductort shifting for sejal shakti work
BADNERA - AMRAVATI	IntraState	30/04/2023	01:27	30/04/2023	01:51	T	Distance protection
OSMANABAD - PARLY (PG)	IntraState	30/04/2023	02:57	30/04/2023	04:27	T	Distance protection
220 KV KHAPARKHEDA 2 (NEW) - KANHAN CKT	IntraState	30/04/2023	03:45	30/04/2023	11:47	T	Distance protection
GOREGAON - AAREY CKT - 2	IntraState	30/04/2023	05:11	30/04/2023	05:50	PO	Charging of 220kV Main Bus 2 through 220kV Aarey-Goregaon Line 2.
KHAPERKHEDA - KALMESHWAR CKT	IntraState	30/04/2023	07:17	30/04/2023	12:10	HT	To Facilitate the work on 220kv kanhan-khaperkheda ckt
BHIRA - KARANJADE 8	IntraState	30/04/2023	08:15	30/04/2023	18:58	PO	Project work TLA installation
MALEGAON (ZODGA) - BALAPUR CKT 2	IntraState	30/04/2023	11:30	30/04/2023	13:13	EO	Replacement of flashover disc at LOC. 136R, 146Y, 152R
NANDED CITY-FLAGSHIP	IntraState	30/04/2023	12:15	30/04/2023	13:34	EO	To remove bird nest from CT Gantry structure
WARORA - WARDHA	IntraState	30/04/2023	17:37	30/04/2023	20:37	T	Distance protection
WARORA - HINGANGHAT	IntraState	30/04/2023	17:50	30/04/2023	18:10	T	Distance protection
TROMBAY DHARAVI - 6	IntraState	30/04/2023	23:13		Continued.	PO	Conductor shifting sejal shakti consumer funded job
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 150 MVA ICT 1 @ SATANA	IntraState	29/04/2023	14:01	29/04/2023	15:06	EO	OLTC oil top-up work & LVCB air drain valve replacement work.
220/132 KV 200 MVA ICT 2	IntraState	30/04/2023	11:30	30/04/2023	16:03	HT	Chattering sound observed on LV side CT
220 KV BUSBAR Outages/Trippings							
MAIN BUS-2 @BHIRA	IntraState	29/04/2023	05:57	29/04/2023	12:25	PO	For Routine maintenance of Main Bus at Bhira generating Station
BUS SECTION 3 @ FLAGSHIP	IntraState	30/04/2023	09:25	30/04/2023	17:14	PO	yearly maintenance work and to remove Bird nest from 220kV Nanded city line bay
BUS SECTION 2 @ FLAGSHIP	IntraState	30/04/2023	09:25	30/04/2023	17:14	PO	yearly maintenance work and to remove Bird nest from 220kV Nanded city line bay
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KALWA KALYAN	IntraState	29/04/2023	18:25	29/04/2023	20:52	EO	Bird Nest & Hanging object removal at LOC 136

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage